

February 11, 2000

*File Center
Temp = NRR-056
Pages Needs
to be Scanned
into Adams*

Mr. S. K. Gambhir
Division Manager - Nuclear Operations
Omaha Public Power District
Fort Calhoun Station FC 2-4-Adm.
Post Office Box 399
Hwy. 75 - North of Fort Calhoun
Fort Calhoun, NE 68023-0399

SUBJECT: FORT CALHOUN STATION, UNIT NO. 1 - TECHNICAL SPECIFICATION BASES CHANGE (TAC NO. MA6108)

Dear Mr. Gambhir:

The staff has incorporated the revision of the technical specification Bases provided by your letter of January 30, 1998, into the Fort Calhoun Station Technical Specifications.

We understand that this change is being made pursuant to 10 CFR 50.59 and does not require NRC review and approval. Therefore, we have not reviewed the change and issuance of the revised technical specification Bases does not constitute NRC approval. Enclosed is the revised Bases page.

Sincerely,
/RA/
L. Raynard Wharton, Project Manager, Section 2
Project Directorate IV and Decommissioning
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-285

Enclosure: Bases Page

cc w/encl: See next page

DISTRIBUTION:
File Center
PUBLIC
PDIV-2 Reading
SRichards (clo)
OGC
ACRS
GHill (2)
WBeckner
JHannon

*Temp = NRR-056
Needs to be
Scanned Tech
Spec Pages are
included in document*

*For previous concurrences see attached **ORC FILE CENTER COPY**

To receive a copy of this document, indicate "C" in the box						
OFFICE	PDIV-2/PM	C	PDIV-2/LA	C	SPLB*	PDIV-2/SC
NAME	RWharton		E ^{esp} Peyton:esp		JHannon	SDembek <i>AS</i>
DATE	2/11/00		2/10/00		8/15/00	2/10/00

DOCUMENT NAME: G:\PDIV-2\FortCalhoun\basespage.wpd
OFFICIAL RECORD COPY

DF01

Ft. Calhoun Station, Unit 1

cc:

**Winston & Strawn
ATTN: Perry D. Robinson, Esq.
1400 L Street, N.W.
Washington, DC 20005-3502**

**Mr. Jack Jensen, Chairman
Washington County Board
of Supervisors
Blair, Nebraska 68008**

**Mr. Wayne Walker, Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 309
Fort Calhoun, Nebraska 68023**

**Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011**

**Ms. Cheryl Rodgers, LLRW Program Manager
Environmental Protection Section
Nebraska Department of Health
301 Centennial Mall, South
P.O. Box 95007
Lincoln, Nebraska 68509-5007**

**Mr. J. M. Solymossy
Manager - Fort Calhoun Station
Omaha Public Power District
Fort Calhoun Station FC-1-1 Plant
Post Office Box 399
Hwy. 75 - North of Fort Calhoun
Fort Calhoun, Nebraska 68023**

**Mr. Mark T. Frans
Manager - Nuclear Licensing
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
Post Office Box 399
Hwy. 75 - North of Fort Calhoun
Fort Calhoun, Nebraska 68023-0399**

2.0 LIMITING CONDITIONS FOR OPERATION

2.5 Steam and Feedwater Systems

can supply sufficient feedwater for removal of decay heat from the plant. The minimum amount of water in the emergency feedwater storage tank is the amount needed for 8 hours of such operation. The tank can be resupplied with water from the raw water system.⁽¹⁾

A closure time of 4 seconds for the main steam stop valves is considered adequate time and was selected as being consistent with expected response time for instrumentation as detailed in the steam line break analysis.⁽²⁾⁽³⁾

References

(1) USAR, Section 9.4.6

(2) USAR, Section 10.3

(3) USAR, Section 14.12