

February 15, 2000

Mr. J. B. Beasley, Jr.
Vice President
Southern Nuclear Operating
Company, Inc.
Post Office Box 1295
Birmingham, Alabama 35201-1295

SUBJECT: GENERIC LETTER 97-01, "DEGRADATION OF CRDM/CEDM NOZZLE AND OTHER VESSEL CLOSURE HEAD PENETRATIONS": REVIEW OF THE RESPONSES FOR VOGTLE ELECTRIC GENERATING PLANT, UNITS 1 AND 2 (TAC NOS. M98608 AND M98609)

Dear Mr. Beasley:

Enclosed is the NRC staff's assessment of your letters of April 28 and July 24, 1997, which provided your 30-day and 120-day responses to Generic Letter (GL) 97-01, "Degradation of CRDM/CEDM Nozzle and Other Vessel Closure Head Penetrations," and your letter of December 16, 1998, which provided your response to the staff's request for additional information (RAI) dated September 16, 1998, relative to the issuance of the GL. Your responses provided your proposed program and efforts to address the potential for primary water stress corrosion cracking (PWSCC) to occur in the control rod drive mechanism (CRDM) nozzles at the Vogtle Electric Generating Plant, Units 1 and 2.

On April 1, 1997, the staff issued GL 97-01, "Degradation of CRDM/CEDM Nozzle and Other Vessel Closure Head Penetrations," to the industry, requesting that addressees provide a description of the plans to inspect the vessel head penetrations (VHPs) at their respective pressurized water reactor (PWR) designed plants. In the discussion section of the GL, the staff indicated that it did not object to individual PWR licensees basing their inspection activities on an integrated, industry-wide inspection program.

The Westinghouse Owners Group (WOG), in coordination with the efforts of the Nuclear Energy Institute (NEI) and the other PWR Owners Groups (the Babcock and Wilcox Owners Group [B&WOG] and Combustion Engineering Owners Group [CEOG]), determined that it was appropriate for its members to develop a cooperative integrated inspection program in response to GL 97-01. Therefore, on July 25, 1997, the WOG submitted two Topical Reports, WCAP-14901, Revision 0, and WCAP-14902, Revision 0, on behalf of the member utilities in the WOG. In these reports, the WOG provided descriptions of the two models, the EPRI/Dominion Engineering CIRSE Model (crack initiation and growth susceptibility model) and the Westinghouse Model, that were being used to rank the VHPs at the participating plants in the owners group. You provided your 30-day and 120-day responses for Vogtle on April 28 and July 24, 1997. In these responses, you indicated that you were a participant in the WOG's integrated program for evaluating the potential for PWSCC to occur in the VHPs of Westinghouse designed PWRs, and that you were endorsing the probabilistic susceptibility model in WCAP-14901 as being applicable to the assessment of VHPs at the Vogtle Electric Generating Plant, Units 1 and 2.

The staff performed a review of your responses of April 28 and July 24, 1997, and the applicable WCAP for your facility and determined that some additional information was needed for completion of the review. Therefore, on September 16, 1998, the staff issued an RAI requesting: (1) a description of the probabilistic susceptibility ranking for a plant's VHPs to undergo PWSCC relative to the rankings for the rest of the industry; (2) a description of how the respective susceptibility models were benchmarked; (3) a description of how the variability in the product forms, material specifications, and heat treatments used to fabricate a plant's VHPs were addressed in the susceptibility models; and (4) a description of how the models would be refined in the future to include plant-specific inspection results. As was the case for the earlier responses to the GL, the staff encouraged a coordinated, generic response to the requests in the RAI.

On December 11, 1998, NEI submitted a generic, integrated response to the RAIs on GL 97-01 on behalf of the PWR-industry and the utility members in the owners groups. In the generic submittal, NEI informed the staff that it normalized the susceptibility rankings for the industry based on a calculation of the time it would take for a VHP of a subject plant to have the same predicted probability of containing a 75 percent through-wall flaw relative as the "worst-case flawed" VHP at DC Cook Unit 2. The normalized ranking for a plant's nozzles was then grouped by histogram into one of three time-dependent susceptibility groupings: (1) those plants whose 75 percent through-wall probability would occur within 5 years of January 1, 1997 (e.g., plants with high susceptibility VHPs); (2) those plants whose 75 percent through-wall probability would occur within 5-15 years of January 1, 1997 (e.g., plants with moderate susceptibility VHPs); and (3) those plants whose 75 percent through-wall probability would occur at a time beyond 15 years of January 1, 1997 (e.g., plants with low susceptibility VHPs).

The generic response to the RAIs also provided sufficient information to answer the information requests in the RAIs, and emphasized that the integrated program is an ongoing program that will be implemented in conjunction with EPRI, the PWR Owners Groups, the participating utilities, and the Material Reliability Projects' Subcommittee on Alloy 600. By letter dated March 21, 1999, the staff informed NEI that the integrated program was an acceptable approach for addressing the potential for PWSCC to occur in the VHPs of PWR-designed nuclear plants, and that licensees responding to the GL could refer to the integrated program as a basis for assessing the postulated occurrence of PWSCC in PWR-design VHPs.

To-date, all utilities have implemented VT-2 type visual examinations of their VHPs in compliance with the ASME requirements specified in Table IWB-2500 for Category B-P components. Most utilities, if not all, have also performed visual examinations as part of plant-specific boric acid wastage surveillance programs. In addition, the following plants have completed voluntary, comprehensive augmented volumetric inspections (eddy current examinations or ultrasonic testing examinations) of their CRDM nozzles:

- 1994 - Point Beach Unit 1 (Westinghouse design)
- 1994 - Oconee Unit 2 (B&W design)
- 1994 - D.C. Cook Unit 2 (Westinghouse design)
- 1996 - North Anna Unit 1 (Westinghouse design)
- 1998 - Millstone Unit 2 (a CE design)
- 1999 - Ginna (a Westinghouse design)

In addition, the following plants have completed voluntary, limited augmented volumetric inspections of their VHPs as well:

- 1995 - Palisades - eight instrument nozzles (CE design)
- 1996 - Oconee Unit 2 - reinspection of two CRDM nozzles (B&W design)
- 1997 - Calvert Cliffs Unit 2 - vessel head vent pipe (CE design)

The majority of these plants have been ranked as having the more susceptible VHPs in the industry. Of these inspections, only the inspections at D.C. Cook Unit 2 have resulted in the identification of any domestic PWSCC type flaw indications. The current program includes additional commitments to perform further volumetric inspections of the CRDM nozzles at Oconee Unit 2 (a reinspection of 2-12 nozzles in 1999), Crystal River 3 (in 2001, a B&W design), Diablo Canyon Unit 2 (in 2001, a Westinghouse design), Farley Unit 2 (in 2002, a Westinghouse design), and San Onofre Unit 3 (in 2002-2008, a CE design). These plants are currently ranked in either the high or moderate susceptibility categories.

On December 16, 1998, you provided your response to the staff's RAI of September 16, 1998. In your letter of December 16, 1998, you endorsed the NEI submittal of December 11, 1998, and indicated that you were a participant in the NEI/WOG integrated program. Since the additional voluntary volumetric inspections performed to date have confirmed that PWSCC is not an immediate safety concern with respect to the structural integrity of VHPs in domestic PWRs, and since we have approved the integrated program for implementation, we conclude that the integrated program provides an acceptable basis for evaluating your VHPs. You may refer to the integrated program when submitting related VHP-related licensing action submittals for the remainder of the current 40-year licensing period. However, if you are considering applying for license renewal of your facilities, your application will need to address the following items: (1) an assessment of the susceptibility of your VHPs to develop PWSCC during the extended license terms for the facilities; (2) a confirmation that the VHPs at your facilities are included under the scope of your boric acid corrosion inspection program; and (3) a summary of the results of any inspections that have been completed on your VHPs prior to the license renewal application, as appropriate.

This completes the staff's efforts relative to your responses to GL 97-01. Thank you for your consideration and efforts in addressing this issue.

Sincerely,

/RA/

Ramin Assa, Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-424 and 50-425

cc: See next page

GH File (SFBUS) Section Next Page 50-424 and 50-425 centered at [REDACTED]

• • •

1979050 P. Cliff Hill 2/2

PSkinneP,UBLIC

Office of Personnel Management Section 1

ACWS Tech E260-11 F23

OGC PDII-1 R/F

DOCUMENT NAME: C:\GL97-01.wpd
To receive a copy of this document, indicate in the box C=Copy w/o attachment/closure E=Copy with attachment/closure N = No copy

OFFICE	PDII-1/PM		PDII-1/LA		PDII-1/SC	
NAME	Rassa:cn		CHawes		RENch	
DATE	2/1/00		2/1/00		2/8/00	

OFFICIAL RECORD COPY

Waynesboro, Georgia 30830
Burke County Commission
Office of the County Commissioner

Waynesboro, Georgia 30830
8805 River Road
Vogtle Plant
Resident Inspector

Atlanta, Georgia 30308-2216
Suite 5200
600 Peachtree Street, NE.
NationsBank Plaza
Troutman Sanders
Arthur H. Domby, Esquire

Washington, DC 20004-9500
1299 Pennsylvania Avenue
10th Floor
Paul, Hastings, Janofsky & Walker
Charles A. Patrizia, Esquire

Tucker, Georgia 30085-1349
P. O. Box 1349
2100 East Exchange Place
Oglethorpe Power Corporation
Fossil & Nuclear Operations
Program Manager
Mr. R. D. Barker

Atlanta, Georgia 30334
132 Judicial Building
Law Department
Attorney General

Atlanta, Georgia 30334
205 Butler Street, SE. Suite 1252
Department of Natural Resources
Harold Reheis, Director

Atlanta, Georgia
1470 Riveredge
of Georgia
Municipal Electric
Senior Engineer
Steven M. Jackson

Birmingham, Alabama
P. O. Box 1295
Company, Inc.
Southern Nuclear
Executive Vice President
Mr. J. D. Wood

Atlanta, Georgia
270 Washington
Room 615B
Office of Planning

Waynesboro, Georgia
P. O. Box 1600
Company, Inc.
Southern Nuclear
Generating Plant
General Manager
Mr. J. Gasser

Birmingham, Alabama
P. O. Box 1295
Company, Inc.
Southern Nuclear
Manager, License
Mr. J. A. Bailey
cc:

Vogtle Electric