

Docket No.: 50-339  
 Unit Name: North Anna Unit 2  
 Date: 01/05/00  
 Contact: W. R. Matthews  
 Telephone: (540) 894-2101

**UNIT SHUTDOWN AND POWER REDUCTION**  
 (EQUAL TO OR GREATER THAN 20%)

REPORT MONTH: December, 1999

Date	(1) Type	Duration Hours	(2) Reason	(3) Method of Shutting Down Rx	LER No.	(4) System Code	(5) Component Code	Cause & Corrective Action to Prevent Recurrence
12-2-99	F	27.6	A	2	99-004	NA	NA	Manual reactor trip due to the tripping of 2 of 3 feedwater pumps on low suction pressure.

(1)  
 F: Forced  
 S: Scheduled

(2)  
 REASON:  
 A - Equipment Failure (Explain)  
 B - Maintenance or Test  
 C - Refueling  
 D - Regulatory Restriction  
 E - Operator Training & Licensing Examination  
 F - Administrative  
 G - Operational Error (Explain)

(3)  
 METHOD:  
 1 - Manual  
 2 - Manual Scram  
 3 - Automatic Scram  
 4 - Other (Explain)

(4)  
 Exhibit G - Instructions for Preparation of Data Entry Sheets  
 for Licensee Event Report (LER) File (NUREG 0161)

(5)  
 Exhibit 1 - Same Source