

Commonwealth Edison Company
LaSalle Generating Station
2601 North 21st Road
Marseilles, IL 61341-9757
Tel 815-357-6761



February 23, 2000

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

LaSalle County Station, Unit 1
Facility Operating License No. NPF-11
NRC Docket No. 50-373

Subject: 90-Day Post Outage ISI Summary Report

Reference: Milton H. Richter (ComEd) letter to Dr. Thomas E. Murley
(NRC), "Structural Margin Evaluation for Reactor Pressure
Vessel Head Studs," dated October 3, 1991

Title 10, Code of Federal Regulations, Part 50, Section 55a, Paragraph g
(10 CFR 50.55a(g)) requires Commonwealth Edison (ComEd) Company to
maintain an Inservice Inspection Program in accordance with the
requirements of the American Society of Mechanical Engineers (ASME)
Boiler and Pressure Vessel Code. This report is submitted in accordance
with the requirements of ASME Section XI, Article IWA-6200,
Paragraph IWA-6230.

Enclosed please find the Post-Outage (90 day) Summary Report for
Inservice Inspection examinations and Repair/Replacement activities
performed between the end of the previous refueling outage May 6, 1996
through the end of the current refueling outage. The current refueling outage
was the 8th refueling outage for LaSalle County Station Unit 1. The outage
started October 23, 1999 and ended November 22, 1999. This refueling
outage was the second outage scheduled for the First Inspection Period of
the Second Inspection Interval. The Second Inservice Inspection Interval is
effective from November 23, 1994 through October 11, 2006 for LaSalle
County Station Unit 1.

A047

February 23, 2000
U.S. Nuclear Regulatory Commission
Page 2

LaSalle County Station Unit 1 is owned and operated by ComEd, whose address is:

One First National Plaza
P.O. Box 767
Chicago, Illinois 60690

LaSalle County Station Unit 1 has a gross generating capacity of 3323 MWt and began commercial operation on January 1, 1984.

Should you have any questions concerning this letter, please contact Mr. Frank A. Spangenberg, III, Regulatory Assurance Manager, at (815) 357-6761, extension 2383.

Respectfully,

A handwritten signature in black ink, appearing to read "Jeffrey A. Benjamin", followed by a horizontal line and the word "for" written in a cursive script.

Jeffrey A. Benjamin
Site Vice President
LaSalle County Station

Attachment

cc: Regional Administrator - NRC Region III
NRC Senior Resident Inspector - LaSalle County Station

ATTACHMENT

I. INTRODUCTION

This Inservice Inspection Summary Report addresses examinations performed between the end of the previous refueling outage May 6, 1996 through the end of the current refueling outage. The current refueling outage was the 8th refueling outage for LaSalle County Station Unit One. The outage started October 23, 1999 and ended November 22, 1999. This refueling outage was the second outage scheduled for the First Inspection Period of the Second Inspection Interval. The Second Inservice Inspection Interval is effective from November 23, 1994 through October 11, 2006 for LaSalle Unit 1. Paragraph IWA-2430(e) of ASME Section XI allows an inspection Interval to be extended for a period of time equivalent to the duration of a continuous outage that exceeds six months. The Second Inservice Inspection Interval is divided into three successive inspection periods as determined by calendar years of plant service within the Inspection Interval. Identified below are the period dates for the Second Inservice Inspection Interval as defined by Inspection Program B. In accordance with IWB-2412(b), the inspection periods specified below may be decreased or extended by as much as 1 year to enable inspections to coincide with LaSalle Station's refueling outages.

Unit 1, Period 1 (November 23, 1994 through October 11, 1999**)

Unit 1, Period 2 (October 12, 1999 through October 11, 2003)

Unit 1, Period 3 (October 12, 2003 through October 11, 2006)

** This date reflects a 690 day extension allowed by IWA-2430(e) for L1F35.

Inservice Inspection examinations, Augmented Inservice Inspection (AISI) examinations and Preservice Inspections were completed during the refueling outage as required by the Code of Federal Regulations, Technical Specifications, and Section XI of the ASME Boiler and Pressure Vessel Code, 1989 Edition.

Personnel from GE Nuclear Energy (GENE) Inspection Services performed the Non-Destructive Evaluations (NDE), Magnetic Particle (MT), Liquid Dye Penetrant (PT), and manual and automated Ultrasonic (UT) techniques that were used during these inspections. All IGSCC examinations were completed by personnel qualified for the detection and discrimination of Intergranular Stress Corrosion Cracking in accordance with the Performance Demonstration Initiative (PDI). LaSalle's Programs Engineering Group provided necessary resolution of technical problems, reviewed all ISI personnel qualifications, and all visual, surface, and volumetric examination results.

Visual examinations of reactor vessel internals, component supports, and piping pressure tests were performed by GENE personnel and ComEd employees of the LaSalle's Programs Engineering Group. These individuals were appropriately certified as ASME Section XI Visual Examiners to ComEd's written practice. An underwater camera was used in the reactor vessel for the visual inspection of the reactor vessel internals. The camera was proven capable of resolving both 0.001", and 0.0005" stainless steel wires while underwater and in the same lighting conditions found during the actual inspection.

The services of Authorized Nuclear Inservice Inspectors (ANII)/Authorized Nuclear Inspectors (ANI) were provided by Hartford Steam Boiler Inspection & Insurance Co., Chicago Branch, 2443 Warrenville Road, Suite 500, Lisle, IL 60532.

Mr. Rocky W. White ANII/ANI, State of ILL # 1927, reviewed all procedures, personnel qualifications, instrument and material certifications, all Section XI examination results, all Owner's Reports of Repair or Replacement (Forms NIS-2), and the Owners Data Report for Inservice Inspection (Form NIS-1).

II. SCOPE OF INSPECTIONS

The tables following this section summarize the extent and results of inspections performed during the period between the end of the previous refueling outage May 6, 1996 (L1R07), through the end of the current refueling outage (L1R08). An explanation of any abbreviations can be found at the end of this report as Attachment 3.

Table A provides a summary listing of all completed ASME Section XI examinations for this outage with the exception of Component Support examinations, Pressure Testing, and containment examinations which are addressed separately. Table A is divided by ASME Code Category with a description of the item examined, as well as the examination type(s), and the examination results. Due to the limitations imposed by their design and construction, several components could not be examined to the full extent required by the Code. In accordance with 10 CFR 50.55a(g)(5), Request for Relief CR-26 from the Code required examination coverage will be submitted for these components in subsequent revisions to the Second 10-Year ISI Plan for LaSalle County Station Units 1 & 2. Applicable existing Relief Requests are noted in the tables.

Table B provides a summary listing of all Augmented Inservice Inspections (AISI). These are not ASME Section XI Code requirements, but are either additional examination area requirements, or increased frequency requirements, or combinations of these which are requested by the Nuclear Regulatory Commission, or which have been deemed prudent in view of ComEd or other industry experience. Table B also gives a description of the item examined as well as the examination type, and examination results(s). Table B includes the following categories as described below.

TYPE 1A - These are ASME Code Category B-F, and B-J welds of the High Energy Line Break exclusion regions which are identified in the SAR and are examined as required by the Nuclear Regulatory Commission.

TYPE 1B/NUREG-0619 - These examinations include the visual examination of the Feedwater Spargers.

GENERIC LETTER 88-01 - These examinations are of austenitic stainless steel piping for the detection of IGSCC.

REACTOR VESSEL INTERNALS AISI – These examinations include inspection of reactor internal components which have been required by the Nuclear Regulatory Commission such as Core Spray Spargers and Core Shroud Ultrasonic Testing, those which have been adopted by ComEd through its commitment to the Boiling Water Reactor Vessel and Internals Project (BWRVIP), such as Ultrasonic Examination of Core Spray Piping, and others which ComEd has deemed prudent from industry experience, such as the examination of the Steam Dryer and Steam Separator.

MISCELLANEOUS AISI -

Pursuant to LaSalle County Station's commitment to the Nuclear Regulatory Commission (reference letter), the AISI examinations included an augmented "End-Shot" Ultrasonic examination of 100% (68) of the Reactor Pressure Vessel Closure Studs. The "End Shot" UT examination was completed using procedures, calibration standards, and personnel which met all applicable requirements of the 1989 Edition of ASME Section XI.

Table C provides a summary listing of all completed ASME Section XI Class 1 and 2 Component Support examinations for this outage. Table C gives the support number, the examination type, and examination results(s). Table C is divided by ASME Code Class.

Table D provides a listing of pressure testing of ASME Class 1 & 2 piping and components completed in accordance with ASME Section XI during the period between the L1R07 outage and the L1R08 outage. Class 1 components and piping were visually examined using the VT-2 method during the System Leakage Test conducted at 1020 PSIG prior to reactor start-up, which is within the nominal operating pressure range of the Reactor Pressure Vessel associated with 100% rated reactor power.

Table E is a listing of ASME Class 1 and 2 Repair/Replacements which have been completed since the previous refueling outage and those completed during the eighth refueling outage of Unit 1 in accordance with ASME Section XI, Articles IWA-4000 and IWA-7000. The listing includes the documentation package (Nuclear Work Request) number which served to implement the applicable activity as well as a short description of the activity. The Nuclear Work Requests are on file at LaSalle. Each activity has been certified on Form NIS-2 (Owners Report of Repair or Replacement) which will serve as documentation of these Repair/Replacements. The NIS-2 forms are included in this report as Attachment 2. The work request packages associated with 14 repair/replacement activities are still in processing, and these will be included in the 90 day ISI Summary Report following the next Unit 1 refueling outage (L1R09). Action Tracking Item # 24046, has been issued to track submittal of these NIS-2 forms.

The name of each major component inspected during the eighth refueling outage is listed on Form NIS-1 (Attachment 1) in column #1. Only the major components inspected during the outage are listed on Form NIS-1. These include the Reactor Pressure Vessel and the Class 1 piping system. A more detailed list of components inspected appears in the abstracts listed as items 13, 14, and 15 on Form NIS-1. Since descriptions including size, capacity, material, location, and drawings to aid in identification of the components have been previously submitted, as well as our N-5 Code Data Reports, and our Second 10-Year ISI Plan, this information was not included in this Summary Report. These documents are on file at LaSalle County Nuclear Station. This also applies to our Preservice and previous Inservice Inspection Summary Reports.

III. SUMMARY OF RESULTS AND CORRECTIVE ACTIONS

The ASME Section XI Inservice Inspection results obtained this outage were compared with the applicable Preservice and previous Inservice Inspection results. The following is a summary of the results and the corrective actions taken this outage.

1. ASME Section XI Components

No reportable indications were detected in any ASME Section XI components or their supports. Recordable indications were detected in these components as well as in other components, during routine and or augmented examinations as discussed below.

2. Steam Dryer

Based on LaSalle experience, an augmented visual examination of the Steam Dryer is completed during each refueling outage. The Steam Dryer contains numerous indications, all of which have been recorded during previous examinations. Areas where indications were identified include the lifting eye bracket welds, upper dryer bank vertical welds, upper support ring, and drain channel welds. All indication during the examination conducted for L1R08 were evaluated as acceptable as-is with no repair required in accordance with the acceptance criteria of GENE Chron. 118054, dated 12/3/92. As all of these indications had been previously identified, no PIF was generated to disposition them. These examination results have been documented on the VT-3/4 examination data sheet by the Station Level III Visual Examiner.

3. Steam Separator

Based on LaSalle experience, an augmented visual examination of the Steam Separator is completed during each refueling outage. At the sixth refueling outage, cracking was identified on several middle support ring gussets. Reinspection of the Separator during this outage revealed no further damage to any additional gussets, and none of the previously identified cracking appeared significantly changed. As these indications had been previously identified, no PIF was generated to

disposition them. These examination results have been documented on the VT-3/4 examination data sheet by the Station Level III Visual Examiner.

4. Jet Pump Pumps

During augmented visual inspection of the number nine Jet Pump in the previous refueling outage, wear was detected on the inlet mixer wedge and restrainer bracket pad. Cracking of the adjusting screw tack welds was also identified. At that time, a partial repair was made by installing a pair of wedge assemblies. During this outage, a permanent repair was made by refacing the restrainer bracket pad, installing a new inlet mixer with an over-sized wedge, and installing two permanent wedges which functionally replace the restrainer bracket adjusting screws. Visual inspection of the adjusting screws on the remaining jet pumps revealed additional gaps between the adjusting screws and their respective inlet mixers. The following gaps were identified:

Jet Pump # 1 - .027" Gap on vessel side adjusting screw
Jet Pump # 5 - .022" Gap on vessel side adjusting screw
Jet Pump # 6 - .023" Gap on shroud side adjusting screw
Jet Pump # 6 - .010" Gap on vessel side adjusting screw
Jet Pump # 7 - .029" Gap on vessel side adjusting screw
Jet Pump # 8 - .017" Gap on vessel side adjusting screw
Jet Pump # 10 - .025" Gap on vessel side adjusting screw
Jet Pump # 11 - .013" Gap on shroud side adjusting screw

PIF L1999-05508 was generated to disposition these gaps. Permanent repair wedges were installed under Design Change Package 9600289 to eliminate all of the gaps with the exception of the number six Jet Pump vessel side, and the number 11 shroud side gaps. The gaps on these two pumps were evaluated by GENE and ComEd engineering as acceptable as is for one refueling cycle. This evaluation is documented under GENE evaluation number GENE-B13-02028-00-03 which is on file at LaSalle County Station under Site Engineering Administrative Group (SEAG) # 99-001006. Action Tracking Item # 19556, has been issued to track reinspection of these items during future refueling outages.

5. ASME Section XI Piping & Component Support Examinations

A total of 40 piping and component supports were inspected during this refueling outage. These were distributed between ASME Class 1 and 2/D+ supports as follows:

Class 1 - 22 supports.
Class 2/D+ - 12 supports.
Components – 6 Supports

No reportable indications were detected during these examinations, and all recordable indications were evaluated as acceptable by the Station Level III Visual Examiner.

LASALLE COUNTY STATION UNIT 1
EIGHTH REFUELING OUTAGE
ASME SECTION XI SUMMARY REPORT

TABLE OF CONTENTS

I. INTRODUCTION

II. SCOPE OF INSPECTIONS

Table A ASME Section XI Examinations

Table B Augmented Inservice Inspections AISI

Table C ASME Section XI Component Support Examinations

Table D ASME Section XI Pressure Testing

Table E Class 1 & 2 Repair/Replacements

III. SUMMARY OF RESULTS, EVALUATIONS, AND CORRECTIVE ACTIONS

IV. ATTACHMENTS

1. NIS-1 Form

2. NIS-2 Forms

3. Abbreviations

**TABLE A
ASME SECTION XI ISI INSPECTIONS**

ASME CATEGORY B-A

<u>ITEM #</u>	<u>ITEM DESCRIPTION</u>	<u>EXAM TYPE</u>	<u>RESULT</u>
1	LCS-1-AA (0°-180°)	UT	NRI
2	LCS-1-AE (180°-360°)	UT	NRI
3	LCS-1-BS	UT	NRI
4	GEL-1006-AJ (0°-180°)	UT	NRI
5	GEL-1006-CA	UT	NRI
6	GEL-1006-CB	UT	NRI
7	GEL-1006-CC	UT	NRI
8	GEL-1006-CD	UT	NRI
9	GEL-1006-DA	UT	NRI
10	GEL-1006-DB	UT	NRI
11	GEL-1006-DC	UT	NRI
12	GEL-1006-DD	UT	NRI
13	GEL-1006-DE	UT	NRI

ASME CATEGORY B-D

1	LCS-1-N6A	UT	NRI, 69.5% COVERAGE, CR-26
2	1-NIR-6A	UT	NRI
3	LCS-1-N6C	UT	NRI, 69.5% COVERAGE, CR-26
4	1-NIR-6C	UT	NRI

ASME CATEGORY B-F

1	1-CRD-CAP	UT&PT	ROOT GEOMETRY/NRI
2	RH-1003-35A	AUTO UT&PT	ID & ROOT GEOMETRY/NRI
3	RH-1004-35A	AUTO UT&PT	ROOT GEOMETRY/NRI
4	RH-1003-35B	AUTO UT&PT	NRI
5	RH-1004-35B	AUTO UT&PT	NRI
6	RI-1002-22	UT&PT	NRI
7	RR-1001-13A	AUTO UT&PT	ID GEOMETRY/NRI
8	RR-1005-17C	AUTO UT&PT	ID GEOMETRY/NRI
9	RR-1009-6	UT&PT	NRI

ASME CATEGORY B-G-1

1	RPV FLANGE (1-22)	UT	NRI
2	IRR-PU1A	UT	NRI

ASME CATEGORY B-G-2

1	1B21-F013M	VT-1	NRI
2	1B33-F023B	VT-1	NRI
3	1E21-F006	VT-1	NRI
4	1E12-F041B	VT-1	NRI

**TABLE A (CONT'D.)
ASME SECTION XI ISI INSPECTIONS**

ASME CATEGORY B-H

1	RPV-SS-5	PT	NRI, 66% COVERAGE, CR-25
2	1VS-1, 2, 3 (0°-180°)	UT/MT	UT PER RELIEF REQUEST CR-18

ASME CATEGORY B-J

1	MS-1002-07	UT/MT	NRI
2	MS-1002-26	UT/MT	NRI
3	MS-1055-06	UT/MT	NRI
4	RH-1004-19	UT/MT	NRI
5	RH-1004-26	UT/MT	NRI
6	RI-1001-01	UT/MT	NRI
7	RI-1002-03	UT/MT	NRI
8	RI-1002-04	UT/MT	NRI
9	RI-1002-05	UT/MT	ROOT GEOMETRY/NRI
10	RI-1002-06	UT/MT	NRI
11	RI-1002-08	UT/MT	NRI
12	RR-1003-08	UT/PT	NRI
13	RR-1007-15	UT/PT	NRI
14	RR-1007-20	UT/PT	NRI
15	RR-1009-01	UT/PT	NRI
16	MS-1001-10	UT/MT	NRI
17	MS-1001-11	UT/MT	NRI, 85.6% COVERAGE, CR-26
18	MS-1002-12	UT/MT	NRI
19	MS-1002-20	UT/MT	NRI
20	MS-1002-24	UT/MT	NRI
21	MS-1002-28	UT/MT	NRI

ASME SECTION XI ISI INSPECTIONS

ASME CATEGORY B-K-1

<u>ITEM #</u>	<u>ITEM DESCRIPTION</u>	<u>EXAM TYPE</u>	<u>RESULT</u>
1	FW02-1004V	MT	NRI

ASME CATEGORY B-M-2

1	1B33-F023B	VT-3/4	NRI
2	1E21-F006	VT-3/4	NRI
3	1E12-F042C	VT-3/4	NRI
4	1E12-F041B	VT-3/4	NRI
5	1E51-F063	VT-3/4	NRI

ASME CATEGORY B-N-1

1	DRYER SUPPORT LUGS	VT-3/4	MINOR WEAR, ACCEPTABLE
2	JET PUMP COMPONENTS	VT-3/4	GAPS SEE PAGE 5
3	JET PUMP HOLD DOWNS	VT-3/4	NRI
4	LPCI COUPLING ASSY.	VT-3/4	NRI

**TABLE A (CONT'D.)
ASME SECTION XI ISI INSPECTIONS**

ASME CATEGORY B-N-2

1	DRYER SUPPORT LUG WELDS	VT-3/4	NRI
2	HP CORE SPRAY PIPING BRACKETS	VT-3/4	NRI
3	LP CORE SPRAY PIPING BRACKETS	VT-3/4	NRI
4	SUPPORT PLATE GUSSET ATT. WELDS	VT-3/4	NRI, 6 OF 22
5	SUPPORT PLATE ATT. WELDS	VT-3/4	NRI, 90° OF RPV
6	SUPPORT PLATE	VT-3/4	NRI, 90° OF RPV
7	JET PUMP RISER BRACE ATT. WELDS	VT-1	NRI, PUMPS 11-20

ASME CATEGORY C-C

1	HP02-1018X	MT	NRI
---	------------	----	-----

ASME CATEGORY C-F-1

1	RH-1033-44	UT/PT	NRI
2	RH-1033-46	UT/PT	NRI
3	RH-1033-47	UT/PT	NRI
4	RH-1046-09	UT/PT	NRI
5	RH-1046-10	UT/PT	NRI
6	RH-1046-12	UT/PT	NRI
7	RH-1046-14	UT/PT	NRI
8	RH-1046-15	UT/PT	NRI
9	RH-1046-20	UT/PT	NRI

**TABLE B
AUGMENTED ISI INSPECTIONS**

AISI CATEGORY TYPE 1A

<u>ITEM #</u>	<u>ITEM DESCRIPTION</u>	<u>EXAM TYPE</u>	<u>RESULT</u>
1	LP-1001-12	UT	NRI
2	LP-1001-13	UT	NRI
3	LP-1001-14	UT	NRI
4	LP-1001-15	UT	NRI
5	RH-1004-19	UT	NRI
6	RH-1004-20	UT	NRI
7	RH-1004-26	UT	NRI
8	RI-1001-01	UT	NRI
9	RI-1002-01	UT	NRI
10	RI-1002-03	UT	NRI
11	RI-1002-04	UT	NRI
12	RI-1002-05	UT	NRI
13	RI-1002-06	UT	NRI
14	RI-1002-08	UT	NRI
15	RI-1003-09	UT	NRI
16	RI-1003-10	UT	NRI
17	RI-1003-11	UT	NRI
18	RI-1003-13C	UT	NRI
19	RI-1003-14	UT	NRI
20	RI-1003-15	UT	NRI
21	RI-1003-17	UT	NRI
22	RI-1003-18	UT	NRI
23	RI-1003-19	UT	NRI
24	RI-1003-20	UT	NRI
25	RI-1003-22	UT	NRI
26	RI-1003-23	UT	NRI
27	RI-1003-24	UT	NRI
28	RI-1003-25	UT	NRI
29	RI-1003-27	UT	NRI
30	RI-1003-28	UT	NRI
31	RI-1003-29	UT	NRI
32	RI-1003-30	UT	NRI
33	RI-1003-31	UT	NRI
34	RI-1003-32	UT	NRI

AISI CATEGORY 88-01 IGSCC

1	1-CRD-CAP	UT&PT	NRI
2	RH-1003-35A	AUTO UT&PT	ID & ROOT GEOMETRY/NRI
3	RH-1004-35A	AUTO UT&PT	ROOT GEOMETRY/NRI
4	RH-1003-35B	AUTO UT&PT	NRI
5	RH-1004-35B	AUTO UT&PT	NRI
6	RI-1002-22	UT&PT	NRI
7	RR-1001-13A	AUTO UT&PT	ID GEOMETRY/NRI
8	RR-1005-17C	AUTO UT&PT	ID GEOMETRY/NRI
9	RR-1009-6	UT&PT	NRI
10	RR-1001-24	UT/PT	NRI
11	RR-1001-25	UT/PT	NRI
12	RR-1001-28	UT/PT	NRI

TABLE B (CONT'D.)
AISI CATEGORY 88-01 IGSCC

<u>ITEM #</u>	<u>ITEM DESCRIPTION</u>	<u>EXAM TYPE</u>	<u>RESULT</u>
13	RR-1001-29	UT/PT	NRI
14	RR-1003-08	UT/PT	NRI
15	RR-1003-21	UT/PT	NRI
16	RR-1007-14	UT	NRI
17	RR-1007-15	UT/PT	NRI
18	RR-1009-01	UT/PT	NRI
19	RR-1009-02	UT	NRI
20	RR-1009-04	UT/PT	NRI
21	RR-1009-05	UT/PT	NRI
22	RR-1007-20	UT/PT	NRI

AISI CATEGORY NUREG-0619

1	FEEDWATER SPARGERS	VT-1	NRI
---	--------------------	------	-----

AISI CATEGORY VESSEL INTERNALS

1	STEAM DRYER	VT-3/4	SEE REPORT PG. 4
2	DRYER HOLD DOWN LUGS	VT/PT	NRI, RICSIL 072
3	STEAM SEPARATOR	VT-3/4	SEE REPORT PG. 4
4	CORE SPRAY PIPING	EVT-1/UT	NRI, IEB 80-3, BWRVIP-18
5	CORE SPRAY SPARGERS	VT-1	NRI, IEB 80-3, BWRVIP-18
6	JET PUMP BEAM KEEPERS	VT-1	NRI
7	(19) TOP GUIDE CELLS	VT-1	NRI, BWRVIP-26
8	ACCESS HOLE COVERS	VT-1	NRI
9	(10) JET PUMP BEAMS	UT	NRI, BWRVIP-41
10	(4) INCORE DRY TUBES	VT-1	IRM-"A" CRACKED, REPLACED
11	JET PUMP TO SUPPORT	VT-1	NRI, WELDS ON PUMPS 11-20 BWRVIP-41
12	JET PUMP ASSY. WELDS	VT-1	NRI, WELDS ON PUMPS 11-20 BWRVIP-41
13	CRD GUIDE TUBE LUGS	VT-3/4	NRI, (19) LUG WELDS, BWRVIP-47
14	FUEL SUPPORT PINS	VT-3/4	NRI, (19) PINS, BWRVIP-47
15	LPCI COUPLING WELDS	VT-1	NRI, (3) ASSEMBLIES, BWRVIP-42
16	LPCI COUPLING BOLTS	VT-3/4	NRI, (3) ASSEMBLIES, BWRVIP-42
17	LPCI COUPLING BOLT TACKS	VT-3/4	NRI, (3) ASSEMBLIES, BWRVIP-42

AISI CATEGORY MISC.

<u>ITEM #</u>	<u>ITEM DESCRIPTION</u>	<u>EXAM TYPE</u>	<u>RESULT</u>
1	RPV STUDS (1-68)	UT	NRI, SEE REPORT PG. 3

TABLE C
ASME SECTION XI COMPONENT & SUPPORT EXAMINATIONS

ASME CLASS 1

<u>ITEM #</u>	<u>ITEM DESCRIPTION</u>	<u>EXAM TYPE</u>	<u>RESULT</u>
1	FW02-1004V	VT-3/4	NRI
2	HP02-1022X	VT-3/4	NRI
3	LP02-1004V	VT-3/4	SETTINGS, ACCEPTABLE
4	MS00-1010X	VT-3/4	NRI
5	MS00-1020X	VT-3/4	NRI
6	MS00-1035V	VT-3/4	SETTINGS, ACCEPTABLE
7	RH40-1005C	VT-3/4	SPRING CAN DENTED, ACCEPTABLE
8	RHG4-1001R	VT-3/4	NRI
9	RI24-1017X	VT-3/4	NRI
10	RI24-1018X	VT-3/4	NRI
11	RI24-1020X	VT-3/4	NRI
12	RI24-1500C	VT-3/4	NRI
13	RI24-1518V	VT-3/4	NRI
14	RR00-1031X	VT-3/4	NRI
15	RR16-1002C	VT-3/4	SETTINGS, ACCEPTABLE
16	RR28-1003G	VT-3/4	NRI
17	RT01-1076X	VT-3/4	NRI
18	RT01-1084R	VT-3/4	NRI
19	PENETRATION M-2	VT-3/4	GROUT CRACKED, ACCEPTABLE
20	PENETRATION M-7	VT-3/4	NRI
21	PENETRATION M-11	VT-3/4	NRI
22	PENETRATION M-30	VT-3/4	NRI
23	RR00-1034C	VT-3/4	NRI
24	RR00-1035C	VT-3/4	NRI
25	RR00-1036C	VT-3/4	NRI
26	RR00-1037C	VT-3/4	NRI
27	1B13-D003	VT-3/4	NRI, RPV SUPPORT SKIRT

ASME CLASS 2

1	HG05-1023X	VT-3/4	NRI
2	HP02-1006X	VT-3/4	NRI
3	HP02-1009V	VT-3/4	NRI
4	LP02-1010V	VT-3/4	NRI
5	MS01-1029C	VT-3/4	NRI
6	MS33-1061R	VT-3/4	NRI
7	RH03-1052X	VT-3/4	NRI
8	RH03-1531X	VT-3/4	NRI
9	RH13-1130R	VT-3/4	NRI
10	RH58-1010X	VT-3/4	NRI
11	RHE2-1005X	VT-3/4	NRI
12	PENETRATION M-68	VT-3/4	NRI
13	1E22-C001	VT-3/4	NRI

TABLE D
ASME SECTION XI PRESSURE TESTING

<u>ITEM #</u>	<u>ITEM DESCRIPTION</u>	<u>EXAM TYPE</u>	<u>RESULT</u>
1	1-CM-01	VT-2	NRI, CASE N-522
2	1-CM-02	VT-2	NRI, CASE N-522
3	1-CM-03	VT-2	NRI
4	1-CM-04	VT-2	NRI, CASE N-522
5	1-CM-05	VT-2	NRI
6	1-CM-06	VT-2	NRI, CASE N-522
7	1-CM-07	VT-2	NRI
8	1-CM-08	VT-2	NRI
9	1-CM-09	VT-2	NRI
10	1-CM-10	VT-2	NRI
11	1-CM-11	VT-2	NRI
12	1-CM-12	VT-2	NRI
13	1-CM-13	VT-2	NRI
14	1-CM-14	VT-2	NRI
15	1-ES-01	VT-2	NRI
16	1-FC-09	VT-2	NRI
17	1-FC-10	VT-2	NRI
18	1-FW-01	VT-2	NRI
19	1-HG-01	VT-2	NRI
20	1-HG-02	VT-2	NRI
21	1-HG-05	VT-2	NRI
22	1-HP-01	VT-2	NRI
23	1-IN-01	VT-2	NRI
24	1-IN-02	VT-2	NRI
25	1-IN-03	VT-2	NRI
26	1-IN-04	VT-2	NRI
27	1-IN-05	VT-2	NRI
28	1-IN-06	VT-2	NRI
29	1-IN-07	VT-2	NRI
30	1-IN-08	VT-2	NRI
31	1-IN-09	VT-2	NRI
32	1-IN-10	VT-2	NRI
33	1-IN-11	VT-2	NRI
34	1-IN-12	VT-2	NRI
35	1-IN-13	VT-2	NRI
36	1-IN-14	VT-2	NRI
37	1-IN-15	VT-2	NRI
38	1-IN-16	VT-2	NRI
39	1-IN-17	VT-2	NRI
40	1-LP-01	VT-2	NRI
41	1-MC-01	VT-2	NRI
42	1-MS-01	VT-2	NRI
43	1-NB-01	VT-2	NRI
44	1-NB-02	VT-2	NRI
45	1-NB-03	VT-2	NRI
46	1-NB-04	VT-2	NRI
47	1-NB-05	VT-2	NRI
48	1-PC-01	VT-2	NRI
49	1-PC-02	VT-2	NRI
50	1-PC-03	VT-2	NRI
51	1-PC-04	VT-2	NRI

TABLE D (CONT'D)
ASME SECTION XI PRESSURE TESTING

<u>ITEM #</u>	<u>ITEM DESCRIPTION</u>	<u>EXAM TYPE</u>	<u>RESULT</u>
52	1-RC-PB	VT-2	NRI/PACKING & GASKET LEAKS
53	1-RD-01	VT-2	NRI/PACKING & GASKET LEAKS
54	1-RE-01	VT-2	NRI/PACKING & GASKET LEAKS
55	1-RF-01	VT-2	NRI
56	1-RH-01	VT-2	NRI
57	1-RH-02	VT-2	NRI
58	1-RH-03	VT-2	NRI
59	1-RR-01	VT-2	NRI
60	1-RR-02	VT-2	NRI
61	1-RR-03	VT-2	NRI, IWA-5243
62	1-RR-04	VT-2	NRI
63	1-RR-05	VT-2	NRI
64	1-RR-06	VT-2	NRI
65	1-RR-07	VT-2	NRI, IWA-5243
66	1-RR-08	VT-2	NRI
67	1-SA-01	VT-2	NRI
68	1-VG-01	VT-2	NRI
69	1-VP-01	VT-2	NRI
70	1-VP-02	VT-2	NRI
71	1-VQ-01	VT-2	NRI
72	1-VQ-02	VT-2	NRI
73	1-VQ-03	VT-2	NRI, CASE N-522
74	1-VQ-04	VT-2	NRI, CASE N-522
75	1-VQ-05	VT-2	NRI, CASE N-522
76	1-WR-01	VT-2	NRI

TABLE -E
REPAIR REPLACEMENT ACTIVITIES

CLASS-1

<u>WORK REQUEST NUMBER</u>	<u>DESCRIPTION</u>	
1.	950064426	Replace Control Rod Drive & capscrews
2.	960060078	Repair valve bonnet seal weld
3.	960064247	Replace snubber
4.	960064248	Replace snubber
5.	960078266	Replace valve disc
6.	960094667	Replace piping components
7.	970011261	Replace explosive valve
8.	970042731	Replace pipe clamp bolts
9.	970060141	Replace Main Steam SRV
10.	970060143	Replace Main Steam SRV
11.	970060144	Replace Main Steam SRV
12.	970060147	Replace Main Steam SRV
13.	970060148	Replace Main Steam SRV
14.	970060151	Replace Main Steam SRV
15.	970060152	Replace Main Steam SRV
16.	970060154	Replace Main Steam SRV
17.	970060155	Replace Main Steam SRV
18.	970060157	Replace Main Steam SRV
19.	970085115	Repair valve bonnet
20.	970102500	Replace piping components
21.	970102501	Replace piping components
22.	970105771	Replace testable check valve parts
23.	970105773	Replace testable check valve parts
24.	970105779	Replace testable check valve parts
25.	970105783	Replace testable check valve parts
26.	970105784	Replace testable check valve parts
27.	970105785	Replace testable check valve parts
28.	970105786	Replace testable check valve parts
29.	980042592	Repair stuffing box
30.	980050034	Replace valve and component support pin
31.	980050035	Replace valve
32.	980050050	Replace explosive valve
33.	980089092	Replace Control Rod Drive & capscrews
34.	980095087	Replace Main Steam SRV
35.	980101916	Replace Control Rod Drive & capscrews
36.	980105189	Replace snubber
37.	980105195	Replace snubber
38.	980105201	Replace snubber
39.	980105206	Replace snubber
40.	980105207	Replace snubber
41.	980107450	Replace snubber
42.	980107451	Replace snubber
43.	980107477	Replace snubber
44.	980121581	Replace explosive valve
45.	980129183	Replace valve disc
46.	980133196	Replace Main Steam SRV

TABLE -E (CONT'D)
REPAIR REPLACEMENT ACTIVITIES
CLASS-1 (CONT'D)

<u>WORK REQUEST NUMBER</u>	<u>DESCRIPTION</u>
47. 990002937	Replace Main Steam SRV
48. 990002939	Replace Main Steam SRV
49. 990002940	Replace Main Steam SRV
50. 990002941	Replace Main Steam SRV
51. 990002942	Replace Main Steam SRV
52. 990002943	Replace Main Steam SRV
53. 990002944	Replace Main Steam SRV
54. 990004085	Replace Control Rod Drive & capscrews
55. 990004089	Replace Control Rod Drive & capscrews
56. 990008339	Replace Control Rod Drive & capscrews
57. 990011480	Repair OD piping defect
58. 990012997	Replace Control Rod Drive & capscrews
59. 990012998	Replace Control Rod Drive & capscrews
60. 990023223	Replace snubber
61. 990023565	Replace snubber
62. 990026903	Replace Control Rod Drive & capscrews
63. 990026904	Replace Control Rod Drive & capscrews
64. 990026908	Replace Control Rod Drive & capscrews
65. 990026909	Replace Control Rod Drive & capscrews
66. 990026911	Replace Control Rod Drive & capscrews
67. 990026912	Replace Control Rod Drive & capscrews
68. 990026913	Replace Control Rod Drive & capscrews
69. 990026915	Replace Control Rod Drive & capscrews
70. 990026916	Replace Control Rod Drive & capscrews
71. 990026917	Replace Control Rod Drive & capscrews
72. 990026918	Replace Control Rod Drive & capscrews
73. 990026919	Replace Control Rod Drive & capscrews
74. 990026920	Replace Control Rod Drive & capscrews
75. 990026922	Replace Control Rod Drive & capscrews
76. 990026923	Replace Control Rod Drive & capscrews
77. 990026927	Replace Control Rod Drive & capscrews
78. 990026929	Replace Control Rod Drive & capscrews
79. 990026930	Replace Control Rod Drive & capscrews
80. 990026963	Replace Control Rod Drive & capscrews
81. 990026964	Replace Control Rod Drive & capscrews
82. 990026966	Replace Control Rod Drive & capscrews
83. 990026967	Replace Control Rod Drive & capscrews
84. 990064689	Replace snubber
85. 990090171	Machine gland on LPRM
86. 990109838	Replace snubber
87. 990111900	Replace Control Rod Drive & capscrews

TABLE -E (CONT'D)
REPAIR REPLACEMENT ACTIVITIES

CLASS-2

<u>WORK REQUEST NUMBER</u>	<u>DESCRIPTION</u>
1. 910046478	Replace valve internals
2. 940059011	Drill hole in valve disc
3. 940059012	Drill hole in valve disc
4. 940059577	Replace valve bonnet studs
5. 960018506	Drill hole in valve disc
6. 960018507	Drill hole in valve disc
7. 960034215	Repair valve guides
8. 960047939	Replace ECCS suction strainer
9. 960080889	Replace double block valves
10. 960120891	Replace valve disc
11. 970021197	Plug heat exchanger tubes
12. 970031298	Replace piping flange fastners
13. 970035389	Replace support bolting
14. 970058309	Replace valve
15. 970061888	Replace pipe clamp
16. 970071549	Replace ECCS suction strainer
17. 970071613	Replace ECCS suction strainer
18. 970071641	Replace ECCS suction strainer
19. 970071689	Replace ECCS suction strainer
20. 970071718	Replace ECCS suction strainer
21. 970073644	Replace valve bonnet studs & nuts
22. 970083508	Replace snubber
23. 970083536	Replace support bolting
24. 970103338	Repair valve disc
25. 970136967	Replace valve
26. 980021310	Replace valve studs & nuts
27. 980021311	Replace valve studs & nuts
28. 990013946	Replace piping

ATTACHMENT 1

NIS-1

OWNERS REPORT FOR INSERVICE INSPECTION

FORM NIS-1 (Back)

8. Examination Dates: 5/6/96 to 11/22/99
9. Inspection Period Identification : 1st Period - From 11/23/94 to 10/11/99
10. Inspection Interval Identification : 2nd Interval - From 11/23/94 to 10/11/2006
11. Applicable Edition of Section XI 1989 Addenda N/A
12. Date/Revision of Inspection Plan: 2/2/96 Rev.1
13. Abstract of Examination and Tests. Include a list of examinations and tests and a statement concerning status of work required for the Inspection Plan. See Summary Report for item 13.
14. Abstract of Results of Examinations and Tests. See Summary Report for item 14.
15. Abstract of Corrective Measures. See Summary Report for item 15.

We certify that a) the statement made in this report are correct, b) the examinations and tests meet Inspection Plan as required by the ASME Code, Section XI, and c) corrective measures taken conform to the ASME Code, Section XI.

Certificate of Authorization No. (if applicable) N/A Expiration Date N/A
Date February 21 20 00 Signed Commonwealth Edison Co. By *Shawn C. Toellis*
Owner

CERTIFICATE OF INSERVICE INSPECTION

I, the under signed, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois And employed by H. S. B. I. & I. Co. of Hartford, CT have inspected the components described in the Owner's Report during the period 5/6/96 To 11/22/99, and state that to the best of my knowledge and belief, the Owner has performed examinations and tests and taken corrective measures described in this Owner's Report in accordance with the Inspection Plan and as required by the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations, tests, and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Robert White Commissions Ill. 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-23-20 00

ATTACHMENT 2

NIS-2

OWNERS REPORT OF REPAIR OR REPLACEMENT

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 950064426
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Section III 1971 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	7466	N/A	N/A	42-43	*	Replaced	N/A
CRD Assembly	G.E.	8594	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	42-43	*	Replaced	N/A
CRD Capscrews	Nova	Code NXG	N/A	N/A	42-43	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 8594 was refurbished with documentation provided under (Applicable Manufacturer's Data Report to be Attached) Quality Receipt Inspection 44036 and installed as a replacement for SN# 7466 under work request 950064426. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John J. Koles* ISI Coordinator Date February 19, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-20-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/4/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 960060078
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (NB) Nuclear Boiler
5. (a) Applicable Construction Code Sect III 19 74 Edition W75 Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases N-416-1
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Globe Valve Disc	Anderson Greenwood	*	N/A	N/A	1B21-F001	*	Replaced	N/A
Globe Valve Disc	Anderson Greenwood	A965-7	N/A	N/A	1B21-F001	1997**	Replacement	N/A

7. Description of Work Class 1 Replacement. Replaced Globe Valve Disc.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)
Construction Code of Replacement valve is ASME Section III, Class 1, 1974 Ed., W75 Ad.,
Reconciled per Evaluation BOM 1998-3496-1 on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John C. Kallis* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Ricky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-14-20 00

RIN/QRI M 97-05221

FORM N-2 CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL
NUCLEAR PARTS AND APPURTENANCES*

PAGE 1 of 2

As Required by the Provisions of the ASME Code, Section III
Not to Exceed One Day's Production

Pg. 1 of 2

S/O: S444400000.001 & .003

- 1. Manufactured and certified by ANDERSON, GREENWOOD & CO. 3950 GREENBRIAR, STAFFORD, TX 77477
(name and address of NPT Certificate Holder)
- 2. Manufactured for COMMONWEALTH EDISON CO., P.O. BOX 767, CHICAGO, IL 60690
(name and address of Purchaser)
- 3. Location of installation CTEAM/CRIT FACILITY 555 SOUTH JOLIET ROAD, BOLINGBROOK, IL 60440
(name and address)
- 4. Type: N04.3989.001, R/D CoCr6, AMS-5387 n/a n/a 1997
(drawing no.) (mat'l. spec. no.) (tensile strength) (CRN) (year built)
- 5. ASME Code, Section III, Division 1: 1974 W-1975 1 n/a
(edition) (addenda date) (class) (Code Case no.)
- 6. Fabricated in accordance with Const. Spec. (Div. 2 only) n/a Revision n/a Date n/a
(no.)
- 7. Remarks: REPLACEMENT PARTS, REF. VALVE ASSEMBLY N03.6492.500

RIN / QRI L 97-00304

- 8. Nom. thickness (in.) n/a Min. design thickness (in.) n/a Dia. ID (ft & in.) n/a Length overall (ft & in.) n/a
- 9. When applicable, Certificate Holders' Data Reports are attached for each item of this report:

Part or Appurtenance Serial Number	National Board No. in Numerical Order
(1) A965-7	
(2) A965-10	
(3) A965-8	
(4)	
(5)	
(6)	
(7)	
(8)	
(9)	
(10)	
(11)	
(12)	
(13)	
(14)	
(15)	
(16)	
(17)	
(18)	
(19)	
(20)	
(21)	
(22)	
(23)	
(24)	
(25)	

Part or Appurtenance Serial Number	National Board No. in Numerical Order
(26)	
(27)	
(28)	
(29)	
(30)	
(31)	
(32)	
(33)	
(34)	
(35)	
(36)	
(37)	
(38)	
(39)	
(40)	
(41)	
(42)	
(43)	
(44)	
(45)	
(46)	
(47)	
(48)	
(49)	
(50)	

- 10. Design pressure 2160 psi. Temp. 100 °F. Hydro. test pressure n/a at temp. °F
(when applicable)

* Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 2 and 3 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/88)

This form (E00040) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300.

RIN/QRI N 97-05221

FORM N-2 (Back - Pg. 2 of 2)

10520-508 105210

CODE: A965-7, -8, -10

Certificate Holder's Serial Nos. n/a through n/a

CERTIFICATION OF DESIGN

Design specifications certified by DAVID C. HAAN (when applicable) P.E. State IL Reg. no. 62-32917

Design report* certified by ALAN WEST (when applicable) P.E. State TX Reg. no. 41731

CERTIFICATE OF COMPLIANCE

RIN/QRI L 97-00304

We certify that the statements made in this report are correct and that this (these) PARTS conforms to the rules of construction of the ASME Code, Section III, Division 1.

NPT Certificate of Authorization No. N-2824 Expires 9-10-99

Date 4/30/97 Name ANDERSON, GREENWOOD & CO. (NPT Certificate Holder) Signed Joseph A. Parks (authorized representative)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TEXAS and employed by C.U.I.C.

of have inspected these items described in this Data Report on 4-30-97, and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III, Division 1. Each part listed has been authorized for stamping on the date shown above.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 4-30-97 Signed [Signature] (Authorized Inspector) Commissions Tex 803 (Nat'l. Bd. (incl. endorsements) and state or prov. and no.)

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/7/99
(Name)
One First National Plaza, Chicago, IL, 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 960064247
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, IL 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RR) Reactor Recirculation
5. (a) Applicable Construction Code * 19 * Edition * Addenda, Code Cases *
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Mech. Snubber	PSA	*	N/A	N/A	RR00-1053S	*	Replaced	N/A
Hydraulic Snubber	Liseaga	SN 61310/112	N/A	N/A	RR00-1053S	1996	Replacement	N/A

7. Description of Work Class 1 Replacement Replaced Mechanical Snubber with Hydraulic Snubber.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Visual
Pressure _____ psi Test Temp. _____ Deg. F
9. Remarks * = Per Original Design Specification J-2530 & J-2918. Original Const. Code is ANSI B31.7, 1969 Edition
(Applicable Manufacturer's Data Report to be Attached)
No Addenda

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Andrew C. Lewis* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-14-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/7/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 960064248
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RR) Reactor Recirculation
5. (a) Applicable Construction Code * 19 * Edition * Addenda, Code Cases *
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Mech. Snubber	PSA	*	N/A	N/A	RR00-1025S	*	Replaced	N/A
Hydraulic Snubber	Lisega	SN 61359/50	N/A	N/A	RR00-1025S	1996	Replacement	N/A

7. Description of Work Class 1 Replacement Replaced Mechanical Snubber with Hydraulic Snubber.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Visual
Pressure _____ psi Test Temp. _____ Deg. F
9. Remarks * = Per Original Design Specification J-2530 & J-2918. Original Const. Code is ANSI B31.7, 1969 Edition
(Applicable Manufacturer's Data Report to be Attached)
No Addenda.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Archie L. Loefer* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-14-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 1/3/97
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 960078266
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (NB) Nuclear Boiler
5. (a) Applicable Construction Code Section III 1974 Edition W75 Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1989, No Ad, Code Cases N-416-1
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Globe Valve	Anderson Greenwood	*	N/A	N/A	1B21-F002	*	Replaced	N/A
Globe Valve	Anderson Greenwood	N24920	N/A	N/A	1B21-F002	1988**	Replacement	N/A

7. Description of Work Class 1 Replacement. Replaced Globe Valve.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1039 psi Test Temp. Amb Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)
Construction Code of Replacement valve is ASME Section III, Class 1, 1974 Ed., W74 Ad., with Code Case N-345, Reconciled per Evaluation L94-0092 on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John C. Coelis* ISI Coordinator Date February 4, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-7- 20 00

FORM NPV-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*
 (As Required by the Provisions of the ASME Code, Section III, Div. 1)

S/O 05.4324.01
P.O. 318380

1. Manufactured by Anderson, Greenwood & Co., 5425 S. Rice Ave., Houston, TX 77081
(Name and Address of Manufacturer)
2. Manufactured for Commonwealth Edison Co., P.O. Box 767, Chicago, IL 60690
(Name and Address of Purchaser or Owner)
3. Location of Installation LaSalle County Station, 2601 N. 21st. Rd., Marseilles, IL 61341
(Name and Address)
4. Pump or Valve Valve Nominal Inlet Size 2 (inch) Outlet Size 2 (inch)

	(a) Model No., Series No. or Type	(b) Manufacturers' Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l. Bd. No.	(g) Year Built
(1)	G12B09C-8S8S-1M	N24920	N/A	N03-6495-515	1	N/A	1988
(2)		thru					
(3)		N24922					
(4)							
(5)							
(6)							
(7)							
(8)							
(9)							
(10)							

5. _____
(Brief description of service for which equipment was designed)

6. Design Conditions 2160 psi 100 °F or Valve Pressure Class 900# (1)
(Pressure) (Temperature)

7. Cold Working Pressure 2160 psi at 100°F.

8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
N04-3989-001	AMS 5387	AGCO	Disc
(b) Forgings			
N04-3986-005	SA105	AGCO	Body

(1) For manually operated valves only.

* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8-1/2" x 11", (2) information in items 1, 2 and 5 on this data report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting	N/A		
(d) Other Parts			
N04-4005-005	SA105	AGCO	Bonnet Assy

9. Hydrostatic test 3350 psi.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. I, Edition 1974.
 Addenda W-74 (Date), Code Case No. N-345 Date 8/30/88
 Signed Anderson, Greenwood & Co. by Joseph A. Parks
 (Manufacturer)
 Our ASME Certificate of Authorization No. N2203 to use the N (N) (NFV) symbol expires 8-4-90 (Date)
 Note: Mat'l meets 1983 Edition, Summer 1983

CERTIFICATION OF DESIGN

Design information on file at Anderson, Greenwood & Co.
 Stress analysis report (Class 1 only) on file at Anderson, Greenwood & Co.
 Design specifications certified by (1) David C. Haan
 PE State II Reg. No. 62-32917
 Stress analysis certified by (1) J. Alan West
 PE State TX Reg. No. 41731
 (1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TX and employed by C.U.I.C. of Boston, MA have inspected the pump, or valve, described in this Data Report on 8/30 19 88, and state that to the best of my knowledge and belief, the Manufacturer has constructed this pump, or valve, in accordance with the ASME Code, Section III.
 By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 8/30 19 88
A. J. Young (Inspector) Commissions Tex. 673
 (Nat'l Bd., State, Prov. and No.)

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 2/21/97
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 960094667
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System RH
5. (a) Applicable Construction Code Sect III 19 74 Edition No Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases N-416-1
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
2" Sch. 160 Pipe	*	*	N/A	N/A	1RHB4AB-2"	*	Replaced	N/A
2" Sch. 160 Pipe	CPS	Ht. # L00716	N/A	N/A	1RHB4AB-2"	1997	Replacement	N/A
(2) 2" 90° S.W Elbows	*	*	N/A	N/A	1RHB4AB-2"	*	Replaced	N/A
(2) 2" 90° S.W. Elbows	CPS	Ht. # R110N	N/A	N/A	1RHB4AB-2"	1997	Replacement	N/A
2" 6000# 1/2 Coupling	*	*	N/A	N/A	1RHB4AB-2"	*	Replaced	N/A
2" 6000# 1/2 Coupling	CPS	Ht. # 171YNA	N/A	N/A	1RHB4AB-2"	1996	Replacement	N/A

7. Description of Work Class 1, Replacement, Replaced Coupling, Pipe, and Elbows.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1030 psi Test Temp. Amb Deg. F
(Applicable Manufacturer's Data Report to be Attached)
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
The Replacement Pipe, 1/2 Coupling, and elbows are ASME Section III, Class 1, 1989 Ed., 89 Ad., reconciled per PTE L-94-0092 for the Pipe, PTE L-1996-113-1 for the 1/2 Coupling and M-1996-0584-003 for the elbows. All evaluations are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Don C. Lewis* ISI Coordinator Date February 3, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-21-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 6/1/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970011261
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System Standby Liquid Control
5. (a) Applicable Construction Code Sect III 19 77 Edition S77 Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No. Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Inlet Fitting	Conax	*	N/A	N/A	1C41-F004B	*	Replaced	N/A
Inlet Fitting	Conax	5385	N/A	N/A	1C41-F004B	1997**	Replacement	N/A
Trigger Body	Conax	*	N/A	N/A	1C41-F004B	*	Replaced	N/A
Trigger Body	Conax	5383	N/A	N/A	1C41-F004B	1997**	Replacement	N/A

7. Description of Work Class 1 Replacement. Replaced existing components with new after explosive firing.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1225/1025 psi Test Temp. 88 Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)
** = Replacement components were constructed to ASME Section III, Class 1, 1977 Ed., with S77 Addenda
Replacement reconciled per PTE 88-161 on file at LaSalle County Station

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Robert C. Kowalski* ISI Coordinator Date February 4, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-4 20 00

**FORM N-2 CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL
NUCLEAR PARTS AND APPURTENANCES***
As Required by the Provisions of the ASME Code, Section III
Not to Exceed One Day's Production

1. Manufactured and certified by Conax Buffalo Corporation, 2300 Walden Avenue, Cheektowaga, NY 14225
(name and address of NPT Certificate Holder)

2. Manufactured for Commonwealth Edison Co., P.O. Box 767, Chicago, IL 60609
(name and address of Purchaser)

3. Location of installation N/A
(name and address)

4. Type: N20000, Rev. G SA479 304SST 75 KSI N/A 1997
(drawing no.) (mat'l spec. no.) (tensile strength) (CRN) (year built)

5. ASME Code, Section III, Division 1: 77 S77 1 N/A
(edition) (addenda data) (class) (Code Case no.)

6. Fabricated in accordance with Const. Spec. (Div. 2 only) N/A Revision _____ Date _____
(no.)

7. Remarks: Trigger Body Subassembly for explosive actuated valve replacement kit for standby liquid control system.
Para. NB-2121 (b) is applicable to ram. Press Fit/Seal on .328 & .4375 diameters. Overall subassembly length is 2.5".
Pressure Test at 2800 psi for 10 minutes.

8. Nom. thickness (in.) See Remarks Min. design thickness (in.) See Remarks Dia. ID (ft & in.) See Remarks Length overall (ft & in.) See Remarks

9. When applicable, Certificate Holders' Data Reports are attached for each item of this report:

Part or Appurtenance Serial Number	National Board No. in Numerical Order
(1) <u>5383</u>	<u>5383</u>
(2) <u>5384</u>	<u>5384</u>
(3)	
(4)	
(5)	
(6)	
(7)	
(8)	
(9)	
(10)	
(11)	
(12)	
(13)	
(14)	
(15)	
(16)	
(17)	
(18)	
(19)	
(20)	
(21)	
(22)	
(23)	
(24)	
(25)	

Part or Appurtenance Serial Number	National Board No. in Numerical Order
(26)	
(27)	
(28)	
(29)	
(30)	
(31)	
(32)	
(33)	
(34)	
(35)	
(36)	
(37)	
(38)	
(39)	
(40)	
(41)	
(42)	
(43)	
(44)	
(45)	
(46)	
(47)	
(48)	
(49)	
(50)	

10. Design pressure 1400 psi. Temp. 150 °F. Hydro. test pressure * See Remarks at temp. °F
(when applicable)

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 2 and 3 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

Certificate Holder's Serial Nos. 5383 through 5384

CERTIFICATION OF DESIGN

Design specifications certified by George I. Skoda P.E. State CA Reg. no. 15847
(when applicable)

Design report* certified by Francis J. Domino P.E. State NY Reg. no. 36832
(when applicable)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this (these) Trigger Body Subassemblies conforms to the rules of construction of the ASME Code, Section III, Division 1.

NPT Certificate of Authorization No. N-1850 Expires September 2, 1998

Date 5/7/97 Name Conax Buffalo Corporation Signed [Signature]
(NPT Certificate Holder) (authorized representative)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of New York and employed by Hartford Steam Boiler Inspection & Insurance Company

of Hartford, CT have inspected these items described in this Data Report on MAY 6, 1997, and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III, Division 1. Each part listed has been authorized for stamping on the date shown above. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 5-12-97 Signed [Signature] Commissions NB 10964AN NY 5057
(Authorized Inspector) (Nat'l Bd. (incl. endorsements) and state or prov. and no.)

87-00510

RIN/ORI M 97-05748

FORM N-2 CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL NUCLEAR PARTS AND APPURTENANCES* As Required by the Provisions of the ASME Code, Section III Not to Exceed One Day's Production

1. Manufactured and certified by Conax Buffalo Corporation, 2300 Walden Avenue, Cheektowaga, NY 14225
2. Manufactured for Commonwealth Edison Co., P.O. Box 767, Chicago, IL 60609
3. Location of installation N/A
4. Type: N38017, Rev. F SA479 304SS 75 KSI N/A 1997
5. ASME Code, Section III, Division 1: 77 S77 1 N/A
6. Fabricated in accordance with Const. Spec. (Div. 2 only) N/A Revision Date
7. Remarks: Inlet Fitting for explosive actuated valve replacement kit for standby liquid control system.

Pressure Test at 2800 psi for 10 minutes.

8. Nom. thickness (in.) .040 Min. design thickness (in.) .031 Dia. ID (ft & in.) .895" Length overall (ft & in.) 2.245"
9. When applicable, Certificate Holders' Data Reports are attached for each item of this report:

Table with 2 columns: Part or Appurtenance Serial Number, National Board No. in Numerical Order. Rows 1-25.

Table with 2 columns: Part or Appurtenance Serial Number, National Board No. in Numerical Order. Rows 26-50.

10. Design pressure 1400 psi. Temp. 150 °F. Hydro. test pressure * See Remarks at temp. °F

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 2 and 3 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

Certificate Holder's Serial Nos. 5385 through 5386

CERTIFICATION OF DESIGN

Design specifications certified by George I. Skoda P.E. State CA Reg. no. 15847
(when applicable)

Design report* certified by Francis J. Domino P.E. State NY Reg. no. 36832
(when applicable)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this (these) Inlet Fittings conforms to the rules of construction of the ASME Code, Section III, Division 1.

NPT Certificate of Authorization No. N-1850 Expires September 2, 1998

Date 5/12/97 Name Conax Buffalo Corporation Signed [Signature]
(NPT Certificate Holder) (authorized representative)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of New York and employed by Hartford Steam Boiler Inspection & Insurance Company

of Hartford, CT have inspected these items described in this Data Report on MAY 6, 1997 and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III, Division 1. Each part listed has been authorized for stamping on the date shown above. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 5-12-97 Signed [Signature] Commissions NB 10964AN NY 5057
(Authorized Inspector) (Nat'l Bd. (incl. endorsements) and state or prov. and no.)

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 7/18/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970042731
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System RI
5. (a) Applicable Construction Code ANSI B31.7 19 69 Edition No Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Clamp Bolt	*	*	N/A	N/A	RI42-1011X	*	Replaced	N/A
Capscrew	Mighty Mill	*	N/A	N/A	RI42-1011X	1998**	Replacement	N/A
(2) Hex Nuts	*	*	N/A	N/A	RI42-1011X	*	Replaced	N/A
(2) Hex Nuts	Nova	*	N/A	N/A	RI42-1011X	1996**	Replacement	N/A

7. Description of Work Class 1 Replacement Replaced clamp bolt, and nuts.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Visual
Pressure psi Test Temp. Deg. F
9. Remarks * =Per Original Design Spec. J-2530
(Applicable Manufacturer's Data Report to be Attached)
** = Replacement Nut material is ASME Sect. III, Class 1, 1989 Ed., No Ad.
Replacement Capscrew is Nuclear Safety Related

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Paul C. Lewis* ISI Coordinator Date February 3, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-3- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 12/20/97
(Name)
One First National Plaza, Chicago, IL, 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 See Item 6 "Other Identification" Below
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, IL 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (MS) Main Steam
5. (a) Applicable Construction Code Sect III 19 71 Edition S72 Addenda, Code Cases 1567 & 1711
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
SRV Valve	Crosby	N63790-00-0002	N/A	N/A	970060141	*	Replaced	N/A
SRV Valve	Crosby	N63790-00-0076	N/A	N/A	L97-00468	*	Replacement	N/A
Spindle Assembly	Crosby	K62873-31-0076	N/A	N/A	L97-00468	*	Replaced	N/A
Spindle Assembly	Crosby	K82137-41-0028	N/A	N/A	L97-00468	1996	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1039 psi Test Temp. Amb Deg. F
9. Remarks Valve SN# N63790-00-0076 was refurbished at Wyle Labs with documentation provided under Quality (Applicable Manufacturer's Data Report to be Attached)
Receipt Inspection L97-00468 and installed as a replacement for SN# N63790-00-0002 under work request 970060141

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Richard L. Gales* ISI Coordinator Date February 4, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-9- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 12/20/97
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 2
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 See Item 6 "Other Identification" Below
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (MS) Main Steam
5. (a) Applicable Construction Code Sect III 19 71 Edition S72 Addenda, Code Cases 1567 & 1711
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No. Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
SRV Valve	Crosby	N63790-00-0015	N/A	N/A	970060143	*	Replaced	N/A
SRV Valve	Crosby	N63790-00-0070	N/A	N/A	L97-00577	*	Replacement	N/A
Spindle Assembly	Crosby	K62873-31-0070	N/A	N/A	L97-00577	*	Replaced	N/A
Spindle Assembly	Crosby	K82137-42-0038	N/A	N/A	L97-00577	1996	Replacement	N/A
(4) Inlet Studs	Crosby	*	N/A	N/A	*	*	Replaced	N/A
(4) Inlet Studs	Crosby	Ht. Code NAD	N/A	N/A	L97-00577	1993	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1039 psi Test Temp. Amb Deg. F
9. Remarks Valve SN# N63790-00-0070 was refurbished at Wyle Labs with documentation provided under Quality (Applicable Manufacturer's Data Report to be Attached)
Receipt Inspection L97-00577 and installed as a replacement for SN# N63790-00-0015 under work request 970060143. For the remainder of the Replaced and Replacement items, see Form NIS-2 Supplemental Sheet on Page 2 of 2.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A


Signed *John C. Kucis* ISI Coordinator Date February 4, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-7-2000

L93-02101



CROSBY VALVE & GAGE COMPANY
WRENTHAM, MA

Q.C.-392
SHEET 1 OF 2

FORM N-2, N OR NPT CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL NUCLEAR PARTS AND APPURTENANCES
As Required by the Provisions of the ASME Code, Section III, Division 1 - Not to Exceed One Day's Production

1. Manufactured and certified by Crosby Valve & Gage Company 43 Kendrick St. Wrentham, MA 02093
 (Name and Address of N Certificate Holder)

2. Manufactured for COMMONWEALTH EDISON CO., CHICAGO, IL 60690
 (Name and Address of Purchaser or Owner)

3. Location of Installation COMMONWEALTH EDISON CO., MARSEILLES, IL 61341
 (Name and Address)

4. DS-A-63790 REV.D 1993
 (Drawing No.) (Year Built)

5. ASME SA 637 GR. 718 327,670
 (Material Spec No.) (Tensile Strength)

6. Norm. Thickness(in.) Min. Design Thickness
 Dia. ID Length Overall Inch Inch

7. °F
 Design Pressure(PSI) Temperature

Hydrostatic Test (psig) at °F
 (When applicable)

8. Fabricated in accordance with Const. Spec.(Div. 2 only) Revision Date
 (No.)

9. ASME Code, Section III, Division 1: 1971 572 1 1711
 (Edition) (Addenda Date) (Class) (Code Case No.)

10. Remarks

11. When applicable, Certificate Holders' data reports are attached for each item of this report:

Part or Appurtenance Serial Number	National Board No. Numerical Order	Part or Appurtenance Serial Number	National Board No. Numerical Order
(1) <u>N93185-53-0206</u>	<u> </u>	(11) <u> </u>	<u> </u>
(2) <u>N93185-53-0207</u>	<u> </u>	(12) <u> </u>	<u> </u>
(3) <u>N93185-53-0208</u>	<u> </u>	(13) <u> </u>	<u> </u>
(4) <u>N93185-53-0210</u>	<u> </u>	(14) <u> </u>	<u> </u>
(5) <u>N93185-53-0211</u>	<u> </u>	(15) <u> </u>	<u> </u>
(6) <u>N93185-53-0212</u>	<u> </u>	(16) <u> </u>	<u> </u>
(7) <u>N93185-53-0214</u>	<u> </u>	(17) <u> </u>	<u> </u>
(8) <u>N93185-53-0215</u>	<u> </u>	(18) <u> </u>	<u> </u>
(9) <u>N93185-53-0216</u>	<u> </u>	(19) <u> </u>	<u> </u>
(10) <u> </u>	<u> </u>	(20) <u> </u>	<u> </u>

Manufacturer Serial No. N93185-53-0208

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this (these) DISC INSERTS conform to the rules of construction of the ASME Code, Section III.

Date 30 Nov 93 Signed [Signature] Crosby Valve & Fitting Company
 (Npt. Certificate) Holder (Authorized Representative)
 NV Certificate of Authorization No. N-1877 Expires 30 SEP 95
 (Date)

CERTIFICATE OF DESIGN

Design specification certified by C.T. NIEH
 PE State CA Reg No. 15587
 Design Report Certified by W.D. GREENLAW
 PE State MA Reg No. 14784
 *Signature not required - list name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Massachusetts and employed by Arkwright Mutual Insurance Co. of Norwood, Massachusetts have inspected these items described in this Data Report on Nov 10, 1993 and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III. Each part listed has been authorized for stamping on the date shown above.
 By signing this certificate, neither the inspector nor the employer makes any warrant, expressed or implied, concerning the component described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date 11/10 1993
 Signed [Signature]
 (Inspector)
 Commission M41455
 (Mett. Bd., State, Prov. and No.)
 Factory Mutual System

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 12/20/97
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 See Item 6 "Other Identification" Below
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (MS) Main Steam
5. (a) Applicable Construction Code Sect III 19 71 Edition S72 Addenda, Code Cases 1567 & 1711
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
SRV Valve	Crosby	N63790-00-0007	N/A	N/A	970060144	*	Replaced	N/A
SRV Valve	Crosby	N63790-00-0068	N/A	N/A	L97-00468	*	Replacement	N/A
Spindle Assembly	Crosby	K62873-31-0068	N/A	N/A	L97-00468	*	Replaced	N/A
Spindle Assembly	Crosby	K82137-42-0035	N/A	N/A	L97-00468	1996	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1039 psi Test Temp. Amb Deg. F
9. Remarks Valve SN# N63790-00-0068 was refurbished at Wyle Labs with documentation provided under Quality (Applicable Manufacturer's Data Report to be Attached)
Receipt Inspection L97-00468 and installed as a replacement for SN# N63790-00-0007 under work request 970060144

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Alan C. Willis* ISI Coordinator Date February 4, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Ricky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-7-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 1/7/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 2
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 See Item 6 "Other Identification" Below
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (MS) Main Steam
5. (a) Applicable Construction Code Sect III 19 71 Edition S72 Addenda, Code Cases 1567 & 1711
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
SRV Valve	Crosby	N63790-00-0070	N/A	N/A	970060147	*	Replaced	N/A
SRV Valve	Crosby	N63790-00-0015	N/A	N/A	L97-00577	*	Replacement	N/A
Spindle Assembly	Crosby	K62873-34-0016	N/A	N/A	L97-00577	*	Replaced	N/A
Spindle Assembly	Crosby	K82137-42-0034	N/A	N/A	L97-00577	1996	Replacement	N/A
(3) Inlet Studs	Crosby	*	N/A	N/A	*	*	Replaced	N/A
(2) Inlet Studs	Crosby	Ht. Code ATZ	N/A	N/A	L97-00577	1992	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1039 psi Test Temp. Amb Deg. F
9. Remarks Valve SN# N63790-00-0015 was refurbished at Wyle Labs with documentation provided under Quality (Applicable Manufacturer's Data Report to be Attached)
Receipt Inspection L97-00577 and installed as a replacement for SN# N63790-00-0070 under work request 970060147. For the remainder of the Replaced and Replacement items, see Form NIS-2 Supplemental Sheet on Page 2 of 2.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Allen C. Goules* ISI Coordinator Date February 4, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Kathy W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-7-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 12/20/97
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 See Item 6 "Other Identification" Below
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Mechanical Maintenance Authorization No. N/A
(Address) Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (MS) Main Steam
5. (a) Applicable Construction Code Sect III 19 71 Edition S72 Addenda, Code Cases 1567 & 1711
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
SRV Valve	Crosby	N63790-00-0080	N/A	N/A	970060148	*	Replaced	N/A
SRV Valve	Crosby	N63790-00-0069	N/A	N/A	L97-00468	*	Replacement	N/A
Spindle Assembly	Crosby	K62873-31-0069	N/A	N/A	L97-00468	*	Replaced	N/A
Spindle Assembly	Crosby	K82137-41-0024	N/A	N/A	L97-00468	1996	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1039 psi Test Temp. Amb Deg. F
9. Remarks Valve SN# N63790-00-0069 was refurbished at Wyle Labs with documentation provided under Quality (Applicable Manufacturer's Data Report to be Attached)
Receipt Inspection L97-00468 and installed as a replacement for SN# N63790-00-0080 under work request 970060148

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John C. Gales* ISI Coordinator Date February 4, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-7-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 1/3/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 See Item 6 "Other Identification" Below
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (MS) Main Steam
5. (a) Applicable Construction Code Sec III 19 71 Edition S72 Addenda, Code Cases 1567 & 1711
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
SRV Valve	Crosby	N63790-00-0004	N/A	N/A	970060151	*	Replaced	N/A
SRV Valve	Crosby	N63790-00-0063	N/A	N/A	L97-00468	*	Replacement	N/A
Spindle Assembly	Crosby	K62873-31-0063	N/A	N/A	L97-00468	*	Replaced	N/A
Spindle Assembly	Crosby	K82137-41-0026	N/A	N/A	L97-00468	1996	Replacement	N/A
(2) Inlet Nuts	Crosby	*	N/A	N/A	*	*	Replaced	N/A
(2) Inlet Nuts	Vitco	Ht. Code NBU-1	N/A	N/A	970060151	1993	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1039 psi Test Temp. Amb Deg. F
9. Remarks Valve SN# N63790-00-0063 was refurbished at Wyle Labs with documentation provided under Quality (Applicable Manufacturer's Data Report to be Attached)
Receipt Inspection L97-00468 and installed as a replacement for SN# N63790-00-0004 under work request 970060151.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Robert C. Koelsch* ISI Coordinator Date February 19, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-20-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 1/3/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 2
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 See Item 6 "Other Identification" Below
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (MS) Main Steam
5. (a) Applicable Construction Code Sect III 19 71 Edition S72 Addenda, Code Cases 1567 & 1711
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
SRV Valve	Crosby	N63790-00-0009	N/A	N/A	970060152	*	Replaced	N/A
SRV Valve	Crosby	N63790-00-0075	N/A	N/A	L97-00468	*	Replacement	N/A
Spindle Assembly	Crosby	K62873-32-0022	N/A	N/A	L97-00468	*	Replaced	N/A
Spindle Assembly	Crosby	K82137-42-0033	N/A	N/A	L97-00468	1996	Replacement	N/A
Nozzle	Crosby	N93184-36-0130	N/A	N/A	*	*	Replaced	N/A
Nozzle	Crosby	N93184-49-0136	N/A	N/A	L97-00468	1992	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1039 psi Test Temp. Amb Deg. F
9. Remarks Valve SN# N63790-00-0075 was refurbished at Wyle Labs with documentation provided under Quality (Applicable Manufacturer's Data Report to be Attached)
Receipt Inspection L97-00468 and installed as a replacement for SN# N63790-00-0009 under work request 970060152. For the remainder of the Replaced and Replacement items, see Form NIS-2 Supplemental Sheet on Page 2 of 2.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Arthur L. Harris* ISI Coordinator Date February 4, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION


I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Harley W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-7-20 00

L 92.01991



CROSBY VALVE & GAGE COMPANY
WRENTHAM, MASS

Q.C.-392
Form N-2

FORM N-2 N OR NPT CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL
NUCLEAR PARTS AND APPURTENANCES*
As Required by the Provisions of the ASME Code, Section III, Division 1
Not to Exceed One Day's Production

Pg 1 of 1

1. Manufactured and certified by Crosby Valve & Gage Company, 43 Kendrick St., Wrentham MA 02093
(name and address of certificate holder)

2. Manufactured for COMMONWEALTH EDISON CO., CHICAGO IL 60690
(name and address of purchaser)

3. Location of installation LASALLE STATION #1, 2601 N. 21ST ROAD, MARSEILLES IL 61341
(name and address)

4. Type DS-A-63790 ASME SA182 GR. F316 83,830 PSI --- 1992
(drawing no.) (mat'l spec no.) (tensile strength) (CRN) (year built)

5. ASME Code, Section III 1971 SUMMER 1972 1 1711
(edition) (addenda) (class) (Code Case no.)

6. Fabricated in accordance with Const. Spec. (Div. 2 only) --- Revision --- Date ---
(No.)

7. Remarks:

8. Nom. thickness (in.) --- Min. design thickness (in.) --- Dia. ID (ft. & in.) --- Length overall (ft. & in.) ---

9. When applicable, Certificate Holders' data reports are attached for each item of this report:

Part or Appurtenance Serial Number	National Board No. In Numerical Order	Part or Appurtenance Serial Number	National Board No. In Numerical Order
(1) N93184-49-0136		(11)	
(2)		(12)	
(3)		(13)	
(4)		(14)	
(5)		(15)	
(6)		(16)	
(7)		(17)	
(8)		(18)	
(9)		(19)	
(10)		(20)	

10. Design pressure --- psi Temp. --- °F Hydro. test pressure 2370 at temp. --- °F.
(when applicable)

L92-01991

Form N-2

FORM N-2 (back)

Mfr. Serial No. N93183-49-0136

CERTIFICATION OF DESIGN

Design specification certified by C. T. NIEH P.E. state CA Reg. No. 15587
(when applicable)

Design report* certified by W. D. GREENLAW P.E. state MA Reg. No. 14784
(when applicable)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this (~~XXXX~~) NOZZLE
conform to the rules of construction of the ASME Code, Section III.

NPT Certificate of Authorization no. N-1877 Expires 9-30-92

Date 9-23-92 Name Crosby Valve & Gage Co. Signed Lawrence J. [Signature]
(NPT Certificate Holder) (authorized representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or province of Massachusetts and employed by *See Below of Norwood, MA have inspected these items described in this data report on 9-23-92 and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III. Each part listed has been authorized for stamping on the date shown above.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 9-23-92 Signed [Signature] Commissions MA 1207
(Authorized Inspector) (Nat'l Bd (incl. endorsements) state or prov. and no.)

*Arkwright Mutual Insurance Company



CROSBY VALVE & GAGE COMPANY
WRENTHAM, MASS


O.C.-382
Form N-2

FORM N-2 N OR NPT CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL
NUCLEAR PARTS AND APPURTENANCES*
As Required by the Provisions of the ASME Code, Section III, Division 1
Not to Exceed One Day's Production

**Corrected Report
11-25-91
11-25-91
11-25-91
Pg 1 of 1

- Manufactured and certified by Crosby Valve & Gage Co., 43 Kendrick St., Wrentham, MA 02093
(name and address of certificate holder)
- Manufactured for Commonwealth Edison Co. P.O.Box 767 Chicago, IL 60690
(name and address of purchaser)
- Location of installation LaSalle Station #1 2601 N. 21ST RD., Marseilles IL 61341
(name and address)
- Type DS-A-63790 ASME SAG37 Gr.718 216,000 -- 1991
(drawing no.) (mat'l spec no.) (tensile strength) (CRN) (year built)
- ASME Code, Section III 1971 Summer 1972 1 **1711
(edition) (addenda) (class) (Code Case no.)
- Fabricated in accordance with Const. Spec. (Div. 2 only) -- Revision -- Date --
(No.)
- Remarks:
- Nom. thickness (in.) -- Min. design thickness (in.) -- Dia. ID (ft. & in.) -- Length overall (ft. & in.) --
- When applicable, Certificate Holders' data reports are attached for each item of this report:

Part or Appurtenance Serial Number	National Board No. In Numerical Order	Part or Appurtenance Serial Number	National Board No. In Numerical Order
(1) N93185-46-0164		(26)	
(2) N93185-46-0165		(27)	
(3) N93185-46-0166		(28)	
(4) N93185-46-0168		(29)	
(5) N93185-46-0169		(30)	
(6) N93185-46-0170		(31)	
(7) N93185-46-0171		(32)	
(8) N93185-46-0172		(33)	
(9) N93185-46-0174		(34)	
(10) N93185-46-0175		(35)	
(11) N93185-46-0176		(36)	
(12) N93185-46-0178		(37)	
(13) N93185-46-0180		(38)	
(14) N93185-46-0181		(39)	
(15) N93185-46-0182		(40)	
(16) N93185-46-0184		(41)	
(17) N93185-46-0185		(42)	
(18) N93185-47-0186		(43)	
(19) N93185-47-0187		(44)	
(20)		(45)	
(21)		(46)	
(22)		(47)	
(23)		(48)	
(24)		(49)	
(25)		(50)	



10. Design pressure -- psi Temp. -- °F. Hydro. test pressure -- at temp. -- °F.
(when applicable)

EVAL NO# L-92-006-0026
PAGE 7 OF 4

Form N-2

FORM N-2 (back)

Mr. Serial No. (1) See front side for remaining serial numbers.

CERTIFICATION OF DESIGN

Design specification certified by C.T. Nieh P.E. state CA Reg. No. 15587
(when applicable)

Design report* certified by W.D. Greenlaw P.E. state MA Reg. No. 14784
(when applicable)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this (these) Disc Inserts conform to the rules of construction of the ASME Code, Section III.

NPT Certificate of Authorization no. N-1877 Expires 9/30/92

Date 10-28-91 Name Crosby Valve & Gage Co. Signed Lawrence J. Price
(NPT Certificate Holder) (authorized representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or province of Massachusetts and employed by *See Below or Norwood, MA have inspected these items described in this data report on 10-28-91 and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III. Each part listed has been authorized for stamping on the date shown above.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Factory Mutual System

Date 10-28-91 Signed W.S. [Signature] Commissions MA 1207
(Authorized Inspector) (Nat'l Bd (incl. endorsements) state or prov. and no.)

*Arkwright Mutual Insurance Company

- ** Report corrected to add Code Case 1711
- ** Lawrence J. Price 11-25-91
Crosby Valve & Gage Company Date
- ** [Signature] 11-25-91
Authorized Nuclear Inspector Date

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 1/2/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 2
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 See Item 6 "Other Identification" Below
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (MS) Main Steam
5. (a) Applicable Construction Code Sect III 19 71 Edition S72 Addenda, Code Cases 1567 & 1711
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
SRV Valve	Crosby	N63790-00-0003	N/A	N/A	970060154	*	Replaced	N/A
SRV Valve	Crosby	N63790-00-0077	N/A	N/A	L97-00468	*	Replacement	N/A
Spindle Assembly	Crosby	K62873-31-0077	N/A	N/A	*	*	Replaced	N/A
Spindle Assembly	Crosby	K82137-42-0031	N/A	N/A	L97-00468	1996	Replacement	N/A
(1) Inlet Stud	Crosby	*	N/A	N/A	*	*	Replaced	N/A
(1) Inlet Stud	Crosby	Ht. Code GAM	N/A	N/A	L97-00468	1992	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1039 psi Test Temp. Amb Deg. F
9. Remarks Valve SN# N63790-00-0077 was refurbished at Wyle Labs with documentation provided under Quality (Applicable Manufacturer's Data Report to be Attached)
Receipt Inspection L97-00468 and installed as a replacement for SN# N63790-00-0003 under work request 970060154. For the remainder of the Replaced and Replacement items, see Form NIS-2 Supplemental Sheet on Page 2 of 2.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John C. Kallis* ISI Coordinator Date February 5, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-7- 20 00

CROSBY

CROSBY VALVE & GAGE COMPANY WRENTHAM, MASS

Q.C.-392
Form N-2

FORM N-2 N OR NPT CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL
NUCLEAR PARTS AND APPURTENANCES*
As Required by the Provisions of the ASME Code, Section III, Division 1
Not to Exceed One Day's Production

Pg 1 of 1

1. Manufactured and certified by Crosby Valve & Gage Co., 43 Kendrick St., Wrentham, MA 02093
(name and address of certificate holder)
2. Manufactured for Commonwealth Edison Co. P.O.Box 767 Chicago, IL 60690
(name and address of purchaser)
3. Location of installation LaSalle Station #1 2601 N. 21ST RD., Marseilles IL 61341
(name and address)
4. Type DS-A-63790 ASME SA637 Gr.718 216,000 --- 1991
(drawing no.) (mat'l spec no.) (tensile strength) (CRN) (year built)
5. ASME Code, Section III 1971 Summer 1972 1 ---
(edition) (addenda) (class) (Code Case no.)
6. Fabricated in accordance with Const. Spec. (Div. 2 only) --- Revision --- Date ---
(No.)
7. Remarks: _____
8. Nom. thickness (in.) --- Min. design thickness (in.) --- Dia. ID (ft. & in.) --- Length overall (ft. & in.) ---
9. When applicable, Certificate Holders' data reports are attached for each item of this report:

Part or Appurtenance Serial Number	National Board No. In Numerical Order	Part or Appurtenance Serial Number	National Board No. In Numerical Order
(1) N93185-46-0164		(26)	
(2) N93185-46-0165		(27)	
(3) N93185-46-0166		(28)	
(4) N93185-46-0168		(29)	
(5) N93185-46-0169		(30)	
(6) N93185-46-0170		(31)	
(7) N93185-46-0171		(32)	
(8) N93185-46-0172		(33)	
(9) N93185-46-0174		(34)	
(10) N93185-46-0175		(35)	
(11) N93185-46-0176		(36)	
(12) N93185-46-0178		(37)	
(13) N93185-46-0180		(38)	
(14) N93185-46-0181		(39)	
(15) N93185-46-0182		(40)	
(16) N93185-46-0184		(41)	
(17) N93185-46-0185		(42)	
(18) N93185-47-0186		(43)	
(19) N93185-47-0187		(44)	
(20)		(45)	
(21)		(46)	
(22)		(47)	
(23)		(48)	
(24)		(49)	
(25)		(50)	

10. Design pressure --- psi Temp. --- °F. Hydro. test pressure --- at temp. --- °F.
(when applicable)

FORM N-2 (back)

Mfr. Serial No. (1) See front side for remaining serial numbers.

CERTIFICATION OF DESIGN		
Design specification certified by <u>C.T. Nieh</u> <small>(when applicable)</small>	P.E. state <u>CA</u>	Reg. No. <u>15587</u>
Design report* certified by <u>W.D. Greenlaw</u> <small>(when applicable)</small>	P.E. state <u>MA</u>	Reg. No. <u>14784</u>
CERTIFICATE OF SHOP COMPLIANCE		
We certify that the statements made in this report are correct and that this (these) <u>Disc Inserts</u> conform to the rules of construction of the ASME Code, Section III.		
NPT Certificate of Authorization no. <u>N-1877</u>		Expires <u>9/30/92</u>
Date <u>10-28-91</u>	Name <u>Crosby Valve & Gage Co.</u> <small>(NPT Certificate Holder)</small>	Signed <u>Laurence J. Pines</u> <small>(authorized representative)</small>
CERTIFICATE OF SHOP INSPECTION		
I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or province of <u>Massachusetts</u> and employed by <u>*See Below</u> of <u>NORWOOD, MA</u> have inspected these items described in this data report on <u>10-28-91</u> and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III. Each part listed has been authorized for stamping on the date shown above.		
By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.		
Factory Mutual System		
Date <u>10-28-91</u>	Signed <u>[Signature]</u> <small>(Authorized Inspector)</small>	Commissions <u>MA 1207</u> <small>(Nat'l Bd (incl. endorsements) state or prov. and no.)</small>

*Arkwright Mutual Insurance Company

CROSBYCROSBY VALVE & GAGE COMPANY
WRENTHAM, MASSQ.C.-392
Form N-2

L92-01986

FORM N-2 N OR NPT CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL
NUCLEAR PARTS AND APPURTENANCES*
As Required by the Provisions of the ASME Code, Section III, Division 1
Not to Exceed One Day's Production

Pg 1 of 1

1. Manufactured and certified by Crosby Valve & Gage Company, 43 Kendrick St., Wrentham MA 02093
(name and address of certificate holder)
2. Manufactured for COMMONWEALTH EDISON CO., CHICAGO IL 60690
(name and address of purchaser)
3. Location of installation LASALLE STATION #1, 2601 N. 21ST ROAD, MARSEILLES IL 61341
(name and address)
4. Type DS-A-63790 ASME SA182 GR. F316 83,830 PSI — 1992
(drawing no.) (mat'l spec no.) (tensile strength) (CRN) (year built)
5. ASME Code, Section III 1971 SUMMER 1972 1 1711
(edition) (addenda) (class) (Code Case no.)
6. Fabricated in accordance with Const. Spec. (Div. 2 only) — Revision — Date —
(No.)
7. Remarks:
8. Nom. thickness (in.) — Min. design thickness (in.) — Dia. ID (ft. & in.) — Length overall (ft. & in.) —
9. When applicable, Certificate Holders' data reports are attached for each item of this report:

Part or Appurtenance Serial Number	National Board No. In Numerical Order	Part or Appurtenance Serial Number	National Board No. In Numerical Order
(1) N93184-49-0137		(11)	
(2) N93184-49-0138		(12)	
(3) N93184-49-0139		(13)	
(4) N93184-49-0140		(14)	
(5) N93184-49-0141		(15)	
(6) N93184-49-0142		(16)	
(7) N93184-49-0143		(17)	
(8) N93184-49-0144		(18)	
(9)		(19)	
(10)		(20)	

10. Design pressure — psi Temp. — Hydro. test pressure 2370 at temp. —
(when applicable)

FORM N-2 (back)

Mfr. Serial No. N93183-49-0137 Thru 0144

CERTIFICATION OF DESIGN			
Design specification certified by	<u>C. T. NIEH</u> <small>(when applicable)</small>	P.E. state	<u>CA</u> Reg. No. <u>15587</u>
Design report* certified by	<u>W. D. GREENLAW</u> <small>(when applicable)</small>	P.E. state	<u>MA</u> Reg. No. <u>14784</u>
CERTIFICATE OF SHOP COMPLIANCE			
We certify that the statements made in this report are correct and that NOX (these) <u>NOZZLES</u> conform to the rules of construction of the ASME Code, Section III.			
NPT Certificate of Authorization no.		<u>N-1877</u>	Expires <u>9-30-92</u>
Date <u>9-23-92</u>	Name <u>Crosby Valve & Gage Co.</u> <small>(NPT Certificate Holder)</small>	Signed <u>Lawrence J. Price</u> <small>(authorized representative)</small>	
CERTIFICATE OF SHOP INSPECTION			
I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the state or province of <u>Massachusetts</u> and employed by <u>*See Below</u> of <u>Norwood, MA</u> have inspected these items described in this data report on <u>9-23-92</u> and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III. Each part listed has been authorized for stamping on the date shown above.			
By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.			
Factory Mutual System			
Date <u>9-23-92</u>	Signed <u>W. D. Greenlaw</u> <small>(Authorized Inspector)</small>	Commissions <u>MA 1207</u> <small>(Nat'l Bd (incl. endorsements) state or prov. and no.)</small>	

*Arkwright Mutual Insurance Company

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 12/20/97
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 See Item 6 "Other Identification" Below
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (MS) Main Steam
5. (a) Applicable Construction Code Sec III 19 71 Edition S72 Addenda, Code Cases 1567 & 1711
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No. Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
SRV Valve	Crosby	N63790-00-0102	N/A	N/A	970060155	*	Replaced	N/A
SRV Valve	Crosby	N63790-00-0066	N/A	N/A	L97-00468	*	Replacement	N/A
Spindle Assembly	Crosby	K62873-31-0066	N/A	N/A	L97-00468	*	Replaced	N/A
Spindle Assembly	Crosby	K82137-41-0027	N/A	N/A	L97-00468	1996	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1039 psi Test Temp. Amb Deg. F
9. Remarks Valve SN# N63790-00-0066 was refurbished at Wyle Labs with documentation provided under Quality (Applicable Manufacturer's Data Report to be Attached)
Receipt Inspection L97-00468 and installed as a replacement for SN# N63790-00-0102 under work request 970060155

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Shawn C. Koles* ISI Coordinator Date February 4, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-7- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 12/20/97
(Name)
One First National Plaza, Chicago, IL, 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 See Item 6 "Other Identification" Below
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, IL 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (MS) Main Steam
5. (a) Applicable Construction Code Sect III 19 71 Edition S72 Addenda, Code Cases 1567 & 1711
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
SRV Valve	Crosby	N63790-00-0013	N/A	N/A	970060157	*	Replaced	N/A
SRV Valve	Crosby	N63790-00-0012	N/A	N/A	L96-00861	*	Replacement	N/A
(1) Inlet Stud	Crosby	*	N/A	N/A	L96-00861	*	Replaced	N/A
(1) Inlet Stud	Crosby	Ht. Code GAM	N/A	N/A	L96-00861	1992	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1039 psi Test Temp. Amb Deg. F
9. Remarks Valve SN# N63790-00-0012 was refurbished at Wyle Labs with documentation provided under Quality (Applicable Manufacturer's Data Report to be Attached)
Receipt Inspection L96-00861 and installed as a replacement for SN# N63790-00-0013 under work request 970060157

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John L. Kucera* ISI Coordinator Date February 4, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-7- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 12/31/97
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970085115
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RI) Reactor Core Isolation Cooling
5. (a) Applicable Construction Code Sect III 19 71 Edition W72 Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Valve Bonnet	Anchor Darling	*	N/A	N/A	1E51-F064	*	Repaired	N/A

7. Description of Work Class 1 Repair. Repaired valve Bonnet by machining.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other
Pressure 1039 psi Test Temp. Amb Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Repair conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *[Signature]* ISI Coordinator Date February 3, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-4- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 6/16/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970102500
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RR) Reactor Recirculation
5. (a) Applicable Construction Code Sec III 19 74 Edition No Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases N-416-1
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
2" X 3/4" Reducing Insert	Morrison	*	N/A	N/A	1RR17BB-2"	*	Replaced	N/A
2" X 3/4" Reducing Insert	CPS	Ht.# 998XNA	N/A	N/A	1RR17BB-2"	1997	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1039 psi Test Temp. Amb Deg. F
9. Remarks Replaced reducing insert.
(Applicable Manufacturer's Data Report to be Attached)

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Paul L. Torres* ISI Coordinator Date February 4, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-7- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 6/18/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970102501
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RR) Reactor Recirculation
5. (a) Applicable Construction Code Sect III 19 74 Edition No Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases N-416-1
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
1½" X ¾" Reducing Insert	Morrison	*	N/A	N/A	1RR17AB-1½"	*	Replaced	N/A
1½" X ¾" Reducing Insert	CPS	Ht.# 817YNA	N/A	N/A	1RR17AB-1½"	1997	Replacement	N/A
1½" X ¾" Reducing Insert	CPS	Ht.# 817YNA	N/A	N/A	1RR17AB-1½"	1997	Repaired	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1039 psi Test Temp. Amb Deg. F
9. Remarks Replaced reducing insert and repaired gouge mark created during installation.
(Applicable Manufacturer's Data Report to be Attached)

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Repair & Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Paul L. Loeber* ISI Coordinator Date February 4, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Robert W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-8- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 5/10/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 2
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970105771
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RH) Residual Heat Removal
5. (a) Applicable Construction Code Sec III 19 74 Edition W74 Addenda, Code Cases 1567, 1622 & 1682
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Stuffing Box	Anchor Darling	*	N/A	N/A	1E12-F041A	*	Replaced	N/A
Stuffing Box	Anchor Darling	Ht. # 89796	N/A	N/A	1E12-F041B	*	Replacement	N/A
Hinge Pin Cover	Anchor Darling	*	N/A	N/A	1E12-F041A	*	Replaced	N/A
Hinge Pin Cover	BW/IP	Code B454	N/A	N/A	1E12-F041A	1998**	Replacement	N/A
(6) Cover Studs	Anchor Darling	*	N/A	N/A	1E12-F041A	*	Replaced	N/A
(6) Cover Studs	BW/IP	Code S76	N/A	N/A	1E12-F041A	1998**	Replacement	N/A

7. Description of Work Class 1 Replacement. Replaced stuffing box, Hinge Pin Cover, and Cover Studs and Nuts
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1040 psi Test Temp. Amb Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)
Replacement Stuffing Box taken from valve 1E12-F041B and installed in 1E12-F041A. See Form NIS-2
Supplemental Sheet Page 2 of 2 for additional replaced and replacement items.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Shawn C. Socolis* ISI Coordinator Date February 5, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-9- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 4/25/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 2
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970105773
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RH) Residual Heat Removal
5. (a) Applicable Construction Code Sect III 19 74 Edition W74 Addenda, Code Cases 1567, 1622 & 1682
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Stuffing Box	Anchor Darling	*	N/A	N/A	1E12-F050A	*	Replaced	N/A
Stuffing Box	Anchor Darling	Ht. # 89796	N/A	N/A	1E12-F050B	*	Replacement	N/A
Hinge Pin Cover	Anchor Darling	*	N/A	N/A	1E12-F050A	*	Replaced	N/A
Hinge Pin Cover	BW/IP	Code B454	N/A	N/A	1E12-F050A	1998**	Replacement	N/A
(6) Cover Studs	Anchor Darling	*	N/A	N/A	1E12-F050A	*	Replaced	N/A
(6) Cover Studs	BW/IP	Code K7	N/A	N/A	1E12-F050A	1998**	Replacement	N/A

7. Description of Work Class 1 Replacement. Replaced stuffing box, Hinge Pin Cover, and Cover Studs and Nuts
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1040 psi Test Temp. Amb Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)
Replacement Stuffing Box taken from valve 1E12-F050B and installed in 1E12-F050A. Valve Disc also replaced. See Form NIS-2 valve supplemental Sheet Page 2 of 2 for additional replaced and replacement items.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Andrew C. Collins* ISI Coordinator Date February 19, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Ruby W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-21-20 00

197-00355

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*

As required by the Provision of the ASME Code Rules, Section III, Div. 1

RIN/ORI M 97-06481

1. (a) Manufactured by Anchor/Darling Valve Co., 701 First St., Williamsport, PA 17701
(Name and address of NPT Certificate Holder)
- (b) Manufactured for Commonwealth Edison Co., P.O. Box 767, Chicago, IL 60690
(Name and address of N Certificate Holder for completed nuclear component)
2. Identification-Certificate Holder's Serial No. of Part W266 Nat'l Bd. No. N/A
- (a) Constructed According to Drawing No. C32202 R/B Drawing Prepared by Anchor/Darling Valve Company
- (b) Description of Part Inspected Disc w/Stellite Heat #E3101 SA216-WCB
1567, 1622
- (c) Applicable ASME Code: Section III, Edition 1974, Addenda date W'74, Case No. & 1682 Class 1
3. Remarks: Spare Part(s) for 12"-900# TDC Valve
(Brief description of service for which component was designed)
A/DV S.O. and Item No.: P288D-1
- No Hydrotesting Performed

We certify that the statements made in this report are correct and this vessel part or appurtenance as defined in the Code conforms to the rules of construction of the ASME Code Section III. (The applicable Design Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certificate Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report.)

Date 5/29/1997 Signed Anchor/Darling Valve Co. By [Signature]
(NPT Certificate Holder)
Certificate of Authorization Expires 4/15/98 Certificate of Authorization No. N1713

CERTIFICATION OF DESIGN FOR APPURTENANCE (when applicable)

Design information on file at _____
Stress analysis report do file at _____
Design specifications certified by _____ Prof. Eng. State _____ Reg. No. _____
Stress analysis report certified by _____ Prof. Eng. State _____ Reg. No. _____

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of ~~Mass~~ of Pennsylvania and employed by Commercial Union Insurance Company of Boston, Mass have inspected the part of a pressure vessel described in this Partial Data Report on 4-17-97 5-29-97 1997, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the part described in this Partial Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 5-29 1997
[Signature] Inspector's Signature
Commissions Pennsylvania 2392
National Board, State, Province and No.

*Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2" x 11", (2) information in items 1-2 on this Data Report is repeated on each sheet, and (3) each sheet is numbered and subject of sheet is recorded in item 3, "Remarks".

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 5/6/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970105779
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (LP) Low Pressure Core Spray
5. (a) Applicable Construction Code Sect III 19 74 Edition W74 Addenda, Code Cases 1567, 1622 & 1682
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Hinge Pin Cover	Anchor Darling	*	N/A	N/A	1E21-F006	*	Replaced	N/A
Hinge Pin Cover	BW/IP	Code B454	N/A	N/A	1E21-F006	*	Replacement	N/A
(6) Cover Studs	Anchor Darling	*	N/A	N/A	1E21-F006	*	Replaced	N/A
(6) Cover Studs	BW/IP	Code K7	N/A	N/A	1E21-F006	1998**	Replacement	N/A
(6) Cover Nuts	Anchor Darling	*	N/A	N/A	1E21-F006	*	Replaced	N/A
(6) Cover Nuts	BW/IP	Code CDD	N/A	N/A	1E21-F006	1998**	Replacement	N/A

7. Description of Work Class 1 Replacement. Replaced, Hinge Pin Cover, and Cover Studs and Nuts.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1030 psi Test Temp. Amb Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Arthur C. Lewis* ISI Coordinator Date February 19, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Ruby W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-21- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 4/15/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 2
(Address)

2. Plant LaSalle County Nuclear Station Unit 1 970105783
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)

3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)

4. Identification of System (RH) Residual Heat Removal

5. (a) Applicable Construction Code Sect III 19 74 Edition W74 Addenda, Code Cases 1567, 1622 & 1682
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Stuffing Box	Anchor Darling	*	N/A	N/A	1E12-F041B	*	Replaced	N/A
Stuffing Box	BW/IP	Ht. # Y3267	N/A	N/A	1E12-F041B	*	Replacement	N/A
Hinge Pin Cover	Anchor Darling	*	N/A	N/A	1E12-F041B	*	Replaced	N/A
Hinge Pin Cover	BW/IP	Code B454	N/A	N/A	1E12-F041B	1998**	Replacement	N/A
(6) Cover Studs	Anchor Darling	*	N/A	N/A	1E12-F041B	*	Replaced	N/A
(6) Cover Studs	BW/IP	Code K7	N/A	N/A	1E12-F041B	1998**	Replacement	N/A

7. Description of Work Class 1 Replacement. Replaced stuffing box, Hinge Pin Cover, and Cover Studs and Nuts

8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1010 psi Test Temp. Amb Deg. F

9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)
See Form NIS-2 Supplemental Sheet Page 2 of 2 for additional replaced and replacement items.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Robert L. Koels* ISI Coordinator Date February 19, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Robert W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-21-20 00

RIN / ORI L 98-00304 RIN / ORI M 98-03062
FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
 As required by the Provision of the ASME Code Rules, Section III, Div. 1

1. (a) Manufactured by BW/IP International, Inc. Valve Division, 701 First St., Williamsport, PA
(Name and address of NPT Certificate Holder)

(b) Manufactured for Commonwealth Edison Co., POBox 767, Chicago, IL 60690
(Name and address of N Certificate Holder for completed nuclear component)

2. Identification-Certificate Holder's Serial No. of Part 1 & 2 Nat'l Bd. No. N/A

(a) Constructed According to Drawing No. C33453 R/A Drawing Prepared by BW/IP International, Inc. Valve Division

(b) Description of Part Inspected Stuffing Box w/ Stellite, Heat No. Y3267 SA479-410A
1567, 1622

(c) Applicable ASME Code Section III, Edition 1974, Addenda date W '74, Case No. & 1682 Class 1

3. Remarks Spare Part (S) for 12" - 900# TDC Valve
(Brief description of service for which component was designed)
BW/IP S.O. & Item No.: E287A-7 (2pcs)
No Hydrotesting Performed
LaSalle Station

We certify that the statements made in this report are correct and this vessel part or appurtenance as defined in the Code conforms to the rules of construction of the ASME Code Section III.
 (The applicable Design Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certificate Holder for appurtenance is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report.)

Date 3/20/98 Signed BW/IP International, Inc. Valve Division By [Signature]
(NPT Certificate Holder)

Certificate of Authorization Expires 4/15/98 Certificate of Authorization No. N1713

CERTIFICATION OF DESIGN FOR APPURTENANCE (when applicable)

Design information on file at _____

Stress analysis report on file at _____

Design specifications certified by _____ Prof. Eng. Score _____ Reg. No. _____

Stress analysis report certified by _____ Prof. Eng. Score _____ Reg. No. _____

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Pennsylvania and employed by Commercial Union Insurance Company of Boston, Mass. have inspected the part of a pressure vessel described in this Partial Data Report on 3-20-98 thru 3-20-98 and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the part described in this Partial Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 3-20 19 98

[Signature] Commissions Pennsylvania 2392
National Board, State, Province and No.

Charles Young

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 4/15/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)

2. Plant LaSalle County Nuclear Station Unit 1 970105784
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)

3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)

4. Identification of System (RH) Residual Heat Removal

5. (a) Applicable Construction Code Sec III 19 74 Edition W74 Addenda, Code Cases 1567, 1622 & 1682
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Hinge Pin Cover	Anchor Darling	*	N/A	N/A	1E12-F041C	*	Replaced	N/A
Hinge Pin Cover	BW/IP	Code B454	N/A	N/A	1E12-F041C	*	Replacement	N/A
(6) Cover Studs	Anchor Darling	*	N/A	N/A	1E12-F041C	*	Replaced	N/A
(6) Cover Studs	BW/IP	Code K7	N/A	N/A	1E12-F041C	1998**	Replacement	N/A
(6) Cover Nuts	Anchor Darling	*	N/A	N/A	1E12-F041C	*	Replaced	N/A
(6) Cover Nuts	BW/IP	Code CDD	N/A	N/A	1E12-F041C	1998**	Replacement	N/A

7. Description of Work Class 1 Replacement. Replaced, Hinge Pin Cover, and Cover Studs and Nuts.

8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1030 psi Test Temp. Amb Deg. F

9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John C. Lane* ISI Coordinator Date February 19, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-21-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 4/15/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 2
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970105785
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RH) Residual Heat Removal
5. (a) Applicable Construction Code Sect III 19 74 Edition W74 Addenda, Code Cases 1567, 1622 & 1682
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Stuffing Box	Anchor Darling	*	N/A	N/A	1E12-F050B	*	Replaced	N/A
Stuffing Box	BW/IP	Ht. # Y3267	N/A	N/A	1E12-F050B	1998	Replacement	N/A
Hinge Pin Cover	Anchor Darling	*	N/A	N/A	1E12-F050B	*	Replaced	N/A
Hinge Pin Cover	BW/IP	Code B454	N/A	N/A	1E12-F050B	1998**	Replacement	N/A
(6) Cover Studs	Anchor Darling	*	N/A	N/A	1E12-F050B	*	Replaced	N/A
(6) Cover Studs	BW/IP	Code K7	N/A	N/A	1E12-F050B	1998**	Replacement	N/A

7. Description of Work Class 1 Replacement. Replaced stuffing box, Hinge Pin Cover, and Cover Studs and Nuts
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1030 psi Test Temp. Amb Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)
Repaired valve disc, valve bonnet, and replacement stuffing box by metal removal. See Form NIS-2 Supplemental Sheet Page 2 of 2 for additional repaired, replaced and replacement items.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Repair & Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Robert C. Collins* ISI Coordinator Date February 19, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Robert W. Rabite Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-21-20 00

RIN/QRI L 98-00304

RIN/QRI M 98-03062

FORM N-3 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*

As required by the Provision of the ASME Code Rules, Section III, Div. 1

1. (a) Manufactured by BW/IP International, Inc. Valve Division, 701 First St., Williamsport, PA
(Name and address of NPT Certificate Holder)

(b) Manufactured for Commonwealth Edison Co., POBox 767, Chicago, IL 60690
(Name and address of N Certificate Holder for established nuclear customers)

2. Identification-Certificate Holder's Serial No. of Part 1 & 2 Nat'l Id. No. N/A

(a) Constructed According to Drawing No. C33453 R/A Drawing Prepared by BW/IP International, Inc. Valve Division

(b) Description of Part Inspected Stuffing Box w/ Stellite, Heat No. Y3267 SA479-410A
1567, 1622

(c) Applicable ASME Code: Section III, Edition 1974, Addenda date W '74, Case No. & 1682 Class 1

3. Remarks Spare Part (s) for 12" - 900# TDC Valve
(Brief description of service for which component was designed)

BW/IP S.O. & Item No.: E287A-7 (2pcs)

No Hydrotesting Performed

LaSalle Station

We certify that the statements made in this report are correct and this vessel part or appurtenance as defined in the Code conforms to the rules of construction of the ASME Code Section III.
(The applicable Design Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certificate Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report.)

Date 3/20/98 Signed BW/IP International, Inc. Valve Division By [Signature]
(NPT Certificate Holder)

Certificate of Authorization Expires 4/15/98 Certificate of Authorization No. N1713

CERTIFICATION OF DESIGN FOR APPURTENANCE (when applicable)

Design information on file as _____

Stress analysis report on file as _____

Design specifications certified by _____ Prof. Eng. State _____ Reg. No. _____

Stress analysis report certified by _____ Prof. Eng. State _____ Reg. No. _____

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Pennsylvania and employed by Commercial Union Insurance Company of Boston, Mass.

have inspected the part of a pressure vessel described in this Partial Data Report on 3-20-98 and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the part described in this Partial Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 3-20 19 98

[Signature] Commissions Pennsylvania 2392
(Inspector's Signature) National Board, State, Province and No.

* Supplemental sheets in form of logs, sketches or drawings may be used provided (1) each is BW' s 12", (2) information on items 1-1 on this form is checked on each sheet, and (3) each sheet is submitted and retained as provided in item 1, "Remarks".

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 1/21/98
(Name)
One First National Plaza, Chicago, IL., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970105786
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st. Rd. Marseilles, IL. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (HP) High Pressure Core Spray
5. (a) Applicable Construction Code Sect. III 19 74 Edition W74 Addenda, Code Cases 1516-1, 1567
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1989, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Hinge Pin Cover	Anchor Darling	*	N/A	N/A	1E22-F005	*	Replaced	N/A
Hinge Pin Cover	BW/IP	Ht.# 217P288	N/A	N/A	1E22-F005	1997**	Replacement	N/A
(6) Cover Studs	Anchor Darling	*	N/A	N/A	1E22-F005	*	Replaced	N/A
(6) Cover Studs	BW/IP	Ht. # 886607	N/A	N/A	1E22-F005	1997**	Replacement	N/A
(6) Cover Nuts	Anchor Darling	*	N/A	N/A	1E22-F005	*	Replaced	N/A
(6) Cover Nuts	BW/IP	Ht.# 8868157	N/A	N/A	1E22-F005	1997**	Replacement	N/A

7. Description of Work Class 1 Replacement. Replaced Check Valve Hinge Pin Cover, Studs & Nuts
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other
Pressure 1025 psi Test Temp. Amb. Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station.
(Applicable Manufacturer's Data Report to be Attached)
** = Certified to Original Code of Construction by BW/IP International Valve Division.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp None

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Arthur L. Lewis* ISI Coordinator Date June 9, 19 98
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. of

Hartford, CT. have inspected the components described in this Owner's Report during the period 2/19/98 to 2/19/98

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Ruby W. White
Inspector's Signature

Commissions NB 9304, IL 1927
National Board, State, Province, and Endorsements

Date 6-15-98 19 98

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 5/5/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 980042592
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RH) Residual Heat Removal
5. (a) Applicable Construction Code Sect III 19 74 Edition W74 Addenda, Code Cases 1567, 1622 & 1682
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Stuffing Box	Anchor Darling	Ht. # 89796	N/A	N/A	1E12-F041B	*	Repaired	N/A

7. Description of Work Class 1 Replacement. Repaired stuffing box, from valve 1E12-F041B and installed in
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other
Pressure N/A psi Test Temp. N/A Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)
1E12-F041A under Work Request 970105771.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Repair conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Andrew C. Loeis* ISI Coordinator Date February 5, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-7- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/6/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 980050034
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RR) Reactor Recirculation
5. (a) Applicable Construction Code Sec III 19 ** Edition ** Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases N-416-1
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
1½" Globe Valve	Anderson Green Wood	*	N/A	N/A	1B33-F051B	*	Replaced	N/A
1½" Globe Valve	Yarway	C3292	N/A	N/A	1B33-F051B	1995**	Replacement	N/A
1½" Pipe	Morrison	*	N/A	N/A	1RR17AB-1½"	*	Replaced	N/A
1½" Pipe	CPS	Ht. # A4556H	N/A	N/A	1RR17AB-1½"	1995**	Replacement	N/A
Pivot Pin Assembly	PSA	*	N/A	N/A	RR17-1007S	*	Replaced	N/A
Pivot Pin Assembly	Grinnell	SI # 507E59	N/A	N/A	RR17-1007S	1990	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1050 psi Test Temp. Amb Deg. F
9. Remarks Replaced valve, piping, and snubber pivot pin.
(Applicable Manufacturer's Data Report to be Attached)
**** = Original Code of Construction of the piping is ASME Section III, Class-1, 1974 Edition, No Addenda. Original Code of Construction of the component support is ANSI B31.7, 1969, No Addenda. Original valve Construction Code is ASME Section III Class 1, 1974 Ed., W75 Ad., Replacement valve is ASME Section III, Class 1, 1986 Ed., No Addenda reconciled per BOM evaluation L-1999-5622-0 on file at LaSalle County Station.**

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Andrew C. Koelsch* ISI Coordinator Date February 19, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-20-2000

8. Remarks Valves are bonnetless design. Backseat bushing listed in lieu of bonnet.

9. Design conditions psi °F or valve pressure class 1700 (1)
(pressure) (temperature)

10. Cold working pressure 4080 psi at 100°F

11. Hydrostatic test 6125 psi. Disk differential test pressure 4500 psi

CERTIFICATION OF DESIGN

Design Specification certified by George J. Paptzun P.E. State PA Reg. no. PE-034809-E
Design Report certified by Murray W. Randall P.E. State MA Reg. no. 27395

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this pump or valve conforms to the rules for construction of the ASME Code, Section III, Division 1.

N Certificate of Authorization No. N2449 Expires 11/14/95

Date 18 MAY 95 Name Yarway Corporation Signed [Signature]
(N Certificate Holder) (authorized representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Ins. Co of Norwood, MA* have inspected the pump, or valve, described in this Data Report on MAY 18, 19 95, and state that to the best of my knowledge and belief, the Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III, Division 1.

*Factory Mutual Engineering Association

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the component described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 5-18-95 Signed William R. Rogers III Commissions NB7980 NIBSIS PA2204
(Authorized Inspector) (Nat'l. Bd. (incl. endorsements) state or prov. and no.)

(1) For manually operated valves only.



FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/6/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 980050035
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RR) Reactor Recirculation
5. (a) Applicable Construction Code Section III 19 ** Edition ** Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases N-416-1
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
1½" Globe Valve	Anderson Green Wood	*	N/A	N/A	1B33-F052B	*	Replaced	N/A
1½" Globe Valve	Yarway	C3291	N/A	N/A	1B33-F052B	1995**	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1050 psi Test Temp. Amb Deg. F
9. Remarks Replaced valve.
(Applicable Manufacturer's Data Report to be Attached)
**** = Original valve Construction Code is ASME Section III Class 1, 1974 Ed., W75 Ad., Replacement valve is ASME Section III, Class 1, 1986 Ed., No Addenda reconciled per BOM evaluation L-1999-5622-0 on file at LaSalle County Station.**

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Andrew C. Kosloski* ISI Coordinator Date February 19, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-20-2000

8. Remarks Valves are bonnetless design. Backseat bushing listed in lieu of bonnet.

9. Design conditions --- psi --- °F or valve pressure class 1700 (1)

10. Cold working pressure 4080 psi at 100°F

11. Hydrostatic test 6125 psi. Disk differential test pressure 4500 psi

CERTIFICATION OF DESIGN

Design Specification certified by George J. Paptzun P.E. State PA Reg. no. PE-034809-E
Design Report certified by Murray W. Randall P.E. State MA Reg. no. 27395

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this pump or valve conforms to the rules for construction of the ASME Code, Section III, Division 1.

N Certificate of Authorization No. N2449 Expires 11/14/95

Date 18 MAY 95 Name Yarway Corporation Signed [Signature]
(N Certificate Holder) (authorized representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Ins. Co of Norwood, MA* have inspected the pump, or valve, described in this Data Report on MAY 18, 19 95, and state that to the best of my knowledge and belief, the Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III, Division 1.

*Factory Mutual Engineering Association

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the component described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 5-18-95 Signed William R. Rogers III Commissions NB7980 NIBSIS PA2204
(Authorized Inspector) (Nat'l. Bd. (incl. endorsements) state or prov. and no.)

(1) For manually operated valves only.



FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/9/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 980050050
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System Standby Liquid Control
5. (a) Applicable Construction Code Sect III 19 77 Edition S77 Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Inlet Fitting	Conax	*	N/A	N/A	1C41-F004B	*	Replaced	N/A
Inlet Fitting	Conax	5512	N/A	N/A	1C41-F004B	1998**	Replacement	N/A
Trigger Body	Conax	*	N/A	N/A	1C41-F004B	*	Replaced	N/A
Trigger Body	Conax	5510	N/A	N/A	1C41-F004B	1998**	Replacement	N/A

7. Description of Work Class 1 Replacement. Replaced existing components with new after explosive firing.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1220/1044 psi Test Temp. Amb. Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)
** = Replacement components were constructed to ASME Section III, Class 1, 1977 Ed., with S77 Addenda
Replacement reconciled per PTE 88-161 on file at LaSalle County Station

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Alan C. Kovacs* ISI Coordinator Date February 22, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Nicky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-22-2000

L98-00393

FORM N-2 CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL NUCLEAR PARTS AND APPURTENANCES*

As Required by the Provisions of the ASME Code, Section III to Exceed One Day's Production

1. Manufactured and certified by IST Conax Nuclear, 2300 Walden Avenue, Cheektowaga, NY 14225
(name and address of NPT Certificate Holder)

2. Manufactured for Commonwealth Edison Co., P.O. Box 767, Chicago, IL 60690
(name and address of Purchaser)

3. Location of installation Unknown
(name and address)

4. Type: N20000, Rev. G SA479 304SST 75 KSI N/A 1998
(drawing no.) (mat'l spec. no.) (tensile strength) (ICRNI) (year built)

5. ASME Code, Section III, Division 1: 77 S77 1 N/A
(edition) (addenda date) (class) (Code Case no.)

6. Fabricated in accordance with Const. Spec. (Div. 2 only) N/A Revision Date
(no.)

7. Remarks: Trigger Body Subassembly for explosive actuated valve replacement kit for standby liquid control system.
Para. NB-2121 (b) is applicable to ram. Press Fit/Seal on .328 & .4375 diameters. Overall subassembly length is 2.5".
Pressure Test at 2800 psi for 10 minutes.

8. Nom. thickness (in.) See Remarks Min. design thickness (in.) See Remarks Dia. ID (ft & in.) See Remarks Length overall (ft & in.) See Remarks

9. When applicable, Certificate Holders' Data Reports are attached for each item of this report:

Part or Appurtenance Serial Number	National Board No. in Numerical Order
(1) 5510	5510
(2) 5511	5511
(3)	
(4)	
(5)	
(6)	
(7)	
(8)	
(9)	
(10)	
(11)	
(12)	
(13)	
(14)	
(15)	
(16)	
(17)	
(18)	
(19)	
(20)	
(21)	
(22)	
(23)	
(24)	
(25)	

Part or Appurtenance Serial Number	National Board No. in Numerical Order
(26)	
(27)	
(28)	
(29)	
(30)	
(31)	
(32)	
(33)	
(34)	
(35)	
(36)	
(37)	
(38)	
(39)	
(40)	
(41)	
(42)	
(43)	
(44)	
(45)	
(46)	
(47)	
(48)	
(49)	
(50)	

10. Design pressure 1400 psi. Temp 150 °F. Hydro. test pressure * See Remarks at temp. °F
(when applicable)

* Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 2 and 3 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

L98-00393

Certificate Holder's Serial Nos. 5510 through 5511

CERTIFICATION OF DESIGN

Design specifications certified by George I. Skoda P.E. State CA Reg. no. 15847
(when applicable)

Design report* certified by Francis J. Domino P.E. State NY Reg. no. 36832
(when applicable)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this (these) Trigger Body Subassemblies
 conforms to the rules of construction of the ASME Code, Section III, Division 1.

NPT Certificate of Authorization No. N-1850 Expires September 2, 1998

Date 3-16-98 Name IST Conax Nuclear Signed Curt Platt
(NPT Certificate Holder) (authorized representative)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of New York and employed by Hartford Steam Boiler Inspection & Insurance Company
 of Hartford, CT have inspected these items described in this Data Report on MAR 16 1998, and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III, Division 1. Each part listed has been authorized for stamping on the date shown above.
 By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 3-16-98 Signed Allen J. [Signature] Commissions NB 10964AN NY 5057
(Authorized Inspector) (Nat'l Bd. (incl. endorsements) and state or prov. and no.)

L98-00393

**FORM N-2 CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL
NUCLEAR PARTS AND APPURTENANCES***
As Required by the Provisions of the ASME Code, Section III
Not to Exceed One Day's Production

1. Manufactured and certified by IST Conax Nuclear, 2300 Walden Avenue, Cheektowaga, NY 14225
(name and address of NPT Certificate Holder)

2. Manufactured for Commonwealth Edison Co., P.O. Box 767, Chicago, IL 60690
(name and address of Purchaser)

3. Location of installation Unknown
(name and address)

4. Type: N38017, Rev. F SA479 304SST 75 KSI N/A 1998
(drawing no.) (mat. spec. no.) (tensile strength) (CRN) (year built)

5. ASME Code, Section III, Division 1: 77 S77 1 N/A
(edition) (addenda letter) (class) (Code Case no.)

6. Fabricated in accordance with Const. Spec. (Div. 2 only) N/A Revision _____ Date _____
no.

7. Remarks: Inlet Fitting for explosive actuated valve replacement kit for standby liquid control system.

Pressure Test at 2800 psi for 10 minutes.

8. Nom. thickness (in.) .040 Min. design thickness (in.) .031 Dia. ID (ft & in.) .895" Length overall (ft & in.) 2.245"

9. When applicable, Certificate Holders' Data Reports are attached for each item of this report:

Part or Appurtenance Serial Number	National Board No. in Numerical Order
(1) 5512	5512
(2) 5513	5513
(3)	
(4)	
(5)	
(6)	
(7)	
(8)	
(9)	
(10)	
(11)	
(12)	
(13)	
(14)	
(15)	
(16)	
(17)	
(18)	
(19)	
(20)	
(21)	
(22)	
(23)	
(24)	
(25)	

Part or Appurtenance Serial Number	National Board No. in Numerical Ord
(26)	
(27)	
(28)	
(29)	
(30)	
(31)	
(32)	
(33)	
(34)	
(35)	
(36)	
(37)	
(38)	
(39)	
(40)	
(41)	
(42)	
(43)	
(44)	
(45)	
(46)	
(47)	
(48)	
(49)	
(50)	

10. Design pressure 1400 psi. Temp. 150 °F. Hydro. test pressure * See Remarks at temp. °F
(when applicable)

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 2 and 3 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

Certificate Holder's Serial Nos. 5512 through 5513

CERTIFICATION OF DESIGN

Design specifications certified by George I. Skoda P.E. State CA Reg. no. 15847
(When applicable)

Design report* certified by Francis J. Domino P.E. State NY Reg. no. 36832
(When applicable)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this (these) Inlet Fittings
 conforms to the rules of construction of the ASME Code, Section III, Division 1.

NPT Certificate of Authorization No. N-1850 Expires September 2, 1998

Date 3-16-98 Name IST Conax Nuclear Signed Curt Platt
(NPT Certificate Holder) (authorized representative)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of New York and employed by Hartford Steam Boiler Inspection & Insurance Company

of Hartford, have inspected these items described in this Data Report on MAR 16, 1998, and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III, Division 1. Each part listed has been authorized for stamping on the date shown above. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 3-16-98 Signed Allen J. [Signature] Commissions NB 10964AN NY 5057
(Authorized Inspector) (Nat'l Bd. (incl. endorsements) and state or prov. and no.)

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 980089092
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Section III 1971 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	A1050	N/A	N/A	10-11	*	Replaced	N/A
CRD Assembly	G.E.	9337	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	10-11	*	Replaced	N/A
CRD Capscrews	Nova	Code NXF	N/A	N/A	10-11	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 9337 was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# A1050 under work request
980089092. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John L. Kocis* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Nancy W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-18-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/5/97
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 2
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 See Item 6 "Other Identification" Below
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (MS) Main Steam
5. (a) Applicable Construction Code Sect III 19 71 Edition S72 Addenda, Code Cases 1567 & 1711
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
SRV Valve	Crosby	N63790-00-0015	N/A	N/A	980095087	*	Replaced	N/A
SRV Valve	Crosby	N63790-00-0065	N/A	N/A	RIN 47533	*	Replacement	N/A
Spindle Assembly	Crosby	K62873-31-0015	N/A	N/A	RIN 47533	*	Replaced	N/A
Spindle Assembly	Crosby	K82137-48-0058	N/A	N/A	RIN 47533	1996	Replacement	N/A
(3) Inlet Studs	Crosby	*	N/A	N/A	*	*	Replaced	N/A
(1) Inlet Stud	Ronson	Ht. Code Q194-6	N/A	N/A	RIN 47533	1996	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks Valve SN# N63790-00-0065 was refurbished at Wyle Labs with documentation provided under Quality (Applicable Manufacturer's Data Report to be Attached)
Receipt Inspection 47533 and installed as a replacement for SN# N63790-00-0015 under work request 980095087. For the remainder of the Replaced and Replacement items, see Form NIS-2 Supplemental Sheet on Page 2 of 2.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John C. Lewis* ISI Coordinator Date February 12, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-13-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 980101916
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sect III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	7638	N/A	N/A	34-27	*	Replaced	N/A
CRD Assembly	G.E.	8715	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	34-27	*	Replaced	N/A
CRD Capscrews	Nova	Code PJK	N/A	N/A	34-27	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 8715 was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# 7638 under work request
980101916. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Richard L. Colles* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-19-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 12/7/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 980105189
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System RR
5. (a) Applicable Construction Code * 19 * Edition * Addenda, Code Cases *
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Mech. Snubber	PSA	*	N/A	N/A	RR00-1001S	*	Replaced	N/A
Hydraulic Snubber	Liseiga	61359/44	N/A	N/A	RR00-1001S	1997	Replacement	N/A

7. Description of Work Class 1 Replacement Replaced Mechanical Snubber with Hydraulic Snubber.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Visual
Pressure _____ psi Test Temp. _____ Deg. F
9. Remarks * = Per Original Design Specification J-2530 & J-2918. Original Const. Code is ANSI B31.7, 1969 Edition
(Applicable Manufacturer's Data Report to be Attached)
No Addenda

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Shawn C. Kallis* ISI Coordinator Date February 1, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period 6/10/07 to 6/10/08

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-2-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 12/9/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 980105195
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System RR
5. (a) Applicable Construction Code * 19 * Edition * Addenda, Code Cases *
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Mech. Snubber	PSA	*	N/A	N/A	RR00-1003S	*	Replaced	N/A
Hydraulic Snubber	Lisega	61244/119	N/A	N/A	RR00-1003S	1997	Replacement	N/A

7. Description of Work Class 1 Replacement Replaced Mechanical Snubber with Hydraulic Snubber.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Visual
Pressure _____ psi Test Temp. _____ Deg. F
9. Remarks * = Per Original Design Specification J-2530 & J-2918. Original Const. Code is ANSI B31.7, 1969 Edition
(Applicable Manufacturer's Data Report to be Attached)
No Addenda

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI.
(repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Andrew L. Harris* ISI Coordinator Date February 1, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period 6/19/97 to 6/19/98, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Paul W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-2- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/8/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 980105201
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RR) Reactor Recirculation
5. (a) Applicable Construction Code * 19 * Edition * Addenda, Code Cases *
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Snubber Load Stud	PSA	*	N/A	N/A	RR00-1032S	*	Replaced	N/A
Snubber Load Stud	Grinnell	SI # 507E71	N/A	N/A	RR00-1032S	1983	Replacement	N/A
Pivot Pin Assembly	PSA	*	N/A	N/A	RR00-1032S	*	Replaced	N/A
Pivot Pin Assembly	Grinnell	SI # 507E64	N/A	N/A	RR00-1032S	1983	Replacement	N/A

7. Description of Work Class 1 Replacement Replaced Snubber load stud and pivot pin assembly.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Visual
Pressure psi Test Temp. Deg. F
9. Remarks * = Per Original Design Specification J-2530 & J-2918. Original Const. Code is ANSI B31.7, 1969 Edition
(Applicable Manufacturer's Data Report to be Attached)
No Addenda

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Robert I. Collins* ISI Coordinator Date February 22, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Robert W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-22-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/8/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 980105206
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RR) Reactor Recirculation
5. (a) Applicable Construction Code * 19 * Edition * Addenda, Code Cases *
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Mech. Snubber	PSA	*	N/A	N/A	RR00-1010S	*	Replaced	N/A
Hydraulic Snubber	Liseiga	SN 61344/88	N/A	N/A	RR00-1010S	1996	Replacement	N/A

7. Description of Work Class 1 Replacement Replaced Mechanical Snubber with Hydraulic Snubber.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure I, X, I Other Visual
Pressure _____ psi Test Temp. _____ Deg. F
9. Remarks * = Per Original Design Specification J-2530 & J-2918. Original Const. Code is ANSI B31.7, 1969 Edition
(Applicable Manufacturer's Data Report to be Attached)
No Addenda

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Adam C. Kucis* ISI Coordinator Date February 10, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Ruby W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-17-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/7/99
(Name)
One First National Plaza, Chicago, IL, 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 980105207
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, IL 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RR) Reactor Recirculation
5. (a) Applicable Construction Code * 19 * Edition * Addenda, Code Cases *
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Mech. Snubber	PSA	*	N/A	N/A	RR00-1011S	*	Replaced	N/A
Hydraulic Snubber	Lisega	SN 61359/54	N/A	N/A	RR00-1011S	1996	Replacement	N/A

7. Description of Work Class 1 Replacement Replaced Mechanical Snubber with Hydraulic Snubber.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Visual
Pressure _____ psi Test Temp. _____ Deg. F
9. Remarks * = Per Original Design Specification J-2530 & J-2918. Original Const. Code is ANSI B31.7, 1969 Edition
(Applicable Manufacturer's Data Report to be Attached)
No Addenda

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Alan I. Lewis* ISI Coordinator Date February 10, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Harley W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-17-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 10/29/99
(Name)
One First National Plaza, Chicago, IL, 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 980107450
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, IL 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RI) Reactor Core Isolation Cooling
5. (a) Applicable Construction Code * 19 * Edition * Addenda, Code Cases *
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Mech. Snubber	PSA	*	N/A	N/A	RI09-1026S	*	Replaced	N/A
Mech. Snubber	PSA	SN 303	N/A	N/A	RI09-1026S	1996	Replacement	N/A

7. Description of Work Class 1 Replacement Replaced Mechanical Snubber.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Visual
Pressure _____ psi Test Temp. _____ Deg. F
9. Remarks * = Per Original Design Specification J-2530 & J-2918. Original Const. Code is ANSI B31.7, 1969 Edition
(Applicable Manufacturer's Data Report to be Attached)
No Addenda

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Allen C. Lewis* ISI Coordinator Date February 10, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Robert W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-10-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 10/29/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 980107451
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RH) Residual Heat Removal
5. (a) Applicable Construction Code * 19 * Edition * Addenda, Code Cases *
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Mech. Snubber	PSA	*	N/A	N/A	RH13-1127S	*	Replaced	N/A
Mech. Snubber	PSA	SN 41175	N/A	N/A	RH13-1127S	1999	Replacement	N/A

7. Description of Work Class 1 Replacement Replaced Mechanical Snubber.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Visual
Pressure _____ psi Test Temp. _____ Deg. F
9. Remarks * = Per Original Design Specification J-2530 & J-2918. Original Const. Code is ANSI B31.7, 1969 Edition.
(Applicable Manufacturer's Data Report to be Attached)
No Addenda

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Robert L. Gales* ISI Coordinator Date February 10, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Robert W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-10-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/1/99
(Name)
One First National Plaza, Chicago, IL, 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 980107477
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, IL 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RH) Residual Heat Removal
5. (a) Applicable Construction Code * 19 * Edition * Addenda, Code Cases *
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Mech. Snubber	PSA	*	N/A	N/A	RH40-1561S	*	Replaced	N/A
Mech. Snubber	PSA	SN 11083	N/A	N/A	RH40-1561S	1983	Replacement	N/A

7. Description of Work Class 1 Replacement Replaced Mechanical Snubber.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Visual
Pressure _____ psi Test Temp. _____ Deg. F
9. Remarks * = Per Original Design Specification J-2530 & J-2918. Original Const. Code is ANSI B31.7, 1969 Edition
(Applicable Manufacturer's Data Report to be Attached)
No Addenda

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John C. Lewis* ISI Coordinator Date February 10, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-10-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/9/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 980121581
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System Standby Liquid Control
5. (a) Applicable Construction Code Sect III 19 77 Edition S77 Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Inlet Fitting	Conax	*	N/A	N/A	1C41-F004A	*	Replaced	N/A
Inlet Fitting	Conax	5803	N/A	N/A	1C41-F004A	1999**	Replacement	N/A
Trigger Body	Conax	*	N/A	N/A	1C41-F004A	*	Replaced	N/A
Trigger Body	Conax	5802	N/A	N/A	1C41-F004A	1999**	Replacement	N/A

7. Description of Work Class 1 Replacement. Replaced existing components with new after explosive firing.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1220/1044 psi Test Temp. Amb. Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)
** = Replacement components were constructed to ASME Section III, Class 1, 1977 Ed., with S77 Addenda
Replacement reconciled per PTE 88-161 on file at LaSalle County Station

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Paul L. Loeis* ISI Coordinator Date February 22, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Wally W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-22-20 00

L99-02192

L99-02192

03

FORM N-2 CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL NUCLEAR PARTS AND APPURTENANCES* As Required by the Provisions of the ASME Code, Section III Not to Exceed One Day's Production

1. Manufactured and certified by IST Conax Nuclear, 402 Sonwil Drive, Cheektowaga, NY 14225
2. Manufactured for Commonwealth Edison, P.O. Box 767, Chicago, IL 60690
3. Location of installation Unknown
4. Type: N20000, Rev. G SA479 304SST 75 KSI N/A 1999
5. ASME Code, Section III, Division 1: 77 S77 1 N/A
6. Fabricated in accordance with Const. Spec. (Div. 2 only) N/A Revision Date
7. Remarks: Trigger Body Subassembly for explosive actuated valve replacement kit for standby liquid control system.

Para. NB-2121 (b) is applicable to ram. Press Fit/Seal on .328 & .4375 diameters. Overall subassembly length is 2.5". Pressure Test at 2800 psi for 10 minutes.

8. Nom. thickness (in.) See Remarks Min. design thickness (in.) See Remarks Dia. ID (ft & in.) See Remarks Length overall (ft & in.) See Remarks
9. When applicable, Certificate Holders' Data Reports are attached for each item of this report:

Table with 2 columns: Part or Appurtenance Serial Number, National Board No. in Numerical Order. Row 1: (1) 5802, 5802.

Table with 2 columns: Part or Appurtenance Serial Number, National Board No. in Numerical Order. Rows 26-50.

10. Design pressure 1500 psi. Temp. 150 °F. Hydro. test pressure * See Remarks at temp. °F (when applicable)

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 2 and 3 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

L99-02192

03

Certificate Holder's Serial Nos. 5802 through 5802

CERTIFICATION OF DESIGN

Design specifications certified by George I. Skoda P.E. State CA Reg. no. 15847
(when applicable)

Design report* certified by Francis J. Domino P.E. State NY Reg. no. 36832
(when applicable)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this (these) Trigger B ody Sub Assembly
conforms to the rules of construction of the ASME Code, Section III, Division 1.

NPT Certificate of Authorization No. N-1850 Expires September 2, 2001

Date 7/20/99 Name IST Conax Nuclear Signed Paul E. Couchman
(NPT Certificate Holder) (authorized representative)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of New York and employed by Hartford Steam Boiler Inspection & Insurance Company

of Hartford, CT have inspected these items described in this Data Report on JUL 20 1999, and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III, Division 1. Each part listed has been authorized for stamping on the date shown above.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 7-20-99 Signed Allen J. Demaschke Commissions NB 10964AN NY 5057
(Authorized Inspector) (Nat'l Bd. (incl. endorsements) and state or prov. and no.)

L99-02192

L99-02192

04

FORM N-2 CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL NUCLEAR PARTS AND APPURTENANCES* As Required by the Provisions of the ASME Code, Section III Not to Exceed One Day's Production

- 1. Manufactured and certified by IST Conax Nuclear, 402 Sonwil Drive, Cheektowaga, NY 14225
2. Manufactured for Commonwealth Edison, P.O. 767, Chicago, IL 60690
3. Location of installation Unknown
4. Type: N38017, Rev. F SA479 304SST 75 KSI N/A 1999
5. ASME Code, Section III, Division 1: 77 S77 1 N/A
6. Fabricated in accordance with Const. Spec. (Div. 2 only) N/A Revision Date
7. Remarks: Inlet Fitting for explosive actuated valve replacement kit for standby liquid control system.

Pressure Test at 2800 psi for 10 minutes.

8. Nom. thickness (in.) .040 Min. design thickness (in.) .031 Dia. ID (ft & in.) .895" Length overall (ft & in.) 2.245"

9. When applicable, Certificate Holders' Data Reports are attached for each item of this report:

Table with 2 columns: Part or Appurtenance Serial Number, National Board No. in Numerical Order. Row 1: (1) 5803, 5803.

Table with 2 columns: Part or Appurtenance Serial Number, National Board No. in Numerical Order. Rows 26-50 are empty.

10. Design pressure 1500 psi. Temp. 150 °F. Hydro. test pressure * See Remarks at temp. °F (when applicable)

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 2 and 3 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

L99-02192

L99-02192

04

Certificate Holder's Serial Nos. 5803 through 5803

CERTIFICATION OF DESIGN

Design specifications certified by George I. Skoda P.E. State CA Reg. no. 15847
(when applicable)

Design report* certified by Francis J. Domino P.E. State NY Reg. no. 36832
(when applicable)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this (these) Inlet Fittings
conforms to the rules of construction of the ASME Code, Section III, Division 1.

NPT Certificate of Authorization No. N-1850 Expires September 2, 2001

Date 7/20/99 Name IST Conax Nuclear Signed Paul E. Coughman
(NPT Certificate Holder) (authorized representative)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of New York and employed by Hartford Steam Boiler Inspection & Insurance Company

of Hartford, CT have inspected these items described in this Data Report on JUL 20, 1999, and state that to the best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section III, Division 1. Each part listed has been authorized for stamping on the date shown above. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 7-20-99 Signed [Signature] Commissions NB 10964AN NY 5057
(Authorized Inspector) (Nat'l Bd. (incl. endorsements) and state or prov. and no.)

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/8/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 980129183
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System RI
5. (a) Applicable Construction Code Sect III 19 71 Edition W72 Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Valve Disc	Anchor Darling	*	N/A	N/A	1E51-F008	*	Replaced	N/A
Valve Disc	Anchor Darling	SN# 13	N/A	N/A	1E51-F008	1993	Replacement	N/A

7. Description of Work Class 1 Replacement, Replaced Valve Disc.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other
Pressure 1020 psi Test Temp. Deg. F
9. Remarks (Applicable Manufacturer's Data Report to be Attached)
* = Per N-5 Code Data Report on file at LaSalle County Station

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *David C. Kocis* ISI Coordinator Date February 8, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Ruby W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-22-20 00

RIN/QRI L94-00119

FORM N-3 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*

As required by the Provision of the ASME Code Rules, Section III, Div. 1

1. (a) Manufactured by Anchor/Darling Valve Co., 701 First St., Williamsport, PA 17701
(Name and address of NPT Certificate Holder)
- (b) Manufactured for Commonwealth Edison Company, PO Box 767, Chicago, IL 60690
(Name and address of N Certificate Holder for completed nuclear component)
2. Identification-Certificate Holder's Serial No. of Part 13, 14 Nat'l Bd. No. N/A
- (a) Constructed According to Drawing No. B65331 R/B Drawing Prepared by Anchor/Darling Valve Company
- (b) Description of Part Inspected Disc; Trace Code A685 Mat'l: SA105
- (c) Applicable ASME Code: Section III, Edition 1971, Addenda date Wint '72 Case No. --- Class 1
3. Remarks: Spare Parts for 4"-900# Double Disc Gate Valve; Dwg. W9223688;
(Brief description of service for which component was designed)
S.O. ET145-1; CED P.O. 345778 REL. XX153; A/DV S.O. P-W837-2
- No Hydro Performed

RIN/QRI L94-00119

We certify that the statements made in this report are correct and this vessel part or appurtenance as defined in the Code conforms to the rules of construction of the ASME Code Section III. (The applicable Design Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certificate Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report.)

Date 12/10/93 Signed Anchor/Darling Valve Co. By [Signature]
(NPT Certificate Holder)
Certificate of Authorization Expires 4/15/95 Certificate of Authorization No. N1713

CERTIFICATION OF DESIGN FOR APPURTENANCE (when applicable)

Design information on file as _____
Stress analysis report on file as EVAL NO.
Design specifications certified by L-94-0017 Prof. Eng. Score _____ Reg. No. _____
Stress analysis report certified by PAGE 14 Prof. Eng. Score _____ Reg. No. _____



CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Pennsylvania and employed by Commercial Union Insurance Company of Boston, Mass. have inspected the part of a pressure vessel described in this Partial Data Report on 9-21-93 12-14-93 and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the part described in this Partial Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 12-14 19 93
[Signature] Commission Pennsylvania 2392
Charles Young National Board, State, Province and No.

* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2" x 11", (2) information in items 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and identity of sheet is recorded in item 2. "Remarks".

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/3/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 2
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 See Item 6 "Other Identification" Below
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (MS) Main Steam
5. (a) Applicable Construction Code Sect III 19 71 Edition S72 Addenda, Code Cases 1567 & 1711
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No. Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
SRV Valve	Crosby	N63790-00-0076	N/A	N/A	980133196	*	Replaced	N/A
SRV Valve	Crosby	N63790-00-0104	N/A	N/A	RIN 44036	*	Replacement	N/A
Spindle Assembly	Crosby	K62873-33-0105	N/A	N/A	RIN 44036	*	Replaced	N/A
Spindle Assembly	Crosby	K82137-46-0053	N/A	N/A	RIN 44036	1996	Replacement	N/A
(1) Inlet Stud	Crosby	*	N/A	N/A	*	*	Replaced	N/A
(1) Inlet Stud	Vitco	Ht. Code NAD	N/A	N/A	RIN 44036	1993	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks Valve SN# N63790-00-0104 was refurbished at Wyle Labs with documentation provided under Quality (Applicable Manufacturer's Data Report to be Attached)
Receipt Inspection 44036 and installed as a replacement for SN# N63790-00-0076 under work request 980133196. For the remainder of the Replaced and Replacement items, see Form NIS-2 Supplemental Sheet on Page 2 of 2.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Robert C. Kocis* ISI Coordinator Date February 19, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Robert W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-20-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/3/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 See Item 6 "Other Identification" Below
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (MS) Main Steam
5. (a) Applicable Construction Code Sec III 19 71 Edition S72 Addenda, Code Cases 1567 & 1711
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No. Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
SRV Valve	Crosby	N63790-00-0065	N/A	N/A	990002937	*	Replaced	N/A
SRV Valve	Crosby	N63790-00-0072	N/A	N/A	RIN 44036	*	Replacement	N/A
Spindle Assembly	Crosby	K62873-31-0072	N/A	N/A	RIN 44036	*	Replaced	N/A
Spindle Assembly	Crosby	K82137-46-0056	N/A	N/A	RIN 44036	1996	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks Valve SN# N63790-00-0072 was refurbished at Wyle Labs with documentation provided under Quality (Applicable Manufacturer's Data Report to be Attached)
Receipt Inspection 44036 and installed as a replacement for SN# N63790-00-0065 under work request 990002937.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John I. Lewis* ISI Coordinator Date February 12, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-13-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/3/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 2
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 See Item 6 "Other Identification" Below
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (MS) Main Steam
5. (a) Applicable Construction Code Sect III 19 71 Edition S72 Addenda, Code Cases 1567 & 1711
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases N-496-1
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
SRV Valve	Crosby	N63790-00-0005	N/A	N/A	990002939	*	Replaced	N/A
SRV Valve	Crosby	N63790-00-0006	N/A	N/A	RIN 44036	*	Replacement	N/A
Spindle Assembly	Crosby	K62873-37-0154	N/A	N/A	RIN 44036	*	Replaced	N/A
Spindle Assembly	Crosby	K82137-46-0054	N/A	N/A	RIN 44036	1996	Replacement	N/A
(12) Inlet Nuts	Crosby	*	N/A	N/A	*	*	Replaced	N/A
(12) Inlet Nuts	Nova	Ht. Code A7VY	N/A	N/A	990002939	1999	Replacement	N/A

7. Description of Work Class 1 Repair & Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks Valve SN# N63790-00-0006 was refurbished at Wyle Labs with documentation provided under Quality (Applicable Manufacturer's Data Report to be Attached)
Receipt Inspection 44036 and installed as a replacement for SN# N63790-00-0005 under work request 990002939. For the remainder of the Repaired, Replaced and Replacement items, see Form NIS-2 Supplemental Sheet on Page 2 of 2.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Repair & Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Don C. Lewis* ISI Coordinator Date February 12, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Robert W. Schute Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-13-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/3/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 See Item 6 "Other Identification" Below
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (MS) Main Steam
5. (a) Applicable Construction Code Sect III 19 71 Edition S72 Addenda, Code Cases 1567 & 1711
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
SRV Valve	Crosby	N63790-00-0106	N/A	N/A	990002940	*	Replaced	N/A
SRV Valve	Crosby	N63790-00-0073	N/A	N/A	RIN 44036	*	Replacement	N/A
Spindle Assembly	Crosby	K62873-32-0038	N/A	N/A	RIN 44036	*	Replaced	N/A
Spindle Assembly	Crosby	K82137-46-0052	N/A	N/A	RIN 44036	1996	Replacement	N/A
(12) Inlet Nuts	Crosby	*	N/A	N/A	*	*	Replaced	N/A
(12) Inlet Nuts	Nova	Ht. Code A7VY	N/A	N/A	990002940	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks Valve SN# N63790-00-0073 was refurbished at Wyle Labs with documentation provided under Quality (Applicable Manufacturer's Data Report to be Attached)
Receipt Inspection 44036 and installed as a replacement for SN# N63790-00-0106 under work request 990002940.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *[Signature]* ISI Coordinator Date February 12, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-13-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/4/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 2
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 See Item 6 "Other Identification" Below
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (MS) Main Steam
5. (a) Applicable Construction Code Section III 1971 Edition S72 Addenda, Code Cases 1567 & 1711
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1989, No. Ad, Code Cases N-496-1
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
SRV Valve	Crosby	N63790-00-0004	N/A	N/A	990002941	*	Replaced	N/A
SRV Valve	Crosby	N63790-00-0001	N/A	N/A	RIN 44036	*	Replacement	N/A
Spindle Assembly	Crosby	K62873-34-0015	N/A	N/A	RIN 44036	*	Replaced	N/A
Spindle Assembly	Crosby	K82137-46-0051	N/A	N/A	RIN 44036	1996	Replacement	N/A
(12) Inlet Nuts	Crosby	*	N/A	N/A	*	*	Replaced	N/A
(12) Inlet Nuts	Nova	Ht. Code A7VY	N/A	N/A	990002941	1999	Replacement	N/A

7. Description of Work Class 1 Repair & Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks Valve SN# N63790-00-0001 was refurbished at Wyle Labs with documentation provided under Quality (Applicable Manufacturer's Data Report to be Attached)
Receipt Inspection 44036 and installed as a replacement for SN# N63790-00-0004 under work request 990002941. For the remainder of the Repaired, Replaced and Replacement items, see Form NIS-2 Supplemental Sheet on Page 2 of 2.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Repair & Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Andrew L. Keeley* ISI Coordinator Date February 19, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Nancy W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-20-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/4/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 See Item 6 "Other Identification" Below
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (MS) Main Steam
5. (a) Applicable Construction Code Sec III 19 71 Edition S72 Addenda, Code Cases 1567 & 1711
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
SRV Valve	Crosby	N63790-00-0109	N/A	N/A	990002942	*	Replaced	N/A
SRV Valve	Crosby	N63790-00-0071	N/A	N/A	RIN 44036	*	Replacement	N/A
Spindle Assembly	Crosby	K62873-31-0071	N/A	N/A	RIN 44036	*	Replaced	N/A
Spindle Assembly	Crosby	K82137-46-0055	N/A	N/A	RIN 44036	1996	Replacement	N/A
(12) Inlet Nuts	Crosby	*	N/A	N/A	*	*	Replaced	N/A
(12) Inlet Nuts	Nova	Ht. Code A7VY	N/A	N/A	990002942	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks Valve SN# N63790-00-0071 was refurbished at Wyle Labs with documentation provided under Quality (Applicable Manufacturer's Data Report to be Attached)
Receipt Inspection 44036 and installed as a replacement for SN# N63790-00-0109 under work request 990002942.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Shane C. Keenan* ISI Coordinator Date February 12, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-13-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/3/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 2
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 See Item 6 "Other Identification" Below
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (MS) Main Steam
5. (a) Applicable Construction Code Sect III 19 71 Edition S72 Addenda, Code Cases 1567 & 1711
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases N-496-1
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
SRV Valve	Crosby	N63790-00-0078	N/A	N/A	990002943	*	Replaced	N/A
SRV Valve	Crosby	N63790-00-000103	N/A	N/A	RIN 44036	*	Replacement	N/A
Spindle Assembly	Crosby	K62873-34-0102	N/A	N/A	RIN 44036	*	Replaced	N/A
Spindle Assembly	Crosby	K82137-47-0057	N/A	N/A	RIN 44036	1996	Replacement	N/A
(12) Inlet Nuts	Crosby	*	N/A	N/A	*	*	Replaced	N/A
(11) Inlet Nuts	Nova	Ht. Code A7VY	N/A	N/A	990002943	1999	Replacement	N/A

7. Description of Work Class 1 Repair & Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks Valve SN# N63790-00-0103 was refurbished at Wyle Labs with documentation provided under Quality (Applicable Manufacturer's Data Report to be Attached)
Receipt Inspection 44036 and installed as a replacement for SN# N63790-00-0078 under work request 990002943. For the remainder of the Repaired, Replaced and Replacement items, see Form NIS-2 Supplemental Sheet on Page 2 of 2.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Repair & Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John C. Davis* ISI Coordinator Date February 12, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Ricky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-13- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/4/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 2
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 See Item 6 "Other Identification" Below
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (MS) Main Steam
5. (a) Applicable Construction Code Sect III 19 71 Edition S72 Addenda, Code Cases 1567 & 1711
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 89, No. Ad, Code Cases N-496-1
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
SRV Valve	Crosby	N63790-00-0110	N/A	N/A	990002944	*	Replaced	N/A
SRV Valve	Crosby	N63790-00-0010	N/A	N/A	RIN 44036	*	Replacement	N/A
Spindle Assembly	Crosby	K62873-31-0132	N/A	N/A	RIN 44036	*	Replaced	N/A
Spindle Assembly	Crosby	K82137-46-0049	N/A	N/A	RIN 44036	1996	Replacement	N/A
(12) Inlet Nuts	Crosby	*	N/A	N/A	*	*	Replaced	N/A
(12) Inlet Nuts	Nova	Ht. Code A7VY	N/A	N/A	990002944	1999	Replacement	N/A

7. Description of Work Class 1 Repair & Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks Valve SN# N63790-00-0010 was refurbished at Wyle Labs with documentation provided under Quality (Applicable Manufacturer's Data Report to be Attached)
Receipt Inspection 44036 and installed as a replacement for SN# N63790-00-0110 under work request 990002944. For the remainder of the Repaired, Replaced and Replacement items, see Form NIS-2 Supplemental Sheet on Page 2 of 2.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Repair & Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John C. Kobas* ISI Coordinator Date February 12, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Harvey S. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-13- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990004085
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Section III 1971 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1989, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	9369	N/A	N/A	14-43	*	Replaced	N/A
CRD Assembly	G.E.	9438	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	14-43	*	Replaced	N/A
CRD Capscrews	Nova	Code NXG	N/A	N/A	14-43	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 9438 was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# 9369 under work request
990004085. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Allen L. Lewis* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-18- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990004089
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sect III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	7494	N/A	N/A	50-43	*	Replaced	N/A
CRD Assembly	G.E.	6474	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	50-43	*	Replaced	N/A
CRD Capscrews	Nova	Code MZL	N/A	N/A	50-43	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 6474 was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# 7494 under work request
990004089. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconcilled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconcilled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Robert L. Kocis* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-18-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990008339
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sect III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	7607	N/A	N/A	38-51	*	Replaced	N/A
CRD Assembly	G.E.	8400	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	38-51	*	Replaced	N/A
CRD Capscrews	Nova	Code NXG	N/A	N/A	38-51	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 8400 was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# 7607 under work request
990008339. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John L. Gellis* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Norby W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-18-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 10/31/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990011480
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (MS) Main Steam
5. (a) Applicable Construction Code Sect III 19 74 Edition No Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
1.5" Carbon Steel Pipe	Morrison	*	N/A	N/A	1MS20BB-1.5"	*	Repaired	N/A

7. Description of Work Class 1 Repair. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other MT & UT
Pressure N/A psi Test Temp. Amb Deg. F
9. Remarks Repaired linear indication on outside diameter of 1.5" pipe by metal removal.
(Applicable Manufacturer's Data Report to be Attached)

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Repair conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Alan C. Goulet* ISI Coordinator Date February 9, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. Gubite Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-10-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990012997
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sec III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	8726	N/A	N/A	06-19	*	Replaced	N/A
CRD Assembly	G.E.	6639	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	06-19	*	Replaced	N/A
CRD Capscrews	Nova	Code NXF	N/A	N/A	06-19	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 6639 was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# 8726 under work request
990012997. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Alan C. Kocis* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Nancy W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-19-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, IL, 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990012998
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, IL 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sect III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	A991	N/A	N/A	50-51	*	Replaced	N/A
CRD Assembly	G.E.	9526	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	50-51	*	Replaced	N/A
CRD Capscrews	Nova	Code NXG	N/A	N/A	50-51	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 9526 was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# A991 under work request
990012998. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John C. Coelis* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-18-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/8/99
(Name)
One First National Plaza, Chicago, IL, 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990023223
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, IL 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (NB) Nuclear Boiler
5. (a) Applicable Construction Code * 19 * Edition * Addenda, Code Cases *
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Mech. Snubber	PSA	*	N/A	N/A	RR00-1002S	*	Replaced	N/A
Hydraulic Snubber	PSA	SN 61359/49	N/A	N/A	RR00-1002S	1996	Replacement	N/A

7. Description of Work Class 1 Replacement Replaced Mechanical Snubber with Hydraulic Snubber.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Visual
Pressure _____ psi Test Temp. _____ Deg. F
9. Remarks * = Per Original Design Specification J-2530 & J-2918. Original Const. Code is ANSI B31.7, 1969 Edition (Applicable Manufacturer's Data Report to be Attached)
No Addenda

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI.
(repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *[Signature]* ISI Coordinator Date February 9, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-10-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 10/30/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant: LaSalle County Nuclear Station Unit 1 990023565
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RH) Residual Heat Removal
5. (a) Applicable Construction Code * 19 * Edition * Addenda, Code Cases *
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Mech. Snubber	PSA	*	N/A	N/A	RH04-1503S	*	Replaced	N/A
Hydraulic Snubber	PSA	SN 61344/87	N/A	N/A	RH04-1503S	1996	Replacement	N/A

7. Description of Work Class 1 Replacement Replaced Mechanical Snubber with Hydraulic Snubber.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Visual
Pressure _____ psi Test Temp. _____ Deg. F
9. Remarks * = Per Original Design Specification J-2530 & J-2918. Original Const. Code is ANSI B31.7, 1969 Edition
(Applicable Manufacturer's Data Report to be Attached)
No Addenda

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Andrew T. Gules* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Ruby W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-14-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026903
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sec III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	9324	N/A	N/A	14-23	*	Replaced	N/A
CRD Assembly	G.E.	7545A	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	14-23	*	Replaced	N/A
CRD Capscrews	Nova	Code NXF	N/A	N/A	14-23	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 7545A was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# 9324 under work request
990026903. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John C. Cooley* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. Sebaste Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-17- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026904
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Section III 1971 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1989, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	9585	N/A	N/A	02-39	*	Replaced	N/A
CRD Assembly	G.E.	9007	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	02-39	*	Replaced	N/A
CRD Capscrews	Nova	Code NXF	N/A	N/A	02-39	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 9007 was refurbished with documentation provided under (Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# 9585 under work request 990026904. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Paul L. Koles* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-17-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026908
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Section III, 1971 Edition, NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1989, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	8531	N/A	N/A	10-47	*	Replaced	N/A
CRD Assembly	G.E.	9575	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	10-47	*	Replaced	N/A
CRD Capscrews	Nova	Code NXG	N/A	N/A	10-47	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 9575 was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# 8531 under work request
990026908. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *[Signature]* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-18-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026909
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Section III 1971 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1989, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	7522A	N/A	N/A	14-19	*	Replaced	N/A
CRD Assembly	G.E.	7624	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	14-19	*	Replaced	N/A
CRD Capscrews	Nova	Code NXF	N/A	N/A	14-19	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 7624 was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# 7522A under work request
990026909. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Allen C. Kocis* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Ricky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-15-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, IL, 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026911
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, IL 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Section III 1971 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1989, No. Ad., Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	9304	N/A	N/A	18-19	*	Replaced	N/A
CRD Assembly	G.E.	9434	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	18-19	*	Replaced	N/A
CRD Capscrews	Nova	Code NME	N/A	N/A	18-19	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 9434 was refurbished with documentation provided under (Applicable Manufacturer's Data Report to be Attached) Quality Receipt Inspection 44036 and installed as a replacement for SN# 9304 under work request 990026911. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Michael L. Caseri* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Robert W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-17- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026912
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sec III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	7784	N/A	N/A	18-59	*	Replaced	N/A
CRD Assembly	G.E.	7845	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	18-59	*	Replaced	N/A
CRD Capscrews	Nova	Code NXG	N/A	N/A	18-59	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 7845 was refurbished with documentation provided under (Applicable Manufacturer's Data Report to be Attached) Quality Receipt Inspection 44036 and installed as a replacement for SN# 7784 under work request 990026912. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Paul I. Koskus* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 02-17 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026913
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sect III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	9379	N/A	N/A	22-11	*	Replaced	N/A
CRD Assembly	G.E.	9584	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	22-11	*	Replaced	N/A
CRD Capscrews	Nova	Code NXG	N/A	N/A	22-11	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 9584 was refurbished with documentation provided under (Applicable Manufacturer's Data Report to be Attached) Quality Receipt Inspection 44036 and installed as a replacement for SN# 9379 under work request 990026913. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Robert I. Koculis* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-18-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026915
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sec III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	6819	N/A	N/A	42-27	*	Replaced	N/A
CRD Assembly	G.E.	8383	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	42-27	*	Replaced	N/A
CRD Capscrews	Nova	Code NXG	N/A	N/A	42-27	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 8383 was refurbished with documentation provided under (Applicable Manufacturer's Data Report to be Attached) Quality Receipt Inspection 44036 and installed as a replacement for SN# 6819 under work request 990026915. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Shelley K. Collier* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-18-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026916
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sec III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	9535	N/A	N/A	26-35	*	Replaced	N/A
CRD Assembly	G.E.	5849	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	26-35	*	Replaced	N/A
CRD Capscrews	Nova	Code NXF	N/A	N/A	26-35	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 5849 was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# 9535 under work request
990026916. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Paul C. Coles* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-18-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026917
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sect III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	9038	N/A	N/A	26-51	*	Replaced	N/A
CRD Assembly	G.E.	9286	N/A	N/A	44036	*	Replacement	N/A
CRD Cylinder Tube & Flange	G.E.	*	N/A	N/A	44036	*	Replaced	N/A
CRD Cylinder Tube & Flange	G.E.	A8850	N/A	N/A	44036	1999	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	26-51	*	Replaced	N/A
CRD Capscrews	Nova	Code NXF	N/A	N/A	26-51	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 9286 was refurbished and its Cylinder Tube & Flange replaced with documentation provided (Applicable Manufacturer's Data Report to be Attached)
Under Quality Receipt Inspection 44036 and installed as a replacement for SN# 9038 under work request 990026917. Replacement Cylinder Tube & Flange are ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-2 reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Robert L. Lucci* ISI Coordinator Date February 15, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Robert W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-19-20 00

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

- 1. Manufactured & Certified by : General Electric Company Nuclear Energy (GE-NE)
3901 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : LaSalle 1 & 2 Marselles, Illinois 61341
(Name and Address of N Certificate Holder for completed nuclear component)
- 2. Identification - Certificate Holder's S/N of Part : A6850 Nat'l Bd. No. N/A
- (a) Constructed According to Drawing No: 919D258G003 Rev 16 Dwg. Prepared by D.L. Peterson
- (b) Description of Part Inspected: Cylinder Tube & Flange
- (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W75, Case No. 1361-2 Class 1
- 3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1820 psi min.
(Brief description of service for which component was designed)

**POOR
QUALITY
ORIGINAL**

Sheet 1 of 2

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

Date: 10/07/99 Signed GE-NE By [Signature]
(NPT Certificate Holder) (SC QA Representative)

Certificate of Authorization Expires: 6/16/2002 Certification of Authorization No. : NPTN-1151

Certification of Design for Appurtenance

Design information on file at GE Company, San Jose, California

Stress analysis report on file at GE Company, San Jose, California

DC22A6253 Rev. 2
Design specification certified by B.N. Sridhar Prof. Eng. State Calif. Reg. No. 18345

DC22A6254 Rev 1
Stress analysis report certified by Edward Y. Gibo Prof. Eng. State Calif. Reg. No. M018646

Certification of Shop Inspection

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Inspectors and/or the State or Province of North Carolina and employed by Department of Labor of State of North Carolina have inspected the part of a pressure vessel described in this Partial Data Report on 10/3/99 and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

10/3/1999 Date [Signature] Inspector's Signature NC 1231, Ohio, WC 3686 PA National Board, State, Province And No.

*Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 8-1/2" x 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS".

440 3 E


FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by : General Electric Company Nuclear Energy (GE-NE)
3901 Castle Hayne Road, Wilmington, North Carolina 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for : LaSalle 1 & 2, Marseilles, Illinois 61341
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification - Certificate Holder's S/N of Part : A8850 Nat'l Bd. No. N/A
- (a) Constructed According to Drawing No: 919D258G003 Rev 16 Dwg. Prepared by D.L.Peterson
- (b) Description of Part Inspected: Cylinder Tube & Flange
- (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Class 1
3. REMARKS: Standard part for use with Reactor, Hydrostatically tested at 1820 psi. min.
(Brief description of service for which component was designed)

Sheet 2 of 2

1. Cap 165B9274P001
SA182 - F316
3/8" thick x 1 1/16" OD
2. Indicator Tube 167B4908P001
SA312 - TP316
3/4" sch 40 - seamless pipe
0.113" wall thickness
1.065" max. dia.
3. Plug 150A1176P001
SA182 - F304
1/4" thick x 0.812" OD
4. Flange 919D810P001 (719E474)
SA182 - F304
3.37" thick x 9 5/8" OD
5. Head 129B3539P005
SA182 - F304
7/8" thick x 2.875" dia.
6. Ring Flange 114B5122P002
SA182 - F304
1" thick x 5.0" OD x 1.75" ID
7. Cap Screw 117C4516P002
SA193 - B6
6 ea. 1/2" dia. on 4 1/8" bolt circle
8. Plug 175A7961P001
SA182 - F304
0.38" thick x 1.307" dia.
9. Nut 114B5460P001
XM - 19 SA479
1.30" thick x 2.62" dia.

44036



FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026918
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sec III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	9520	N/A	N/A	30-19	*	Replaced	N/A
CRD Assembly	G.E.	8533	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	30-19	*	Replaced	N/A
CRD Capscrews	Nova	Code NXG	N/A	N/A	30-19	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 8533 was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# 9520 under work request
990026918. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Alan C. Lewis* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Robert W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-17-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026919
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sect III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	9573	N/A	N/A	30-27	*	Replaced	N/A
CRD Assembly	G.E.	9604	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	30-27	*	Replaced	N/A
CRD Capscrews	Nova	Code NXG	N/A	N/A	30-27	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 9604 was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# 9573 under work request
990026919. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John L. Keller* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Richard W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-15-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026920
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sect III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	7517A	N/A	N/A	30-59	*	Replaced	N/A
CRD Assembly	G.E.	A2663	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	30-59	*	Replaced	N/A
CRD Capscrews	Nova	Code NXG	N/A	N/A	30-59	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# A2663 was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# 7517A under work request
990026920. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Robert L. Corley* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Robert W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-15- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026922
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sec III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No. Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	6841	N/A	N/A	34-15	*	Replaced	N/A
CRD Assembly	G.E.	7590A	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	34-15	*	Replaced	N/A
CRD Capscrews	Nova	Code PKJ	N/A	N/A	34-15	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 7590A was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# 6841 under work request
990026922. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Robert L. Lewis* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-15- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026923
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sect III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	6788	N/A	N/A	34-19	*	Replaced	N/A
CRD Assembly	G.E.	8948	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	34-19	*	Replaced	N/A
CRD Capscrews	Nova	Code PKJ	N/A	N/A	34-19	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 8948 was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# 6788 under work request
990026923. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John C. Harris* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-15- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026927
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sect III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	A945	N/A	N/A	38-11	*	Replaced	N/A
CRD Assembly	G.E.	8401	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	38-11	*	Replaced	N/A
CRD Capscrews	Nova	Code NXG	N/A	N/A	38-11	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 8401 was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# A945 under work request
990026927. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John C. Focis* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Ricky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-15- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026929
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sec III, 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	7602A	N/A	N/A	38-19	*	Replaced	N/A
CRD Assembly	G.E.	A958	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	38-19	*	Replaced	N/A
CRD Capscrews	Nova	Code NXF	N/A	N/A	38-19	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# A958 was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# 7602A under work request
990026929. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John C. Toulis* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-15-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026930
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sec III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	1019	N/A	N/A	38-27	*	Replaced	N/A
CRD Assembly	G.E.	8506	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	38-27	*	Replaced	N/A
CRD Capscrews	Nova	Code PKJ	N/A	N/A	38-27	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 8506 was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# 1019 under work request
990026930. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Adam L. Kocis* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Reed W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-19 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026963
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sec III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	A982	N/A	N/A	46-07	*	Replaced	N/A
CRD Assembly	G.E.	7750	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	46-07	*	Replaced	N/A
CRD Capscrews	Nova	Code NXF	N/A	N/A	46-07	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 7750 was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# A982 under work request
990026963. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Sam C. Kallis* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-12 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026964
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sec III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	8211	N/A	N/A	46-23	*	Replaced	N/A
CRD Assembly	G.E.	8706	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	46-23	*	Replaced	N/A
CRD Capscrews	Nova	Code NXG	N/A	N/A	46-23	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 8706 was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# 8211 under work request
990026964. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Shawn L. Lewis* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Derek W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-15- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026966
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sec III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	7581A	N/A	N/A	58-23	*	Replaced	N/A
CRD Assembly	G.E.	8781	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	58-23	*	Replaced	N/A
CRD Capscrews	Nova	Code NME	N/A	N/A	58-23	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 8781 was refurbished with documentation provided under
(Applicable Manufacturer's Data Report to be Attached)
Quality Receipt Inspection 44036 and installed as a replacement for SN# 7581A under work request
990026966. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-
reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No
Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Robert L. Kocis* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Robert L. Kocis Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-17-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/11/99
(Name)
One First National Plaza, Chicago, IL, 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990026967
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, IL 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Sec III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None

6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Assembly	G.E.	6714	N/A	N/A	58-35	*	Replaced	N/A
CRD Assembly	G.E.	8307	N/A	N/A	RIN 44036	*	Replacement	N/A
CRD Capscrews	G.E.	*	N/A	N/A	58-35	*	Replaced	N/A
CRD Capscrews	Nova	Code NXG	N/A	N/A	58-35	1999	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks CRD SN# 8307 was refurbished with documentation provided under (Applicable Manufacturer's Data Report to be Attached) Quality Receipt Inspection 44036 and installed as a replacement for SN# 6714 under work request 990026967. Replacement CRD is ASME Section III, Class 1, 1974 Edition, W75 Ad. with Code Case 1361-reconciled per PTE M93-0535-02. Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No Addendum, reconciled per PTE M91-007-0320-01. PTEs are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John C. Koalis* ISI Coordinator Date February 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-17-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 10/31/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990064689
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RR) Reactor Recirculation
5. (a) Applicable Construction Code * 19 * Edition * Addenda, Code Cases *
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Mech. Snubber	PSA	*	N/A	N/A	RR00-1041S	*	Replaced	N/A
Hydraulic Snubber	Lisega	SN 61359/42	N/A	N/A	RR00-1041S	1996	Replacement	N/A

7. Description of Work Class 1 Replacement Replaced Mechanical Snubber with Hydraulic Snubber.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Visual
Pressure _____ psi Test Temp. _____ Deg. F
9. Remarks * = Per Original Design Specification J-2530 & J-2918. Original Const. Code is ANSI B31.7, 1969 Edition
(Applicable Manufacturer's Data Report to be Attached)
No Addenda

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John C. Lewis* ISI Coordinator Date February 22, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Ricky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-22- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 10/22/99
 (Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
 (Address)
2. Plant LaSalle County Nuclear Station Unit 1 990090171
 (Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
 (Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
 (Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
 (Address)
4. Identification of System (NR) Neutron Monitoring
5. (a) Applicable Construction Code Sect. III 19 77 Edition S77 Addenda, Code Cases N-176-1
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
LPRM Gland Seal	GE	95S01704	N/A	N/A	48-41	1999	Repaired	N/A

7. Description of Work Class 1 Repaired LPRM detector gland fit by metal removal.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
 Pressure 1020 psi Test Temp. Amb. Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station.
 (Applicable Manufacturer's Data Report to be Attached)

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Repair conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Alan L. Forciss* ISI Coordinator Date February 11, 20 00
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Robert W. White Commissions IL 1927
 Inspector's Signature National Board, State, Province, and Endorsements

Date 2-13- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/18/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990109838
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (NB) Nuclear Boiler
5. (a) Applicable Construction Code * 19 * Edition * Addenda, Code Cases *
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Mech. Snubber	PSA	*	N/A	N/A	NB13-1001S	*	Replaced	N/A
Mech. Snubber	PSA	4064	N/A	N/A	NB13-1001S	1976	Replacement	N/A

7. Description of Work Class 1 Replacement Replaced Mechanical Snubber
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Visual
Pressure psi Test Temp. Deg. F
9. Remarks * = Per Original Design Specification J-2530 & J-2918. Original Const. Code is ANSI B31.7, 1969 Edition
(Applicable Manufacturer's Data Report to be Attached)
No Addenda

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Paul C. Corleo* ISI Coordinator Date February 9, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-9-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/12/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990111900
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RD) Control Rod Drive
5. (a) Applicable Construction Code Section III 19 71 Edition NO Addenda, Code Cases 1361-1
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
CRD Capscrews	G.E.	*	N/A	N/A	06-23	*	Replaced	N/A
CRD Capscrews	Nova	Code NXF	N/A	N/A	06-23	1999**	Replacement	N/A

7. Description of Work Class 1 Replacement. * = Per N-5 Code Data Report on file at LaSalle County Station.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1020 psi Test Temp. Amb Deg. F
9. Remarks Replaced CRD Capscrews.
(Applicable Manufacturer's Data Report to be Attached)

** = Replacement . Replacement Capscrews are ASME Section III, Class 1, 1986 Edition, No Addendum, reconciled per PTE M91-007-0320-01. PTE is on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John L. Taylor* ISI Coordinator Date February 9, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Robert W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-9-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 9/29/97
(Name)
One First National Plaza, Chicago, IL., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 910046478
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st. Rd. Marseilles, IL. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System Low Pressure Core Spray
5. (a) Applicable Construction Code Sect. III 19 71 Edition W72 Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1989, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Valve Disc Assy.	Anchor Darling	*	N/A	N/A	1E21-F012	*	Replaced	N/A
Valve Disc Assy.	Anchor Darling	MC36854	N/A	N/A	1E21-F012	1991	Replacement	N/A

7. Description of Work Class 2 Replacement. Replaced existing valve trim kit with new designed parts.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other
Pressure 66 psi Test Temp. Amb. Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station.
(Applicable Manufacturer's Data Report to be Attached)

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp None

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John C. Collins* ISI Coordinator Date November 21, 19 97
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. of

Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personnel injury or property damage or a loss of any kind arising from or connected with this inspection.

Ruby W. White Commissions NB9304, IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date Nov. 21, 19 97

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 10/30/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 940059011
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System RH
5. (a) Applicable Construction Code Sect III 19 71 Edition W72 Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
1E12-F027A	Anchor Darling	*	N/A	N/A	1E12-F027A	*	Repaired	N/A

7. Description of Work Class 2 Repaired. Drilled 1/4" Vent hole in upstream side of Disc
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 150 psi Test Temp. Amb Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)
Original Design Specification J-2938

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Repair conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John C. Kocis* ISI Coordinator Date February 7, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Randy W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-12 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/6/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 940059012
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System RH
5. (a) Applicable Construction Code Sect III 19 71 Edition W72 Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
1E12-F027B	Anchor Darling	*	N/A	N/A	1E12-F027B	*	Repaired	N/A

7. Description of Work Class 2 Repaired. Drilled 1/4" Vent hole in upstream side of Disc
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 135 psi Test Temp. Amb Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)
Original Design Specification J-2938

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Repair conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Alan C. Collins* ISI Coordinator Date February 8, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rakya W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-19-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 5/14/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 940059577
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System HG
5. (a) Applicable Construction Code Sect III 19 71 Edition W72 Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
(8) Stud Bolts	*	*	N/A	N/A	1HG005A	*	Replaced	N/A
(8) Stud Bolts	Nova	Ht. Code LFY	N/A	N/A	1HG005A	1998	Replacement	N/A

7. Description of Work Class 2 Replacement. Replaced Valve Bonnet Studs.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other None
Pressure psi Test Temp. Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)
Replacement studs are ASME Section III, Class 1, 1989 Edition, No Ad., reconciled to the original Code of Construction per the ComEd Fastner Standards on file at LaSalle County Station

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Robert W. White* ISI Coordinator Date February 15, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Robert W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-19 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 9/8/97
(Name)
One First National Plaza, Chicago, IL., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 960018506
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st. Rd. Marseilles, IL. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System Residual Heat Removal
5. (a) Applicable Construction Code Sect. III 19 71 Edition W72 Addenda, Code Cases 1516-1, 1567
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1989, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Gate Valve Disc	Anchor Darling	*	N/A	N/A	1E12-F003A	*	Repaired	N/A

7. Description of Work Class 2 Repair. Drilled a 1/4" hole through the upstream disc half to preclude
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other
Pressure 155 psi Test Temp. Amb. Deg. F
9. Remarks pressure/hydraulic locking of the valve. * = Per N-5 Code Data Report on file at LaSalle Station.
(Applicable Manufacturer's Data Report to be Attached)

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Repair conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp None

Certificate of Authorization No. N/A Expiration Date N/A

Signed Alan L. Laskis ISI Coordinator Date April 2, 19 98
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. of Hartford, CT. have inspected the components described in this Owner's Report during the period LIRO7 to LIRO8

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personnel injury or property damage or a loss of any kind arising from or connected with this inspection.

Ruby W. White Commissions NB 9304, IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date April 2, 19 98

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 1/4/97
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 960018507
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System RH
5. (a) Applicable Construction Code Sect III 19 71 Edition W72 Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No. Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Valve Disc	Anchor Darling	*	N/A	N/A	1E12-F003B	*	Repaired	N/A

7. Description of Work Class 2 Repaired. Drilled 1/4" Vent hole in upstream side of Disc
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other
Pressure 135 psi Test Temp. Amb Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)
Original Design Specification J-2938

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Repair conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Alan C. Coates* ISI Coordinator Date February 4, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Nancy W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-8-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 3/24/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 960034215
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System RH
5. (a) Applicable Construction Code Sect III 19 71 Edition W72 Addenda, Code Cases 1567
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases N-416-1
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
3" 300# Gate Valve	Anchor Darling	*	N/A	N/A	1E12-F072C	1978	Repaired	N/A

7. Description of Work Class 2, Repaired lower guide of Valve Body by Grinding and Welding
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other
Pressure 140 psi Test Temp. Amb Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Repair conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Alan C. Lewis* ISI Coordinator Date Feb. 14, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Randy W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-14- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/18/97
(Name)
One First National Plaza, Chicago, IL., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 960047939
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st. Rd. Marseilles, IL. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System Residual Heat Removal
5. (a) Applicable Construction Code Sect. III 19 74 Edition No Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1989, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Suction Strainer	Permutit	*	N/A	N/A	1E12-D301A	*	Replaced	N/A
Suction Strainer	PCI	None	N/A	N/A	1E12-D301A	1997**	Replacement	N/A

7. Description of Work Class 2 Replacement. Replaced "1A" RHR ECCS Suction Strainer and fasteners.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Flow
Pressure _____ psi Test Temp. _____ Deg. F
9. Remarks * = Per N-5 Code Data Report on File at LaSalle County Station.
(Applicable Manufacturer's Data Report to be Attached)
** = Replacement Strainers and fastners designed and fabricated to specification DS-ECCS-LS-01 which has been reconcilled to the original specification J-2530 through Design Change Package 9600290. The specifications are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI.
(repair or replacement)

Type Code Symbol Stamp None

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Richard L. Coelius* ISI Coordinator Date April 18, 19 98
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. of Hartford, CT. have inspected the components described in this Owner's Report during the period 41807 to 41808 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personel injury or property damage or a loss of any kind arising from or connected with this inspection.

Ray W. White Commissions NB 9304, IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date April 28, 19 98

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 9/8/97
(Name)
One First National Plaza, Chicago, IL., 60690 Sheet 1 of 2
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 960080889
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st. Rd. Marseilles, IL. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (LP) Low Pressure Core Spray
5. (a) Applicable Construction Code Sect. III 1974 Edition W75 Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1989, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Dbl. Blk. Valve	Anderson Greenwood	*	N/A	N/A	1E12-F331/2	*	Replaced	N/A
Gate Valve	Velan	951050-11	N/A	N/A	1E12-F331	1995**	Replacement	N/A
Gate Valve	Velan	951050-12	N/A	N/A	1E12-F332	1995**	Replacement	N/A
2" Sch. 80 Pipe	CPS	Ht.# B45687	N/A	N/A	1LP35A-2"	1997**	Replacement	N/A
2", 150# Flange	WFI	Code 869SNT	N/A	N/A	1LP35A-2"	1991**	Replacement	N/A
(4) Studs	Morrison	*	N/A	N/A	1LP35A-2"	*	Replaced	N/A

7. Description of Work Class 2 Replacement. Replaced Double Block valve with pipe spool, flange, and two
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other
Pressure 135/66 psi Test Temp. Amb. Deg. F
9. Remarks single valves. * = Per N-5 Code Data Report on File at LaSalle County Station.
(Applicable Manufacturer's Data Report to be Attached)
** = Replacement valves are ASME Sect. III, CL-1, 1989 Ed., No Ad., reconciled per DCP 9600374. The replacement flange is ASME Sect. III, CL-1, 1989 Ed., 89 Ad., and the replacement pipe is ASME Sect. III, CL-2, 1974 Ed., S75 Ad. Both the pipe & flange are reconciled per PTE L-1997-159-0. The replacement Studs & Nuts are ASME Sect. III, CL-1, 1989 Ed., No Ad., reconciled per the ComEd Fastner Standards. The DCP, PTE, and Fastner Standards are all on file at LaSalle Station. See form NIS-2 Supplemental Sheet for additional items.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp None

Certificate of Authorization No. N/A Expiration Date N/A

Signed Andrew C. Coates ISI Coordinator Date April 10, 19 98
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. of

Hartford, CT. have inspected the components described in this Owner's Report during the period 4/10/97 to 4/22/98

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Ruby W. White Commissions NB 9304, IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 6-15-98 19 98

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 1/3/97
(Name)
One First National Plaza, Chicago, IL., 60690
(Address) Sheet 1 of 1
2. Plant LaSalle County Nuclear Station Unit 1 960120891
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st. Rd. Marseilles, IL. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System Residual Heat Removal
5. (a) Applicable Construction Code Sect. III 19 71 Edition W72 Addenda, Code Cases 1567
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1989, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Valve Disc	Anchor Darling	*	N/A	N/A	1E12-F064A	*	Replaced	N/A
Valve Disc	Anchor Darling	SN# R9430	N/A	N/A	1E12-F064A	1987**	Replacement	N/A
(8) Bonnet Studs	Anchor Darling	*	N/A	N/A	1E12-F064A	*	Replaced	N/A
(8) Bonnet Studs	Cardinal Anchor	Ht. Code F8	N/A	N/A	1E12-F064A	1991**	Replacement	N/A
(16) Hex Nuts	Darling	*	N/A	N/A	1E12-F064A	*	Replaced	N/A
(16) Hex Nuts	Nova	Ht. Code AST	N/A	N/A	1E12-F064A	1995**	Replacement	N/A

7. Description of Work Class 2 Replacement. Replaced Valve Disc and all Bonnet Studs and Hex Nuts.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other
Pressure 210 psi Test Temp. Amb. Deg. F
9. Remarks * = Per N-5 Code Data Report on File at LaSalle County Station.
(Applicable Manufacturer's Data Report to be Attached)
** = Replacement Disc is ASME Class 2, 1980 Ed., W80 Ad., reconciled per DR 01-85-380. Replacement Studs & Nuts are ASME Section III, Class 1, 1989 Ed., No Ad., reconciled per the ComEd Fastner Standards. The DR & and the Fastner Standards are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp None

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ISI Coordinator Date April 10, 1997
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. of Hartford, CT. have inspected the components described in this Owner's Report during the period LR07 to LR08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personnel injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] HSB Commissions NB11053, IL 1561
Inspector's Signature National Board, State, Province, and Endorsements
Date May 08, 1997

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 9/13/97
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970021197
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System RH
5. (a) Applicable Construction Code Sec III 19 68 Edition June70 Addenda, Code Cases 1332-5
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Tube Plugs	AI Tech	Ht. # A2863H	N/A	N/A	1E12-B001A	1995	Repaired	N/A
(1) Hex Nut	Struthers-Wells	*	N/A	N/A	1E12-B001A	*	Replaced	N/A
(1) Hex Nut	Cardinal	Ht. Code D7	N/A	N/A	1E12-B001A	1995**	Replacement	N/A

7. Description of Work Class 2 Repair & Replacement. Repaired the "1A RH Heat Exchanger by plugging tubes and
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 71 psi Test Temp. Amb Deg. F
9. Remarks and replaced channel cover hex nut.
(Applicable Manufacturer's Data Report to be Attached)
** = Replacement hex nut is ASME Section III, Class 1, 1989 Ed., 89 Ad., reconciled per evaluation L-91-06-0324.
The evaluation is on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Repair & Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John L. Coles* ISI Coordinator Date February 19, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-20-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 4/9/97
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970031298
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (LP) Low Pressure Core Spray
5. (a) Applicable Construction Code Section III 1974 Edition No Addenda, Code Cases No
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
(8) Studs	Morrison	*	N/A	N/A	1LP19A-3"	*	Replaced	N/A
(8) Studs	Nova	Ht. Code FNX	N/A	N/A	1LP19A-3"	1997**	Replacement	N/A
(16) Hvy. Hex Nuts	Morrison	*	N/A	N/A	1LP19A-3"	*	Replaced	N/A
(16) Hvy. Hex Nuts	Nova	Ht. Code EKP	N/A	N/A	1LP19A-3"	1997**	Replacement	N/A

7. Description of Work Class 2, Replaced a studs and Nuts on LP spool piece blind flange.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other
Pressure 310 psi Test Temp. Amb Deg. F
9. Remarks (Applicable Manufacturer's Data Report to be Attached)
* = Per N-5 Code Data Report on file at LaSalle County Station. ** = Replacement material is ASME Section III, Class-1, 1989 Ed., No Ad. Reconciled per the ComEd Fastner Standards on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Shew C. Kallis* ISI Coordinator Date February 4, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Nancy W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-4-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 1/17/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970035389
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (HP) High Pressure Core Spray
5. (a) Applicable Construction Code * 19 * Edition * Addenda, Code Cases *
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No. Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Pivot Pin Assy.	Morrison	*	N/A	N/A	HP01-1004X	*	Replaced	N/A
Pivot Pin Assy.	Grinnell	SI# 507E64	N/A	N/A	HP01-1004X	1989	Replacement	N/A

7. Description of Work Class 2 Replacement Replaced pivot pin assembly for rigid strut.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Visual
Pressure _____ psi Test Temp. _____ Deg. F
9. Remarks * = Per Original Design Specification J-2530 & J-2918. Original Const. Code is ANSI B31.1, 1973 Edition (Applicable Manufacturer's Data Report to be Attached) S74 & W76 Addenda.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Robert L. Coelis* ISI Coordinator Date February 18, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-19-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 5/18/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970058309
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (VQ) Primary Containment Vent and Purge
5. (a) Applicable Construction Code Sect III 19 83 Edition S84 Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Valve Body	Atwood Morrill	*	N/A	N/A	1VQ034	*	Replaced	N/A
Valve Body	Clow Corp.	84-2842-01N-08	N/A	N/A	2VQ034	1985	Replacement	N/A

7. Description of Work Class 2 Replacement. Replaced valve with valve removed from LaSalle Unit 2.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other
Pressure 40 psi Test Temp. Amb Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)
** = Original Code of Construction of valves is ASME Section III, Class-2, 1983 Edition, S84 Addenda.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Shewl. Colesio* ISI Coordinator Date February 19, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Nady W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-20-2000

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR POWER VALVES^o
 As Required by the Provisions of the ASME Code, Section III, Div. 1

151340

1. Manufactured by Clow Corporation, EPD 40 Chestnut Ave. Westmont, IL 60559
(Name and Address of N Certificate Holder)
2. Manufactured for Commonwealth Edison Co. One First National Plaza, Chicago, IL
(Name and Address of Purchaser or Owner)
3. Location of Installation Commonwealth Edison Co. LaSalle County Sta. Ut. 1 Seneca, IL
(Name and Address)
4. Pump or Valve Valve Nominal Inlet Size 26 Outlet Size 26
(inch) (inch)

	(a) Model No. or Type	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l. Bd. No.	(g) Year Built
(1)	Wafer Stop	84-2842-01N-08	N/A	D-0805 E	2	N/A	1985
(2)							
(3)							
(4)							
(5)							
(6)							
(7)							
(8)							
(9)							
(10)							

5. Vent & Purge Containment Isolation System - Media Air/Nitrogen
(Brief description of service for which equipment was designed)

6. Design Conditions 60 psi 340 °F or Valve Pressure Class 1501b.C1.Body (1)
(Pressure) (Temperature)
7. Cold Working Pressure 285 psi at 100°F. Body Only 60 psid Disc
8. Pressure Retaining Pieces

Mark No.	Material Spcc. No.	Manufacturer	Remarks
(a) Castings			
(b) Forgings			
NG	SA182 F316	Camco Fittings	Pipe Plug
NN	SA182 F316	Camco Fittings	Pipe Plug

(1) For manually operated valves only.

^oSupplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 9 1/2 x 11, (2) information in items 1 through 4 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form, and (4) each additional sheet shall be signed by the Certificate Holder and the ANI.

(5/83) This form (E00037) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			151340
HT#D31672/TR.LTR."U"	SA193 Gr B7	Cardinal	Cover Plate Bolts
HT#X569B/TR.LTR."Y2"	SA193 Gr B7	Cardinal	Gland Stud
HT#A27055/TR.LTR."CAT-10"	SA194 Gr 2H	Cardinal	Gland Hex Nut
(d) Other Parts			
VJB	SA516 Gr 70	Bethlehem Steel	Body
ZTB	SA516 Gr 70	Bethlehem Steel	Disc
JUB	SA516 Gr 70	Bethlehem Steel	Cover Plate
QTB	SA564 T630	Crucible Specialty	Thru Shaft
NTB	SA516 Gr 70	Bethlehem Steel	Gland Flange

9. Hydrostatic test 450 psi. Disk Differential test pressure 66 psi.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. I, Edition 1983, Addenda Summer 1984 (Date), Code Case No. N/A, Date N/A.

Signed Clow Corporation, EPD by [Signature] 8/30/85
(N Certificate Holder)

Our ASME Certificate of Authorization No. N-2587 to use the N symbol expires 1/10/86.
(N) (Date)

CERTIFICATION OF DESIGN

Design information on file at Sargent & Lundy Engineers Chicago, IL
 Stress analysis report (Class T only) on file at N/A

Design specifications certified by (1) David C. Haan
 PE State Illinois Reg. No. 62-32917

Stress analysis certified by (1) Manu C. Patel Patel Engineers Huntsville, AL
 PE State Alabama Reg. No. 9186

(1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Allendale Mutual Ins. Co. of Norwood, Massachusetts have inspected the pump, or valve, described in this Data Report on 8-30 19 85, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 8-30 19 85 [Signature] Factory Mutual System
(Inspector) Commissions IL 917
(Nat'l Bd., State, Prov. and No.)

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 9/15/97
(Name)
One First National Plaza, Chicago, IL., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970061888 & 950008013
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st. Rd. Marseilles, IL. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (VQ) Primary Containment Vent and Purge
5. (a) Applicable Construction Code ANSI 31.1 19 73 Edition S74, W76 Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1989, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Pipe Clamp	Morrison	*	N/A	N/A	VQ5-H04X	*	Replaced	N/A
Pipe Clamp	Grinnell	SI# 819E65	N/A	N/A	VQ5-H04X	1997	Replacement	N/A

7. Description of Work Class 2 Replacement of a Pipe Clamp for Component Support VQ5-H04X. Also upgraded
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Visual
Pressure psi Test Temp. Deg. F
9. Remarks support weld from fillet joint to groove joint. * = Per Original Construction Design and
(Applicable Manufacturer's Data Report to be Attached)
Installation Specifications J-2918 and J-2530.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp None

Certificate of Authorization No. N/A Expiration Date N/A

Signed Paul C. Coelis ISI Coordinator Date February 26, 1998
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. of

Hartford, CT. have inspected the components described in this Owner's Report during the period
1/20/97 to 1/20/98

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personnel injury or property damage or a loss of any kind arising from or connected with this inspection.

Ricky W. White
Inspector's Signature

Commissions NB9304, IL 1927
National Board, State, Province, and Endorsements

Date 2-26-1998

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/4/97
(Name)
One First National Plaza, Chicago, IL., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970071549
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st. Rd. Marseilles, IL. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System Residual Heat Removal
5. (a) Applicable Construction Code Sect. III 19 74 Edition No. Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1989, No. Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Suction Strainer	Permutit	*	N/A	N/A	1E12-D301B	*	Replaced	N/A
Suction Strainer	PCI	None	N/A	N/A	1E12-D301B	1997**	Replacement	N/A

7. Description of Work Class 2 Replacement. Replaced "1B" RHR ECCS Suction Strainer and fasteners.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Flow
Pressure _____ psi Test Temp. _____ Deg. F
9. Remarks * = Per N-5 Code Data Report on File at LaSalle County Station.
(Applicable Manufacturer's Data Report to be Attached)
** = Replacement Strainers and fastners designed and fabricated to specification DS-ECCS-LS-01 which has been reconcilled to the original specification J-2530 through Design Change Package 9700300. The specifications are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp None

Certificate of Authorization No. N/A Expiration Date N/A

Signed Andrew L. Lockers ISI Coordinator Date April 1, 19 98
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. of

Hartford, CT. have inspected the components described in this Owner's Report during the period 4/1/98 to 4/3/98

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personel injury or property damage or a loss of any kind arising from or connected with this inspection.

Ruby W. White
Inspector's Signature

Commissions NB 9304, IL 1927
National Board, State, Province, and Endorsements

Date April 3, 19 98

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/3/97
 (Name)
One First National Plaza, Chicago, IL., 60690 Sheet 1 of 1
 (Address)
2. Plant LaSalle County Nuclear Station Unit 1 970071613
 (Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st. Rd. Marseilles, IL. 61341
 (Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
 (Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
 (Address)
4. Identification of System Residual Heat Removal
5. (a) Applicable Construction Code Sect. III 19 74 Edition No. Addenda, Code Cases None
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1989, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Suction Strainer	Permutit	*	N/A	N/A	1E12-D301C	*	Replaced	N/A
Suction Strainer	PCI	None	N/A	N/A	1E12-D301C	1997**	Replacement	N/A

7. Description of Work Class 2 Replacement. Replaced "1C" RHR ECCS Suction Strainer and fasteners.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Flow
 Pressure _____ psi Test Temp. _____ Deg. F
9. Remarks * = Per N-5 Code Data Report on File at LaSalle County Station.
 (Applicable Manufacturer's Data Report to be Attached)
** = Replacement Strainers and fastners designed and fabricated to specification DS-ECCS-LS-01 which has been reconcilled to the original specification J-2530 through Design Change Package 9700301. The specifications are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp None

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Andrew L. Coelius* ISI Coordinator Date April 1, 19 98
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. of

Hartford, CT. have inspected the components described in this Owner's Report during the period 6/19/97 to 6/19/98

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personel injury or property damage or a loss of any kind arising from or connected with this inspection.

Ricky W. White Commissions NB 9304, IL 1927
 Inspector's Signature National Board, State, Province, and Endorsements

Date April 3, 19 98

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 11/7/97
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970071641
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RI) Reactor Core Isolation Cooling
5. (a) Applicable Construction Code ASME Sect III 1974 Edition No Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Suction Strainer	Permuitt	*	N/A	N/A	1E51-D300	*	Replaced	N/A
Suction Strainer	PCI	None	N/A	N/A	1E51-D300	1997	Replacement	N/A

7. Description of Work Class 2 Replacement. Replaced RI Suction Strainer and Fasteners
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Flow
Pressure _____ psi Test Temp. _____ Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station.
(Applicable Manufacturer's Data Report to be Attached)
** = Replacement Strainer and Fasteners designed and fabricated to Spec. DE-ECCS-LS-01 which has been
Reconciled to the original Specification J-2530 through Design Change Package 9700546. The Specifications are
on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI.
(repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John H. Kulis* ISI Coordinator Date February 3, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co., Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Robert W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-8- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 3/14/98
(Name)
One First National Plaza, Chicago, IL., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970071689
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st. Rd. Marseilles, IL. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System Low Pressure Core Spray
5. (a) Applicable Construction Code Sect. III 19 74 Edition No. Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1989, No. Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Suction Strainer	Permutit	*	N/A	N/A	1E21-D302	*	Replaced	N/A
Suction Strainer	PCI	None	N/A	N/A	1E21-D302	1997**	Replacement	N/A

7. Description of Work Class 2 Replacement. Replaced LPCS ECCS Suction Strainer and fasteners.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Flow
Pressure psi Test Temp. Deg. F
9. Remarks * = Per N-5 Code Data Report on File at LaSalle County Station.
(Applicable Manufacturer's Data Report to be Attached)
** = Replacement Strainers and fasteners designed and fabricated to specification DS-ECCS-LS-01 which has been reconciled to the original specification J-2530 through Design Change Package 9700303. The specifications are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp None

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Andrew C. Collins* ISI Coordinator Date April 1, 19 98
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. of

Hartford, CT. have inspected the components described in this Owner's Report during the period 4/10/98 to 4/10/98

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Randy W. White Commissions NB 9304, IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date April 3, 19 98

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 12/4/97
(Name)
One First National Plaza, Chicago, IL., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970071718
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st. Rd. Marseilles, IL. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System High Pressure Core Spray
5. (a) Applicable Construction Code Sect. III 19 74 Edition No. Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-1989, No. Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Suction Strainer	Permutit	*	N/A	N/A	1E22-D302	*	Replaced	N/A
Suction Strainer	PCI	None	N/A	N/A	1E22-D302	1997**	Replacement	N/A

7. Description of Work Class 2 Replacement. Replaced HPCS ECCS Suction Strainer and fasteners.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Flow
Pressure _____ psi Test Temp. _____ Deg. F
9. Remarks * = Per N-5 Code Data Report on File at LaSalle County Station.
(Applicable Manufacturer's Data Report to be Attached)
** = Replacement Strainers and fastners designed and fabricated to specification DS-ECCS-LS-01 which has been reconciled to the original specification J-2530 through Design Change Package 9700304. The specifications are on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp None

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Paul C. Kessler* ISI Coordinator Date April 1, 19 98
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. of Hartford, CT. have inspected the components described in this Owner's Report during the period 4/1/98 to 4/10/98 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personel injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions NB 9304, IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date April 3, 19 98

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 9/29/97
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 2
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970073644
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RH) Residual Heat Removal
5. (a) Applicable Construction Code Sect III 19 71 Edition W72 Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
(20) Stud Bolts	Anchor Darling	*	N/A	N/A	1E12-F003A	*	Replaced	N/A
(20) Stud Bolts	Vitco	Ht. Code 4C	N/A	N/A	1E12-F003A	1980**	Replacement	N/A
(40) Hvy. Hex Nuts	Anchor Darling	*	N/A	N/A	1E12-F003A	*	Replaced	N/A
(40) Hvy. Hex Nuts	Vitco	Ht. Code 6C	N/A	N/A	1E12-F003A	1980**	Replacement	N/A
Load Stud	*	*	N/A	N/A	RH03-1541X	*	Replaced	N/A
Load Stud	Vitco	Ht. Code 4C	N/A	N/A	RH03-1541X	1980**	Replacement	N/A

7. Description of Work Class 2 Replacement. Replaced valve body studs and nuts, and load stud & nuts for component support. * = Per N-5 Code Data Report on file at LaSalle County Station. ** = Original Code of
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 155 psi Test Temp. N/A Deg. F
9. Remarks Construction of the support is ANSI B31.1, 1973 Ed., S74 Ad., & Design Specifications J-2918 & J2530. (Applicable Manufacturer's Data Report to be Attached)
Replacement material for the Stud Bolts and hex nuts is ASME Sect. III, Class 2, 1974 Ed., No Ad.
Replacement Studs and hex nuts were reconciled per evaluation L-1997-0156-000 on file at LaSalle County Station.
See Form Nis-2 Supplemental Sheet Page 2 of 2 for additional replaced and replacement items.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed Alan L. Lewis ISI Coordinator Date February 2, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-2-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 8/27/97
(Name)
One First National Plaza, Chicago, IL, 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970083508
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, IL 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RH) Residual Heat Removal
5. (a) Applicable Construction Code * 19 * Edition * Addenda, Code Cases *
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Mechanical Snubber	PSA	4169	N/A	N/A	RH01-1017S	*	Replaced	N/A
Mechanical Snubber	PSA	4455	N/A	N/A	RH01-1017S	1994	Replacement	N/A

7. Description of Work Class 2 Replacement Replaced Mechanical Snubber.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Visual
Pressure _____ psi Test Temp. _____ Deg. F
9. Remarks * = Per Original Design Specification J-2530 & J-2918. Original Const. Code is ANSI B31.1, 1973 Edition (Applicable Manufacturer's Data Report to be Attached) S74 & W76 Addenda.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Robert L. Collins* ISI Coordinator Date February 19, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements
Date 2-19-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 10/24/97
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970083536
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (RH) Residual Heat Removal
5. (a) Applicable Construction Code * 19 * Edition * Addenda, Code Cases *
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Pivot Pin Assembly	PSA	*	N/A	N/A	RH53-1024S	*	Replaced	N/A
Pivot Pin Assembly	Grinnell	SI # 507E64	N/A	N/A	RH53-1024S	1983	Replacement	N/A

7. Description of Work Class 2 Replacement Replaced Pivot Pin Assembly.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other Visual
Pressure _____ psi Test Temp. _____ Deg. F
9. Remarks * = Per Original Design Specification J-2530 & J-2918. Original Const. Code is ANSI B31.1, 1973 Edition (Applicable Manufacturer's Data Report to be Attached) S74 & W76 Addenda.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Alan C. Lucas* ISI Coordinator Date February 19, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Ricky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-20-2000

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 1/22/98
(Name)
One First National Plaza, Chicago, IL, 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970103338
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, IL 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System HP
5. (a) Applicable Construction Code Sect III 19 71 Edition W72 Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases N-416-1
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
1E22-F024	Anchor Darling	*	N/A	N/A	1E22-F024	*	Repaired	N/A

7. Description of Work Class 2 Repair. Added weld metal to disc to build up counterweight.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 12 psi Test Temp. Amb Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)
Original Design Specification J-2938-01.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Repair conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John C. Kelley* ISI Coordinator Date February 1, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co., Of Hartford, CT. have inspected the components described in this Owner's Report during the period 1/18/98 to 1/20/98,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Ruby W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-21-20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 1/22/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 970136967
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System (FW) Feedwater
5. (a) Applicable Construction Code Sec III 19 74 Edition W75 Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases N-416-1
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
Double-Block Valve	Anderson Greenwood	*	N/A	N/A	1B21-F030A/31A	*	Replaced	N/A
Double-Block Valve	Anderson Greenwood	N28440	N/A	N/A	1B21-F030A/31A	1995	Replacement	N/A

7. Description of Work Class 2 Replacement. Replaced Double - Block Valve.
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 1000 psi Test Temp. Amb Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Andrew C. Gellis* ISI Coordinator Date February 4, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Nicky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-4- 20 00

FORM NPV-1 (Back --- Pg. 2 of 2)

Certificate Holder's Serial No. N28440

8. Design conditions 2600 psi 575 °F or valve pressure class 1500 (1)
(pressure) (temperature)
9. Cold working pressure 3600 psi at 100°F
10. Hydrostatic test 5575 psi. Disk differential test pressure 4075 psi
11. Remarks: DISC MATERIAL COMPLIES WITH S-75 FOR SA217-CA15

CERTIFICATION OF DESIGN

Design Specification certified by David C. Haan P.E. State IL Reg. no. 62-32917
 Design Report certified by N/A P.E. State N/A Reg. no. N/A

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump or valve conforms to the rules for construction of the ASME Code, Section III, Division 1.

N Certificate of Authorization No. N-2823 Expires 9/10/96
 Date 9/29/95 Name Anderson, Greenwood & Co. Signed Joseph A. Parker
(in Certificate Holder) (Authorized representative)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of TX and employed by C.U.I.C. of Boston, MA have inspected the pump, or valve, described in this Data Report on 9-29-95, and state that to the best of my knowledge and belief, the Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III, Division 1.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the component described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 9-29-95 Signed [Signature] Commission: Tex 803
(Authorized Inspector) (Nat'l. Bd. incl. endorsements) and state or prov. and no.1

(1) For manually operated valves only.

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 4/10/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 980021310
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System HG
5. (a) Applicable Construction Code Sect III 19 74 Edition No Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
(8) Stud Bolts	*	*	N/A	N/A	1HG007	*	Replaced	N/A
(8) Stud Bolts	Nova	Ht. Code JDR	N/A	N/A	1HG007	1998	Replacement	N/A
(16) Hex Nuts	*	*	N/A	N/A	1HG007	*	Replaced	N/A
(16) Hex Nuts	Nova	Ht. Code DJQ	N/A	N/A	1HG007	1997	Replacement	N/A

7. Description of Work Class 2 Replacement. Replaced Studs and Nuts
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other
Pressure 40.5 psi Test Temp. Amb Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)
Replacement studs are same as original Code of Construction, replacement nuts are ASME Section III, Class 1, 1989 Edition, No Ad., reconciled to the original Code of Construction per the ComEd Fastner Standards on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Andrew C. Kocio* ISI Coordinator Date February 4, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-4 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 4/11/98
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 980021311
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System HG
5. (a) Applicable Construction Code Sect III 19 74 Edition No Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 89, No Ad, Code Cases None
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
(8) Stud Bolts	*	*	N/A	N/A	1HG016	*	Replaced	N/A
(8) Stud Bolts	Nova	Ht. Code JDR	N/A	N/A	1HG016	1998	Replacement	N/A
(16) Hex Nuts	*	*	N/A	N/A	1HG016	*	Replaced	N/A
(16) Hex Nuts	Nova	Ht. Code DJQ	N/A	N/A	1HG016	1997	Replacement	N/A

7. Description of Work Class 2 Replacement. Replaced Studs and Nuts
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other _____
Pressure 40.5 psi Test Temp. Amb Deg. F
9. Remarks * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)
Replacement studs are same as original Code of Construction, replacement nuts are ASME Section III, Class 1, 1989 Edition, No Ad., reconciled to the original Code of Construction per the ComEd Fastner Standards on file at LaSalle County Station.

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Shel C. Lucas* ISI Coordinator Date February 3, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-3- 20 00

FORM NIS-2 OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner Commonwealth Edison Company Date 10/30/99
(Name)
One First National Plaza, Chicago, Il., 60690 Sheet 1 of 1
(Address)
2. Plant LaSalle County Nuclear Station Unit 1 990013946
(Name) Repair Organization, P.O. No., Job No., etc.
2601 N. 21st Rd. Marseilles, Il. 61341
(Address)
3. Work Performed by Mechanical Maintenance Type Code Symbol Stamp N/A
(Name) Authorization No. N/A
Mechanical Maintenance Expiration Date N/A
(Address)
4. Identification of System RI
5. (a) Applicable Construction Code Sect III 19 74 Edition No Addenda, Code Cases None
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements-19 89, No Ad, Code Cases N-416-1
6. Identification of Components Repaired or Replaced, and Replacement Components

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	CRN No.	Other Identification	Year Built	Repaired Replaced, Replacement	ASME Code Stamped (Yes or No)
(2) 10" Butt Welds	Morrison	*	N/A	N/A	1RI40A-10"	*	Replaced	N/A
(2) 10" Butt Welds	ComEd	N/A	N/A	N/A	1RI40A-10"	1999	Replacement	N/A

7. Description of Work Class 2 Replacement. Replaced two 10" Butt welds and removed piping due to
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure Other
Pressure 60.9 psi Test Temp. Amb Deg. F
9. Remarks misalignment of piping and relief valve. * = Per N-5 Code Data Report on file at LaSalle County Station
(Applicable Manufacturer's Data Report to be Attached)
Original Design Specification J-2530

CERTIFICATION OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. (repair or replacement)

Type Code Symbol Stamp NONE

Certificate of Authorization No. N/A Expiration Date N/A

Signed *John C. Kulis* ISI Coordinator Date February 8, 20 00
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Illinois and employed by Hartford Steam Boiler Insp. & Ins. Co. Of Hartford, CT. have inspected the components described in this Owner's Report during the period L1R07 to L1R08,

and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this owner's Report in accordance with the requirements of the ASME Code, Section XI. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, Neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Rocky W. White Commissions IL 1927
Inspector's Signature National Board, State, Province, and Endorsements

Date 2-19 20 00

ATTACHMENT 3

ABBREVIATIONS

AD	ADDENDA
ANI	AUTHORIZED NUCLEAR INSPECTOR
ANII	AUTHORIZED NUCLEAR INSERVICE INSPECTOR
AISI	AUGMENTED INSERVICE INSPECTIONS
ASSY	ASSEMBLY
ATT	ATTACHMENT
ASME	AMERICAN SOCIETY OF MECHANICAL ENGINEERS
AUTO UT	AUTOMATED ULTRASONIC TEST
BOM	BILL OF MATERIAL
BWRVIP	BOILING WATER REACTOR VESSEL AND INTERNALS PROJECT
CHRON	TRACKING SYSTEM FOR ENGINEERING EVALUATIONS
CM	CONTAINMENT MONITERING
ComEd	COMMONWEALTH EDISON
CR	COMPONENT RELIEF REQUEST
CRD	CONTROL ROD DRIVE
ED	EDITION
ES	EXTRACTION STEAM
EVT	ENHANCED VISUAL TEST
FC	FUEL POOL COOLING
FW	FEEDWATER
GENE	GENERAL ELECTRIC NUCLEAR ENERGY
HG	CONTAINMENT COMBUSTIBLE GAS CONTROL
HP	HIGH PRESSURE CORE SPRAY
H.S.B.I. & I. Co.	HARTFORD STEAM BOILER INSPECTION AND INSURANCE COMPANY
HT#	HEAT NUMBER

ATTACHMENT 3 (CONT'D)

ID/OD	INSIDE DIAMETER/OUTSIDE DIAMETER
IGSCC	INTERGRANULAR STRESS CORROSION CRACKING
IL	ILLINOIS
IN	INSTRUMENT NITROGEN
ISI	INSERVICE INSPECTION
LPRM	LOCAL POWER RANGE MONITOR
LP	LOW PRESSURE CORE SPRAY
MIL	MILLIMETER
MC	CLEAN CONDENSATE STORAGE
MS	MAIN STEAM
MSIV	MAIN STEAM ISOLATION VALVE
MT	MAGNETIC PARTICLE TEST
N/A	NOT APPLICABLE
NB	NUCLEAR BOILER
NDE	NON-DESTRUCTIVE EVALUATION
NIR	NOZZLE INNER RADIUS
NR	NUCLEAR INSTRUMENTATION
NRC	NUCLEAR REGULATORY COMMISSION
NRI	NON-RECORDABLE/NON-RELEVANT INDICATION
PC	PRIMARY CONTAINMENT
PCE	PART CLASSIFICATION EVALUATION
PDI	PERFORMANCE DEMONSTRATION INITIATIVE
PG	PAGE
PIF	PROBLEM IDENTIFICATION FORM
PR	PRESSURE TESTING RELIEF REQUEST
PSI	PRESERVICE INSPECTION

ATTACHMENT 3 (CONT'D)

PSIG	POUNDS PER SQUARE INCH GAGE
PT	LIQUID PENETRANT TEST
PTE	PART TECHNICAL EVALUATION
QRI	QUALITY RECEIPT INSPECTION
RC-PB	REACTOR COOLANT PRESSURE BOUNDARY
RD	ROD DRIVE
RE	REACTOR BUILDING EQUIPMENT DRAINS
RF	REACTOR BUILDING FLOOR DRAINS
RH	RESIDUAL HEAT REMOVAL
RI	REACTOR CORE ISOLATION COOLING
RICSIL	RAPID SERVICES COMMUNICATION SERVICES INFORMATION LETTER
RPV	REACTOR PRESSURE VESSEL
RR	REACTOR RECIRCULATION
RT	REACTOR WATER CLEAN-UP
SA	SERVICE AIR
SAR	SAFETY ANALYSIS REPORT
SC	STANDBY LIQUID CONTROL
SDC	SHUTDOWN COOLING
SEAG	SITE ENGINEERING ADMIN GROUP
SIL	SERVICES INFORMATION LETTER
SRV	SAFETY RELIEF VALVE
STM	STEAM
UT	ULTRASONIC TEST
VG	STANDBY GAS TREATMENT
VLV	VALVE
VP	PRIMARY CONTAINMENT CHILLED WATER

ATTACHMENT 3 (CONT'D)

VQ	PRIMARY CONTAINMENT VENT AND PURGE
VT	VISUAL TEST
WR	REACTOR BUILDING CLOSED COOLING WATER