PETER E. KATZ
Plant General Manager
Calvert Cliffs Nuclear Power Plant

Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, Maryland 20657
410 495-4101

A Member of the Constellation Energy Group

February 25, 2000

U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
1999 Steam Generator Tube Inspection Results Report

REFERENCE: (a) Calvert Cliffs Nuclear Power Plant Units 1 and 2 Technical Specification 5.6.9.b

Reference (a) requires that we report, on an annual basis, the results of the steam generator tube inservice inspection conducted in the past year. This letter provides the steam generator tube examinations conducted on the Unit 2 steam generators during the spring of 1999. No similar inspections were conducted on the Unit 1 steam generators in 1999. This report includes the number and extent of tubes examined, imperfections noted, and the identity of tubes plugged. The Unit 2 steam generator tube inspection results required 253 total tubes to be plugged in No. 21 Steam Generator and 301 total tubes to be plugged in No. 22 Steam Generator. The number of circumferential flaws detected were 17 in No. 21 Steam Generator and 31 in No. 22 Steam Generator.

INSPECTION SCOPE

The examination of Calvert Cliffs Unit 2 Steam Generators (Nos. 21 and 22) consisted of bobbin coil and motorized rotating plus point inspection technologies. All distorted bobbin coil indications were dispositioned with the plus point probe. The table below identifies the number and extent of tubes inspected.

Inspection Zones	Number of Tubes Inspected (SG21/SG22)	Tube Extent Examined
100% Full Length Bobbin Coil	7815/8076	tube end to tube end
100% Plus Point on top of hot leg tube sheet	7815/8076	TSH minus 1" to TSH plus 5"
100% Plus Point of the Steam Blanket Region	566/465	05H to 06C
100% Plus Point on top of cold leg tube sheet (plus expansion)	7815/8076	TSC minus 1" to TSC plus 5"
20% Plus Point at tubes with tight radius U-bends	23/23	06H Egg Crate to 06C Egg Crate
20% Plus Point Dents and Dings ≥ 5V	106/213	NA

SG = Steam Generator TSH = Tubesheet Hot TSC = Tubesheet Cold

EDDY CURRENT INSPECTION RESULTS

Attachment (1) contains the results of the motorized rotating plus point and bobbin coil exams for Nos. 21 and 22 Steam Generators. All steam generator tubes with crack-like indications, both circumferential and axial, and all tubes with volumetric indications were removed from service.

Should you have questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

Peter Katz

PEK/GT/dlm

Attachment: (1) Results of Bobbin Coil and Motorized Rotating Plus Point Exams for Unit 2 Nos. 21 and 22 Steam Generators

cc: H. J. Miller, NRC

Without Attachment

R. S. Fleishman, Esquire
J. E. Silberg, Esquire
Director, Project Directorate I-1, NRC
A. W. Dromerick, NRC
Resident Inspector, NRC
R. I. McLean, DNR
J. H. Walter, PSC

ATTACHMENT (1)

RESULTS OF BOBBIN COIL AND MOTORIZED ROTATING PLUS POINT EXAMS FOR UNIT 2 NOs. 21 AND 22 STEAM GENERATORS

Baltimore Gas & Electric Company
Docket Nos. 50-317 and 50-318
February 25, 2000

Final Report

Summary, Certification & Examination Results

Eddy Current Examination

Calvert Cliffs Nuclear Power Plant
Unit II

Steam Generators
21 & 22

March 1999

for
Baltimore Gas and Electric

FRAMATOME
TECHNOLOGIES

9. Three Letter Codes

Code	Description
Bobbin:	
ADR	Absolute Drift
BDA	Bad Data
BLG	Bulge
CUD	Copper Deposits
DEP	Deposit
DNI	Dent w/possible Indication
DNG	Ding
DNT	Dent
DRI	Distorted Roll with a possible Indication
DSI	Distorted Support with a possible Indication
DTI	Distorted Tubesheet Indication
EXP	Expansion
ETL	Expansion Transition Location
FIX	Fixture
FSA	Free Span Absolute
FSD	Free Span Differential
IDC	Chatter (Pilgering, ID Variations, etc.)
INC	Incomplete Test
INF	Indication Not Found
INR	Indication Not Reportable
LDE	Lower Deposit Elevation
LPI	Loose Part Indication
MBM	Manufacturing Burnish Mark
NDD	No Detectable Degradation
NQI	Non Quantifiable Indication
NRC	No Roll on Coldleg (partial explansion)
NRH	No Roll on Hotleg (partial explansion)
NSY	Noisy Tube
OBS	Obstructed
PBC	Previous Bobbin Call
PID	Positive Identification of Defect
PLG	Plugged
PLP	Possible Loose Part
PTS	PID Tubesheet
PVN	Permeability Variation
SLG	Sludge
TBP	To Be Plugged
TNC	Tube Number Check
TNT	Tube Not Tested
UDE	Upper Deposit Elevation

Code	Description
Plus Point/MRPC:	
BDA	Bad Data
DEP	Deposit
DNG	Ding
DNT	Dent
FIX	Fixture
INC	Incomplete Test
INF	Indication Not Found
INR	Indication Not Reportable
LDE	Lower Deposit Elevation
LPI	Loose Part Indication
NDD	No Detectable Degradation
MAI	Multiple Axial Indications
MCI	Multiple Circumferential Indications
MMI	Mixed Mode Indication
MSI	Multiple Single Indications
MVI	Multiple Volumetric Indications
NDD	No Detectable Degradation
NDF	No Defect Found
NSY	Noisy Tube
OBS	Obstructed
PID	Positive Identification of Defect
PLG	Plugged
PLP	Possible Loose Part
PPI	Plus Point Indication
PPS	Plus Point Signal
PRC	Previous MRPC Call
PVN	Permeability Variation
SAI	Single Axial Indication
SCI	Single Circumferential Indication
SVI	Single Volumetric Indication
TBP	To Be Plugged
TNC	Tube Number Check
TNT	Tube Not Tested
UDE	Upper Deposit Elevation
VOL	Volumetric Indication (Plus Pt. MBM)
WAR	Wear

See Appendix B for selected definitions

BOBBIN INDICATIONS

May 17,1999 10:23

UTILITY:	Baltimore Gas & Electric
PLANT:	CCNPP
UNIT:	2
SG:	21
DATABASE:	CCNPP_UNIT2_SG21_0399_Final

****
* INSPECTION SUMMARY QUERY REPORT *
****

* Test Plans included in summary: 3 Total Test Plans in database: 13 *

Test Plan Name:	Probe Type:	Probe Size:	Leg:
1. ROWS 1-5 STRAIGHT SECT (G65-68)	BOBBIN	580UL	HL
2. F/L ROWS 6-140 (G1-19)	BOBBIN	600UL	CL
3. ROWS 1-5 CANDY CANE (G20-23)	BOBBIN	580SF	CL

****
* EIMS MAIN QUERY PARAMETERS *
****

ROW	ALL
LINE	ALL
VOLTS	ALL
DEGREES	ALL
PERCENT	0 to 100
LOCATION	ALL
ELEVATION	ALL
EXTENT	ALL
UTILITY1	ALL
UTILITY2	ALL
NAME	ALL
EVAL TYPE	ALL
CAL GROUP	ALL
PROBE	ALL
IND. CODES	ADR DNI DRI DSI DTI
	LPI NQI PLP
CHANNELS	ALL

BOBBIN INDICATIONS

UTILITY: Baltimore Gas & Electric

May 17,1999 10:23

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
1	3	1	0.60	59	23	P2	01C +0.81	06HTEC			A9608	reso	21C00186	C 1	560SF
2	10	4	2.95	170	DSI	P1	VM +0.00	TECTEH			K7060	reso	21H00115	C 0	600UL
3	30	4	0.40	56	DSI	P1	03H +0.74	TECTEH			K2858	rpri	21H00115	C 0	600UL
4	26	6	0.32	143	14	P2	DC +1.73	TECTEH			H2131	reso	21H00116	C 0	600UL
5	32	6	0.52	42	DSI	P1	05C -0.83	TECTEH			K2858	rpri	21H00115	C 0	600UL
6	44	6	0.49	111	DSI	P1	03H -0.99	TECTEH			K2858	rpri	21H00115	C 0	600UL
7	59	9	0.27	69	DSI	P1	04C -0.45	TECTEH			A9608	reso	21H00115	C 0	600UL
8	28	12	0.29	126	8	P2	03H +0.73	TECTEH			A9608	reso	21H00115	C 0	600UL
9	60	12	0.45	56	DSI	P1	01H -1.35	TECTEH			K2858	rpri	21H00115	C 0	600UL
10	91	21	1.23	110	DSI	P1	06C -0.16	TECTEH			L7871	rpri	21H00117	C 0	600UL
11	14	22	0.10	101	NQI	P1	TSH +0.54	TECTEH			A9608	reso	21H00119	C 0	600UL
12	96	26	0.37	95	13	P2	VC -1.85	TECTEH			O1057	rpri	21H00119	C 0	600UL
13	95	27	0.35	138	13	P2	VH +1.23	TECTEH			A9608	reso	21H00120	C 0	600UL
14	48	28	0.36	160	NQI	P1	TSH +0.49	TECTEH			L6066	rsec	21H00122	C 0	600UL
15	66	28	0.27	87	NQI	5	07H +5.45	TECTEH			A9608	reso	21H00121	C 0	600UL
16	29	29	0.33	86	NQI	P1	TSH +0.81	TECTEH			L2157	rpri	21H00129	C 0	600UL
17	95	31	0.49	104	17	P2	VM -1.08	TEHTEC			B6768	rpri	21C00105	C 0	600UL
18	55	33	0.32	133	NQI	P1	TSH +0.90	TEHTEC			C3340	reso	21C00103	C 0	600UL
19	46	34	0.27	98	NQI	P1	TSH +0.73	TEHTEC			D4576	rsec	21C00102	C 0	600UL
20	48	34	0.36	97	NQI	P1	TSH +0.69	TEHTEC			D4576	rsec	21C00102	C 0	600UL
2	23	35	0.31	130	NQI	P1	TSH +1.39	TEHTEC			K2858	rpri	21C00103	C 0	600UL
2.	106	36	0.66	36	DSI	P1	08H -0.31	TEHTEC			D4576	rsec	21C00102	C 0	600UL
23	16	38	0.19	99	NQI	P1	TSH +2.64	TEHTEC			C3340	reso	21C00100	C 0	600UL
24	95	39	0.66	109	DSI	P1	09H +0.19	TEHTEC			K2858	rpri	21C00101	C 0	600UL
25	28	40	0.57	31	NQI	P1	TSH +1.16	TEHTEC			K2858	rpri	21C00099	C 0	600UL
26	58	42	0.36	136	NQI	P1	TSH +0.95	TEHTEC			M1680	reso	21C00098	C 0	600UL
27	62	42	0.46	116	DSI	P1	05C -0.48	TEHTEC			P5436	rpri	21C00098	C 0	600UL
28	119	43	1.46	159	DSI	P1	DC -0.79	TEHTEC			D3858	reso	21C00098	C 0	600UL
29	82	44	0.65	53	NQI	P1	TSH +0.55	TEHTEC			P4634	rsec	21C00099	C 0	600UL
30	82	48	0.49	41	NQI	P1	TSH +0.83	TEHTEC			F7467	rsec	21C00053	C 0	600UL
31	11	49	1.59	121	DSI	P1	VM +0.20	TEHTEC			H2131	reso	21C00097	C 0	600UL
32	101	49	0.27	110	10	P2	VH -1.03	TEHTEC			A9608	reso	21C00053	C 0	600UL
33	10	52	0.72	142	DSI	P1	VM -0.16	TEHTEC			P4634	rsec	21C00097	C 0	600UL
34	21	53	0.73	124	NQI	P1	TSH +0.62	TEHTEC			L2157	rpri	21C00029	C 0	600UL
35	100	54	0.43	67	16	P2	VM +2.02	TEHTEC			H2131	reso	21C00050	C 0	600UL
36	11	55	1.89	157	DSI	P1	VM +0.11	TEHTEC			K7060	reso	21C00096	C 0	600UL
37	21	55	0.57	142	NQI	P1	TSH +0.73	TEHTEC			D4576	rsec	21C00029	C 0	600UL
38	45	55	0.37	133	NQI	P1	TSH +0.87	TEHTEC			O1057	rpri	21C00016	C 0	600UL
39	119	55	0.43	49	DSI	P1	10H +0.00	TEHTEC			S1848	rpri	21C00050	C 0	600UL
40	14	58	0.33	104	DSI	P1	02H +0.52	TEHTEC			H2131	reso	21C00097	C 0	600UL
41	74	58	0.87	90	NQI	6	03H +4.20	TEHTEC			S7752	reso	21C00051	C 0	600UL
42			0.35	81	NQI	5	07H +8.80	TEHTEC			S7752	reso	21C00051	C 0	600UL
43	113	58	0.29	76	NQI	5	04C +8.09	TEHTEC			R6452	reso	21C00050	C 0	600UL
44	7	59	1.10	43	NQI	P1	TSH +2.71	TEHTEC			L7871	rpri	21C00097	C 0	600UL
45	79	59	0.34	67	NQI	5	01H +14.17	TEHTEC			R6452	reso	21C00050	C 0	600UL
46	50	60	0.20	82	NQI	P1	TSH +1.49	TEHTEC			L2157	rpri	21C00029	C 0	600UL
	86	60	0.68	11	NQI	P1	TSH +0.62	TEHTEC			M9715	rsec	21C00088	C 0	600UL
48	98	60	0.36	95	DSI	P1	DH +1.16	DH TEC			L2157	rpri	21C00050	C 0	600UL
49			0.56	154	21	P2	DH +1.34	TEHTEC			T0042	reso	21C00087	C 0	580SF

BOBBIN INDICATIONS

UTILITY: Baltimore Gas & Electric

May 17,1999 10:23

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
50	123	63	0.67	88	DSI	P1 10H	+0.13	TEHTEC			R9311	rpri	21C00055	C 0	580UL
51	60	64	0.59	61	DSI	P1 04C	-1.30	TEHTEC			S1848	rpri	21C00017	C 0	600UL
52	90	64	0.30	20	NQI	P1 TSH	+1.00	TEHTEC			M9715	rsec	21C00088	C 0	600UL
53	51	65	0.60	75	DSI	P1 02H	+1.18	TEHTEC			S1848	rpri	21C00017	C 0	600UL
54	124	66	0.87	85	DSI	P1 10H	+0.00	TEHTEC			S1848	rpri	21C00054	C 0	580UL
55	127	67	0.78	134	DSI	P1 10H	+0.00	TEHTEC			S1848	rpri	21C00054	C 0	580UL
56	32	68	0.26	75	NQI	P1 TSH	+1.38	TEHTEC			S1848	rpri	21C00017	C 0	600UL
57	65	71	0.51	43	DSI	P1 01H	+0.65	TEHTEC			W4892	rpri	21C00041	C 0	600UL
58	128	72	0.66	136	DSI	P1 10H	+0.00	TEHTEC			S1848	rpri	21C00054	C 0	580UL
59	39	77	0.18	99	DSI	P1 02H	-0.21	TEHTEC			M9715	rsec	21C00085	C 0	600UL
60	122	78	0.82	98	DSI	P1 10H	+0.11	TEHTEC			K7060	reso	21C00057	C 0	580UL
61	81	79	0.31	91	NQI	P1 TSH	+0.89	TEHTEC			W4892	rpri	21C00043	C 0	600UL
62	57	81	0.36	75	NQI	5 TSH	+7.10	TEHTEC			C3340	reso	21C00085	C 0	600UL
63	123	81	0.98	119	DSI	P1 10H	-0.11	TEHTEC			K7060	reso	21C00057	C 0	580UL
64	139	81	0.32		13	P2 07H	+1.00	TEHTEC			R6452	reso	21C00057	C 0	580UL
65			0.58		23	P2 DH	+1.92	TEHTEC			R9311	rpri	21C00057	C 0	580UL
66	123	83	0.95	88	DSI	P2 10H	+0.18	TEHTEC			D3858	reso	21C00057	C 0	580UL
67	125	83	0.72	117	DSI	P1 10H	+0.02	TEHTEC			D3858	reso	21C00056	C 0	580UL
68	42	84	0.21	134	NQI	P1 TSH	+1.45	TEHTEC			K2858	rpri	21C00085	C 0	600UL
69	98	84	0.48	82	DSI	P1 04H	+0.38	TEHTEC			B6768	rpri	21C00045	C 0	600UL
7	118	84	0.57	120	DSI	P1 10H	+0.14	TEHTEC			K4444	rsec	21C00044	C 0	600UL
7.	42	86	0.22	40	NQI	P1 TSH	+1.39	TEHTEC			C3340	reso	21C00086	C 0	600UL
72	125	87	1.02	104	DSI	P1 10H	+0.00	TEHTEC			K7060	reso	21C00057	C 0	580UL
73	121	89	0.28	111	NQI	P1 TSH	+7.91	TEHTEC			A9608	reso	21C00056	C 0	580UL
74	116	92	0.27	81	DSI	P1 06C	-0.26	TEHTEC			C5184	rsec	21C00032	C 0	600UL
75	126	92	0.81	130	DSI	P1 10H	+0.02	TEHTEC			K7060	reso	21C00057	C 0	580UL
76	73	93	0.40	73	NQI	5 TSH	+13.14	TEHTEC			R6452	reso	21C00032	C 0	600UL
77	75	93	0.46	124	NQI	P1 TSH	+5.61	TEHTEC			J6276	rpri	21C00031	C 0	600UL
78	115	93	0.41	84	DSI	P1 09H	+0.15	TEHTEC			J6276	rpri	21C00031	C 0	600UL
79	82	94	0.38	47	NQI	P1 TSH	+1.15	TEHTEC			O1057	rpri	21C00032	C 0	600UL
80	122	96	0.84	80	NQI	5 TSH	+23.49	TEHTEC			K7060	reso	21C00057	C 0	580UL
81	101	99	0.41	127	15	P2 VH	-0.82	TEHTEC			W4892	rpri	21C00033	C 0	600UL
82			0.36	124	14	P2 VM	+2.11	TEHTEC			G6391	rsec	21C00033	C 0	600UL
83	22	102	0.24	94	NQI	P1 03H	+5.24	TECTEH			H2131	reso	21H00124	C 0	600UL
84	42	106	1.35	86	NQI	6 02C	+30.65	TSCTEH			H2131	reso	21H00124	C 0	600UL
85	100	106	0.55	35	DSI	P1 09H	+0.15	TEHTEC			W4892	rpri	21C00037	C 0	600UL
86			0.68	70	DSI	P1 09C	-0.11	TEHTEC			W4892	rpri	21C00037	C 0	600UL
87	98	110	2.60	20	DSI	P1 09H	-0.02	TEHTEC			B3720	reso	21C00039	C 0	600UL
88	85	113	0.14	122	NQI	P1 TSH	+0.71	TEHTEC			B1055	rpri	21C00038	C 0	600UL
89	76	114	0.35	123	NQI	P1 TSH	+0.69	TEHTEC			B1055	rpri	21C00038	C 0	600UL
90	55	115	0.33	88	NQI	5 04H	+11.51	TECTEH			R6452	reso	21H00125	C 0	600UL
91	89	115	0.23	90	NQI	P1 TSH	+0.71	TEHTEC			B1055	rpri	21C00038	C 0	600UL
92	14	118	0.35	121	NQI	P1 TSH	+3.63	TEHTEC			H3464	rpri	21C00020	C 0	600UL
93	27	119	0.42	67	15	P2 VM	+2.08	TEHTEC			S1848	rpri	21C00021	C 0	600UL
94	1	121	0.81	52	NQI	5 05H	+30.90	06HTEH			C3340	reso	21H00001	H 1	600UL
95	125	121	0.62	90	NQI	5 07H	+21.96	TEHTEC			M1680	reso	21C00059	C 0	580UL
	66	122	0.65	73	NQI	5 TSH	+0.62	TEHTEC			B3720	reso	21C00026	C 0	600UL
97	43	125	0.75		23	P2 01C	+0.52	TEHTEC			H3464	rpri	21C00020	C 0	600UL
98	65	125	0.53	119	NQI	5 TSH	+1.63	TEHTEC			B3720	reso	21C00027	C 0	600UL

BOBBIN INDICATIONS

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 10:23

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE SIZE
99	44	126	0.26	97	NQI	P1 TSH	+0.52	TEHTEC			H3464	rpri	21C00020	C	0	600UL
100	76	126	0.40	71	NQI	5 TSH	+0.84	TEHTEC			B3720	reso	21C00028	C	0	600UL
101	102	126	0.39	56	16	P2 VH	+1.64	TEHTEC			L2157	rpri	21C00027	C	0	600UL
102	55	127	0.76	140	NQI	P1 TSH	+0.58	TEHTEC			A9608	reso	21C00020	C	0	600UL
103	73	127	0.33	62	NQI	5 TSH	+1.12	TEHTEC			B3720	reso	21C00027	C	0	600UL
104	52	128	0.49	135	NQI	P1 TSH	+1.05	TEHTEC			A9608	reso	21C00020	C	0	600UL
105	60	128	0.83	128	NQI	P1 TSH	+0.91	TEHTEC			S1848	rpri	21C00019	C	0	600UL
106			0.26	109	DSI	P1 01H	+0.95	TEHTEC			S1848	rpri	21C00019	C	0	600UL
107	53	129	0.53	108	NQI	P1 TSH	+0.81	TEHTEC			S1848	rpri	21C00023	C	0	600UL
108	55	129	0.46	103	NQI	P1 TSH	+0.76	TEHTEC			B3720	reso	21C00024	C	0	600UL
109	57	129	0.46	71	NQI	P1 TSH	+0.93	TEHTEC			S1848	rpri	21C00023	C	0	600UL
110	79	129	0.25	64	NQI	P1 TSC	+0.90	TEHTEC			L2157	rpri	21C00027	C	0	600UL
111	12	130	1.27	111	DSI	P1 02H	+1.04	TEHTEC			S1848	rpri	21C00019	C	0	600UL
112	58	130	0.20	122	NQI	P1 TSH	+0.97	TEHTEC			B3720	reso	21C00024	C	0	600UL
113	66	130	0.84	83	NQI	5 TSH	+0.93	TEHTEC			B3720	reso	21C00027	C	0	600UL
114	46	132	0.44	74	NQI	P1 TSH	+0.72	TEHTEC			B2860	rpri	21C00024	C	0	600UL
115	9	133	0.59	103	21	P2 VM	-0.34	TEHTEC			P4634	rsec	21C00019	C	0	600UL
116	39	133	0.68	112	NQI	P1 TSH	+0.92	TEHTEC			P4634	rsec	21C00023	C	0	600UL
117	63	133	0.32	112	NQI	5 TSH	+0.78	TEHTEC			B3720	reso	21C00030	C	0	600UL
118	37	135	0.72	150	NQI	P1 TSH	+0.83	TEHTEC			P4634	rsec	21C00023	C	0	600UL
[illegible]	79	135	0.61	109	DSI	P1 01H	+0.57	TEHTEC			L2157	rpri	21C00029	C	0	600UL
1[illegible]	38	136	0.36	86	NQI	P1 TSH	+0.72	TEHTEC			B3720	reso	21C00024	C	0	600UL
121	40	136	0.55	101	NQI	P1 TSH	+0.68	TEHTEC			S1848	rpri	21C00023	C	0	600UL
122	17	137	0.23	47	NQI	P1 TSH	+1.31	TEHTEC			S1848	rpri	21C00019	C	0	600UL
123	99	137	0.59	134	NQI	P1 04C	+5.65 TO+7.66	TEHTEC			B3720	reso	21C00029	C	0	600UL
124			0.42	87	NQI	P1 03C	+31.35 TO+32.69	TEHTEC			B3720	reso	21C00029	C	0	600UL
125	32	138	0.48	141	NQI	P1 TSH	+0.70	TEHTEC			T7451	rsec	21C00008	C	0	600UL
126	34	138	0.96	92	NQI	5 TSH	+0.54	TEHTEC			B3720	reso	21C00007	C	0	600UL
127			0.86	79	NQI	5 TSH	+0.93	TEHTEC			B3720	reso	21C00007	C	0	600UL
128	31	139	0.65	59	NQI	5 TSH	+0.67	TEHTEC			B3720	reso	21C00007	C	0	600UL
129			0.49	63	NQI	5 TSH	+1.13	TEHTEC			B3720	reso	21C00007	C	0	600UL
130	37	139	0.33	66	NQI	P1 TSH	+0.62	TEHTEC			M1680	reso	21C00008	C	0	600UL
131	16	140	0.40	56	NQI	P1 TSH	+1.07	TEHTEC			B1055	rpri	21C00004	C	0	600UL
132	94	140	0.52	147	DSI	P1 02H	-0.25	TEHTEC			L2157	rpri	21C00029	C	0	600UL
133	17	143	0.44	108	NQI	P1 TSH	+1.15	TEHTEC			B1055	rpri	21C00004	C	0	600UL
134	23	145	0.64	88	NQI	5 TSH	+0.69	TEHTEC			B3720	reso	21C00007	C	0	600UL
135	93	145	0.39	67	16	P2 VC	-1.04	TEHTEC			B3720	reso	21C00014	C	0	600UL
136	24	146	0.72	135	NQI	5 TSH	+0.65	TEHTEC			B3720	reso	21C00007	C	0	600UL
137	9	149	1.34	74	DSI	P1 VM	-1.20	TEHTEC			B3720	reso	21C00004	C	0	600UL
138	17	153	0.48	41	NQI	P1 TSH	+3.22	TEHTEC			L7871	rpri	21C00003	C	0	600UL
139	29	157	0.57	29	DSI	P1 02H	+0.31	TEHTEC			M9715	rsec	21C00010	C	0	600UL
140	12	162	0.77	92	NQI	5 TSH	+14.10	TEHTEC			R6452	reso	21C00003	C	0	600UL
141	29	163	0.29	57	NQI	P1 TSH	+0.73	TEHTEC			M9715	rsec	21C00012	C	0	600UL
142	38	164	0.61	123	20	P2 VM	+1.98	TEHTEC			R6452	reso	21C00011	C	0	600UL
143	15	167	0.20	131	DSI	P1 DH	-0.17	TEHTEC			S7752	reso	21C00001	C	0	600UL

BOBBIN INDICATIONS

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 10:23

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE	SIZE

QUERY REPORT SUMMARY:

QUERY PARAMETER	ENTRIES	TUBES
0 to 100 Percent	19	17
ADR Indication Code	0	0
DNI Indication Code	0	0
DRI Indication Code	0	0
DSI Indication Code	45	44
DTI Indication Code	0	0
LPI Indication Code	0	0
NQI Indication Code	79	75
PLP Indication Code	0	0

TOTAL ENTRIES: 143

TOTAL TUBES: 134

RPC SPECIAL INTEREST INDICATIONS

UTILITY:	Baltimore Gas & Electric	May 18,1999 15:32
PLANT:	CCNPP	
UNIT:	2	
SG:	21	
DATABASE:	CCNPP_UNIT2_SG21_0399_Final	

****
* INSPECTION SUMMARY QUERY REPORT *
****

* Test Plans included in summary: 2 Total Test Plans in database: 13 *

Test Plan Name:	Probe Type:	Probe Size:	Leg:
1. Bobbin SI TEH-VM+0.00	MRPC	600PP	HL
2. Bobbin SI VM+0.01-TEC	MRPC	600HF	CL

****
* EIMS MAIN QUERY PARAMETERS *
****

ROW	ALL				
LINE	ALL				
VOLTS	ALL				
DEGREES	ALL				
PERCENT	NONE				
LOCATION	ALL				
ELEVATION	ALL				
EXTENT	ALL				
UTILITY1	ALL				
UTILITY2	ALL				
NAME	ALL				
EVAL TYPE	ALL				
CAL GROUP	ALL				
PROBE	ALL				
IND. CODES	LPI	MAI	MCI	MMI	MSI
	MVI	SAI	SCI	SVI	
CHANNELS	ALL				

RPC SPECIAL INTEREST INDICATIONS

UTILITY: Baltimore Gas & Electric

May 18,1999 15:32

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE SIZE
1	65	71	0.22	95	SAI	1	01H	+0.51	01H01H	0.3		T0042	reso	21H00066	H 4	600PP
2			0.32	83	SAI	2	01H	+0.51	01H01H	0.3		T0042	reso	21H00066	H 4	600PP

QUERY REPORT SUMMARY:

QUERY PARAMETER		ENTRIES	TUBES
LPI	Indication Code	0	0
MAI	Indication Code	0	0
MCI	Indication Code	0	0
MMI	Indication Code	0	0
MSI	Indication Code	0	0
MVI	Indication Code	0	0
SAI	Indication Code	2	1
SCI	Indication Code	0	0
SVI	Indication Code	0	0

TOTAL ENTRIES: 2

TOTAL TUBES: 1

RPC C/L UBENDS ROWS 1-2 INDICATIONS

May 13,1999 16:14

UTILITY: Baltimore Gas & Electric
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0399_Final

****
* INSPECTION SUMMARY QUERY REPORT *
****

* Test Plans included in summary: 1 Total Test Plans in database: 13 *

Test Plan Name:	Probe Type:	Probe Size:	Leg:
1. ROWS 1-2 UBENDS (G43-46)	MRPC	560PP	CL

****
* EIMS MAIN QUERY PARAMETERS *
****

ROW	ALL
LINE	ALL
VOLTS	ALL
DEGREES	ALL
PERCENT	NONE
LOCATION	ALL
ELEVATION	ALL
EXTENT	ALL
UTILITY1	ALL
UTILITY2	ALL
NAME	ALL
EVAL TYPE	ALL
CAL GROUP	ALL
PROBE	ALL
IND. CODES	LPI MAI MCI MMI MSI
	MVI SAI SCI SVI
CHANNELS	ALL

*** There were no report entries returned by the current sort parameters! ***

RPC H/L STEAM BLANKET REGION INDICATIONS

UTILITY:	Baltimore Gas & Electric	May 17,1999 09:59
PLANT:	CCNPP	
UNIT:	2	
SG:	21	
DATABASE:	CCNPP_UNIT2_SG21_0399_Final	

****
* INSPECTION SUMMARY QUERY REPORT *
****

* Test Plans included in summary: 1 Total Test Plans in database: 13 *

	Test Plan Name:	Probe Type:	Probe Size:	Leg:
1.	100%STEAM BLANKET R6-15(G69-72)	MRPC	560PF	HL

****
* EIMS MAIN QUERY PARAMETERS *
****

ROW	ALL
LINE	ALL
VOLTS	ALL
DEGREES	ALL
PERCENT	NONE
LOCATION	ALL
ELEVATION	ALL
EXTENT	ALL
UTILITY1	ALL
UTILITY2	ALL
NAME	ALL
EVAL TYPE	ALL
CAL GROUP	ALL
PROBE	ALL
IND. CODES	LPI MAI MCI MMI MSI
	MVI SAI SCI SVI
CHANNELS	ALL

RPC H/L STEAM BLANKET REGION INDICATIONS

UTILITY: Baltimore Gas & Electric

May 17,1999 09:59

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
1	11	49	0.37	26	SAI	1 VM	+0.40	06C05H	0.4		R6452	reso	21H00163	H 2	560PF
2			0.30	89	SAI	2 VM	+0.40	06C05H	0.3		R6452	reso	21H00163	H 2	560PF
3	9	149	1.34	48	SAI	1 VM	-1.45	06C05H	0.8		B3720	reso	21H00074	H 2	560PF
4			0.68	100	SAI	2 VM	-1.45	06C05H	0.8		B3720	reso	21H00074	H 2	560PF
5	8	150	0.16	57	SCI	1 VM	-1.04	06C05H	0.3		M1680	reso	21H00075	H 2	560PF
6			0.36	93	SCI	P1 VM	-1.04	06C05H	0.2		M1680	reso	21H00075	H 2	560PF

QUERY REPORT SUMMARY:

QUERY PARAMETER		ENTRIES	TUBES
LPI	Indication Code	0	0
MAI	Indication Code	0	0
MCI	Indication Code	0	0
MMI	Indication Code	0	0
MSI	Indication Code	0	0
MVI	Indication Code	0	0
SAI	Indication Code	4	2
SCI	Indication Code	2	1
SVI	Indication Code	0	0

TOTAL ENTRIES: 6

TOTAL TUBES: 3

RPC C/L TTS INDICATIONS

UTILITY:	Baltimore Gas & Electric	May 17,1999 09:55
PLANT:	CCNPP	
UNIT:	2	
SG:	21	
DATABASE:	CCNPP_UNIT2_SG21_0399_Final	

****
* INSPECTION SUMMARY QUERY REPORT *
****

* Test Plans included in summary: 1 Total Test Plans in database: 13 *

Test Plan Name:	Probe Type:	Probe Size:	Leg:
1. TSC (G24-42)	MRPC	600HF	CL

****
* EIMS MAIN QUERY PARAMETERS *
****

ROW	ALL
LINE	ALL
VOLTS	ALL
DEGREES	ALL
PERCENT	NONE
LOCATION	ALL
ELEVATION	ALL
EXTENT	ALL
UTILITY1	ALL
UTILITY2	ALL
NAME	ALL
EVAL TYPE	ALL
CAL GROUP	ALL
PROBE	ALL
IND. CODES	LPI MAI MCI MMI MSI
	MVI SAI SCI SVI
CHANNELS	ALL

RPC C/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 09:55

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE SIZE
1	1	1	0.26	50	LPI	2 TSC	+0.65	TSCTSC			M1680	reso	21C00178	C	3	600PP
2	68	12	0.17	103	LPI	P5 TSC	+0.38	TSCTSC	0.3		B3720	reso	21C00176	C	3	600PP
3			0.44	58	LPI	2 TSC	+0.38	TSCTSC			M1680	reso	21C00176	C	3	600PP
4	67	13	0.30	57	LPI	2 TSC	+0.12	TSCTSC	0.2		K7060	reso	21C00177	C	3	600PP
5			0.26	75	LPI	1 TSC	+0.15	TSCTSC	0.2		K7060	reso	21C00177	C	3	600PP
6	69	13	0.25	96	LPI	P5 TSC	+0.26	TSCTSC	0.3		B3720	reso	21C00176	C	3	600PP
7			0.45	52	LPI	2 TSC	+0.27	TSCTSC			M1680	reso	21C00176	C	3	600PP
8			0.12	103	LPI	P5 TSC	+0.42	TSCTSC	0.3		B3720	reso	21C00176	C	3	600PP
9			0.30	78	LPI	2 TSC	+0.42	TSCTSC			M1680	reso	21C00176	C	3	600PP
10	1	21	0.43	51	SVI	1 TSC	+0.10	TSCTSC	0.3		A9608	reso	21C00093	C	3	600PP
11			0.27	99	SVI	2 TSC	+0.10	TSCTSC	0.3		A9608	reso	21C00093	C	3	600PP
12	135	65			SVI	1 TSC	+0.19	TSCTSC	0.0		B3720	reso	21C00158	C	3	600PP
13			0.09	82	SVI	2 TSC	+0.19	TSCTSC	0.3		B3720	reso	21C00158	C	3	600PP
14	21	125			SCI	1 TSC	+0.02	TSCTSC	0		R6452	reso	21C00127	C	3	600PP
15			0.05	124	SCI	P1 TSC	+0.02	TSCTSC	0.3		R6452	reso	21C00127	C	3	600PP
16	8	138			SCI	1 TSC	+0.00	TSCTSC	0.0		B3720	reso	21C00115	C	3	600PP
17			0.20	107	SCI	P1 TSC	+0.00	TSCTSC	0.4		B3720	reso	21C00115	C	3	600PP
18	19	153	0.23	82	SVI	1 TSC	+0.09	TSCTSC	0.3		C3340	reso	21C00116	C	3	600PP
19			0.22	86	SVI	P1 TSC	+0.09	TSCTSC	0.3		C3340	reso	21C00116	C	3	600PP

QUERY REPORT SUMMARY:

QUERY PARAMETER		ENTRIES	TUBES
LPI	Indication Code	9	4
MAI	Indication Code	0	0
MCI	Indication Code	0	0
MMI	Indication Code	0	0
MSI	Indication Code	0	0
MVI	Indication Code	0	0
SAI	Indication Code	0	0
SCI	Indication Code	4	2
SVI	Indication Code	6	3

TOTAL ENTRIES: 19

TOTAL TUBES: 9

RPC H/L TTS INDICATIONS

UTILITY:	Baltimore Gas & Electric	May 17,1999 09:56
PLANT:	CCNPP	
UNIT:	2	
SG:	21	
DATABASE:	CCNPP_UNIT2_SG21_0399_Final	

****
* INSPECTION SUMMARY QUERY REPORT *
****

* Test Plans included in summary: 1 Total Test Plans in database: 13 *

Test Plan Name:	Probe Type:	Probe Size:	Leg:
1. 100% TSH (G47-64,73)	MRPC	600HF	HL

****
* EIMS MAIN QUERY PARAMETERS *
****

ROW	ALL
LINE	ALL
VOLTS	ALL
DEGREES	ALL
PERCENT	NONE
LOCATION	ALL
ELEVATION	ALL
EXTENT	ALL
UTILITY1	ALL
UTILITY2	ALL
NAME	ALL
EVAL TYPE	ALL
CAL GROUP	ALL
PROBE	ALL
IND. CODES	LPI MAI MCI MMI MSI
	MVI SAI SCI SVI
CHANNELS	ALL

RPC H/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 09:56

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE	SIZE
1	26	18	0.10	95	SAI	2 TSH	+1.52		TSHTSH	0.2		R6452	reso	21H00109	H	0	600PP	
2					SAI	1 TSH	+1.52		TSHTSH	0		R6452	reso	21H00109	H	0	600PP	
3	22	20	0.17	81	MAI	2 TSH	+0.10		TSHTSH	0.2		R6452	reso	21H00109	H	0	600PP	
4			0.16	84	MAI	1 TSH	+0.10		TSHTSH	0.2		R6452	reso	21H00109	H	0	600PP	
5	24	20	0.14	66	SAI	2 TSH	+0.27		TSHTSH	0.3		S7752	reso	21H00108	H	0	600PP	
6					SAI	1 TSH	+0.27		TSHTSH	0		S7752	reso	21H00108	H	0	600PP	
7	9	21	0.10	79	SAI	2 TSH	+0.45		TSHTSH	0.2		R6452	reso	21H00109	H	0	600PP	
8					SAI	1 TSH	+0.45		TSHTSH	0		R6452	reso	21H00109	H	0	600PP	
9	15	21	0.14	89	SAI	2 TSH	+0.15		TSHTSH	0.2		S7752	reso	21H00108	H	0	600PP	
10					SAI	1 TSH	+0.15		TSHTSH	0		S7752	reso	21H00108	H	0	600PP	
11	14	22	0.11	102	SAI	2 TSH	+0.61		TSHTSH	0.2		R6452	reso	21H00106	H	0	600PP	
12					SAI	1 TSH	+0.61		TSHTSH	0		R6452	reso	21H00106	H	0	600PP	
13	21	23	0.11	95	SAI	2 TSH	+0.72		TSHTSH	0.2		C3340	reso	21H00105	H	0	600PP	
14					SAI	1 TSH	+0.72		TSHTSH	0		C3340	reso	21H00105	H	0	600PP	
15	16	24	0.12	77	SAI	2 TSH	+0.88		TSHTSH	0.3		C3340	reso	21H00103	H	0	600PP	
16					SAI	1 TSH	+0.88		TSHTSH	0		C3340	reso	21H00103	H	0	600PP	
17	22	24	0.14	82	SAI	2 TSH	+0.66		TSHTSH	0.6		T0042	reso	21H00102	H	0	600PP	
18			0.42	110	SAI	1 TSH	+0.66		TSHTSH	0.6		T0042	reso	21H00102	H	0	600PP	
19	24	24	0.19	85	MAI	2 TSH	+0.64		TSHTSH	0.2		C3340	reso	21H00103	H	0	600PP	
20			0.12	83	MAI	1 TSH	+0.64		TSHTSH	0.2		C3340	reso	21H00103	H	0	600PP	
21	36	24	0.14	79	MAI	2 TSH	+0.30	TO+0.67	TSHTSH	0.2		C3340	reso	21H00102	H	0	600PP	
22			0.09	62	MAI	1 TSH	+0.30	TO+0.67	TSHTSH	0.2		C3340	reso	21H00102	H	0	600PP	
23	21	25	0.10	85	SAI	2 TSH	+0.78		TSHTSH	0.4		C3340	reso	21H00103	H	0	600PP	
24					SAI	1 TSH	+0.78		TSHTSH	0		C3340	reso	21H00103	H	0	600PP	
25	34	26	0.22	99	MAI	2 TSH	+0.50	TO+1.07	TSHTSH	0.5		C3340	reso	21H00102	H	0	600PP	
26			0.17	86	MAI	1 TSH	+0.50	TO+1.07	TSHTSH	0.5		C3340	reso	21H00102	H	0	600PP	
27	36	26	0.20	110	MAI	2 TSH	+0.18	TO+0.88	TSHTSH	0.2		C3340	reso	21H00102	H	0	600PP	
28			0.23	82	MAI	1 TSH	+0.18	TO+0.88	TSHTSH	0.3		C3340	reso	21H00102	H	0	600PP	
29	40	26	0.10	124	SAI	2 TSH	+0.63		TSHTSH	0.2		C3340	reso	21H00103	H	0	600PP	
30					SAI	1 TSH	+0.63		TSHTSH	0		C3340	reso	21H00103	H	0	600PP	
31	25	27	0.08	49	SAI	2 TSH	+0.78		TSHTSH	0.3		C3340	reso	21H00102	H	0	600PP	
32					SAI	1 TSH	+0.78		TSHTSH	0		C3340	reso	21H00102	H	0	600PP	
33	47	27	0.12	109	SAI	2 TSH	+0.84		TSHTSH	0.2		C3340	reso	21H00102	H	0	600PP	
34			0.05	116	SAI	1 TSH	+0.84		TSHTSH	0.2		C3340	reso	21H00102	H	0	600PP	
35	48	28	0.21	104	MAI	2 TSH	+0.36		TSHTSH	0.4		C3340	reso	21H00103	H	0	600PP	
36					MAI	1 TSH	+0.36		TSHTSH	0		C3340	reso	21H00103	H	0	600PP	
37	29	29	0.20	115	MAI	2 TSH	+0.43	TO+1.36	TSHTSH	0.6		C3340	reso	21H00102	H	0	600PP	
38			0.15	114	MAI	1 TSH	+0.43	TO+1.36	TSHTSH	0.4		C3340	reso	21H00102	H	0	600PP	
39	53	29	0.20	100	SAI	2 TSH	+0.16		TSHTSH	0.2		C3340	reso	21H00103	H	0	600PP	
40			0.10	90	SAI	1 TSH	+0.16		TSHTSH	0.3		C3340	reso	21H00103	H	0	600PP	
41	25	31	0.12	78	MAI	1 TSH	+1.07		TSHTSH	0.4		C3340	reso	21H00096	H	0	600PP	
42			0.14	94	MAI	2 TSH	+1.07		TSHTSH	0.4		C3340	reso	21H00096	H	0	600PP	
43	10	32	0.16	115	SAI	2 TSH	+1.08		TSHTSH	0.4		M1680	reso	21H00097	H	0	600PP	
44			0.19	82	SAI	1 TSH	+1.08		TSHTSH	0.2		M1680	reso	21H00097	H	0	600PP	
45	56	32	0.19	94	SAI	2 TSH	+0.77		TSHTSH	0.3		S7752	reso	21H00095	H	0	600PP	
46			0.29	86	SAI	1 TSH	+0.77		TSHTSH	0.3		S7752	reso	21H00095	H	0	600PP	
	43	33	0.12	133	SCI	P1 TSH	+0.17		TSHTSH	0.2		A9608	reso	21H00095	H	0	600PP	
48				132	SCI	1 TSH	+0.17		TSHTSH	0		A9608	reso	21H00095	H	0	600PP	
49	55	33	0.10	46	MAI	1 TSH	+0.90		TSHTSH	0.2		A9608	reso	21H00096	H	0	600PP	

RPC H/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 09:56

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE SIZE
50			0.11	111	MAI	2	TSH	+0.90		TSHTSH	0.3		C3340	reso	21H00096	H 0	600PP
51	46	34	0.17	106	MSI	2	TSH	+0.37	TO+1.29	TSHTSH	0.3		S7752	reso	21H00095	H 0	600PP
52					MSI	1	TSH	+0.37	TO+1.29	TSHTSH	0		S7752	reso	21H00095	H 0	600PP
53	48	34	0.18	76	MAI	1	TSH	+0.70		TSHTSH	0.4		C3340	reso	21H00096	H 0	600PP
54			0.12	104	MAI	2	TSH	+0.70		TSHTSH	0.4		C3340	reso	21H00096	H 0	600PP
55	17	35	0.11	52	SAI	2	TSH	+0.29		TSHTSH	0.2		K7060	reso	21H00098	H 0	600PP
56					SAI	1	TSH	+0.29		TSHTSH	0.0		K7060	reso	21H00098	H 0	600PP
57					SAI	1	TSH	+3.16		TSHTSH	0.0		K7060	reso	21H00098	H 0	600PP
58			0.10	94	SAI	2	TSH	+3.16		TSHTSH	0.3		K7060	reso	21H00098	H 0	600PP
59	23	35	0.08	85	MAI	1	TSH	+1.19		TSHTSH	0.3		A9608	reso	21H00096	H 0	600PP
60			0.17	110	MAI	2	TSH	+1.19		TSHTSH	0.2		A9608	reso	21H00096	H 0	600PP
61	25	35	0.14	90	SAI	2	TSH	+1.01		TSHTSH	0.2		A9608	reso	21H00096	H 0	600PP
62					SAI	1	TSH	+1.01		TSHTSH	0		A9608	reso	21H00096	H 0	600PP
63	57	35	0.13	118	SAI	2	TSH	+1.03		TSHTSH	0.2		S7752	reso	21H00095	H 0	600PP
64					SAI	1	TSH	+1.03		TSHTSH	0		S7752	reso	21H00095	H 0	600PP
65	26	36	0.11	114	SAI	2	TSH	+1.40		TSHTSH	0.2		S7752	reso	21H00095	H 0	600PP
66					SAI	1	TSH	+1.40		TSHTSH	0		S7752	reso	21H00095	H 0	600PP
67					SAI	1	TSH	+1.59		TSHTSH	0		S7752	reso	21H00095	H 0	600PP
68			0.10	106	SAI	2	TSH	+1.59		TSHTSH	0.2		S7752	reso	21H00095	H 0	600PP
69	52	36	0.21	78	SAI	2	TSH	+0.88		TSHTSH	0.3		A9608	reso	21H00096	H 0	600PP
7			0.25	119	SAI	1	TSH	+0.88		TSHTSH	0.3		A9608	reso	21H00096	H 0	600PP
7_	66	36	0.09	99	SAI	2	TSH	+1.00		TSHTSH	0.3		S7752	reso	21H00093	H 0	600PP
72			0.15	61	SAI	1	TSH	+1.00		TSHTSH	0.3		S7752	reso	21H00093	H 0	600PP
73	23	37	0.12	64	SAI	2	TSH	+0.82		TSHTSH	0.2		A9608	reso	21H00096	H 0	600PP
74			0.08	126	SAI	1	TSH	+0.82		TSHTSH	0.2		C3340	reso	21H00096	H 0	600PP
75	63	37	0.12	115	MAI	2	TSH	+0.69		TSHTSH	0.2		S7752	reso	21H00093	H 0	600PP
76					MAI	1	TSH	+0.69		TSHTSH	0		S7752	reso	21H00093	H 0	600PP
77	73	37	0.17	102	MAI	2	TSH	+0.33		TSHTSH	0.3		H2131	reso	21H00094	H 0	600PP
78			0.14	71	MAI	1	TSH	+0.33		TSHTSH	0.3		H2131	reso	21H00094	H 0	600PP
79	16	38	0.08	81	SAI	2	TSH	+2.62		TSHTSH	0.2		K7060	reso	21H00098	H 0	600PP
80					SAI	1	TSH	+2.62		TSHTSH	0.0		K7060	reso	21H00098	H 0	600PP
81	54	38	0.14	112	MAI	4	TSH	+0.54	TO+1.01	TSHTSH	0.5		K7060	reso	21H00114	H 0	600HF
82			0.21	40	MAI	3	TSH	+0.54	TO+1.01	TSHTSH	0.3		K7060	reso	21H00114	H 0	600HF
83	53	39	0.06	112	SAI	4	TSH	+0.48		TSHTSH	0.2		K7060	reso	21H00114	H 0	600HF
84					SAI	3	TSH	+0.48		TSHTSH	0.0		K7060	reso	21H00114	H 0	600HF
85	55	39	0.18	88	SAI	2	TSH	+0.61		TSHTSH	0.3		C3340	reso	21H00096	H 0	600PP
86			0.13	18	SAI	1	TSH	+0.61		TSHTSH	0.2		A9608	reso	21H00096	H 0	600PP
87	71	39	0.09	107	SAI	2	TSH	+0.55		TSHTSH	0.3		S7752	reso	21H00093	H 0	600PP
88					SAI	1	TSH	+0.55		TSHTSH	0		S7752	reso	21H00093	H 0	600PP
89	22	40	0.20	78	SAI	2	TSH	+0.22		TSHTSH	0.2		A9608	reso	21H00096	H 0	600PP
90			0.06	158	SAI	1	TSH	+0.22		TSHTSH	0.2		C3340	reso	21H00096	H 0	600PP
91	58	40	0.22	100	SAI	4	TSH	+0.94		TSHTSH	0.2		K7060	reso	21H00114	H 0	600HF
92					SAI	3	TSH	+0.94		TSHTSH	0.0		K7060	reso	21H00114	H 0	600HF
93	17	41	0.13	76	SAI	2	TSH	+0.49		TSHTSH	0.2		K7060	reso	21H00098	H 0	600PP
94					SAI	1	TSH	+0.49		TSHTSH	0.0		K7060	reso	21H00098	H 0	600PP
95	21	41	0.21	72	SAI	2	TSH	+0.28		TSHTSH	0.2		A9608	reso	21H00096	H 0	600PP
			0.18	136	SAI	1	TSH	+0.28		TSHTSH	0.2		C3340	reso	21H00096	H 0	600PP
97	65	41	0.12	84	MAI	2	TSH	+0.99		TSHTSH	0.2		H2131	reso	21H00094	H 0	600PP
98					MAI	1	TSH	+0.99		TSHTSH	0		H2131	reso	21H00094	H 0	600PP

RPC H/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 09:56

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
99	71	41	0.10	82	SAI	2 TSH	+0.83		TSHTSH	0.2		H2131	resc	21H00094	H 0	600PP
100			0.14	75	SAI	1 TSH	+0.83		TSHTSH	0.2		H2131	resc	21H00094	H 0	600PP
101	58	42	0.13	104	MAI	4 TSH	+0.00	TO+1.82	TSHTSH	0.4		K7060	resc	21H00114	H 0	600HF
102					MAI	3 TSH	+0.00	TO+1.82	TSHTSH	0.0		K7060	resc	21H00114	H 0	600HF
103	64	42	0.14	99	SAI	2 TSH	+0.95		TSHTSH	0.2		S7752	resc	21H00093	H 0	600PP
104					SAI	1 TSH	+0.95		TSHTSH	0		S7752	resc	21H00093	H 0	600PP
105	25	43	0.17	82	SAI	2 TSH	+0.54		TSHTSH	0.3		S7752	resc	21H00095	H 0	600PP
106					SAI	1 TSH	+0.54		TSHTSH	0		S7752	resc	21H00095	H 0	600PP
107	26	44	0.27	98	MAI	2 TSH	+0.50		TSHTSH	0.4		A9608	resc	21H00096	H 0	600PP
108			0.40	100	MAI	1 TSH	+0.50		TSHTSH	0.3		A9608	resc	21H00096	H 0	600PP
109	72	44	0.12	101	MAI	2 TSH	+0.77		TSHTSH	0.3		H2131	resc	21H00094	H 0	600PP
110					MAI	1 TSH	+0.77		TSHTSH	0		H2131	resc	21H00094	H 0	600PP
111	82	44	0.28	99	MAI	2 TSH	+0.52		TSHTSH	0.4		H2131	resc	21H00094	H 0	600PP
112			0.25	102	MAI	1 TSH	+0.52		TSHTSH	0.3		H2131	resc	21H00094	H 0	600PP
113	21	45	0.16	106	MAI	2 TSH	+0.13	TO+0.71	TSHTSH	0.2		A9608	resc	21H00096	H 0	600PP
114					MAI	2 TSH	+0.13	TO+0.71	TSHTSH	0		A9608	resc	21H00096	H 0	600PP
115	25	45	0.07	112	MAI	2 TSH	+0.46		TSHTSH	0.2		A9608	resc	21H00096	H 0	600PP
116					MAI	1 TSH	+0.46		TSHTSH	0		A9608	resc	21H00096	H 0	600PP
117	81	45	0.44	102	MAI	2 TSH	+0.50		TSHTSH	0.5		H2131	resc	21H00094	H 0	600PP
118			0.78	109	MAI	1 TSH	+0.50		TSHTSH	0.4		H2131	resc	21H00094	H 0	600PP
1	22	46	0.16	101	SCI	P1 TSH	+0.07		TSHTSH	0.2		A9608	resc	21H00096	H 0	600PP
1			0.12	48	SCI	1 TSH	+0.07		TSHTSH	0.3		C3340	resc	21H00096	H 0	600PP
121	36	46	0.09	81	SCI	P1 TSH	+0.15		TSHTSH	0.3		D3858	resc	21H00096	H 0	600PP
122					SCI	1 TSH	+0.15		TSHTSH	0.0		D3858	resc	21H00096	H 0	600PP
123	68	46	0.15	97	SAI	2 TSH	+0.58		TSHTSH	0.3		S7752	resc	21H00093	H 0	600PP
124					SAI	1 TSH	+0.58		TSHTSH	0		S7752	resc	21H00093	H 0	600PP
125	15	47	0.16	104	MAI	2 TSH	+0.11	TO+0.50	TSHTSH	0.2		M1680	resc	21H00097	H 0	600PP
126					MAI	1 TSH	+0.11	TO+0.50	TSHTSH	0.0		M1680	resc	21H00097	H 0	600PP
127	70	48	0.13	94	SAI	2 TSH	+0.80		TSHTSH	0.4		H2131	resc	21H00094	H 0	600PP
128					SAI	1 TSH	+0.80		TSHTSH	0		H2131	resc	21H00094	H 0	600PP
129	76	48	0.11	90	SAI	2 TSH	+0.77		TSHTSH	0.2		A9608	resc	21H00093	H 0	600PP
130					SAI	1 TSH	+0.77		TSHTSH	0		A9608	resc	21H00093	H 0	600PP
131	82	48	0.13	91	MAI	2 TSH	+0.72		TSHTSH	0.5		H2131	resc	21H00094	H 0	600PP
132			0.17	42	MAI	1 TSH	+0.72		TSHTSH	0.5		H2131	resc	21H00094	H 0	600PP
133	84	48	0.15	97	MAI	2 TSH	+0.83		TSHTSH	0.3		S7752	resc	21H00093	H 0	600PP
134					MAI	1 TSH	+0.83		TSHTSH	0		S7752	resc	21H00093	H 0	600PP
135	18	50	0.12	113	SCI	P1 TSH	+0.05		TSHTSH	0.2		M1680	resc	21H00098	H 0	600PP
136					SCI	1 TSH	+0.05		TSHTSH	0.0		M1680	resc	21H00098	H 0	600PP
137	19	51	0.09	86	MAI	2 TSH	+0.30	TO+0.60	TSHTSH	0.1		M1680	resc	21H00097	H 0	600PP
138					MAI	1 TSH	+0.30	TO+0.60	TSHTSH	0.0		M1680	resc	21H00097	H 0	600PP
139	21	51	0.20	104	MAI	2 TSH	+0.43		TSHTSH	0.3		M1680	resc	21H00004	H 0	600PP
140			0.20	123	MAI	1 TSH	+0.43		TSHTSH	0.3		M1680	resc	21H00004	H 0	600PP
141	18	52	0.14	75	SAI	2 TSH	+0.32		TSHTSH	0.2		K7060	resc	21H00098	H 0	600PP
142					SAI	1 TSH	+0.32		TSHTSH	0.0		K7060	resc	21H00098	H 0	600PP
143			0.18	83	SAI	2 TSH	+0.90		TSHTSH	0.2		K7060	resc	21H00098	H 0	600PP
144					SAI	1 TSH	+0.90		TSHTSH	0.0		K7060	resc	21H00098	H 0	600PP
	5	53	0.20	92	SAI	2 TSH	+0.64		TSHTSH	0.4		K7060	resc	21H00098	H 0	600PP
146			0.22	51	SAI	1 TSH	+0.64		TSHTSH	0.4		K7060	resc	21H00098	H 0	600PP
147	21	53	0.50	81	MAI	2 TSH	+0.56		TSHTSH	0.7		M1680	resc	21H00004	H 0	600PP

RPC H/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 09:56

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE SIZE
148			0.90	79	MAI	1	TSH	+0.56		TSHTSH	0.6		M1680	reso	21H00004	H 0	600PP
149	75	53	0.13	111	SAI	2	TSH	+0.94		TSHTSH	0.2		K7060	reso	21H00045	H 0	600PP
150					SAI	1	TSH	+0.94		TSHTSH	0.0		K7060	reso	21H00045	H 0	600PP
151	18	54	0.18	99	MAI	2	TSH	+0.15	TO+1.05	TSHTSH	0.3		K7060	reso	21H00098	H 0	600PP
152			0.14	32	MAI	1	TSH	+0.15	TO+1.05	TSHTSH	0.4		K7060	reso	21H00098	H 0	600PP
153	84	54	0.11	116	SAI	2	TSH	+0.87		TSHTSH	0.2		K7060	reso	21H00045	H 0	600PP
154					SAI	1	TSH	+0.87		TSHTSH	0.0		K7060	reso	21H00045	H 0	600PP
155	17	55	0.35	80	MAI	2	TSH	+0.14	TO+0.78	TSHTSH	0.3		M1680	reso	21H00097	H 0	600PP
156			0.35	73	MAI	1	TSH	+0.14	TO+0.78	TSHTSH	0.4		M1680	reso	21H00097	H 0	600PP
157	21	55	0.17	79	SAI	2	TSH	+0.34		TSHTSH	0.2		M1680	reso	21H00004	H 0	600PP
158					SAI	1	TSH	+0.34		TSHTSH	0.0		M1680	reso	21H00004	H 0	600PP
159			0.33	94	SAI	2	TSH	+0.59		TSHTSH	0.2		M1680	reso	21H00004	H 0	600PP
160			0.56	53	SAI	1	TSH	+0.59		TSHTSH	0.2		M1680	reso	21H00004	H 0	600PP
161	8	56	0.12	92	SAI	2	TSH	+1.80		TSHTSH	0.2		K7060	reso	21H00098	H 0	600PP
162					SAI	1	TSH	+1.80		TSHTSH	0.0		K7060	reso	21H00098	H 0	600PP
163	15	57	0.26	79	MAI	2	TSH	+0.08	TO+0.45	TSHTSH	0.3		M1680	reso	21H00097	H 0	600PP
164			0.26	38	MAI	1	TSH	+0.08	TO+0.45	TSHTSH	0.2		M1680	reso	21H00097	H 0	600PP
165	7	59	0.44	104	SAI	2	TSH	+2.87		TSHTSH	0.4		C3340	reso	21H00097	H 0	600PP
166			0.60	89	SAI	1	TSH	+2.87		TSHTSH	0.4		C3340	reso	21H00097	H 0	600PP
167	50	60	0.12	114	SAI	2	TSH	+1.30		TSHTSH	0.3		R6452	reso	21H00006	H 0	600PP
1					SAI	1	TSH	+1.30		TSHTSH	0.0		R6452	reso	21H00006	H 0	600PP
1	86	60	0.16	74	SAI	2	TSH	+0.54		TSHTSH	0.2		S7752	reso	21H00042	H 0	600PP
170					SAI	1	TSH	+0.54		TSHTSH	0		A9608	reso	21H00042	H 0	600PP
171	94	60	0.14	81	SAI	2	TSH	+0.57		TSHTSH	0.2		S7752	reso	21H00042	H 0	600PP
172					SAI	1	TSH	+0.57		TSHTSH	0		A9608	reso	21H00042	H 0	600PP
173	25	63	0.08	119	SCI	P1	TSH	-0.05		TSHTSH	0.3		R6452	reso	21H00006	H 0	600PP
174					SCI	1	TSH	-0.05		TSHTSH	0.0		R6452	reso	21H00006	H 0	600PP
175	90	64	0.23	84	MAI	2	TSH	+0.60	TO+1.16	TSHTSH	0.4		A9608	reso	21H00039	H 0	600PP
176			0.20	34	MAI	1	TSH	+0.60	TO+1.16	TSHTSH	0.3		A9608	reso	21H00039	H 0	600PP
177	26	66	0.76	26	SAI	2	TEH	-0.05		TEHTEH	0.2		T0042	reso	21H00005	H 0	600PP
178			0.98	9	SAI	1	TEH	-0.05		TEHTEH	0.2	PWSCC	D3858	reso	21H00005	H 0	600PP
179			0.58	23	SAI	2	TEH	+1.95		TEHTEH	0.2		T0042	reso	21H00005	H 0	600PP
180			0.28	10	SAI	1	TEH	+1.95		TEHTEH	0.4	PWSCC	D3858	reso	21H00005	H 0	600PP
181			0.61	29	SCI	P1	TEH	+16.38		TEHTEH	0.2		T0042	reso	21H00005	H 0	600PP
182			0.40	14	SCI	1	TEH	+16.38		TEHTEH	0.3	PWSCC	D3858	reso	21H00005	H 0	600PP
183	84	66	0.16	83	SAI	2	TSH	+0.55		TSHTSH	0.3		S7752	reso	21H00040	H 0	600PP
184					SAI	1	TSH	+0.55		TSHTSH	0		A9608	reso	21H00040	H 0	600PP
185	25	67	2.51	35	SAI	2	TEH	+0.26		TEHTEH	0.2		R6452	reso	21H00006	H 0	600PP
186			1.05	13	SAI	1	TEH	+0.26		TEHTEH	0.4	PWSCC	D3858	reso	21H00006	H 0	600PP
187	91	67	0.15	82	SAI	2	TSH	+0.99		TSHTSH	0.3		S7752	reso	21H00039	H 0	600PP
188			0.18	95	SAI	1	TSH	+0.99		TSHTSH	0.4		S7752	reso	21H00039	H 0	600PP
189	88	70	0.10	120	SCI	P1	TSH	+0.16		TSHTSH	0.3		S7752	reso	21H00040	H 0	600PP
190					SCI	1	TSH	+0.16		TSHTSH	0		A9608	reso	21H00040	H 0	600PP
191	100	70	0.13	106	SAI	2	TSH	+0.71		TSHTSH	0.2		S7752	reso	21H00040	H 0	600PP
192					SAI	1	TSH	+0.71		TSHTSH	0		A9608	reso	21H00040	H 0	600PP
193	88	74	0.11	84	MAI	2	TSH	+0.80	TO+1.19	TSHTSH	0.2		A9608	reso	21H00038	H 0	600PP
					MAI	1	TSH	+0.80	TO+1.19	TSHTSH	0.0		A9608	reso	21H00038	H 0	600PP
195	39	75	0.08	117	SAI	2	TSH	+0.71		TSHTSH	0.1		K7060	reso	21H00046	H 0	600PP
196					SAI	1	TSH	+0.71		TSHTSH	0.0		K7060	reso	21H00046	H 0	600PP

RPC H/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 09:56

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
197	97	75	0.09	89	SAI	2	TSH	+0.60		TSHTSH	0.4		R6452	reso	21H00038	H 0 600PP
198					SAI	1	TSH	+0.60		TSHTSH	0.0		R6452	reso	21H00038	H 0 600PP
199	72	76	0.09	98	SAI	2	TSH	+5.68		TSHTSH	0.4		R6452	reso	21H00038	H 0 600PP
200					SAI	1	TSH	+5.68		TSHTSH	0.0		R6452	reso	21H00038	H 0 600PP
201	88	76	0.29	95	SAI	2	TSH	+0.99		TSHTSH	0.5		R6452	reso	21H00038	H 0 600PP
202			0.49	81	SAI	1	TSH	+0.99		TSHTSH	0.4		R6452	reso	21H00038	H 0 600PP
203	80	78	0.09	133	SAI	2	TSH	+0.99		TSHTSH	0.2		R6452	reso	21H00038	H 0 600PP
204					SAI	1	TSH	+0.99		TSHTSH	0.0		R6452	reso	21H00038	H 0 600PP
205	98	78	0.08	117	SAI	2	TSH	+0.58		TSHTSH	0.2		R6452	reso	21H00038	H 0 600PP
206					SAI	1	TSH	+0.58		TSHTSH	0.0		R6452	reso	21H00038	H 0 600PP
207	106	80	0.18	31	SCI	P1	TSH	-0.17		TSHTSH	0.3	PWSCC	A9608	reso	21H00037	H 0 600PP
208					SCI	1	TSH	-0.17		TSHTSH	0.0	PWSCC	A9608	reso	21H00037	H 0 600PP
209	42	84	0.12	115	SAI	2	TSH	+1.58		TSHTSH	0.2		K7060	reso	21H00046	H 0 600PP
210					SAI	1	TSH	+1.58		TSHTSH	0.0		K7060	reso	21H00046	H 0 600PP
211	80	84	0.09	73	SAI	2	TSH	+0.46		TSHTSH	0.2		R6452	reso	21H00035	H 0 600PP
212					SAI	1	TSH	+0.46		TSHTSH	0.0		R6452	reso	21H00035	H 0 600PP
213	42	86	0.14	107	SAI	2	TSH	+1.42		TSHTSH	0.2		K7060	reso	21H00048	H 0 600PP
214					SAI	1	TSH	+1.42		TSHTSH	0.0		K7060	reso	21H00048	H 0 600PP
215	81	87	0.06	80	SAI	2	TSH	+0.55		TSHTSH	0.3		K7060	reso	21H00036	H 0 600PP
216					SAI	1	TSH	+0.55		TSHTSH	0.0		K7060	reso	21H00036	H 0 600PP
2	81	89	0.07	99	SAI	2	TSH	+0.66		TSHTSH	0.2		K7060	reso	21H00036	H 0 600PP
2					SAI	1	TSH	+0.66		TSHTSH	0.0		K7060	reso	21H00036	H 0 600PP
219	93	89	0.14	99	SAI	2	TSH	+0.49		TSHTSH	0.2		K7060	reso	21H00036	H 0 600PP
220					SAI	1	TSH	+0.49		TSHTSH	0.0		K7060	reso	21H00036	H 0 600PP
221	82	90	0.09	126	MAI	2	TSH	+0.63	TO+1.02	TSHTSH	0.3		K7060	reso	21H00036	H 0 600PP
222					MAI	1	TSH	+0.63	TO+1.02	TSHTSH	0.0		K7060	reso	21H00036	H 0 600PP
223	75	93	0.28	92	SAI	2	TSH	+5.45		TSHTSH	0.2		K7060	reso	21H00033	H 0 600PP
224			0.22	114	SAI	1	TSH	+5.45		TSHTSH	0.3		K7060	reso	21H00033	H 0 600PP
225	69	95	0.12	119	SCI	P1	TSH	+0.30		TSHTSH	0.2		K7060	reso	21H00033	H 0 600PP
226					SCI	1	TSH	+0.30		TSHTSH	0.0		K7060	reso	21H00033	H 0 600PP
227	93	97	0.11	92	SAI	2	TSH	+0.96		TSHTSH	0.2		K7060	reso	21H00031	H 0 600PP
228					SAI	1	TSH	+0.96		TSHTSH	0.0		K7060	reso	21H00031	H 0 600PP
229	98	98	0.14	111	SAI	2	TSH	+0.89		TSHTSH	0.2		K7060	reso	21H00032	H 0 600PP
230					SAI	1	TSH	+0.89		TSHTSH	0.0		K7060	reso	21H00032	H 0 600PP
231	87	99	0.19	88	SAI	2	TSH	+1.49		TSHTSH	0.2		K7060	reso	21H00032	H 0 600PP
232					SAI	1	TSH	+1.49		TSHTSH	0.0		K7060	reso	21H00032	H 0 600PP
233	62	102	0.09	123	SCI	P1	TSH	+0.16		TSHTSH	0.2		K7060	reso	21H00031	H 0 600PP
234					SCI	1	TSH	+0.16		TSHTSH	0.0		K7060	reso	21H00031	H 0 600PP
235	80	102	0.10	76	SAI	1	TSH	+2.25		TSHTSH	0.1		B3720	reso	21H00031	H 0 600PP
236			0.16	113	SAI	2	TSH	+2.25		TSHTSH	0.1		K7060	reso	21H00031	H 0 600PP
237	88	102	0.07	84	SAI	2	TSH	+0.47		TSHTSH	0.2		K7060	reso	21H00031	H 0 600PP
238					SAI	1	TSH	+0.47		TSHTSH	0.0		K7060	reso	21H00031	H 0 600PP
239			0.10	112	SAI	2	TSH	+1.02		TSHTSH	0.2		K7060	reso	21H00031	H 0 600PP
240					SAI	1	TSH	+1.02		TSHTSH	0.0		K7060	reso	21H00031	H 0 600PP
241	45	103	0.12	99	SAI	2	TSH	+4.20		TSHTSH	0.1		B3720	reso	21H00154	H 0 600PP
242			0.16	70	SAI	1	TSH	+4.20		TSHTSH	0.2		B3720	reso	21H00154	H 0 600PP
	86	104	0.12	95	SAI	2	TSH	+0.59		TSHTSH	0.2		K7060	reso	21H00033	H 0 600PP
244					SAI	1	TSH	+0.59		TSHTSH	0.0		K7060	reso	21H00033	H 0 600PP
245	80	106	0.34	75	SAI	1	TSH	+0.32		TSHTSH	0.4		H2131	reso	21H00034	H 0 600PP

RPC H/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 09:56

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE SIZE
246			0.28	100	SAI	2	TSH	+0.32		TSHTSH	0.3		K7060	reso	21H00034	H 0	600PP
247	75	107	0.13	72	SAI	2	TSH	+2.15		TSHTSH	0.2		K7060	reso	21H00034	H 0	600PP
248					SAI	1	TSH	+2.15		TSHTSH	0.0		K7060	reso	21H00034	H 0	600PP
249	15	109	0.12	100	SAI	2	TSH	+1.02		TSHTSH	0.3		H2131	reso	21H00020	H 0	600PP
250			0.31	45	SAI	1	TSH	+1.02		TSHTSH	0.3		H2131	reso	21H00020	H 0	600PP
251	10	110	0.15	91	SAI	2	TSH	+1.78		TSHTSH	0.2		A9608	reso	21H00021	H 0	600PP
252					SAI	1	TSH	+1.78		TSHTSH	0.0		A9608	reso	21H00021	H 0	600PP
253	80	110	0.11	109	SAI	2	TSH	+0.40		TSHTSH	0.1		K7060	reso	21H00033	H 0	600PP
254					SAI	1	TSH	+0.40		TSHTSH	0.0		K7060	reso	21H00033	H 0	600PP
255	17	111	0.17	99	SAI	2	TSH	+0.59		TSHTSH	0.5		R6452	reso	21H00021	H 0	600PP
256					SAI	1	TSH	+0.59		TSHTSH	0.0		R6452	reso	21H00021	H 0	600PP
257					SAI	1	TSH	+0.87		TSHTSH	0.0		A9608	reso	21H00021	H 0	600PP
258			0.10	82	SAI	2	TSH	+0.87		TSHTSH	0.2		A9608	reso	21H00021	H 0	600PP
259	79	111	0.19	92	MAI	2	TSH	+0.42	TO+0.85	TSHTSH	0.2		K7060	reso	21H00029	H 0	600PP
260					MAI	1	TSH	+0.42	TO+0.85	TSHTSH	0.0		K7060	reso	21H00029	H 0	600PP
261	20	112	0.12	85	SAI	2	TSH	+0.34		TSHTSH	0.2		H2131	reso	21H00020	H 0	600PP
262					SAI	1	TSH	+0.34		TSHTSH	0.0		A9608	reso	21H00020	H 0	600PP
263					SAI	1	TSH	+0.71		TSHTSH	0.0		A9608	reso	21H00020	H 0	600PP
264			0.12	92	SAI	2	TSH	+0.71		TSHTSH	0.2		H2131	reso	21H00020	H 0	600PP
265	26	112	0.28	28	SCI	P1	TSH	-2.75		TSHTSH	0.2		B3720	reso	21H00154	H 0	600PP
2			0.08	63	SCI	1	TSH	-2.75		TSHTSH	0.2		B3720	reso	21H00154	H 0	600PP
2	80	112	0.09	76	SAI	2	TSH	+0.69		TSHTSH	0.3		K7060	reso	21H00029	H 0	600PP
268					SAI	1	TSH	+0.69		TSHTSH	0.0		K7060	reso	21H00029	H 0	600PP
269	86	112	0.15	98	SAI	2	TSH	+0.55		TSHTSH	0.2		K7060	reso	21H00030	H 0	600PP
270			0.16	125	SAI	1	TSH	+0.55		TSHTSH	0.2		K7060	reso	21H00030	H 0	600PP
271	19	113	0.19	72	MAI	2	TSH	+0.52		TSHTSH	0.2		H2131	reso	21H00020	H 0	600PP
272					MAI	1	TSH	+0.52		TSHTSH	0.0		A9608	reso	21H00020	H 0	600PP
273	25	113	0.16	105	SCI	P1	TSH	+0.07		TSHTSH	0.2		B3720	reso	21H00154	H 0	600PP
274					SCI	1	TSH	+0.07		TSHTSH	0.0		B3720	reso	21H00154	H 0	600PP
275	79	113	0.15	97	MAI	2	TSH	+0.34	TO+0.83	TSHTSH	0.5		K7060	reso	21H00029	H 0	600PP
276					MAI	1	TSH	+0.34	TO+0.83	TSHTSH	0.0		K7060	reso	21H00029	H 0	600PP
277	81	113	0.12	100	SAI	2	TSH	+0.90		TSHTSH	0.2		K7060	reso	21H00030	H 0	600PP
278					SAI	1	TSH	+0.90		TSHTSH	0.0		K7060	reso	21H00030	H 0	600PP
279	85	113	0.16	53	SAI	2	TSH	+0.71		TSHTSH	0.2		K7060	reso	21H00030	H 0	600PP
280					SAI	1	TSH	+0.71		TSHTSH	0.0		K7060	reso	21H00030	H 0	600PP
281	89	113	0.14	99	MAI	2	TSH	+1.15	TO+1.44	TSHTSH	0.2		K7060	reso	21H00030	H 0	600PP
282					MAI	1	TSH	+1.15	TO+1.44	TSHTSH	0.0		K7060	reso	21H00030	H 0	600PP
283	10	114	0.08	72	SAI	2	TSH	+0.47		TSHTSH	0.2		A9608	reso	21H00021	H 0	600PP
284					SAI	1	TSH	+0.47		TSHTSH	0.0		A9608	reso	21H00021	H 0	600PP
285	14	114	0.11	83	SAI	2	TSH	+0.18		TSHTSH	0.2		A9608	reso	21H00021	H 0	600PP
286					SAI	1	TSH	+0.18		TSHTSH	0.0		A9608	reso	21H00021	H 0	600PP
287			0.18	80	SAI	2	TSH	+0.70		TSHTSH	0.2		R6452	reso	21H00021	H 0	600PP
288					SAI	1	TSH	+0.70		TSHTSH	0.0		R6452	reso	21H00021	H 0	600PP
289					SAI	1	TSH	+0.98		TSHTSH	0.0		A9608	reso	21H00021	H 0	600PP
290			0.10	90	SAI	2	TSH	+0.98		TSHTSH	0.2		A9608	reso	21H00021	H 0	600PP
291	16	114	0.12	68	SAI	2	TSH	+0.29		TSHTSH	0.3		H2131	reso	21H00020	H 0	600PP
					SAI	1	TSH	+0.29		TSHTSH	0.0		A9608	reso	21H00020	H 0	600PP
293	20	114	0.16	89	MAI	2	TSH	+0.37		TSHTSH	0.3		H2131	reso	21H00020	H 0	600PP
294					MAI	1	TSH	+0.37		TSHTSH	0.0		A9608	reso	21H00020	H 0	600PP

RPC H/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 09:56

	ROW	LIN	VOLTS	DEG	PCT	CHN		LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE SIZE
295	89	115	0.11	97	SAI	2	TSH	+0.25		TSHTSH	0.2		K7060	reso	21H00030	H	0	600PP
296					SAI	1	TSH	+0.25		TSHTSH	0.0		K7060	reso	21H00030	H	0	600PP
297			0.09	75	MAI	2	TSH	+0.53	TO+0.70	TSHTSH	0.2		K7060	reso	21H00030	H	0	600PP
298					MAI	1	TSH	+0.53	TO+0.70	TSHTSH	0.0		K7060	reso	21H00030	H	0	600PP
299	76	116	0.13	100	SAI	2	TSH	+1.02		TSHTSH	0.2		K7060	reso	21H00030	H	0	600PP
300					SAI	1	TSH	+1.02		TSHTSH	0.0		K7060	reso	21H00030	H	0	600PP
301	88	116	0.12	102	SAI	2	TSH	+0.94		TSHTSH	0.2		K7060	reso	21H00030	H	0	600PP
302					SAI	1	TSH	+0.94		TSHTSH	0.0		K7060	reso	21H00030	H	0	600PP
303	76	118	0.13	105	SAI	2	TSH	+1.28		TSHTSH	0.2		K7060	reso	21H00030	H	0	600PP
304					SAI	1	TSH	+1.28		TSHTSH	0.0		K7060	reso	21H00030	H	0	600PP
305	46	120	0.10	83	SAI	2	TSH	+4.80		TSHTSH	0.2		B3720	reso	21H00156	H	0	600PP
306					SAI	1	TSH	+4.80		TSHTSH	0.0		B3720	reso	21H00156	H	0	600PP
307	66	120	0.20	105	SAI	2	TSH	+1.68		TSHTSH	0.2		K7060	reso	21H00030	H	0	600PP
308			0.19	99	SAI	1	TSH	+1.68		TSHTSH	0.3		K7060	reso	21H00030	H	0	600PP
309	63	121	0.18	113	SAI	2	TSH	+0.81		TSHTSH	0.3		K7060	reso	21H00030	H	0	600PP
310			0.25	85	SAI	1	TSH	+0.81		TSHTSH	0.3		K7060	reso	21H00030	H	0	600PP
311	73	121	0.10	103	MAI	2	TSH	+0.67	TO+0.98	TSHTSH	0.3		K7060	reso	21H00029	H	0	600PP
312					MAI	1	TSH	+0.67	TO+0.98	TSHTSH	0.0		K7060	reso	21H00029	H	0	600PP
313	85	121	0.15	101	SAI	2	TSH	+1.30		TSHTSH	0.4		K7060	reso	21H00029	H	0	600PP
314					SAI	1	TSH	+1.30		TSHTSH	0.0		K7060	reso	21H00029	H	0	600PP
3	89	121	0.11	82	SAI	2	TSH	+0.60		TSHTSH	0.3		K7060	reso	21H00030	H	0	600PP
3.					SAI	1	TSH	+0.60		TSHTSH	0.0		K7060	reso	21H00030	H	0	600PP
317	72	122	0.11	105	SAI	2	TSH	+0.92		TSHTSH	0.2		K7060	reso	21H00030	H	0	600PP
318					SAI	1	TSH	+0.92		TSHTSH	0.0		K7060	reso	21H00030	H	0	600PP
319	59	123	0.16	95	MAI	2	TSH	+0.80		TSHTSH	0.5		B3720	reso	21H00028	H	0	600PP
320			0.22	33	MAI	1	TSH	+0.80		TSHTSH	0.3		B3720	reso	21H00028	H	0	600PP
321	69	123	0.08	113	MAI	2	TSH	+0.95		TSHTSH	0.5		R6452	reso	21H00023	H	0	600PP
322			0.23	88	MAI	1	TSH	+0.95		TSHTSH	0.7		R6452	reso	21H00023	H	0	600PP
323					SAI	1	TSH	+1.67		TSHTSH	0.0		R6452	reso	21H00023	H	0	600PP
324			0.08	91	SAI	2	TSH	+1.67		TSHTSH	0.2		B3720	reso	21H00023	H	0	600PP
325	26	124	0.17	95	SAI	2	TSH	+0.74		TSHTSH	0.5		B3720	reso	21H00028	H	0	600PP
326					SAI	1	TSH	+0.74		TSHTSH	0.0		B3720	reso	21H00028	H	0	600PP
327	61	125	0.08	87	SAI	2	TSH	+1.26		TSHTSH	0.2		R6452	reso	21H00024	H	0	600PP
328					SAI	1	TSH	+1.26		TSHTSH	0.0		R6452	reso	21H00024	H	0	600PP
329	65	125	0.16	105	MAI	2	TSH	+0.65		TSHTSH	0.3		R6452	reso	21H00024	H	0	600PP
330			0.15	108	MAI	1	TSH	+0.65		TSHTSH	0.2		R6452	reso	21H00024	H	0	600PP
331			0.15	103	MAI	1	TSH	+0.91		TSHTSH	0.3		R6452	reso	21H00024	H	0	600PP
332			0.16	106	MAI	2	TSH	+0.91		TSHTSH	0.2		R6452	reso	21H00024	H	0	600PP
333			0.03	18	MAI	1	TSH	+1.23	TO+1.58	TSHTSH	0.4		A9608	reso	21H00024	H	0	600PP
334			0.12	104	MAI	2	TSH	+1.23	TO+1.58	TSHTSH	0.4		A9608	reso	21H00024	H	0	600PP
335	6	126	0.16	106	SCI	P1	TSH	-0.07		TSHTSH	0.6		R6452	reso	21H00021	H	0	600PP
336					SCI	1	TSH	-0.07		TSHTSH	0.0		R6452	reso	21H00021	H	0	600PP
337	52	126	0.18	97	SAI	2	TSH	+0.68		TSHTSH	0.3		B3720	reso	21H00028	H	0	600PP
338			0.16	65	SAI	1	TSH	+0.68		TSHTSH	0.3		B3720	reso	21H00028	H	0	600PP
339	54	126	0.16	117	MAI	2	TSH	+0.67	TO+1.06	TSHTSH	0.4		K7060	reso	21H00027	H	0	600PP
340			0.21	74	MAI	1	TSH	+0.67	TO+1.06	TSHTSH	0.4		K7060	reso	21H00027	H	0	600PP
	56	126	0.14	101	MAI	2	TSH	+0.49	TO+1.38	TSHTSH	0.4		B3720	reso	21H00028	H	0	600PP
342			0.25	35	MAI	1	TSH	+0.49	TO+1.38	TSHTSH	0.3		B3720	reso	21H00028	H	0	600PP
343	76	126	0.08	104	SAI	2	TSH	+1.21		TSHTSH	0.2		R6452	reso	21H00024	H	0	600PP

RPC H/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 09:56

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE SIZE
344					SAI	1	TSH	+1.21		TSHTSH	0.0		R6452	resc	21H00024	H 0	600PP
345	82	126	0.07	122	SAI	2	TSH	+0.52		TSHTSH	0.2		R6452	resc	21H00023	H 0	600PP
346					SAI	1	TSH	+0.52		TSHTSH	0.0		R6452	resc	21H00023	H 0	600PP
347	37	127	0.15	25	SAI	2	TSH	-0.08		TSHTSH	0.2	PWSCC	B3720	resc	21H00028	H 0	600PP
348			0.80	17	SAI	1	TSH	-0.08		TSHTSH	0.3	PWSCC	B3720	resc	21H00028	H 0	600PP
349	51	127	0.43	91	MAI	2	TSH	+0.27	TO+0.94	TSHTSH	0.5		B3720	resc	21H00028	H 0	600PP
350			0.45	90	MAI	1	TSH	+0.27	TO+0.94	TSHTSH	0.4		B3720	resc	21H00028	H 0	600PP
351	55	127	0.23	81	MAI	2	TSH	+0.75		TSHTSH	0.5		B3720	resc	21H00028	H 0	600PP
352			0.27	108	MAI	1	TSH	+0.75		TSHTSH	0.4		B3720	resc	21H00028	H 0	600PP
353	67	127	0.09	112	SAI	2	TSH	+0.98		TSHTSH	0.3		R6452	resc	21H00024	H 0	600PP
354					SAI	1	TSH	+0.98		TSHTSH	0.0		R6452	resc	21H00024	H 0	600PP
355	73	127	0.15	113	SAI	2	TSH	+1.14		TSHTSH	0.3		R6452	resc	21H00023	H 0	600PP
356			0.27	52	SAI	1	TSH	+1.14		TSHTSH	0.3		R6452	resc	21H00023	H 0	600PP
357	52	128	0.22	97	MAI	2	TSH	+0.55	TO+1.07	TSHTSH	0.4		B3720	resc	21H00028	H 0	600PP
358			0.22	114	MAI	1	TSH	+0.55	TO+1.07	TSHTSH	0.4		B3720	resc	21H00028	H 0	600PP
359	60	128	0.25	91	MAI	2	TSH	+0.52	TO+1.05	TSHTSH	0.4		K7060	resc	21H00027	H 0	600PP
360			0.23	26	MAI	1	TSH	+0.52	TO+1.05	TSHTSH	0.3		K7060	resc	21H00027	H 0	600PP
361	53	129	0.28	81	MAI	2	TSH	+0.50	TO+1.11	TSHTSH	0.3		B3720	resc	21H00028	H 0	600PP
362			0.31	116	MAI	1	TSH	+0.50	TO+1.11	TSHTSH	0.3		B3720	resc	21H00028	H 0	600PP
363	55	129	0.18	93	SAI	2	TSH	+0.82		TSHTSH	0.3		K7060	resc	21H00027	H 0	600PP
[illegible]					SAI	1	TSH	+0.82		TSHTSH	0.0		K7060	resc	21H00027	H 0	600PP
[illegible]	57	129	0.17	102	MAI	2	TSH	+0.74	TO+1.06	TSHTSH	0.4		K7060	resc	21H00027	H 0	600PP
366					MAI	1	TSH	+0.74	TO+1.06	TSHTSH	0.0		K7060	resc	21H00027	H 0	600PP
367	20	130	0.19	92	MAI	2	TSH	+0.17		TSHTSH	0.2		H2131	resc	21H00020	H 0	600PP
368					MAI	1	TSH	+0.17		TSHTSH	0.0		A9608	resc	21H00020	H 0	600PP
369	48	130	0.22	92	MAI	2	TSH	+0.10	TO+1.03	TSHTSH	0.7		K7060	resc	21H00027	H 0	600PP
370			0.23	70	MAI	1	TSH	+0.10	TO+1.03	TSHTSH	0.5		K7060	resc	21H00027	H 0	600PP
371	52	130	0.25	97	MAI	2	TSH	+0.30	TO+1.20	TSHTSH	0.5		B3720	resc	21H00028	H 0	600PP
372			0.35	78	MAI	1	TSH	+0.30	TO+1.20	TSHTSH	0.4		B3720	resc	21H00028	H 0	600PP
373	58	130	0.18	76	MAI	2	TSH	+0.16		TSHTSH	0.2		B3720	resc	21H00028	H 0	600PP
374			0.16	119	MAI	1	TSH	+0.16		TSHTSH	0.2		B3720	resc	21H00028	H 0	600PP
375			0.21	70	SAI	1	TSH	+0.97		TSHTSH	0.4		B3720	resc	21H00028	H 0	600PP
376			0.13	108	SAI	2	TSH	+0.97		TSHTSH	0.4		B3720	resc	21H00028	H 0	600PP
377	25	131	0.15	99	MAI	2	TSH	+0.15	TO+0.78	TSHTSH	0.2		K7060	resc	21H00027	H 0	600PP
378					MAI	1	TSH	+0.15	TO+0.78	TSHTSH	0.0		K7060	resc	21H00027	H 0	600PP
379	22	132	0.09	89	SAI	2	TSH	+2.98		TSHTSH	0.2		B3720	resc	21H00028	H 0	600PP
380					SAI	1	TSH	+2.98		TSHTSH	0.0		B3720	resc	21H00028	H 0	600PP
381	46	132	0.37	99	MAI	2	TSH	+0.34	TO+0.95	TSHTSH	0.4		B3720	resc	21H00028	H 0	600PP
382			0.37	107	MAI	1	TSH	+0.34	TO+0.95	TSHTSH	0.4		B3720	resc	21H00028	H 0	600PP
383	60	132	0.10	71	SAI	2	TSH	+0.73		TSHTSH	0.2		K7060	resc	21H00027	H 0	600PP
384					SAI	1	TSH	+0.73		TSHTSH	0.0		K7060	resc	21H00027	H 0	600PP
385	62	132	0.11	118	SAI	2	TSH	+0.84		TSHTSH	0.2		R6452	resc	21H00023	H 0	600PP
386					SAI	1	TSH	+0.84		TSHTSH	0.0		R6452	resc	21H00023	H 0	600PP
387	27	133	0.14	96	SAI	2	TSH	+1.02		TSHTSH	0.2		B3720	resc	21H00028	H 0	600PP
388					SAI	1	TSH	+1.02		TSHTSH	0.0		B3720	resc	21H00028	H 0	600PP
389	39	133	0.29	108	MAI	2	TSH	+0.71	TO+1.31	TSHTSH	0.7		K7060	resc	21H00027	H 0	600PP
			0.30	91	MAI	1	TSH	+0.71	TO+1.31	TSHTSH	0.7		K7060	resc	21H00027	H 0	600PP
391	53	133	0.20	76	SAI	2	TSH	+0.20		TSHTSH	0.4		K7060	resc	21H00027	H 0	600PP
392					SAI	1	TSH	+0.20		TSHTSH	0.0		K7060	resc	21H00027	H 0	600PP

RPC H/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 09:56

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE SIZE
393	63	133	0.16	86	SAI	2 TSH	+0.86		TSHTSH	0.2		R6452	reso	21H00023	H	0	600PP
394					SAI	1 TSH	+0.86		TSHTSH	0.0		R6452	reso	21H00023	H	0	600PP
395	26	134	0.14	112	MAI	2 TSH	+0.84		TSHTSH	0.5		B3720	reso	21H00028	H	0	600PP
396					MAI	1 TSH	+0.84		TSHTSH	0.0		B3720	reso	21H00028	H	0	600PP
397	36	134	0.13	89	SAI	2 TSH	+0.62		TSHTSH	0.3		K7060	reso	21H00027	H	0	600PP
398					SAI	1 TSH	+0.62		TSHTSH	0.0		K7060	reso	21H00027	H	0	600PP
399	54	134	0.10	77	SAI	2 TSH	+0.85		TSHTSH	0.2		K7060	reso	21H00027	H	0	600PP
400					SAI	1 TSH	+0.85		TSHTSH	0.0		K7060	reso	21H00027	H	0	600PP
401	62	134	0.10	85	SAI	2 TSH	+0.84		TSHTSH	0.3		R6452	reso	21H00026	H	0	600PP
402					SAI	1 TSH	+0.84		TSHTSH	0.0		R6452	reso	21H00026	H	0	600PP
403	64	134	0.12	121	SAI	2 TSH	+0.68		TSHTSH	0.2		A9608	reso	21H00025	H	0	600PP
404					SAI	1 TSH	+0.68		TSHTSH	0.0		A9608	reso	21H00025	H	0	600PP
405	35	135	0.18	91	SAI	2 TSH	+0.84		TSHTSH	0.2		B3720	reso	21H00028	H	0	600PP
406					SAI	1 TSH	+0.84		TSHTSH	0.0		B3720	reso	21H00028	H	0	600PP
407	37	135	0.17	69	MAI	2 TSH	+0.73	TO+0.92	TSHTSH	0.3		K7060	reso	21H00027	H	0	600PP
408			0.20	93	MAI	1 TSH	+0.73	TO+0.92	TSHTSH	0.4		K7060	reso	21H00027	H	0	600PP
409	55	135	0.32	101	MAI	2 TSH	+0.65	TO+1.25	TSHTSH	0.5		B3720	reso	21H00028	H	0	600PP
410			0.23	59	MAI	1 TSH	+0.65	TO+1.25	TSHTSH	0.4		B3720	reso	21H00028	H	0	600PP
411	12	136	0.12	101	SAI	2 TSH	+0.52		TSHTSH	0.2		H2131	reso	21H00020	H	0	600PP
412					SAI	1 TSH	+0.52		TSHTSH	0.0		A9608	reso	21H00020	H	0	600PP
4	20	136	0.07	113	MAI	2 TSH	+1.08		TSHTSH	0.2		H2131	reso	21H00020	H	0	600PP
4.					MAI	1 TSH	+1.08		TSHTSH	0.0		A9608	reso	21H00020	H	0	600PP
415					SAI	1 TSH	+1.42		TSHTSH	0.0		A9608	reso	21H00020	H	0	600PP
416			0.09	61	SAI	2 TSH	+1.42		TSHTSH	0.2		H2131	reso	21H00020	H	0	600PP
417	22	136	0.10	105	SAI	2 TSH	+0.95		TSHTSH	0.2		B3720	reso	21H00028	H	0	600PP
418					SAI	1 TSH	+0.95		TSHTSH	0.0		B3720	reso	21H00028	H	0	600PP
419	24	136	0.16	84	MAI	2 TSH	+0.48	TO+1.01	TSHTSH	0.5		B3720	reso	21H00028	H	0	600PP
420			0.18	13	MAI	1 TSH	+0.48	TO+1.01	TSHTSH	0.4		B3720	reso	21H00028	H	0	600PP
421	34	136	0.11	83	MAI	2 TSH	+0.55	TO+0.86	TSHTSH	0.2		K7060	reso	21H00027	H	0	600PP
422					MAI	1 TSH	+0.55	TO+0.86	TSHTSH	0.0		K7060	reso	21H00027	H	0	600PP
423	38	136	0.20	83	SAI	2 TSH	+0.70		TSHTSH	0.3		K7060	reso	21H00027	H	0	600PP
424			0.25	53	SAI	1 TSH	+0.70		TSHTSH	0.3		K7060	reso	21H00027	H	0	600PP
425	40	136	0.16	77	MAI	2 TSH	+0.50	TO+1.42	TSHTSH	0.5		B3720	reso	21H00028	H	0	600PP
426					MAI	1 TSH	+0.50	TO+1.42	TSHTSH	0.0		B3720	reso	21H00028	H	0	600PP
427	52	136	0.18	98	MAI	2 TSH	+0.50	TO+1.40	TSHTSH	0.5		B3720	reso	21H00028	H	0	600PP
428					MAI	1 TSH	+0.50	TO+1.40	TSHTSH	0.0		B3720	reso	21H00028	H	0	600PP
429	17	137	0.12	96	MAI	2 TSH	+1.21	TO+1.90	TSHTSH	0.8		R6452	reso	21H00021	H	0	600PP
430			0.16	24	MAI	1 TSH	+1.21	TO+1.90	TSHTSH	0.7		R6452	reso	21H00021	H	0	600PP
431	25	137	0.20	110	MAI	2 TSH	+0.23	TO+1.59	TSHTSH	0.4		B3720	reso	21H00028	H	0	600PP
432			0.15	154	MAI	1 TSH	+0.23	TO+1.59	TSHTSH	0.3		B3720	reso	21H00028	H	0	600PP
433	27	137	0.10	81	SAI	2 TSH	+0.66		TSHTSH	0.3		K7060	reso	21H00027	H	0	600PP
434					SAI	1 TSH	+0.66		TSHTSH	0.0		K7060	reso	21H00027	H	0	600PP
435	45	137	0.23	117	MCI	P1 TSH	+0.07		TSHTSH	0.8		B3720	reso	21H00028	H	0	600PP
436			0.58	109	MCI	1 TSH	+0.07		TSHTSH	0.8		B3720	reso	21H00028	H	0	600PP
437	53	137	0.26	86	SAI	2 TSH	+0.86		TSHTSH	0.4		B3720	reso	21H00028	H	0	600PP
438			0.42	76	SAI	1 TSH	+0.86		TSHTSH	0.4		B3720	reso	21H00028	H	0	600PP
	24	138	0.14	110	MAI	2 TSH	+0.54	TO+1.43	TSHTSH	0.4		K7060	reso	21H00016	H	0	600PP
440					MAI	1 TSH	+0.54	TO+1.43	TSHTSH	0.0		K7060	reso	21H00016	H	0	600PP
441	32	138	0.12	87	MAI	2 TSH	+0.81	TO+1.05	TSHTSH	0.2		K7060	reso	21H00016	H	0	600PP

RPC H/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 09:56

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE SIZE
442					MAI	1	TSH	+0.81	TO+1.05	TSHTSH	0.0		K7060	reso	21H00016	H 0	600PP
443	34	138	0.31	95	MAI	2	TSH	+0.50		TSHTSH	0.35		B3720	reso	21H00015	H 0	600PP
444			0.39	77	MAI	1	TSH	+0.50		TSHTSH	0.35		B3720	reso	21H00015	H 0	600PP
445					MAI	1	TSH	+1.19		TSHTSH	0.00		B3720	reso	21H00015	H 0	600PP
446			0.23	93	MAI	2	TSH	+1.19		TSHTSH	0.35		B3720	reso	21H00015	H 0	600PP
447	48	138	0.19	98	MAI	2	TSH	+0.65	TO+0.98	TSHTSH	0.2		K7060	reso	21H00016	H 0	600PP
448					MAI	1	TSH	+0.65	TO+0.98	TSHTSH	0.0		K7060	reso	21H00016	H 0	600PP
449	25	139	0.12	112	MAI	2	TSH	+0.34		TSHTSH	0.25		M1680	reso	21H00015	H 0	600PP
450					MAI	1	TSH	+0.34		TSHTSH	0.00		M1680	reso	21H00015	H 0	600PP
451	31	139	0.23	116	SAI	2	TSH	+0.65		TSHTSH	0.32		B3720	reso	21H00015	H 0	600PP
452			0.25	78	SAI	1	TSH	+0.65		TSHTSH	0.38		B3720	reso	21H00015	H 0	600PP
453			0.24	77	MAI	1	TSH	+1.21		TSHTSH	0.19		B3720	reso	21H00015	H 0	600PP
454			0.16	102	MAI	2	TSH	+1.21		TSHTSH	0.16		B3720	reso	21H00015	H 0	600PP
455	37	139	0.20	114	SAI	2	TSH	+0.60		TSHTSH	0.30		B3720	reso	21H00015	H 0	600PP
456			0.24	85	SAI	1	TSH	+0.60		TSHTSH	0.41		B3720	reso	21H00015	H 0	600PP
457	51	139	0.12	83	SAI	2	TSH	+0.60		TSHTSH	0.33		B3720	reso	21H00015	H 0	600PP
458					SAI	1	TSH	+0.60		TSHTSH	0.00		B3720	reso	21H00015	H 0	600PP
459	16	140	0.21	86	MAI	2	TSH	+1.00		TSHTSH	0.4		A9608	reso	21H00011	H 0	600PP
460			0.22	107	MAI	1	TSH	+1.00		TSHTSH	0.4		A9608	reso	21H00011	H 0	600PP
461	32	140	0.08	78	SAI	2	TSH	+0.14		TSHTSH	0.2		K7060	reso	21H00016	H 0	600PP
[illegible]					SAI	1	TSH	+0.14		TSHTSH	0.0		K7060	reso	21H00016	H 0	600PP
[illegible]			0.20	106	SAI	2	TSH	+0.61		TSHTSH	0.2		K7060	reso	21H00016	H 0	600PP
464					SAI	1	TSH	+0.61		TSHTSH	0.0		K7060	reso	21H00016	H 0	600PP
465					SAI	1	TSH	+1.04		TSHTSH	0.0		K7060	reso	21H00016	H 0	600PP
466			0.13	106	SAI	2	TSH	+1.04		TSHTSH	0.2		K7060	reso	21H00016	H 0	600PP
467	44	140	0.08	94	SAI	2	TSH	+0.15		TSHTSH	0.2		K7060	reso	21H00016	H 0	600PP
468					SAI	1	TSH	+0.15		TSHTSH	0.0		K7060	reso	21H00016	H 0	600PP
469			0.27	93	SAI	2	TSH	+0.57		TSHTSH	0.3		K7060	reso	21H00016	H 0	600PP
470			0.21	70	SAI	1	TSH	+0.57		TSHTSH	0.2		K7060	reso	21H00016	H 0	600PP
471	11	141	0.15	85	SAI	2	TSH	+0.94		TSHTSH	0.2		M1680	reso	21H00009	H 0	600PP
472					SAI	1	TSH	+0.94		TSHTSH	0.0		M1680	reso	21H00009	H 0	600PP
473	12	142	0.15	102	MAI	2	TSH	+0.61	TO+0.91	TSHTSH	0.2		M1680	reso	21H00009	H 0	600PP
474					MAI	1	TSH	+0.61	TO+0.91	TSHTSH	0.0		M1680	reso	21H00009	H 0	600PP
475	24	142	0.95	70	MAI	2	TSH	+0.05	TO+1.56	TSHTSH	0.6		R6452	reso	21H00014	H 0	600PP
476			0.98	53	MAI	1	TSH	+0.05	TO+1.56	TSHTSH	0.5		R6452	reso	21H00014	H 0	600PP
477	28	142	0.08	108	SAI	2	TSH	+0.96		TSHTSH	0.2		K7060	reso	21H00016	H 0	600PP
478					SAI	1	TSH	+0.96		TSHTSH	0.0		K7060	reso	21H00016	H 0	600PP
479					SAI	1	TSH	+1.20		TSHTSH	0.0		K7060	reso	21H00016	H 0	600PP
480			0.04	88	SAI	2	TSH	+1.20		TSHTSH	0.2		K7060	reso	21H00016	H 0	600PP
481	32	142	0.18	107	MAI	2	TSH	+0.57	TO+1.20	TSHTSH	0.3		K7060	reso	21H00016	H 0	600PP
482					MAI	1	TSH	+0.57	TO+1.20	TSHTSH	0.0		M1680	reso	21H00016	H 0	600PP
483	17	143	0.14	126	MAI	2	TSH	+1.24		TSHTSH	0.3		A9608	reso	21H00011	H 0	600PP
484			0.18	86	MAI	1	TSH	+1.24		TSHTSH	0.3		A9608	reso	21H00011	H 0	600PP
485	21	143	0.10	101	SAI	2	TSH	+0.81		TSHTSH	0.2		M1680	reso	21H00014	H 0	600PP
486					SAI	1	TSH	+0.81		TSHTSH	0.0		M1680	reso	21H00014	H 0	600PP
487	31	143	0.13	106	SAI	2	TSH	+0.70		TSHTSH	0.2		R6452	reso	21H00014	H 0	600PP
					SAI	1	TSH	+0.70		TSHTSH	0.0		R6452	reso	21H00014	H 0	600PP
489	35	143	0.16	76	MAI	2	TSH	+0.10	TO+0.70	TSHTSH	0.2		K7060	reso	21H00013	H 0	600PP
490					MAI	1	TSH	+0.10	TO+0.70	TSHTSH	0.0		K7060	reso	21H00013	H 0	600PP

RPC H/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric
PLANT: CCNPP
UNIT: 2
SG: 21
DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 09:56

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE	SIZE
491	15	145	0.06	92	SAI	2	TSH	+0.44		TSHTSH	0.2		A9608	reso	21H00011	H	0	600PP
492					SAI	1	TSH	+0.44		TSHTSH	0.0		A9608	reso	21H00011	H	0	600PP
493			0.05	142	MAI	2	TSH	+0.87		TSHTSH	0.2		A9608	reso	21H00011	H	0	600PP
494					MAI	1	TSH	+0.87		TSHTSH	0.0		A9608	reso	21H00011	H	0	600PP
495	17	145	0.24	103	SAI	2	TSH	+0.71		TSHTSH	0.5		M1680	reso	21H00009	H	0	600PP
496			0.24	133	SAI	1	TSH	+0.71		TSHTSH	0.4		M1680	reso	21H00009	H	0	600PP
497	21	145	0.10	77	SAI	2	TSH	+0.93		TSHTSH	0.1		K7060	reso	21H00013	H	0	600PP
498					SAI	1	TSH	+0.93		TSHTSH	0.0		K7060	reso	21H00013	H	0	600PP
499					SAI	1	TSH	+1.08		TSHTSH	0.0		K7060	reso	21H00013	H	0	600PP
500			0.08	101	SAI	2	TSH	+1.08		TSHTSH	0.1		K7060	reso	21H00013	H	0	600PP
501	23	145	0.10	80	MAI	2	TSH	+0.67		TSHTSH	0.3		R6452	reso	21H00014	H	0	600PP
502					MAI	1	TSH	+0.67		TSHTSH	0.0		R6452	reso	21H00014	H	0	600PP
503	12	146	0.19	110	MAI	1	TSH	+0.31	TO+0.84	TSHTSH	0.3		H2131	reso	21H00009	H	0	600PP
504			0.18	100	MAI	2	TSH	+0.31	TO+0.84	TSHTSH	0.4		M1680	reso	21H00009	H	0	600PP
505	16	146	0.10	84	SAI	2	TSH	+0.47		TSHTSH	0.2		A9608	reso	21H00011	H	0	600PP
506			0.09	23	SAI	1	TSH	+0.47		TSHTSH	0.2		A9608	reso	21H00011	H	0	600PP
507			0.11	99	MAI	2	TSH	+0.75		TSHTSH	0.2		A9608	reso	21H00011	H	0	600PP
508			0.16	82	MAI	1	TSH	+0.75		TSHTSH	0.2		A9608	reso	21H00011	H	0	600PP
509	24	146	0.14	79	SAI	2	TSH	+0.19		TSHTSH	0.2		R6452	reso	21H00014	H	0	600PP
510					SAI	1	TSH	+0.19		TSHTSH	0.0		R6452	reso	21H00014	H	0	600PP
5			0.11	84	MAI	2	TSH	+0.71		TSHTSH	0.3		R6452	reso	21H00014	H	0	600PP
5					MAI	1	TSH	+0.71		TSHTSH	0.0		R6452	reso	21H00014	H	0	600PP
513	28	146	0.08	95	SAI	2	TSH	+0.52		TSHTSH	0.3		R6452	reso	21H00014	H	0	600PP
514					SAI	1	TSH	+0.52		TSHTSH	0.0		R6452	reso	21H00014	H	0	600PP
515	32	146	0.11	97	SAI	2	TSH	+0.16		TSHTSH	0.3		R6452	reso	21H00014	H	0	600PP
516					SAI	1	TSH	+0.16		TSHTSH	0.0		R6452	reso	21H00014	H	0	600PP
517	17	147	0.08	78	SAI	2	TSH	+0.66		TSHTSH	0.3		S7752	reso	21H00011	H	0	600PP
518			0.11	53	SAI	1	TSH	+0.66		TSHTSH	0.3		S7752	reso	21H00011	H	0	600PP
519	12	148	0.25	108	MAI	2	TSH	+0.12	TO+0.46	TSHTSH	0.3		H2131	reso	21H00009	H	0	600PP
520			0.24	60	MAI	1	TSH	+0.12	TO+0.46	TSHTSH	0.3		M1680	reso	21H00009	H	0	600PP
521	16	148	0.12	108	SAI	2	TSH	+0.18		TSHTSH	0.1		M1680	reso	21H00009	H	0	600PP
522			0.11	76	SAI	1	TSH	+0.18		TSHTSH	0.1		M1680	reso	21H00009	H	0	600PP
523	18	148	0.19	104	SAI	2	TSH	+0.47		TSHTSH	0.3		A9608	reso	21H00011	H	0	600PP
524			0.41	82	SAI	1	TSH	+0.47		TSHTSH	0.3		A9608	reso	21H00011	H	0	600PP
525	25	149			SAI	1	TSH	+0.17		TSHTSH	0.0		H2131	reso	21H00013	H	0	600PP
526			0.12	111	SAI	2	TSH	+0.17		TSHTSH	0.2		K7060	reso	21H00013	H	0	600PP

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE	SIZE

QUERY REPORT SUMMARY:

QUERY PARAMETER		ENTRIES	TUBES
LPI	Indication Code	0	0
MAI	Indication Code	180	87
MCI	Indication Code	2	1
MMI	Indication Code	0	0
MSI	Indication Code	2	1
MVI	Indication Code	0	0
SAI	Indication Code	316	143
SCI	Indication Code	26	13
SVI	Indication Code	0	0

TOTAL ENTRIES: 526
TOTAL TUBES: 236

ALL CALLS (EXCLUDING RETEST CODES & NDD)

May 17,1999 10:57

UTILITY:	Baltimore Gas & Electric
PLANT:	CCNPP
UNIT:	2
SG:	21
DATABASE:	CCNPP_UNIT2_SG21_0399_Final

****
* INSPECTION SUMMARY QUERY REPORT *
****

* All Test Plans in the database are included in summary: 13 *

Test Plan Name:	Probe Type:	Probe Size:	Leg:
1. 100% TSH (G47-64,73)	MRPC	600HF	HL
2. F/L ROWS 6-140 (G1-19)	BOBBIN	600UL	CL
3. ROWS 1-5 STRAIGHT SECT (G65-68)	BOBBIN	580UL	HL
4. ROWS 1-5 CANDY CANE (G20-23)	BOBBIN	580SF	CL
5. HL "NEW" DNT/DNG=>5v (G154-172)	MRPC	560PF	HL
6. TSC (G24-42)	MRPC	600HF	CL
7. ROWS 1-2 UBENDS (G43-46)	MRPC	560PP	CL
8. 100%STEAM BLANKET R6-15(G69-72)	MRPC	560PF	HL
9. Bobbin SI TEH-VM+0.00	MRPC	600PP	HL
10. Bobbin SI VM+0.01-TEC	MRPC	600HF	CL
11. HL PREV DNT/DNG=>5VOLT (G74-92)	MRPC	600PP	HL
12. CL PREV DNT/DNG=>5VOLT(G93-111)	MRPC	600PP	CL
13. CL "NEW" DNT/DNG=>5V (G173-191)	MRPC	560PF	CL

****
* EIMS MAIN QUERY PARAMETERS *
****

ROW	ALL				
LINE	ALL				
VOLTS	ALL				
DEGREES	ALL				
PERCENT	0 to 100				
LOCATION	ALL				
ELEVATION	ALL				
EXTENT	ALL				
UTILITY1	ALL				
UTILITY2	ALL				
NAME	ALL				
EVAL TYPE	ALL				
CAL GROUP	ALL				
PROBE	ALL				
IND. CODES	ADR	BLG	CUD	DEP	DNI
	DRI	DSI	DTI	ETL	EXP
	FSA	FSD	IDC	IDM	INF
	INR	LDE	LPI	MAI	MBM
	MCI	MMI	MSI	MVI	NDF
	NQI	NRC	NRH	NSY	OBS
	PBC	PID	PLP	PPS	PRC
	PSP	PTS	PVN	SAI	SCI
	SVI	UDE	VOL	WAR	
CHANNELS	ALL				

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 10:57

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE	SIZE
1	1	1	0.26	50	LPI	2	TSC	+0.65	TSCTSC			M1680	reso	21C00178	C 3	600PP	
2			0.24	102	PID	4	TSC	+0.65	TSCTSC			J6276	rpri	21C00190	C99	600HF	
3	3	1	0.60	59	23	P2	01C	+0.81	06HTEC			A9608	reso	21C00186	C 1	560SF	
4			0.46	121	WAR	4	01C	+0.91	01C01C			K2858	rpri	21C00193	C 2	600HF	
5			0.35	82	PLP	9	TSC	+0.28	TSCTSC			M1680	reso	21C00178	C 3	600PP	
6	2	2	0.37	84	PLP	9	TSC	+0.43	TSCTSC			M1680	reso	21C00178	C 3	600PP	
7	20	2	1.15	85	MBM	6	04C	+7.54	TECTEH			K7060	reso	21H00115	C 0	600UL	
8			0.53	83	MBM	6	03C	+26.11	TECTEH			K7060	reso	21H00115	C 0	600UL	
9	24	2	0.80	56	MBM	6	04C	+18.48	TECTEH			K7060	reso	21H00115	C 0	600UL	
10	10	4	2.95	170	DSI	P1	VM	+0.00	TECTEH			K7060	reso	21H00115	C 0	600UL	
11					NDF		VM	+0.00	06C05H			K7060	reso	21H00139	H 2	560PF	
12	28	4	1.27	67	MBM	6	05H	+17.14	TECTEH			H2131	reso	21H00116	C 0	600UL	
13	30	4	0.40	56	DSI	P1	03H	+0.74	TECTEH			K2858	rpri	21H00115	C 0	600UL	
14					NDF		03H	+0.74	03H03H			T7451	rsec	21H00167	H 4	600PP	
15	36	4	0.41	79	MBM	6	02C	+6.56	TECTEH			H2131	reso	21H00116	C 0	600UL	
16	20	6	0.94	87	MBM	6	02C	+28.60	TECTEH			K7060	reso	21H00115	C 0	600UL	
17	26	6	1.05	81	MBM	6	05H	+14.80	TECTEH			H2131	reso	21H00116	C 0	600UL	
18			0.85	89	MBM	6	05H	+16.76	TECTEH			H2131	reso	21H00116	C 0	600UL	
19					INF		DC	-1.83	TECTEH	HR		H2131	reso	21H00116	C 0	600UL	
20			0.32	143	14	P2	DC	+1.73	TECTEH			H2131	reso	21H00116	C 0	600UL	
21					NDF		DC	+1.73	DC DC			L7871	rpri	21C00183	C 2	560PF	
22	32	6	0.52	42	DSI	P1	05C	-0.83	TECTEH			K2858	rpri	21H00115	C 0	600UL	
23			0.29	116	WAR	2	05C	-0.82	05C05C			A9608	reso	21C00185	C 2	600PP	
24	44	6	0.49	111	DSI	P1	03H	-0.99	TECTEH			K2858	rpri	21H00115	C 0	600UL	
25			0.43	107	WAR	2	03H	-0.99	03H03H			M1680	reso	21H00167	H 4	600PP	
26	15	7	0.49	81	MBM	5	02H	+22.78	TECTEH			H2131	reso	21H00116	C 0	600UL	
27	17	7	0.87	80	MBM	5	TSH	+28.75	TECTEH			K7060	reso	21H00115	C 0	600UL	
28			0.72	84	MBM	5	04H	+9.47	TECTEH			K7060	reso	21H00115	C 0	600UL	
29	31	7	0.49	85	MBM	5	01H	+34.20	TECTEH			H2131	reso	21H00116	C 0	600UL	
30	53	7	0.33	13	INR	P1	TSH	+1.23	TECTEH			K2858	rpri	21H00115	C 0	600UL	
31			0.41	18	MBM	6	01H	+24.12	TECTEH			K7060	reso	21H00115	C 0	600UL	
32	1	9	1.67	81	MBM	5	03H	+10.61	06HTEH			K7060	reso	21H00126	H 1	600UL	
33			1.05	72	MBM	5	03H	+17.88	06HTEH			K7060	reso	21H00126	H 1	600UL	
34			2.64	75	MBM	6	03H	+24.85	06HTEH			K7060	reso	21H00126	H 1	600UL	
35	21	9	1.30	82	MBM	5	01C	+27.67	TECTEH			K7060	reso	21H00115	C 0	600UL	
36	49	9	0.75	51	MBM	6	TSH	+18.55	TECTEH			H2131	reso	21H00116	C 0	600UL	
37			0.81	88	MBM	5	04H	+32.23	TECTEH			H2131	reso	21H00116	C 0	600UL	
38	59	9	0.27	69	DSI	P1	04C	-0.45	TECTEH			A9608	reso	21H00115	C 0	600UL	
39					NDF		04C	-0.45	04C04C			L7871	rpri	21C00185	C 2	600PP	
40	8	10	0.48	67	MBM	5	01C	+10.01	TECTEH			H2131	reso	21H00116	C 0	600UL	
41	12	10	0.61	82	MBM	5	TSH	+2.66	TECTEH			H2131	reso	21H00116	C 0	600UL	
42	30	10	0.10	13	IDM	2	TSH	+0.58	TSHTSH			A9608	reso	21H00111	H 0	600PP	
43	13	11	1.03	83	MBM	6	03C	+35.87	TECTEH			K7060	reso	21H00115	C 0	600UL	
44	33	11	2.93	55	MBM	6	06H	+23.52	TECTEH			K7060	reso	21H00115	C 0	600UL	
45	41	11	0.78	82	MBM	5	04H	+16.06	TECTEH			K7060	reso	21H00115	C 0	600UL	
46	45	11	1.86	89	MBM	6	05C	+20.97	TECTEH			K7060	reso	21H00115	C 0	600UL	
			0.76	79	MBM	5	03C	+20.53	TECTEH			K7060	reso	21H00115	C 0	600UL	
48	14	12	0.18	52	MBM	5	02C	+25.04	TECTEH			D3858	reso	21H00116	C 0	600UL	
49			0.36	102	VOL	1	02C	+25.04	02C03C			D3858	reso	21C00185	C 2	600PP	

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 10:57

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE	SIZE
50			0.10	111	VOL	2	02C	+25.04	02C03C			D3858	reso	21C00185	C	2	600PP
51	28	12	0.29	126	8	P2	03H	+0.73	TECTEH			A9608	reso	21H00115	C	0	600UL
52			0.34	88	WAR	2	03H	+0.80	03H03H			M1680	reso	21H00167	H	4	600PP
53	34	12	0.98	72	MBM	5	01C	+4.70	TECTEH			H2131	reso	21H00116	C	0	600UL
54			0.57	69	MBM	5	01C	+13.97	TECTEH			H2131	reso	21H00116	C	0	600UL
55	46	12	0.91	83	MBM	5	02H	+26.53	TECTEH			H2131	reso	21H00116	C	0	600UL
56	60	12	0.45	56	DSI	P1	01H	-1.35	TECTEH			K2858	rpri	21H00115	C	0	600UL
57					NDF		01H	-1.35	01H01H			T7451	rsec	21H00167	H	4	600PP
58	68	12	0.17	103	LPI	P5	TSC	+0.38	TSCTSC	0.3		B3720	reso	21C00176	C	3	600PP
59			0.44	58	LPI	2	TSC	+0.38	TSCTSC			M1680	reso	21C00176	C	3	600PP
60			0.53	57	PID	4	TSC	+0.38	TSCTSC			J6276	rpri	21C00190	C	99	600HF
61	1	13	1.06	80	MBM	5	03C	+8.31	06HTEC			D3858	reso	21C00186	C	1	580SF
62			1.00	87	MBM	5	02C	+30.93	06HTEC			D3858	reso	21C00186	C	1	580SF
63	13	13	0.33		PLP	9	TSC	+0.09	TSCTSC			K2858	rpri	21C00176	C	3	600PP
64	53	13	0.33		PLP	9	TSC	+0.17	TSCTSC			K2858	rpri	21C00176	C	3	600PP
65	61	13	0.78	1	IDM	2	TSH	+0.33	TSHTSH			S7752	reso	21H00110	H	0	600PP
66	63	13	0.16	112	VOL	2	VM	+2.80	DC VM			D3858	reso	21C00183	C	2	560PF
67			1.18	85	MBM	5	VM	+3.06	TECTEH			D3858	reso	21H00116	C	0	600UL
68	67	13	0.30	57	LPI	2	TSC	+0.12	TSCTSC	0.2		K7060	reso	21C00177	C	3	600PP
69			0.22	52	PID	4	TSC	+0.12	TSCTSC			J6276	rpri	21C00190	C	99	600HF
[illegible]			0.26	75	LPI	1	TSC	+0.15	TSCTSC	0.2		K7060	reso	21C00177	C	3	600PP
7[illegible]	69	13	0.25	96	LPI	P5	TSC	+0.26	TSCTSC	0.3		B3720	reso	21C00176	C	3	600PP
72			0.45	52	LPI	2	TSC	+0.27	TSCTSC			M1680	reso	21C00176	C	3	600PP
73			0.12	103	LPI	P5	TSC	+0.42	TSCTSC	0.3		B3720	reso	21C00176	C	3	600PP
74			0.30	78	LPI	2	TSC	+0.42	TSCTSC			M1680	reso	21C00176	C	3	600PP
75			0.16	138	PID	4	TSC	+0.42	TSCTSC			C5184	rsec	21C00190	C	99	600HF
76	18	14	0.76	77	MBM	5	05C	+26.61	TECTEH			D3858	reso	21H00117	C	0	600UL
77					VOL	1	05C	+26.61	05C06C			D3858	reso	21C00185	C	2	600PP
78			0.18	99	VOL	2	05C	+26.61	05C06C			D3858	reso	21C00185	C	2	600PP
79			0.73	114	INR	6	TSC	+25.98	TECTEH			K2858	rpri	21H00117	C	0	600UL
80	20	14	0.63	81	MBM	5	02H	+4.23	TECTEH			D3858	reso	21H00118	C	0	600UL
81			0.15	65	VOL	2	02H	+4.52	02H03H			M1680	reso	21H00167	H	4	600PP
82	22	14	0.99	73	MBM	5	05C	+5.87	TECTEH			D3858	reso	21H00117	C	0	600UL
83			0.66	140	VOL	1	05C	+5.87	05C06C			D3858	reso	21C00185	C	2	600PP
84			0.19	128	VOL	2	05C	+5.87	05C06C			D3858	reso	21C00185	C	2	600PP
85			1.80	67	MBM	5	05C	+9.80	TECTEH			D3858	reso	21H00117	C	0	600UL
86			0.75	135	VOL	1	05C	+9.80	05C06C			D3858	reso	21C00185	C	2	600PP
87			0.22	113	VOL	2	05C	+9.80	05C06C			D3858	reso	21C00185	C	2	600PP
88			1.42	60	MBM	5	05C	+13.22	TECTEH			D3858	reso	21H00117	C	0	600UL
89			0.64	137	VOL	1	05C	+13.22	05C06C			D3858	reso	21C00185	C	2	600PP
90			0.18	114	VOL	2	05C	+13.22	05C06C			D3858	reso	21C00185	C	2	600PP
91			1.22	90	MBM	5	05C	+15.58	TECTEH			D3858	reso	21H00117	C	0	600UL
92			0.68	114	VOL	1	05C	+15.58	05C06C			D3858	reso	21C00185	C	2	600PP
93			0.17	116	VOL	2	05C	+15.58	05C06C			D3858	reso	21C00185	C	2	600PP
94	36	14			PRC				02C03C			M1680	reso	21C00193	C	3	600HF
95			0.55	80	MBM	5	02C	+32.22	TECTEH			D3858	reso	21H00118	C	0	600UL
			0.12	81	VOL	2	02C	+32.22	02C03C			D3858	reso	21C00185	C	2	600PP
97	44	14	0.55	98	MBM	5	06H	+20.97	TECTEH			D3858	reso	21H00118	C	0	600UL
98			0.17	114	VOL	2	06H	+20.97	06H07H			M1680	reso	21H00167	H	4	600PP

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 10:57

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
99	52	14	0.80	77	MBM	5 TSC	+8.05	TECTEH			D3858	reso	21H00118	C 0	600UL
100			0.54	74	VOL	1 TSC	+8.05	TSC01C			D3858	reso	21C00185	C 2	600PP
101			0.17	137	VOL	2 TSC	+8.05	TSC01C			D3858	reso	21C00185	C 2	600PP
102	17	15	0.26	73	PLP	9 TSC	+0.79	TSCTSC			K7060	reso	21C00175	C 3	600PP
103	19	15	0.31		PLP	9 TSC	+0.79	TSCTSC			S0607	rsec	21C00174	C 3	600PP
104	8	16	1.04	95	MBM	5 05C	+7.72	TECTEH			D3858	reso	21H00118	C 0	600UL
105			0.66	59	VOL	1 05C	+7.72	05C06C			D3858	reso	21C00185	C 2	600PP
106			0.28	152	VOL	2 05C	+7.72	05C06C			D3858	reso	21C00185	C 2	600PP
107			0.46	89	MBM	5 05C	+16.37	TECTEH			D3858	reso	21H00118	C 0	600UL
108			0.43	120	VOL	1 05C	+16.37	05C06C			D3858	reso	21C00185	C 2	600PP
109			0.15	120	VOL	2 05C	+16.37	05C06C			D3858	reso	21C00185	C 2	600PP
110			0.37	82	MBM	5 05C	+23.16	TECTEH			D3858	reso	21H00118	C 0	600UL
111			0.26	106	VOL	1 05C	+23.16	05C06C			D3858	reso	21C00185	C 2	600PP
112			0.18	121	VOL	2 05C	+23.16	05C06C			D3858	reso	21C00185	C 2	600PP
113			0.77	87	MBM	5 05C	+25.60	TECTEH			D3858	reso	21H00118	C 0	600UL
114			0.50	61	VOL	1 05C	+25.60	05C06C			D3858	reso	21C00185	C 2	600PP
115			0.23	128	VOL	2 05C	+25.60	05C06C			D3858	reso	21C00185	C 2	600PP
116	48	16	1.09	82	MBM	5 03H	+18.16	TECTEH			D3858	reso	21H00118	C 0	600UL
117					NDF	03H	+18.16	03H04H			T7451	rsec	21H00167	H 4	600PP
118			0.82	80	MBM	5 03H	+23.80	TECTEH			D3858	reso	21H00118	C 0	600UL
[illegible]					NDF	03H	+23.80	03H04H			T7451	rsec	21H00167	H 4	600PP
[illegible]			0.67	67	MBM	5 03H	+25.61	TECTEH			D3858	reso	21H00118	C 0	600UL
121					NDF	03H	+25.61	03H04H			T7451	rsec	21H00167	H 4	600PP
122			0.47	64	MBM	5 03H	+26.74	TECTEH			D3858	reso	21H00118	C 0	600UL
123					NDF	03H	+26.74	03H04H			T7451	rsec	21H00167	H 4	600PP
124	80	16	0.40	9	IDM	2 TSH	+5.72	TSHTSH			S7752	reso	21H00108	H 0	600PP
125	15	17	0.61	90	MBM	5 04H	+7.43	TECTEH			D3858	reso	21H00118	C 0	600UL
126					NDF	04H	+7.43	04H05H			T7451	rsec	21H00167	H 4	600PP
127	63	17	0.53		PLP	9 TSC	+0.36	TSCTSC			K2858	rpri	21C00174	C 3	600PP
128	65	17			INF	04H	+26.21	TECTEH	HR		H2131	reso	21H00117	C 0	600UL
129	71	17	0.40	79	MBM	5 06H	+19.55	TECTEH			D3858	reso	21H00118	C 0	600UL
130			0.15	125	VOL	2 06H	+19.55	06H07H			M1680	reso	21H00167	H 4	600PP
131			0.34	64	MBM	5 05C	+29.17	TECTEH			D3858	reso	21H00118	C 0	600UL
132			0.20	137	VOL	1 05C	+29.17	05C06C			D3858	reso	21C00185	C 2	600PP
133			0.13	110	VOL	2 05C	+29.17	05C06C			D3858	reso	21C00185	C 2	600PP
134	6	18	0.62	89	MBM	5 01C	+27.95	TECTEH			A9608	reso	21H00118	C 0	600UL
135	12	18	0.69	71	MBM	5 03C	+35.15	TECTEH			H2131	reso	21H00117	C 0	600UL
136	26	18	0.10	95	SAI	2 TSH	+1.52	TSHTSH	0.2		R6452	reso	21H00109	H 0	600PP
137					SAI	1 TSH	+1.52	TSHTSH	0		R6452	reso	21H00109	H 0	600PP
138.			0.11	64	PID	4 TSH	+1.52	TSHTSH			S1848	rpri	21H00149	H99	600HF
139	15	19	0.48	69	MBM	5 02H	+23.30	TECTEH			D3858	reso	21H00118	C 0	600UL
140					NDF	02H	+23.30	02H02H			T7451	rsec	21H00167	H 4	600PP
141	49	19	4.34	89	INR	P3 TSC	+0.20	TECTEH			H2131	reso	21H00117	C 0	600UL
142	61	19	1.15	180	IDM	2 TSH	+2.63	TSHTSH			R6452	reso	21H00109	H 0	600PP
143	63	19	0.26	80	PLP	9 TSC	+0.68	TSCTSC			K7060	reso	21C00174	C 3	600PP
144	65	19	0.41		PLP	9 TSC	+0.27	TSCTSC			K2858	rpri	21C00175	C 3	600PP
	83	19	0.85	80	MBM	5 VM	+21.35	TECTEH			A9608	reso	21H00118	C 0	600UL
146	22	20	0.17	81	MAI	2 TSH	+0.10	TSHTSH	0.2		R6452	reso	21H00109	H 0	600PP
147			0.16	84	MAI	1 TSH	+0.10	TSHTSH	0.2		R6452	reso	21H00109	H 0	600PP

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 10:57

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
148			0.15	93	PID	4 TSH	+0.10		TSHTSH			S1848	rpri	21H00149	H99	600HF
149	24	20	0.14	66	SAI	2 TSH	+0.27		TSHTSH	0.3		S7752	reso	21H00108	H 0	600PP
150					SAI	1 TSH	+0.27		TSHTSH	0		S7752	reso	21H00108	H 0	600PP
151			0.14	76	PID	4 TSH	+0.27		TSHTSH			S1848	rpri	21H00149	H99	600HF
152	32	20	0.63	77	MBM	5 02H	+17.54		TECTEH			A9608	reso	21H00118	C 0	600UL
153	54	20	1.01	79	MBM	6 05H	+32.17		TECTEH			H2131	reso	21H00117	C 0	600UL
154	62	20	6.94	2	PVN	P1 TSC	+10.18		TECTEH			L7871	rpri	21H00117	C 0	600UL
155	70	20	0.78	74	MBM	5 05C	+13.89		TECTEH			H2131	reso	21H00117	C 0	600UL
156	72	20	0.64	61	MBM	5 01H	+5.30		TECTEH			A9608	reso	21H00118	C 0	600UL
157	82	20	1.11	77	MBM	5 04H	+19.71		TECTEH			H2131	reso	21H00117	C 0	600UL
158			0.62	76	MBM	5 05H	+17.21		TECTEH			H2131	reso	21H00117	C 0	600UL
159	1	21	0.43	51	SVI	1 TSC	+0.10		TSCTSC	0.3		A9608	reso	21C00093	C 3	600PP
160			0.27	99	SVI	2 TSC	+0.10		TSCTSC	0.3		A9608	reso	21C00093	C 3	600PP
161					PID	P1 TSC	+0.10		TSCTSC			D3858	reso	21C00112	C99	600PP
162	9	21			SAI	1 TSH	+0.45		TSHTSH	0		R6452	reso	21H00109	H 0	600PP
163			0.10	79	SAI	2 TSH	+0.45		TSHTSH	0.2		R6452	reso	21H00109	H 0	600PP
164			0.11	84	PID	4 TSH	+0.45		TSHTSH			S1848	rpri	21H00149	H99	600HF
165	11	21	0.82	68	MBM	5 TSH	+14.09		TECTEH			D3858	reso	21H00118	C 0	600UL
166			0.17	138	VOL	2 TSH	+14.09		TSH01H			M1680	reso	21H00167	H 4	600PP
167	15	21	0.14	89	SAI	2 TSH	+0.15		TSHTSH	0.2		S7752	reso	21H00108	H 0	600PP
[illegible]					SAI	1 TSH	+0.15		TSHTSH	0		S7752	reso	21H00108	H 0	600PP
[illegible]			0.13	85	PID	4 TSH	+0.15		TSHTSH			S1848	rpri	21H00149	H99	600HF
170	45	21	0.43	80	INR	5 01H	+13.16		TECTEH			H2131	reso	21H00117	C 0	600UL
171	55	21	5.67	5	PVN	P1 03C	+4.06		TECTEH			K9438	rpri	21H00118	C 0	600UL
172	91	21	0.48	5	IDM	2 TSH	+1.96		TSHTSH			R6452	reso	21H00106	H 0	600PP
173			1.23	110	DSI	P1 06C	-0.16		TECTEH			L7871	rpri	21H00117	C 0	600UL
174			0.62	92	WAR	2 06C	-0.16		06C06C			A9608	reso	21C00185	C 2	600PP
175	10	22	0.64	75	MBM	5 TSC	+26.88		TECTEH			R6452	reso	21H00119	C 0	600UL
176			0.72	79	MBM	5 TSC	+28.14		TECTEH			R6452	reso	21H00119	C 0	600UL
177			0.49	75	MBM	5 TSC	+29.58		TECTEH			R6452	reso	21H00119	C 0	600UL
178	14	22	0.10	101	NQI	P1 TSH	+0.54		TECTEH			A9608	reso	21H00119	C 0	600UL
179					SAI	1 TSH	+0.61		TSHTSH	0		R6452	reso	21H00106	H 0	600PP
180			0.11	102	SAI	2 TSH	+0.61		TSHTSH	0.2		R6452	reso	21H00106	H 0	600PP
181			0.13	121	PID	4 TSH	+0.61		TSHTSH			S1848	rpri	21H00149	H99	600HF
182	24	22	2.89	8	INR	6 VM	+6.61	TO+8.30	TECTEH			L7871	rpri	21H00120	C 0	600UL
183	72	22	1.00	90	MBM	5 VM	+20.43		TECTEH			R6452	reso	21H00119	C 0	600UL
184	92	22	0.58	89	MBM	5 03H	+15.40		TECTEH			R6452	reso	21H00119	C 0	600UL
185	21	23	0.11	95	SAI	2 TSH	+0.72		TSHTSH	0.2		C3340	reso	21H00105	H 0	600PP
186					SAI	1 TSH	+0.72		TSHTSH	0		C3340	reso	21H00105	H 0	600PP
187			0.11	122	PID	4 TSH	+0.72		TSHTSH			S1848	rpri	21H00149	H99	600HF
188	45	23	0.82	67	MBM	6 05C	+17.20		TECTEH			R6452	reso	21H00119	C 0	600UL
189	51	23	0.75	71	MBM	5 05C	+4.92		TECTEH			A9608	reso	21H00120	C 0	600UL
190	55	23	0.69	85	MBM	5 07H	+5.98		TECTEH			A9608	reso	21H00120	C 0	600UL
191			0.14	84	PLP	9 TSC	+3.63		TSCTSC			K7060	reso	21C00174	C 3	600PP
192	57	23	0.37	82	PLP	9 TSC	+0.40		TSCTSC			K7060	reso	21C00175	C 3	600PP
193	79	23	0.16	51	INR	5 01H	+29.78		TECTEH			L7871	rpri	21H00120	C 0	600UL
	83	23	0.34	68	MBM	6 02H	+16.60		TECTEH			A9608	reso	21H00120	C 0	600UL
195			0.54	85	MBM	5 02H	+18.09		TECTEH			A9608	reso	21H00120	C 0	600UL
196	87	23	0.49	87	MBM	6 02C	+11.47		TECTEH			A9608	reso	21H00120	C 0	600UL

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
197	89	23	0.31	86	INR	5	05C	+23.66	TECTEH			L7773	rpri	21H00119	C 0	600UL
198	6	24	0.88	71	MBM	5	02H	+3.40	TECTEH			A9608	reso	21H00120	C 0	600UL
199			0.39	79	MBM	5	02H	+4.14	TECTEH			A9608	reso	21H00120	C 0	600UL
200	16	24	0.12	77	SAI	2	TSH	+0.88	TSHTSH	0.3		C3340	reso	21H00103	H 0	600PP
201					SAI	1	TSH	+0.88	TSHTSH	0		C3340	reso	21H00103	H 0	600PP
202			0.11	111	PID	4	TSH	+0.88	TSHTSH			S1848	rpri	21H00149	H99	600HF
203	18	24	2.26	88	MBM	5	04H	+18.61	TECTEH			R6452	reso	21H00119	C 0	600UL
204			1.00	88	MBM	5	04H	+19.82	TECTEH			R6452	reso	21H00119	C 0	600UL
205	22	24	0.14	82	SAI	2	TSH	+0.66	TSHTSH	0.6		T0042	reso	21H00102	H 0	600PP
206			0.42	110	SAI	1	TSH	+0.66	TSHTSH	0.6		T0042	reso	21H00102	H 0	600PP
207			0.11	84	PID	4	TSH	+0.66	TSHTSH			S1848	rpri	21H00149	H99	600HF
208	24	24	0.19	85	MAI	2	TSH	+0.64	TSHTSH	0.2		C3340	reso	21H00103	H 0	600PP
209			0.12	83	MAI	1	TSH	+0.64	TSHTSH	0.2		C3340	reso	21H00103	H 0	600PP
210			0.17	100	PID	4	TSH	+0.64	TSHTSH			S1848	rpri	21H00149	H99	600HF
211	36	24	0.14	79	MAI	2	TSH	+0.30 TO+0.67	TSHTSH	0.2		C3340	reso	21H00102	H 0	600PP
212			0.09	62	MAI	1	TSH	+0.30 TO+0.67	TSHTSH	0.2		C3340	reso	21H00102	H 0	600PP
213			0.10	72	PID	4	TSH	+0.30 TO+0.67	TSHTSH			S1848	rpri	21H00149	H99	600HF
214	42	24	1.02	90	MBM	6	01C	+12.26	TECTEH			A9608	reso	21H00120	C 0	600UL
215			0.87	101	MBM	5	01C	+36.37	TECTEH			A9608	reso	21H00120	C 0	600UL
216	56	24	1.62		PLP	9	TSC	+2.46	TSCTSC			S0607	rsec	21C00174	C 3	600PP
[illegible]	80	24	0.55	86	MBM	5	05H	+7.08	TECTEH			R6452	reso	21H00119	C 0	600UL
2[illegible]			0.60	84	MBM	5	07H	+19.58	TECTEH			R6452	reso	21H00119	C 0	600UL
219	21	25	0.10	85	SAI	2	TSH	+0.78	TSHTSH	0.4		C3340	reso	21H00103	H 0	600PP
220					SAI	1	TSH	+0.78	TSHTSH	0		C3340	reso	21H00103	H 0	600PP
221			0.09	91	PID	4	TSH	+0.78	TSHTSH			S1848	rpri	21H00149	H99	600HF
222	51	25	0.68	79	MBM	5	TSH	+34.53	TECTEH			R6452	reso	21H00119	C 0	600UL
223	61	25	0.78	5	IDM	2	TSH	+1.99	TSHTSH			C3340	reso	21H00102	H 0	600PP
224			0.50	2	IDM	2	TSH	+3.45	TSHTSH			C3340	reso	21H00102	H 0	600PP
225	75	25	0.53	85	MBM	5	03C	+5.23	TECTEH			R6452	reso	21H00119	C 0	600UL
226	89	25	0.60	64	MBM	6	04C	+30.96	TECTEH			A9608	reso	21H00120	C 0	600UL
227	97	25	0.74	78	MBM	5	02H	+3.60	TECTEH			A9608	reso	21H00120	C 0	600UL
228	24	26	0.40	77	MBM	5	05H	+8.81	TECTEH			R6452	reso	21H00119	C 0	600UL
229	34	26	0.22	99	MAI	2	TSH	+0.50 TO+1.07	TSHTSH	0.5		C3340	reso	21H00102	H 0	600PP
230			0.17	86	MAI	1	TSH	+0.50 TO+1.07	TSHTSH	0.5		C3340	reso	21H00102	H 0	600PP
231			0.20	101	PID	4	TSH	+0.50 TO+1.07	TSHTSH			S1848	rpri	21H00149	H99	600HF
232	36	26	0.20	110	MAI	2	TSH	+0.18 TO+0.88	TSHTSH	0.2		C3340	reso	21H00102	H 0	600PP
233			0.23	82	MAI	1	TSH	+0.18 TO+0.88	TSHTSH	0.3		C3340	reso	21H00102	H 0	600PP
234			0.17	116	PID	4	TSH	+0.18 TO+0.88	TSHTSH			S1848	rpri	21H00149	H99	600HF
235	40	26	0.10	124	SAI	2	TSH	+0.63	TSHTSH	0.2		C3340	reso	21H00103	H 0	600PP
236					SAI	1	TSH	+0.63	TSHTSH	0		C3340	reso	21H00103	H 0	600PP
237			0.12	79	PID	4	TSH	+0.63	TSHTSH			S1848	rpri	21H00149	H99	600HF
238	96	26	0.37	95	13	P2	VC	-1.85	TECTEH			O1057	rpri	21H00119	C 0	600UL
239			0.29	114	WAR	P4	VC	-1.77	VC VC			R6452	reso	21C00184	C 2	600PP
240	25	27	0.08	49	SAI	2	TSH	+0.78	TSHTSH	0.3		C3340	reso	21H00102	H 0	600PP
241					SAI	1	TSH	+0.78	TSHTSH	0		C3340	reso	21H00102	H 0	600PP
242			0.11	50	PID	4	TSH	+0.78	TSHTSH			S1848	rpri	21H00149	H99	600HF
	47	27	0.12	109	SAI	2	TSH	+0.84	TSHTSH	0.2		C3340	reso	21H00102	H 0	600PP
244			0.05	116	SAI	1	TSH	+0.84	TSHTSH	0.2		C3340	reso	21H00102	H 0	600PP
245			0.12	115	PID	4	TSH	+0.84	TSHTSH			S1848	rpri	21H00150	H99	600HF

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final —

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
246	87	27	0.94	84	MBM	5	02H	+6.53		TECTEH			A9608	reso	21H00120	C 0 600UL
247			0.55	88	MBM	5	02C	+3.08		TECTEH			A9608	reso	21H00120	C 0 600UL
248	89	27	0.40	84	MBM	5	04H	+18.27		TECTEH			R6452	reso	21H00119	C 0 600UL
249	95	27	0.35	138	13	P2	VH	+1.23		TECTEH			A9608	reso	21H00120	C 0 600UL
250			0.50	85	WAR	2	VH	+1.25		VH 09H			B3720	reso	21H00168	H 4 560PF
251	4	28	0.86	78	MBM	5	03C	+28.25		06HTEC			D3858	reso	21C00186	C 1 580SF
252	24	28	0.25	31	INR	P2	VM	+1.87		TECTEH			A9608	reso	21H00121	C 0 600UL
253	48	28			MAI	1	TSH	+0.36		TSHTSH	0		C3340	reso	21H00103	H 0 600PP
254			0.21	104	MAI	2	TSH	+0.36		TSHTSH	0.4		C3340	reso	21H00103	H 0 600PP
255			0.18	100	PID	4	TSH	+0.36		TSHTSH			S1848	rpri	21H00150	H99 600HF
256			0.36	160	NQI	P1	TSH	+0.49		TECTEH			L6066	rsec	21H00122	C 0 600UL
257	62	28	1.07	90	MBM	5	05C	+10.59		TECTEH			A9608	reso	21H00121	C 0 600UL
258	66	28	0.27	87	NQI	5	07H	+5.45		TECTEH			A9608	reso	21H00121	C 0 600UL
259					NDF		07H	+5.45		07H08H			T7451	rsec	21H00167	H 4 600PP
260	11	29	0.64	88	MBM	5	01H	+22.04		TECTEH			A9608	reso	21H00122	C 0 600UL
261			0.64	78	MBM	5	01H	+22.59		TECTEH			A9608	reso	21H00122	C 0 600UL
262			0.88	87	MBM	5	02H	+31.22		TECTEH			A9608	reso	21H00122	C 0 600UL
263	29	29	0.15	114	MAI	1	TSH	+0.43	TO+1.36	TSHTSH	0.4		C3340	reso	21H00102	H 0 600PP
264			0.20	115	MAI	2	TSH	+0.43	TO+1.36	TSHTSH	0.6		C3340	reso	21H00102	H 0 600PP
265			0.20	110	PID	4	TSH	+0.43	TO+1.36	TSHTSH			S1848	rpri	21H00150	H99 600HF
[illegible]			0.33	86	NQI	P1	TSH	+0.81		TECTEH			L2157	rpri	21H00129	C 0 600UL
2[illegible]	53	29	0.20	100	SAI	2	TSH	+0.16		TSHTSH	0.2		C3340	reso	21H00103	H 0 600PP
268			0.10	90	SAI	1	TSH	+0.16		TSHTSH	0.3		C3340	reso	21H00103	H 0 600PP
269			0.23	84	PID	4	TSH	+0.16		TSHTSH			S1848	rpri	21H00150	H99 600HF
270	63	29	0.46	59	MBM	6	TSH	+18.57		TECTEH			A9608	reso	21H00121	C 0 600UL
271	65	29	0.89	81	MBM	5	01H	+21.75		TECTEH			A9608	reso	21H00122	C 0 600UL
272	71	29	0.57	71	MBM	5	01H	+26.88		TECTEH			A9608	reso	21H00121	C 0 600UL
273	101	29	1.64	66	MBM	6	TSC	+21.54		TECTEH			A9608	reso	21H00122	C 0 600UL
274	60	30	0.55	79	MBM	5	TSH	+30.52		TECTEH			H2131	reso	21H00124	C 0 600UL
275	94	30	2.83	138	INR	6	01C	+4.00	TO+11.44	TECTEH			T7451	rsec	21H00123	C 0 600UL
276	98	30	0.85	88	MBM	6	04H	+16.61		TECTEH			A9608	reso	21H00123	C 0 600UL
277	23	31	1.02	88	MBM	5	04C	+26.23		TEHTEC			C3340	reso	21C00105	C 0 600UL
278	25	31	0.12	78	MAI	1	TSH	+1.07		TSHTSH	0.4		C3340	reso	21H00096	H 0 600PP
279			0.14	94	MAI	2	TSH	+1.07		TSHTSH	0.4		C3340	reso	21H00096	H 0 600PP
280			0.11	93	PID	4	TSH	+1.07		TSHTSH			K2858	rpri	21H00114	H99 600HF
281	71	31	0.90	98	MBM	5	04C	+11.14		TEHTEC			C3340	reso	21C00105	C 0 600UL
282	87	31	0.68	83	MBM	5	05C	+5.05		TEHTEC			C3340	reso	21C00105	C 0 600UL
283	89	31	0.37	54	MBM	6	02H	+28.52		TEHTEC			K7060	reso	21C00106	C 0 600UL
284	95	31	0.43	125	WAR	2	VM	-1.10		VM VM			M1680	reso	21H00168	H 4 560PF
285			0.49	104	17	P2	VM	-1.08		TEHTEC			B6768	rpri	21C00105	C 0 600UL
286	10	32	0.19	82	SAI	1	TSH	+1.08		TSHTSH	0.2		M1680	reso	21H00097	H 0 600PP
287			0.16	115	SAI	2	TSH	+1.08		TSHTSH	0.4		M1680	reso	21H00097	H 0 600PP
288			0.23	108	PID	4	TSH	+1.08		TSHTSH			K2858	rpri	21H00114	H99 600HF
289	36	32	0.66	78	MBM	5	04C	+27.83		TEHTEC			M1680	reso	21C00102	C 0 600UL
290	56	32	0.19	94	SAI	2	TSH	+0.77		TSHTSH	0.3		S7752	reso	21H00095	H 0 600PP
291			0.29	86	SAI	1	TSH	+0.77		TSHTSH	0.3		S7752	reso	21H00095	H 0 600PP
			0.18	94	PID	4	TSH	+0.77		TSHTSH			K2858	rpri	21H00114	H99 600HF
293	84	32	0.67	34	MBM	6	01H	+2.79		TEHTEC			K7060	reso	21C00106	C 0 600UL
294	98	32	0.66	85	MBM	5	05C	+6.12		TEHTEC			C3340	reso	21C00105	C 0 600UL

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
295	7	33			OBS	06H	+16.62		05H06H			M1680	reso	21H00140	H 2	560PF
296	43	33	0.12	133	SCI	P1 TSH	+0.17		TSHTSH	0.2		A9608	reso	21H00095	H 0	600PP
297				132	SCI	1 TSH	+0.17		TSHTSH	0		A9608	reso	21H00095	H 0	600PP
298			0.23	154	PID	P1 TSH	+0.17		TSHTSH			K2858	rpri	21H00114	H99	600HF
299	55	33	0.11	111	MAI	2 TSH	+0.90		TSHTSH	0.3		C3340	reso	21H00096	H 0	600PP
300			0.32	133	NQI	P1 TSH	+0.90		TEHTEC			C3340	reso	21C00103	C 0	600UL
301			0.10	46	MAI	1 TSH	+0.90		TSHTSH	0.2		A9608	reso	21H00096	H 0	600PP
302			0.10	113	PID	4 TSH	+0.90		TSHTSH			K2858	rpri	21H00114	H99	600HF
303	109	33	1.97	82	MBM	5 07C	+23.42		TEHTEC			M1680	reso	21C00102	C 0	600UL
304			0.50	30	INR	P1 TSC	+2.66		TEHTEC			M1680	reso	21C00102	C 0	600UL
305	10	34	0.98	160	INR	P1 VM	-1.84	TO+0.45	TEHTEC			K2858	rpri	21C00103	C 0	600UL
306	28	34	0.51	71	MBM	5 02H	+25.59		TEHTEC			C3340	reso	21C00103	C 0	600UL
307	46	34			MSI	1 TSH	+0.37	TO+1.29	TSHTSH	0		S7752	reso	21H00095	H 0	600PP
308			0.17	106	MSI	2 TSH	+0.37	TO+1.29	TSHTSH	0.3		S7752	reso	21H00095	H 0	600PP
309			0.11	108	PID	4 TSH	+0.37	TO+1.29	TSHTSH			K2858	rpri	21H00114	H99	600HF
310			0.27	98	NQI	P1 TSH	+0.73		TEHTEC			D4576	rsec	21C00102	C 0	600UL
311			2.08	85	MBM	6 05H	+6.57		TEHTEC			M1680	reso	21C00102	C 0	600UL
312	48	34	0.36	97	NQI	P1 TSH	+0.69		TEHTEC			D4576	rsec	21C00102	C 0	600UL
313			0.18	76	MAI	1 TSH	+0.70		TSHTSH	0.4		C3340	reso	21H00096	H 0	600PP
314			0.12	104	MAI	2 TSH	+0.70		TSHTSH	0.4		C3340	reso	21H00096	H 0	600PP
?			0.11	88	PID	4 TSH	+0.70		TSHTSH			K2858	rpri	21H00114	H99	600HF
3.	64	34			INF	TSH	+0.71		TEHTEC	HR		M1680	reso	21C00103	C 0	600UL
317	66	34	0.74	89	MBM	6 07H	+10.76		TEHTEC			M1680	reso	21C00102	C 0	600UL
318	84	34	1.75	94	INR	6 TSH	+28.60		TEHTEC			K2858	rpri	21C00103	C 0	600UL
319			1.12	91	INR	6 VM	+13.13		TEHTEC			K2858	rpri	21C00103	C 0	600UL
320	92	34	0.60	92	MBM	5 03H	+14.59		TEHTEC			C3340	reso	21C00103	C 0	600UL
321	9	35	0.47	152	INR	P1 VM	+0.29		TEHTEC			M1680	reso	21C00102	C 0	600UL
322	17	35	0.11	52	SAI	2 TSH	+0.29		TSHTSH	0.2		K7060	reso	21H00098	H 0	600PP
323					SAI	1 TSH	+0.29		TSHTSH	0.0		K7060	reso	21H00098	H 0	600PP
324			0.07	55	PID	4 TSH	+0.29		TSHTSH			K2858	rpri	21H00114	H99	600HF
325					SAI	1 TSH	+3.16		TSHTSH	0.0		K7060	reso	21H00098	H 0	600PP
326			0.10	94	SAI	2 TSH	+3.16		TSHTSH	0.3		K7060	reso	21H00098	H 0	600PP
327	23	35	0.17	110	MAI	2 TSH	+1.19		TSHTSH	0.2		A9608	reso	21H00096	H 0	600PP
328			0.08	85	MAI	1 TSH	+1.19		TSHTSH	0.3		A9608	reso	21H00096	H 0	600PP
329			0.16	104	PID	4 TSH	+1.19		TSHTSH			K2858	rpri	21H00114	H99	600HF
330			0.31	130	NQI	P1 TSH	+1.39		TEHTEC			K2858	rpri	21C00103	C 0	600UL
331	25	35	0.14	90	SAI	2 TSH	+1.01		TSHTSH	0.2		A9608	reso	21H00096	H 0	600PP
332					SAI	1 TSH	+1.01		TSHTSH	0		A9608	reso	21H00096	H 0	600PP
333			0.11	94	PID	4 TSH	+1.01		TSHTSH			K2858	rpri	21H00114	H99	600HF
334	57	35			SAI	1 TSH	+1.03		TSHTSH	0		S7752	reso	21H00095	H 0	600PP
335			0.13	118	SAI	2 TSH	+1.03		TSHTSH	0.2		S7752	reso	21H00095	H 0	600PP
336			0.13	124	PID	4 TSH	+1.03		TSHTSH			K2858	rpri	21H00114	H99	600HF
337			0.94	65	MBM	6 TSC	+8.41		TEHTEC			M1680	reso	21C00102	C 0	600UL
338	89	35	0.49	82	MBM	5 TSC	+12.78		TEHTEC			C3340	reso	21C00103	C 0	600UL
339	113	35	0.75	83	MBM	5 05C	+7.82		TEHTEC			M1680	reso	21C00102	C 0	600UL
340	2	36	0.61	94	PLP	10 TSH	+0.05		TSHTSH			L6066	rsec	21H00098	H 0	600PP
	24	36	0.72	100	MBM	5 04C	+26.56		TEHTEC			C3340	reso	21C00101	C 0	600UL
342	26	36	0.11	114	SAI	2 TSH	+1.40		TSHTSH	0.2		S7752	reso	21H00095	H 0	600PP
343					SAI	1 TSH	+1.40		TSHTSH	0		S7752	reso	21H00095	H 0	600PP

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
344			0.08	108	PID	4	TSH	+1.40		TSHTSH			K2858	rpri	21H00114	H99 600HF
345					SAI	1	TSH	+1.59		TSHTSH	0		S7752	reso	21H00095	H 0 600PP
346			0.10	106	SAI	2	TSH	+1.59		TSHTSH	0.2		S7752	reso	21H00095	H 0 600PP
347	28	36	0.56	70	MBM	5	TSH	+34.16		TEHTEC			C3340	reso	21C00101	C 0 600UL
348	52	36	0.21	78	SAI	2	TSH	+0.88		TSHTSH	0.3		A9608	reso	21H00096	H 0 600PP
349			0.25	119	SAI	1	TSH	+0.88		TSHTSH	0.3		A9608	reso	21H00096	H 0 600PP
350			0.20	89	PID	4	TSH	+0.88		TSHTSH			K2858	rpri	21H00114	H99 600HF
351	66	36	0.09	99	SAI	2	TSH	+1.00		TSHTSH	0.3		S7752	reso	21H00093	H 0 600PP
352			0.15	61	SAI	1	TSH	+1.00		TSHTSH	0.3		S7752	reso	21H00093	H 0 600PP
353			0.07	91	PID	4	TSH	+1.00		TSHTSH			K2858	rpri	21H00114	H99 600HF
354	106	36	1.43	67	MBM	6	04H	+26.73		TEHTEC			M1680	reso	21C00102	C 0 600UL
355					NDF		08H	-0.33		08H08H			M1680	reso	21H00167	H 4 600PP
356			0.66	36	DSI	P1	08H	-0.31		TEHTEC			D4576	rsec	21C00102	C 0 600UL
357	1	37			OBS		06C	+1.77		06CTEC			A9608	reso	21C00083	C 1 580SF
358	23	37	0.12	64	SAI	2	TSH	+0.82		TSHTSH	0.2		A9608	reso	21H00096	H 0 600PP
359			0.08	126	SAI	1	TSH	+0.82		TSHTSH	0.2		C3340	reso	21H00096	H 0 600PP
360			0.13	61	PID	4	TSH	+0.82		TSHTSH			K2858	rpri	21H00114	H99 600HF
361	27	37	0.72	74	MBM	5	01C	+1.46		TEHTEC			C3340	reso	21C00101	C 0 600UL
362	31	37	0.59	74	MBM	5	TSC	+29.28		TEHTEC			C3340	reso	21C00101	C 0 600UL
363	63	37	0.12	115	MAI	2	TSH	+0.69		TSHTSH	0.2		S7752	reso	21H00093	H 0 600PP
[illegible]					MAI	1	TSH	+0.69		TSHTSH	0		S7752	reso	21H00093	H 0 600PP
3[illegible]			0.09	104	PID	4	TSH	+0.69		TSHTSH			K2858	rpri	21H00114	H99 600HF
366	69	37	1.20	87	MBM	5	05H	+14.14		TEHTEC			C3340	reso	21C00101	C 0 600UL
367	73	37	0.17	102	MAI	2	TSH	+0.33		TSHTSH	0.3		H2131	reso	21H00094	H 0 600PP
368			0.14	71	MAI	1	TSH	+0.33		TSHTSH	0.3		H2131	reso	21H00094	H 0 600PP
369			0.16	110	PID	4	TSH	+0.33		TSHTSH			K2858	rpri	21H00114	H99 600HF
370	95	37	0.90	87	MBM	5	05H	+16.44		TEHTEC			C3340	reso	21C00100	C 0 600UL
371			0.62	96	MBM	5	TSC	+16.19		TEHTEC			C3340	reso	21C00100	C 0 600UL
372	99	37	0.28	97	MBM	5	03H	+18.74		TEHTEC			C3340	reso	21C00100	C 0 600UL
373	109	37	0.63	6	IDM	2	TSH	+5.78		TSHTSH			H2131	reso	21H00094	H 0 600PP
374	113	37	1.26	85	MBM	5	05H	+32.35		TEHTEC			C3340	reso	21C00101	C 0 600UL
375	115	37	0.74	83	MBM	5	01H	+16.30		TEHTEC			C3340	reso	21C00100	C 0 600UL
376			0.45	77	MBM	5	01H	+37.58		TEHTEC			C3340	reso	21C00100	C 0 600UL
377	12	38			OBS		06H	+10.76		05H06H			M1680	reso	21H00141	H 2 560PF
378	16	38			SAI	1	TSH	+2.62		TSHTSH	0.0		K7060	reso	21H00098	H 0 600PP
379			0.08	81	SAI	2	TSH	+2.62		TSHTSH	0.2		K7060	reso	21H00098	H 0 600PP
380			0.08	105	PID	4	TSH	+2.62		TSHTSH			K2858	rpri	21H00114	H99 600HF
381			0.19	99	NQI	P1	TSH	+2.64		TEHTEC			C3340	reso	21C00100	C 0 600UL
382	18	38	0.40	78	MBM	5	01H	+12.62		TEHTEC			C3340	reso	21C00101	C 0 600UL
383			0.41	76	MBM	5	01H	+32.07		TEHTEC			C3340	reso	21C00101	C 0 600UL
384	44	38	1.47	60	MBM	6	05C	+1.50		TEHTEC			C3340	reso	21C00101	C 0 600UL
385			4.06	74	MBM	6	04C	+36.46		TEHTEC			C3340	reso	21C00101	C 0 600UL
386	54	38	0.14	112	MAI	4	TSH	+0.54	TO+1.01	TSHTSH	0.5		K7060	reso	21H00114	H 0 600HF
387			0.21	40	MAI	3	TSH	+0.54	TO+1.01	TSHTSH	0.3		K7060	reso	21H00114	H 0 600HF
388			0.12	111	PID	4	TSH	+0.54	TO+1.01	TSHTSH			S1848	rpri	21H00150	H99 600HF
389	64	38	1.01	87	MBM	5	TSH	+4.34		TEHTEC			C3340	reso	21C00101	C 0 600UL
			0.55	144	VOL	2	TSH	+4.54		TSHTSH			H2131	reso	21H00094	H 0 600PP
391	100	38	0.96	10	INR	P1	TSH	+0.86		TEHTEC			B6768	rpri	21C00100	C 0 600UL
392	104	38	0.54	63	INR	P1	09H	-0.08		TEHTEC			C3340	reso	21C00100	C 0 600UL

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final — PAGE 9

	ROW	LIN	VOLTS	DEG	PCT	CHN.	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
393	110	38	1.14	86	MBM	6	04H	+35.51	TEHTEC			C3340	reso	21C00101	C 0 600UL
394	116	38	0.55	68	MBM	5	TSH	+4.74	TEHTEC			C3340	reso	21C00100	C 0 600UL
395			0.16	78	VOL	2	TSH	+4.82	TSHTSH			S7752	reso	21H00093	H 0 600PP
396	37	39	1.14	67	MBM	6	02H	+29.24	TEHTEC			C3340	reso	21C00100	C 0 600UL
397			1.33	44	MBM	6	02H	+34.54	TEHTEC			C3340	reso	21C00100	C 0 600UL
398	51	39	0.71	78	MBM	6	03C	+31.78	TEHTEC			C3340	reso	21C00101	C 0 600UL
399	53	39			SAI	3	TSH	+0.48	TSHTSH	0.0		K7060	reso	21H00114	H 0 600HF
400			0.06	112	SAI	4	TSH	+0.48	TSHTSH	0.2		K7060	reso	21H00114	H 0 600HF
401			0.07	131	PID	4	TSH	+0.48	TSHTSH			S1848	rpri	21H00150	H99 600HF
402			0.79	87	MBM	5	01C	+23.06	TEHTEC			C3340	reso	21C00100	C 0 600UL
403	55	39	0.18	88	SAI	2	TSH	+0.61	TSHTSH	0.3		C3340	reso	21H00096	H 0 600PP
404			0.13	18	SAI	1	TSH	+0.61	TSHTSH	0.2		A9608	reso	21H00096	H 0 600PP
405			0.20	75	PID	4	TSH	+0.61	TSHTSH			K2858	rpri	21H00114	H99 600HF
406	71	39			SAI	1	TSH	+0.55	TSHTSH	0		S7752	reso	21H00093	H 0 600PP
407			0.09	107	SAI	2	TSH	+0.55	TSHTSH	0.3		S7752	reso	21H00093	H 0 600PP
408			0.08	82	PID	4	TSH	+0.55	TSHTSH			K2858	rpri	21H00114	H99 600HF
409			0.46	80	MBM	5	02C	+14.30	TEHTEC			C3340	reso	21C00100	C 0 600UL
410	95	39	0.66	109	DSI	P1	09H	+0.19	TEHTEC			K2858	rpri	21C00101	C 0 600UL
411					NDF		09H	+0.19	09H09H			T7451	rsec	21H00167	H 4 600PP
412	18	40	0.59	77	MBM	6	02C	+25.95	TEHTEC			K7060	reso	21C00099	C 0 600UL
[illegible]			1.01	65	MBM	6	02C	+29.41	TEHTEC			K7060	reso	21C00099	C 0 600UL
414	23	40	0.20	78	SAI	2	TSH	+0.22	TSHTSH	0.2		A9608	reso	21H00096	H 0 600PP
415			0.06	158	SAI	1	TSH	+0.22	TSHTSH	0.2		C3340	reso	21H00096	H 0 600PP
416			0.17	77	PID	4	TSH	+0.22	TSHTSH			K2858	rpri	21H00114	H99 600HF
417	28	40			NDF	2	TSH	+1.16	TSHTSH			S7752	reso	21H00096	H 0 600PP
418			0.57	31	NQI	P1	TSH	+1.16	TEHTEC			K2858	rpri	21C00099	C 0 600UL
419	38	40	0.58	83	MBM	5	02C	+26.10	TEHTEC			K7060	reso	21C00098	C 0 600UL
420	58	40	0.22	100	SAI	4	TSH	+0.94	TSHTSH	0.2		K7060	reso	21H00114	H 0 600HF
421					SAI	3	TSH	+0.94	TSHTSH	0.0		K7060	reso	21H00114	H 0 600HF
422			0.19	86	PID	4	TSH	+0.94	TSHTSH			S1848	rpri	21H00150	H99 600HF
423	116	40	0.69	81	MBM	5	04H	+22.12	TEHTEC			K7060	reso	21C00098	C 0 600UL
424	7	41	0.56	79	MBM	5	02C	+17.40	TEHTEC			K7060	reso	21C00099	C 0 600UL
425	17	41	0.13	76	SAI	2	TSH	+0.49	TSHTSH	0.2		K7060	reso	21H00098	H 0 600PP
426					SAI	1	TSH	+0.49	TSHTSH	0.0		K7060	reso	21H00098	H 0 600PP
427			0.12	78	PID	4	TSH	+0.49	TSHTSH			K2858	rpri	21H00114	H99 600HF
428	21	41	0.21	72	SAI	2	TSH	+0.28	TSHTSH	0.2		A9608	reso	21H00096	H 0 600PP
429			0.18	136	SAI	1	TSH	+0.28	TSHTSH	0.2		C3340	reso	21H00096	H 0 600PP
430			0.16	79	PID	4	TSH	+0.28	TSHTSH			K2858	rpri	21H00114	H99 600HF
431	65	41	0.12	84	MAI	2	TSH	+0.99	TSHTSH	0.2		H2131	reso	21H00094	H 0 600PP
432					MAI	1	TSH	+0.99	TSHTSH	0		H2131	reso	21H00094	H 0 600PP
433			0.10	117	PID	4	TSH	+0.99	TSHTSH			K2858	rpri	21H00114	H99 600HF
434	71	41	0.14	75	SAI	1	TSH	+0.83	TSHTSH	0.2		H2131	reso	21H00094	H 0 600PP
435			0.10	82	SAI	2	TSH	+0.83	TSHTSH	0.2		H2131	reso	21H00094	H 0 600PP
436			0.12	93	PID	4	TSH	+0.83	TSHTSH			K2858	rpri	21H00114	H99 600HF
437			0.75	70	MBM	5	01H	+23.68	TEHTEC			K7060	reso	21C00098	C 0 600UL
438			0.51	78	MBM	5	03H	+4.61	TEHTEC			K7060	reso	21C00098	C 0 600UL
	101	41	0.46	81	INR	P1	09H	-0.25	TEHTEC			K7060	reso	21C00099	C 0 600UL
440	115	41	0.25	83	PLP	9	TSH	+0.41	TSHTSH			S7752	reso	21H00093	H 0 600PP
441	24	42	0.69	80	MBM	5	TSH	+30.96	TEHTEC			K7060	reso	21C00098	C 0 600UL

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final — PAGE 10

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
442	46	42	0.92	58	MBM	6 02H	+32.68		TEHTEC			K7060	reso	21C00098	C 0	600UL
443	56	42	0.77	72	MBM	5 05H	+17.55		TEHTEC			K7060	reso	21C00099	C 0	600UL
444	58	42			MAI	3 TSH	+0.00	TO+1.82	TSHTSH	0.0		K7060	reso	21H00114	H 0	600HF
445			0.13	104	MAI	4 TSH	+0.00	TO+1.82	TSHTSH	0.4		K7060	reso	21H00114	H 0	600HF
446			0.08	101	PID	4 TSH	+0.00	TO+1.82	TSHTSH			S1848	rpri	21H00150	H99	600HF
447			0.36	136	NQI	P1 TSH	+0.95		TEHTEC			M1680	reso	21C00098	C 0	600UL
448	62	42	0.46	116	DSI	P1 05C	-0.48		TEHTEC			P5436	rpri	21C00098	C 0	600UL
449					NDF	05C	-0.48		05C05C			L7871	rpri	21C00185	C 2	600PP
450	64	42	0.14	99	SAI	2 TSH	+0.95		TSHTSH	0.2		S7752	reso	21H00093	H 0	600PP
451					SAI	1 TSH	+0.95		TSHTSH	0		S7752	reso	21H00093	H 0	600PP
452			0.11	101	PID	4 TSH	+0.95		TSHTSH			K2858	rpri	21H00114	H99	600HF
453	66	42	0.51	64	MBM	5 01H	+26.96		TEHTEC			K7060	reso	21C00098	C 0	600UL
454	78	42	1.43	90	MBM	5 05C	+1.66		TEHTEC			K7060	reso	21C00098	C 0	600UL
455	108	42	0.23	58	INR	P1 05C	+0.50		TEHTEC			L7871	rpri	21C00099	C 0	600UL
456	116	42	0.25	78	INR	9 TSH	+0.58		TSHTSH			H2131	reso	21H00094	H 0	600PP
457	120	42	0.49	80	MBM	5 03C	+24.00		TEHTEC			R6452	reso	21C00055	C 0	580UL
458	1	43	0.49	76	PLP	10 TSH	+0.35		TSHTSH			L6066	rsec	21H00098	H 0	600PP
459	25	43	0.17	82	SAI	2 TSH	+0.54		TSHTSH	0.3		S7752	reso	21H00095	H 0	600PP
460					SAI	1 TSH	+0.54		TSHTSH	0		S7752	reso	21H00095	H 0	600PP
461			0.10	74	PID	4 TSH	+0.54		TSHTSH			K2858	rpri	21H00114	H99	600HF
[illegible]	75	43	0.63	78	MBM	5 03H	+12.35		TEHTEC			K7060	reso	21C00099	C 0	600UL
[illegible]	77	43	0.44	84	MBM	5 02H	+26.80		TEHTEC			K7060	reso	21C00098	C 0	600UL
464	81	43	0.70	71	MBM	6 01C	+14.25		TEHTEC			K7060	reso	21C00099	C 0	600UL
465	109	43	0.61	85	MBM	5 05H	+2.83		TEHTEC			K7060	reso	21C00099	C 0	600UL
466	119	43	1.46	159	DSI	P1 DC	-0.79		TEHTEC			D3858	reso	21C00098	C 0	600UL
467					NDF	DC	-0.79		DC DC			L7871	rpri	21C00184	C 2	560PF
468	2	44	0.48	93	PLP	10 TSH	+2.47		TSHTSH			C3340	reso	21H00098	H 0	600PP
469	26	44	0.27	98	MAI	2 TSH	+0.50		TSHTSH	0.4		A9608	reso	21H00096	H 0	600PP
470			0.40	100	MAI	1 TSH	+0.50		TSHTSH	0.3		A9608	reso	21H00096	H 0	600PP
471			0.32	95	PID	4 TSH	+0.50		TSHTSH			K2858	rpri	21H00114	H99	600HF
472	54	44	0.76	83	MBM	5 01H	+34.16		TEHTEC			K7060	reso	21C00096	C 0	600UL
473	72	44	0.12	101	MAI	2 TSH	+0.77		TSHTSH	0.3		H2131	reso	21H00094	H 0	600PP
474					MAI	1 TSH	+0.77		TSHTSH	0		H2131	reso	21H00094	H 0	600PP
475			0.14	77	PID	4 TSH	+0.77		TSHTSH			K2858	rpri	21H00114	H99	600HF
476	74	44	0.72	19	INR	P1 TSH	+0.89		TEHTEC			L7773	rpri	21C00096	C 0	600UL
477	82	44	0.25	102	MAI	1 TSH	+0.52		TSHTSH	0.3		H2131	reso	21H00094	H 0	600PP
478			0.28	99	MAI	2 TSH	+0.52		TSHTSH	0.4		H2131	reso	21H00094	H 0	600PP
479			0.20	89	PID	4 TSH	+0.52		TSHTSH			K2858	rpri	21H00114	H99	600HF
480			0.65	53	NQI	P1 TSH	+0.55		TEHTEC			P4634	rsec	21C00099	C 0	600UL
481	98	44	0.47	105	MBM	5 02C	+30.97		TEHTEC			K7060	reso	21C00099	C 0	600UL
482	104	44	0.98	117	INR	P1 09H	+0.00		TEHTEC			K7060	reso	21C00098	C 0	600UL
483	110	44	0.42	83	MBM	5 05H	+8.19		TEHTEC			K7060	reso	21C00099	C 0	600UL
484	120	44	1.05	74	MBM	6 05H	+20.33		TEHTEC			A9608	reso	21C00054	C 0	580UL
485	122	44	0.68	92	INR	6 05H	+18.94		TEHTEC			R9311	rpri	21C00055	C 0	580UL
486	21	45	0.16	106	MAI	2 TSH	+0.13	TO+0.71	TSHTSH	0.2		A9608	reso	21H00096	H 0	600PP
487					MAI	2 TSH	+0.13	TO+0.71	TSHTSH	0		A9608	reso	21H00096	H 0	600PP
			0.18	86	PID	4 TSH	+0.13	TO+0.71	TSHTSH			K2858	rpri	21H00114	H99	600HF
489	25	45	0.07	112	MAI	2 TSH	+0.46		TSHTSH	0.2		A9608	reso	21H00096	H 0	600PP
490					MAI	1 TSH	+0.46		TSHTSH	0		A9608	reso	21H00096	H 0	600PP

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final — PAGE 11

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
491			0.07	95	PID	4 TSH	+0.46		TSHTSH			K2858	rpri	21H00114	H99	600HF
492	57	45	0.84	77	MBM	6 04H	+35.22		TEHTEC			H2131	reso	21C00097	C 0	600UL
493	71	45	0.82	53	MBM	5 01H	+26.41		TEHTEC			K7060	reso	21C00096	C 0	600UL
494			0.56	73	MBM	5 03H	+26.82		TEHTEC			K7060	reso	21C00096	C 0	600UL
495	81	45	0.44	102	MAI	2 TSH	+0.50		TSHTSH	0.5		H2131	reso	21H00094	H 0	600PP
496			0.78	109	MAI	1 TSH	+0.50		TSHTSH	0.4		H2131	reso	21H00094	H 0	600PP
497			0.48	100	PID	4 TSH	+0.50		TSHTSH			K2858	rpri	21H00114	H99	600HF
498	95	45	1.30	83	MBM	5 01H	+26.79		TEHTEC			K7060	reso	21C00096	C 0	600UL
499	105	45	0.96	67	MBM	5 09H	+7.35		TEHTEC			H2131	reso	21C00097	C 0	600UL
500	119	45	0.24	82	PLP	9 TSH	+0.50		TSHTSH			S7752	reso	21H00093	H 0	600PP
501	2	46	0.26	40	PLP	10 TSH	+0.15		TSHTSH			L6066	rsec	21H00098	H 0	600PP
502	22	46	0.12	48	SCI	1 TSH	+0.07		TSHTSH	0.3		C3340	reso	21H00096	H 0	600PP
503			0.16	101	SCI	P1 TSH	+0.07		TSHTSH	0.2		A9608	reso	21H00096	H 0	600PP
504			0.15	91	PID	P1 TSH	+0.07		TSHTSH			M0945	rsec	21H00114	H99	600HF
505			2.57	72	MBM	6 TSC	+9.10		TEHTEC			H2131	reso	21C00097	C 0	600UL
506	36	46	0.09	81	SCI	P1 TSH	+0.15		TSHTSH	0.3		D3858	reso	21H00096	H 0	600PP
507					SCI	1 TSH	+0.15		TSHTSH	0.0		D3858	reso	21H00096	H 0	600PP
508			0.08	77	PID	P1 TSH	+0.15		TSHTSH			S1848	rpri	21H00150	H99	600HF
509	68	46	0.15	97	SAI	2 TSH	+0.58		TSHTSH	0.3		S7752	reso	21H00093	H 0	600PP
510					SAI	1 TSH	+0.58		TSHTSH	0		S7752	reso	21H00093	H 0	600PP
[illegible]			0.15	99	PID	4 TSH	+0.58		TSHTSH			K2858	rpri	21H00114	H99	600HF
512	84	46	1.95	65	MBM	6 04H	+18.27		TEHTEC			H2131	reso	21C00097	C 0	600UL
513	100	46	1.17	62	MBM	6 05H	+7.48		TEHTEC			H2131	reso	21C00097	C 0	600UL
514	108	46	0.57	63	MBM	6 01H	+7.73		TEHTEC			H2131	reso	21C00097	C 0	600UL
515			0.67	73	MBM	5 05H	+31.08		TEHTEC			H2131	reso	21C00097	C 0	600UL
516	120	46	0.38	81	PLP	9 TSH	+0.52		TSHTSH			S7752	reso	21H00093	H 0	600PP
517	7	47			OBS	06H	+15.98		05H06H			K2858	rpri	21H00145	H 2	560PF
518	15	47			MAI	1 TSH	+0.11	TO+0.50	TSHTSH	0.0		M1680	reso	21H00097	H 0	600PP
519			0.16	104	MAI	2 TSH	+0.11	TO+0.50	TSHTSH	0.2		M1680	reso	21H00097	H 0	600PP
520			0.12	110	PID	4 TSH	+0.11	TO+0.50	TSHTSH			K2858	rpri	21H00114	H99	600HF
521	53	47	0.58	82	MBM	5 05C	+15.05		TEHTEC			D3858	reso	21C00096	C 0	600UL
522			0.39	39	VOL	1 05C	+15.05		05C06C			D3858	reso	21C00185	C 2	600PP
523			0.14	127	VOL	2 05C	+15.05		05C06C			D3858	reso	21C00185	C 2	600PP
524	65	47	0.18	112	VOL	2 TSH	+3.05		TSHTSH			S7752	reso	21H00093	H 0	600PP
525			1.80	144	MBM	5 TSH	+18.13		TEHTEC			K7060	reso	21C00096	C 0	600UL
526	73	47	0.55	80	MBM	5 04H	+5.10		TEHTEC			K7060	reso	21C00096	C 0	600UL
527	81	47	0.37	77	MBM	5 TSH	+20.05		TEHTEC			K7060	reso	21C00096	C 0	600UL
528	87	47	0.56	83	MBM	5 02H	+29.14		TEHTEC			K7060	reso	21C00096	C 0	600UL
529	91	47	0.65	76	MBM	5 03H	+4.95		TEHTEC			K7060	reso	21C00096	C 0	600UL
530	113	47	0.20	80	PLP	9 TSC	+2.33		TSCTSC			A9608	reso	21C00170	C 3	600PP
531	115	47	0.15	80	PLP	9 TSC	+1.63		TSCTSC			A9608	reso	21C00170	C 3	600PP
532	123	47	0.15	81	PLP	9 TSC	+0.11		TSCTSC			A9608	reso	21C00160	C 3	600PP
533	56	48	1.39	81	MBM	6 TSC	+26.52		TEHTEC			R6452	reso	21C00015	C 0	600UL
534	70	48	0.13	94	SAI	2 TSH	+0.80		TSHTSH	0.4		H2131	reso	21H00094	H 0	600PP
535					SAI	1 TSH	+0.80		TSHTSH	0		H2131	reso	21H00094	H 0	600PP
536			0.11	98	PID	4 TSH	+0.80		TSHTSH			K2858	rpri	21H00114	H99	600HF
	76	48	0.11	90	SAI	2 TSH	+0.77		TSHTSH	0.2		A9608	reso	21H00093	H 0	600PP
538					SAI	1 TSH	+0.77		TSHTSH	0		A9608	reso	21H00093	H 0	600PP
539			0.08	118	PID	4 TSH	+0.77		TSHTSH			K2858	rpri	21H00114	H99	600HF

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 10:57

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
540	82	48	0.17	42	MAI	1 TSH	+0.72		TSHTSH	0.5		H2131	reso	21H00094	H 0	600PP
541			0.13	91	MAI	2 TSH	+0.72		TSHTSH	0.5		H2131	reso	21H00094	H 0	600PP
542			0.14	88	PID	4 TSH	+0.72		TSHTSH			K2858	rpri	21H00114	H99	600HF
543			0.49	41	NQI	P1 TSH	+0.83		TEHTEC			F7467	rsec	21C00053	C 0	600UL
544	84	48			MAI	1 TSH	+0.83		TSHTSH	0		S7752	reso	21H00093	H 0	600PP
545			0.15	97	MAI	2 TSH	+0.83		TSHTSH	0.3		S7752	reso	21H00093	H 0	600PP
546			0.15	105	PID	4 TSH	+0.83		TSHTSH			K2858	rpri	21H00114	H99	600HF
547			1.40	55	MBM	6 02H	+6.17		TEHTEC			A9608	reso	21C00052	C 0	600UL
548	98	48	0.63	63	MBM	5 TSH	+30.10		TEHTEC			H2131	reso	21C00053	C 0	600UL
549			0.54	63	MBM	6 04C	+24.99		TEHTEC			H2131	reso	21C00053	C 0	600UL
550	112	48	0.46	54	MBM	6 04H	+34.53		TEHTEC			A9608	reso	21C00052	C 0	600UL
551			0.63	82	MBM	5 07H	+18.58		TEHTEC			A9608	reso	21C00052	C 0	600UL
552	118	48	0.25	83	PLP	9 TSC	+0.46		TSCTSC			A9608	reso	21C00149	C 3	600PP
553	120	48	0.12	81	PLP	9 TSC	+0.38		TSCTSC			A9608	reso	21C00159	C 3	600PP
554	11	49	1.59	121	DSI	P1 VM	+0.20		TEHTEC			H2131	reso	21C00097	C 0	600UL
555			0.37	26	SAI	1 VM	+0.40		06C05H	0.4		R6452	reso	21H00163	H 2	560PF
556			0.30	89	SAI	2 VM	+0.40		06C05H	0.3		R6452	reso	21H00163	H 2	560PF
557			0.30	82	PID	2 VM	+0.40		06C05H			K2858	rpri	21H00171	H99	560PF
558	23	49	0.71	72	MBM	6 05C	+4.65		TEHTEC			R6452	reso	21C00015	C 0	600UL
559	91	49	0.44	84	MBM	5 02H	+31.66		TEHTEC			A9608	reso	21C00052	C 0	600UL
[illegible]	101	49	0.30	102	WAR	2 VH	-1.20		VH VH			R6452	reso	21H00067	H 4	560PF
5[illegible]			0.27	110	10	P2 VH	-1.03		TEHTEC			A9608	reso	21C00053	C 0	600UL
562	119	49	0.89	85	MBM	5 02H	+25.31		TEHTEC			A9608	reso	21C00052	C 0	600UL
563			1.27	75	MBM	5 04H	+14.90		TEHTEC			A9608	reso	21C00052	C 0	600UL
564			0.19	84	PLP	9 TSC	+0.45		TSCTSC			W4892	rpri	21C00149	C 3	600PP
565	6	50			OBS	06H	+14.09		05H06H			K2858	rpri	21H00144	H 2	560PF
566	18	50	0.12	113	SCI	P1 TSH	+0.05		TSHTSH	0.2		M1680	reso	21H00098	H 0	600PP
567					SCI	1 TSH	+0.05		TSHTSH	0.0		M1680	reso	21H00098	H 0	600PP
568			0.17	116	PID	P1 TSH	+0.05		TSHTSH			K2858	rpri	21H00114	H99	600HF
569	28	50	1.14	77	MBM	6 TSH	+18.62		TEHTEC			R6452	reso	21C00015	C 0	600UL
570	68	50	0.77	69	MBM	5 06C	+21.23		TEHTEC			A9608	reso	21C00052	C 0	600UL
571	108	50	1.40	68	MBM	6 03C	+13.87		TEHTEC			H2131	reso	21C00053	C 0	600UL
572	120	50			INF	10C	-0.44		TEHTEC	HR		A9608	reso	21C00054	C 0	580UL
573	19	51	0.09	86	MAI	2 TSH	+0.30	TO+0.60	TSHTSH	0.1		M1680	reso	21H00097	H 0	600PP
574					MAI	1 TSH	+0.30	TO+0.60	TSHTSH	0.0		M1680	reso	21H00097	H 0	600PP
575			0.06	73	PID	4 TSH	+0.30	TO+0.60	TSHTSH			K2858	rpri	21H00114	H99	600HF
576	21	51	0.20	104	MAI	2 TSH	+0.43		TSHTSH	0.3		M1680	reso	21H00004	H 0	600PP
577			0.20	123	MAI	1 TSH	+0.43		TSHTSH	0.3		M1680	reso	21H00004	H 0	600PP
578			0.28	114	PID	4 TSH	+0.43		TSHTSH			F7467	rsec	21H00063	H99	600HF
579	25	51	0.95	87	MBM	6 02C	+10.62		TEHTEC			R6452	reso	21C00016	C 0	600UL
580	37	51	1.02	47	MBM	6 04H	+1.86		TEHTEC			R6452	reso	21C00016	C 0	600UL
581	79	51	1.34	74	MBM	5 02H	+25.46		TEHTEC			A9608	reso	21C00052	C 0	600UL
582	99	51	1.03	54	MBM	6 05C	+14.74		TEHTEC			A9608	reso	21C00052	C 0	600UL
583	119	51	0.92	60	MBM	6 02H	+36.21		TEHTEC			A9608	reso	21C00052	C 0	600UL
584	127	51	0.26	76	PLP	9 TSH	+0.30		TSHTSH			M1680	reso	21H00049	H 0	600PP
585			1.06	66	MBM	6 02C	+34.88		TEHTEC			A9608	reso	21C00054	C 0	580UL
	129	51	0.82	85	MBM	5 VH	+26.42		TEHTEC			R6452	reso	21C00055	C 0	580UL
587			1.25	83	MBM	6 03C	+13.97		TEHTEC			R6452	reso	21C00055	C 0	580UL
588	2	52	1.13	57	MBM	6 05H	+2.40		06HTEH			C3340	reso	21H00002	H 1	600UL

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
589	10	52	0.72	142	DSI	P1 VM	-0.16	TEHTEC			P4634	rsec	21C00097	C 0	600UL
590			0.35	176	NDF	2 VM	-0.16	06C05H			R6452	resc	21H00144	H 2	560PF
591			0.65	68	MBM	5 04C	+26.99	TEHTEC			H2131	resc	21C00097	C 0	600UL
592	18	52	0.14	75	SAI	2 TSH	+0.32	TSHTSH	0.2		K7060	resc	21H00098	H 0	600PP
593					SAI	1 TSH	+0.32	TSHTSH	0.0		K7060	resc	21H00098	H 0	600PP
594			0.18	83	SAI	2 TSH	+0.90	TSHTSH	0.2		K7060	resc	21H00098	H 0	600PP
595					SAI	1 TSH	+0.90	TSHTSH	0.0		K7060	resc	21H00098	H 0	600PP
596			0.15	64	PID	4 TSH	+0.90	TSHTSH			K2858	rpri	21H00114	H99	600HF
597	48	52	1.44	60	MBM	6 02H	+3.18	TEHTEC			R6452	resc	21C00015	C 0	600UL
598	104	52	0.50	83	MBM	5 03H	+11.94	TEHTEC			H2131	resc	21C00053	C 0	600UL
599	5	53	0.22	51	SAI	1 TSH	+0.64	TSHTSH	0.4		K7060	resc	21H00098	H 0	600PP
600			0.20	92	SAI	2 TSH	+0.64	TSHTSH	0.4		K7060	resc	21H00098	H 0	600PP
601			0.18	105	PID	4 TSH	+0.64	TSHTSH			K2858	rpri	21H00114	H99	600HF
602	11	53	0.55	74	MBM	5 02H	+2.94	TEHTEC			H2131	resc	21C00097	C 0	600UL
603	21	53	0.90	79	MAI	1 TSH	+0.56	TSHTSH	0.6		M1680	resc	21H00004	H 0	600PP
604			0.50	81	MAI	2 TSH	+0.56	TSHTSH	0.7		M1680	resc	21H00004	H 0	600PP
605			0.56	258	PID	4 TSH	+0.56	TSHTSH			F7467	rsec	21H00063	H99	600HF
606			0.73	124	NQI	P1 TSH	+0.62	TEHTEC			L2157	rpri	21C00029	C 0	600UL
607	33	53	0.20	19	INR	P1 TSH	+7.43	TEHTEC			L2157	rpri	21C00029	C 0	600UL
608	75	53	0.13	111	SAI	2 TSH	+0.94	TSHTSH	0.2		K7060	resc	21H00045	H 0	600PP
[illegible]					SAI	1 TSH	+0.94	TSHTSH	0.0		K7060	resc	21H00045	H 0	600PP
6[illegible]			0.18	120	PID	4 TSH	+0.94	TSHTSH			F7467	rsec	21H00063	H99	600HF
611	111	53	0.74	70	MBM	-5 01H	+9.25	TEHTEC			R6452	resc	21C00050	C 0	600UL
612	123	53	0.65	116	INR	P1 TSC	+1.18	TEHTEC			A9608	resc	21C00054	C 0	580UL
613	18	54	0.18	99	MAI	2 TSH	+0.15 TO+1.05	TSHTSH	0.3		K7060	resc	21H00098	H 0	600PP
614			0.14	32	MAI	1 TSH	+0.15 TO+1.05	TSHTSH	0.4		K7060	resc	21H00098	H 0	600PP
615			0.12	117	PID	4 TSH	+0.15 TO+1.05	TSHTSH			K2858	rpri	21H00114	H99	600HF
616	28	54	0.57	103	MBM	6 01C	+23.42	TEHTEC			R6452	resc	21C00015	C 0	600UL
617	40	54	6.77	177	INR	P3 TSH	+0.25	TEHTEC			N0942	rpri	21C00015	C 0	600UL
618	52	54	15.45	7	INR	P3 TSH	+0.11	TEHTEC			N0942	rpri	21C00015	C 0	600UL
619	84	54	0.11	116	SAI	2 TSH	+0.87	TSHTSH	0.2		K7060	resc	21H00045	H 0	600PP
620					SAI	1 TSH	+0.87	TSHTSH	0.0		K7060	resc	21H00045	H 0	600PP
621			0.11	82	PID	4 TSH	+0.87	TSHTSH			F7467	rsec	21H00063	H99	600HF
622	92	54	0.30	61	INR	P1 02H	+0.66	TEHTEC			R6452	resc	21C00050	C 0	600UL
623			0.94	67	MBM	6 03C	+20.56	TEHTEC			R6452	resc	21C00050	C 0	600UL
624	100	54	0.73	117	WAR	2 VM	+1.77	VM VM			R6452	resc	21H00067	H 0	560PF
625			0.43	67	16	P2 VM	+2.02	TEHTEC			H2131	resc	21C00050	C 0	600UL
626	124	54	0.31	86	MBM	5 VC	+13.44	TEHTEC			R6452	resc	21C00055	C 0	580UL
627	11	55	1.89	157	DSI	P1 VM	+0.11	TEHTEC			K7060	resc	21C00096	C 0	600UL
628			0.15	59	NDF	2 VM	+0.11	06C05H			R6452	resc	21H00144	H 2	560PF
629	17	55	0.35	73	MAI	1 TSH	+0.14 TO+0.78	TSHTSH	0.4		M1680	resc	21H00097	H 0	600PP
630			0.35	80	MAI	2 TSH	+0.14 TO+0.78	TSHTSH	0.3		M1680	resc	21H00097	H 0	600PP
631			0.28	78	PID	4 TSH	+0.14 TO+0.78	TSHTSH			K2858	rpri	21H00114	H99	600HF
632	21	55			SAI	1 TSH	+0.34	TSHTSH	0.0		M1680	resc	21H00004	H 0	600PP
633			0.17	79	SAI	2 TSH	+0.34	TSHTSH	0.2		M1680	resc	21H00004	H 0	600PP
634			0.56	53	SAI	1 TSH	+0.59	TSHTSH	0.2		M1680	resc	21H00004	H 0	600PP
			0.33	94	SAI	2 TSH	+0.59	TSHTSH	0.2		M1680	resc	21H00004	H 0	600PP
636			0.28	91	PID	4 TSH	+0.59	TSHTSH			N0942	rpri	21H00063	H99	600HF
637			0.57	142	NQI	P1 TSH	+0.73	TEHTEC			D4576	rsec	21C00029	C 0	600UL

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final —

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
638	45	55	0.37	133	NQI	P1 TSH	+0.87		TEHTEC			O1057	rpri	21C00016	C 0	600UL
639					NDF	TSH	+0.87		TSHTSH			D3858	reso	21H00019	H 0	600PP
640	77	55	0.49	90	MBM	6 05H	+8.08		TEHTEC			S7752	reso	21C00051	C 0	600UL
641	99	55	2.15	78	MBM	6 08C	+21.18		TEHTEC			R6452	reso	21C00050	C 0	600UL
642	109	55	1.25	55	MBM	6 03H	+36.39		TEHTEC			S7752	reso	21C00051	C 0	600UL
643	119	55			NDF	10H	+0.00		10H10H			T0042	reso	21H00066	H 4	600PP
644			0.43	49	DSI	P1 10H	+0.00		TEHTEC			S1848	rpri	21C00050	C 0	600UL
645	8	56			SAI	1 TSH	+1.80		TSHTSH	0.0		K7060	reso	21H00098	H 0	600PP
646			0.12	92	SAI	2 TSH	+1.80		TSHTSH	0.2		K7060	reso	21H00098	H 0	600PP
647			0.11	99	PID	4 TSH	+1.80		TSHTSH			K2858	rpri	21H00114	H99	600HF
648	48	56	1.02	94	MBM	6 03C	+24.54		TEHTEC			R6452	reso	21C00015	C 0	600UL
649			0.73	70	MBM	5 03C	+33.64		TEHTEC			K7060	reso	21C00015	C 0	600UL
650	64	56	2.51	285	NRH	2 TSH	-0.02		TEHTEC			S1848	rpri	21C00050	C 0	600UL
651	68	56	3.73	64	MBM	6 03C	+33.80	TO+28.90	TEHTEC			R6452	reso	21C00050	C 0	600UL
652	132	56	1.32	77	MBM	6 03H	+6.93		TEHTEC			R6452	reso	21C00055	C 0	580UL
653			1.28	96	INR	5 08C	+18.22		TEHTEC			T7451	rsec	21C00055	C 0	580UL
654			0.70	90	MBM	5 07C	+20.18		TEHTEC			R6452	reso	21C00055	C 0	580UL
655	15	57	0.26	38	MAI	1 TSH	+0.08	TO+0.45	TSHTSH	0.2		M1680	reso	21H00097	H 0	600PP
656			0.26	79	MAI	2 TSH	+0.08	TO+0.45	TSHTSH	0.3		M1680	reso	21H00097	H 0	600PP
657			0.20	86	PID	4 TSH	+0.08	TO+0.45	TSHTSH			K2858	rpri	21H00114	H99	600HF
[illegible]	21	57	0.51	82	MBM	5 01H	+22.18		TEHTEC			H2131	reso	21C00018	C 0	600UL
[illegible]	57	57	0.52	73	MBM	5 01H	+35.76		TEHTEC			B3720	reso	21C00029	C 0	600UL
660	99	57	0.27	88	INR	5 TSH	+3.78		TEHTEC			R6452	reso	21C00050	C 0	600UL
661	119	57	0.49	81	MBM	5 09C	+8.81		TEHTEC			R6452	reso	21C00050	C 0	600UL
662	129	57	1.46	100	INR	6 08C	+4.59		TEHTEC			T7451	rsec	21C00055	C 0	580UL
663	14	58	0.53	73	MBM	5 TSH	+22.43		TEHTEC			H2131	reso	21C00097	C 0	600UL
664			0.44	79	MBM	5 TSH	+35.60		TEHTEC			H2131	reso	21C00097	C 0	600UL
665			0.33	104	DSI	P1 02H	+0.52		TEHTEC			H2131	reso	21C00097	C 0	600UL
666					NDF	02H	+0.52		02H02H			T7451	rsec	21H00167	H 4	600PP
667			0.54	82	MBM	5 03H	+15.99		TEHTEC			H2131	reso	21C00097	C 0	600UL
668			0.37	99	INR	5 05C	+4.04		TEHTEC			H2131	reso	21C00097	C 0	600UL
669			0.63	74	MBM	5 05C	+29.28		TEHTEC			H2131	reso	21C00097	C 0	600UL
670			1.00	82	MBM	5 04C	+31.60		TEHTEC			H2131	reso	21C00097	C 0	600UL
671			0.45	83	MBM	5 04C	+32.42		TEHTEC			H2131	reso	21C00097	C 0	600UL
672			0.43	74	MBM	5 01C	+24.04		TEHTEC			H2131	reso	21C00097	C 0	600UL
673			0.91	80	MBM	5 TSC	+17.92		TEHTEC			H2131	reso	21C00097	C 0	600UL
674			0.36	69	MBM	5 TSC	+25.87		TEHTEC			H2131	reso	21C00097	C 0	600UL
675	16	58	0.27	64	MBM	5 TSH	+27.36		TEHTEC			K7060	reso	21C00096	C 0	600UL
676	54	58	0.60	86	MBM	6 01H	+5.05		TEHTEC			H2131	reso	21C00018	C 0	600UL
677			0.37	80	MBM	5 01H	+22.96		TEHTEC			H2131	reso	21C00018	C 0	600UL
678			1.35	84	MBM	5 04C	+28.31		TEHTEC			H2131	reso	21C00018	C 0	600UL
679	68	58	1.96	135	INR	6 TSC	+10.81		TEHTEC			L2157	rpri	21C00050	C 0	600UL
680	72	58			OBS	TEH	+0.00		TEHTEH			A9608	reso	21H00041	H 0	600PP
681					OBS	TEH	+0.00		TEHTEH			A9608	reso	21H00042	H 0	600PP
682					OBS	TEH	+0.00		TEHTEH			S7752	reso	21H00055	H 0	600PP
683					OBS	TSH	-19.90		TSHTEC			L2157	rpri	21C00050	C 0	600UL
	74	58			NDF	03H	+4.20		04H03H			T7451	rsec	21H00086	H 4	600HF
685			0.87	90	NQI	6 03H	+4.20		TEHTEC			S7752	reso	21C00051	C 0	600UL
686					NDF	07H	+8.80		08H07H			T0042	reso	21H00066	H 4	600PP

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final — PAGE 15

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
687			0.35	81	NQI	5	07H +8.80	TEHTEC			S7752	reso	21C00051	C 0	600UL
688	94	58	0.61	74	MBM	5	TSH +34.85	TEHTEC			R6452	reso	21C00050	C 0	600UL
689	106	58	0.64	76	MBM	5	08C +9.08	TEHTEC			R6452	reso	21C00050	C 0	600UL
690	110	58	0.44	76	MBM	5	01H +28.85	TEHTEC			R6452	reso	21C00050	C 0	600UL
691			0.96	87	MBM	5	04C +6.59	TEHTEC			R6452	reso	21C00050	C 0	600UL
692			0.37	123	VOL	2	04C +6.59	04C05C			H2131	reso	21C00072	C 2	600PP
693					NDF		04C +8.09	04C05C			M1680	reso	21C00072	C 2	600PP
694			0.29	76	NQI	5	04C +8.09	TEHTEC			R6452	reso	21C00050	C 0	600UL
695			0.50	90	MBM	5	TSC +21.42	TEHTEC			R6452	reso	21C00050	C 0	600UL
696	7	59	1.10	43	NQI	P1	TSH +2.71	TEHTEC			L7871	rpri	21C00097	C 0	600UL
697			0.60	89	SAI	1	TSH +2.87	TSHTSH	0.4		C3340	reso	21H00097	H 0	600PP
698			0.44	104	SAI	2	TSH +2.87	TSHTSH	0.4		C3340	reso	21H00097	H 0	600PP
699			0.42	116	PID	4	TSH +2.87	TSHTSH			K2858	rpri	21H00114	H99	600HF
700	19	59	0.23	73	MBM	5	02H +24.99	TEHTEC			K7060	reso	21C00096	C 0	600UL
701			0.35	75	MBM	5	02H +30.76	TEHTEC			K7060	reso	21C00096	C 0	600UL
702			0.73	80	MBM	5	03H +29.34	TEHTEC			K7060	reso	21C00096	C 0	600UL
703	21	59	0.77	54	MBM	6	TSH +12.80	TEHTEC			H2131	reso	21C00018	C 0	600UL
704			0.55	74	MBM	5	01H +13.70	TEHTEC			H2131	reso	21C00018	C 0	600UL
705			0.46	65	MBM	5	04H +27.59	TEHTEC			H2131	reso	21C00018	C 0	600UL
706	39	59	2.55	69	MBM	6	02H +13.14	TEHTEC			H2131	reso	21C00017	C 0	600UL
[illegible]	79	59	0.91	82	MBM	5	TSH +19.86	TEHTEC			R6452	reso	21C00050	C 0	600UL
[illegible]					NDF		01H +14.17	02H01H			K7060	reso	21H00086	H 4	600HF
709			0.34	67	NQI	5	01H +14.17	TEHTEC			R6452	reso	21C00050	C 0	600UL
710			0.70	82	MBM	5	03H +8.64	TEHTEC			R6452	reso	21C00050	C 0	600UL
711			0.31	80	MBM	5	05H +12.99	TEHTEC			R6452	reso	21C00050	C 0	600UL
712	107	59	1.71	89	MBM	6	09H +9.11	TEHTEC			R6452	reso	21C00050	C 0	600UL
713	111	59	1.01	86	MBM	6	01C +16.39	TEHTEC			R6452	reso	21C00050	C 0	600UL
714	123	59	0.34	34	INR	P1	TSH +1.72	TEHTEC			S1848	rpri	21C00054	C 0	580UL
715	131	59	0.26	45	INR	P1	TSH +20.12	TEHTEC			A9608	reso	21C00054	C 0	580UL
716	133	59	0.20		PLP	9	TSC +0.21	TSCTSC			L2157	rpri	21C00158	C 3	600PP
717	26	60	0.55	61	MBM	5	TSH +8.11	TEHTEC			H2131	reso	21C00018	C 0	600UL
718	50	60			SAI	1	TSH +1.30	TSHTSH	0.0		R6452	reso	21H00006	H 0	600PP
719			0.12	114	SAI	2	TSH +1.30	TSHTSH	0.3		R6452	reso	21H00006	H 0	600PP
720			0.14	122	PID	4	TSH +1.30	TSHTSH			F7467	rsec	21H00063	H99	600HF
721			0.20	82	NQI	P1	TSH +1.49	TEHTEC			L2157	rpri	21C00029	C 0	600UL
722	86	60			SAI	1	TSH +0.54	TSHTSH	0		A9608	reso	21H00042	H 0	600PP
723			0.16	74	SAI	2	TSH +0.54	TSHTSH	0.2		S7752	reso	21H00042	H 0	600PP
724			0.14	130	PID	4	TSH +0.54	TSHTSH			F7467	rsec	21H00063	H99	600HF
725			0.68	11	NQI	P1	TSH +0.62	TEHTEC			M9715	rsec	21C00088	C 0	600UL
726	88	60	0.57	58	MBM	6	01H +31.83	TEHTEC			S7752	reso	21C00051	C 0	600UL
727			0.76	62	MBM	6	02H +16.95	TEHTEC			S7752	reso	21C00051	C 0	600UL
728			0.83	78	MBM	6	02C +35.01	TEHTEC			S7752	reso	21C00051	C 0	600UL
729	94	60	0.14	81	SAI	2	TSH +0.57	TSHTSH	0.2		S7752	reso	21H00042	H 0	600PP
730					SAI	1	TSH +0.57	TSHTSH	0		A9608	reso	21H00042	H 0	600PP
731			0.14	143	PID	4	TSH +0.57	TSHTSH			F7467	rsec	21H00063	H99	600HF
732	98	60			OBS		DH -10.55	DHTEC			L2157	rpri	21C00050	C 0	600UL
			0.36	95	INR	P1	DH +0.96	DH TEC			R6452	reso	21C00050	C 0	600UL
734			0.33	74	WAR	2	DH +1.00	DH DH			R6452	reso	21H00067	H 4	560PF
735			0.36	95	DSI	P1	DH +1.16	DH TEC			L2157	rpri	21C00050	C 0	600UL

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 10:57

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
736			0.56	154	21	P2	DH +1.34	TEHTEC			T0042	reso	21C00087	C 0	580SF
737	104	60	0.63	81	MBM	5	05H +6.41	TEHTEC			R6452	reso	21C00050	C 0	600UL
738			1.63	72	MBM	6	05H +31.21	TEHTEC			R6452	reso	21C00050	C 0	600UL
739	120	60	0.95	118	INR	P1	TSC +1.40	TEHTEC			A9608	reso	21C00054	C 0	580UL
740	124	60	0.29	103	INR	P1	TSC +1.95	TEHTEC			A9608	reso	21C00054	C 0	580UL
741	128	60	0.30	73	PLP	9	TSC +0.14	TSCTSC			M1680	reso	21C00157	C 3	600PP
742	132	60	0.29	85	PLP	9	TSC +0.16	TSCTSC			M1680	reso	21C00157	C 3	600PP
743	11	61	1.13	73	MBM	6	01C +6.60	TEHTEC			K7060	reso	21C00096	C 0	600UL
744			0.63	62	MBM	5	01C +23.90	TEHTEC			K7060	reso	21C00096	C 0	600UL
745	19	61	1.49	69	MBM	6	02C +6.07	TEHTEC			K7060	reso	21C00096	C 0	600UL
746	111	61	0.38	83	MBM	5	03C +4.40	TEHTEC			B3720	reso	21C00048	C 0	600UL
747	115	61	0.35	151	INR	P1	06H +0.98	TEHTEC			L2157	rpri	21C00048	C 0	600UL
748	121	61	2.56	81	MBM	6	DH +17.88	TEHTEC			A9608	reso	21C00054	C 0	580UL
749	129	61	0.68	83	MBM	5	07H +10.56	TEHTEC			A9608	reso	21C00054	C 0	580UL
750	22	62			INF		TSC -0.11	TEHTEC	HR		H2131	reso	21C00018	C 0	600UL
751	34	62	1.15	81	MBM	5	03C +34.39	TEHTEC			H2131	reso	21C00018	C 0	600UL
752	48	62	0.49	79	MBM	6	01H +6.51	TEHTEC			H2131	reso	21C00017	C 0	600UL
753	66	62	1.44	7	INR	P1	03H +14.80 TO+25.15	TEHTEC			B3720	reso	21C00049	C 0	600UL
754	80	62	0.35	83	MBM	5	07H +17.99	TEHTEC			B3720	reso	21C00048	C 0	600UL
755	84	62	0.37	78	MBM	5	05C +6.75	TEHTEC			B3720	reso	21C00049	C 0	600UL
7[illegible]	92	62			OBS		DH -8.15	DHTEC			B3720	reso	21C00049	C 0	600UL
7[illegible]	100	62			OBS		DH -9.17	DHTEC			B3720	reso	21C00049	C 0	600UL
758	112	62	1.31	71	MBM	6	01C +20.10	TEHTEC			B3720	reso	21C00049	C 0	600UL
759	114	62	0.99	36	INR	5	TSH +4.73	TEHTEC			B3720	reso	21C00048	C 0	600UL
760	120	62	0.70	72	MBM	5	03H +30.79	TEHTEC			A9608	reso	21C00054	C 0	580UL
761	17	63	0.90	80	MBM	6	TSC +30.50	TEHTEC			H2131	reso	21C00097	C 0	600UL
762	25	63	0.08	119	SCI	P1	TSH -0.05	TSHTSH	0.3		R6452	reso	21H00006	H 0	600PP
763					SCI	1	TSH -0.05	TSHTSH	0.0		R6452	reso	21H00006	H 0	600PP
764			0.14	168	PID	P1	TSH -0.05	TSHTSH			F7467	rsec	21H00063	H99	600HF
765	53	63	0.63	65	MBM	5	06C +7.23	TEHTEC			H2131	reso	21C00018	C 0	600UL
766	55	63	2.89	106	INR	P3	TSH +0.46	TEHTEC			H2131	reso	21C00017	C 0	600UL
767	89	63	0.64	67	MBM	5	03H +4.88	TEHTEC			B3720	reso	21C00047	C 0	600UL
768	95	63	0.43	6	INR	P1	09C +0.06	TEHTEC			K7060	reso	21C00088	C 0	600UL
769	101	63	0.35	80	MBM	5	03H +26.31	TEHTEC			B3720	reso	21C00047	C 0	600UL
770			0.30	72	MBM	6	TSC +6.96	TEHTEC			B3720	reso	21C00047	C 0	600UL
771	123	63	0.67	88	DSI	P1	10H +0.13	TEHTEC			R9311	rpri	21C00055	C 0	580UL
772					NDF		10H +0.13	10H10H			T0042	reso	21H00066	H 4	600PP
773	131	63	0.37	41	INR	3	TSH +2.85	TEHTEC			R9311	rpri	21C00055	C 0	580UL
774	135	63	1.30	90	MBM	5	TSC +17.67	TEHTEC			R6452	reso	21C00055	C 0	580UL
775			0.68	61	MBM	5	TSC +18.23	TEHTEC			R6452	reso	21C00055	C 0	580UL
776	60	64	0.59	61	DSI	P1	04C -1.30	TEHTEC			S1848	rpri	21C00017	C 0	600UL
777			0.24	101	VOL	2	04C -1.30	03C04C			H2131	reso	21C00072	C 2	600PP
778					INF		03C +37.58	TEHTEC	HR		H2131	reso	21C00017	C 0	600UL
779	90	64	0.23	84	MAI	2	TSH +0.60 TO+1.16	TSHTSH	0.4		A9608	reso	21H00039	H 0	600PP
780			0.20	34	MAI	1	TSH +0.60 TO+1.16	TSHTSH	0.3		A9608	reso	21H00039	H 0	600PP
781			0.25	75	PID	4	TSH +0.60 TO+1.16	TSHTSH			F7467	rsec	21H00063	H99	600HF
			0.30	20	NQI	P1	TSH +1.00	TEHTEC			M9715	rsec	21C00088	C 0	600UL
783	116	64	0.70	72	MBM	5	05H +14.51	TEHTEC			B3720	reso	21C00046	C 0	600UL
784	126	64	1.29	74	MBM	6	09H +12.68	TEHTEC			R6452	reso	21C00055	C 0	580UL

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final — PAGE 17

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
785			1.02	95	INR	6 TSC	+32.83	TEHTEC			T7451	rsec	21C00055	C 0	580UL
786	134	64	0.85	59	MBM	5 TSC	+17.22	TEHTEC			R6452	reso	21C00055	C 0	580UL
787	51	65	0.60	75	DSI	P1 02H	+1.18	TEHTEC			S1848	rpri	21C00017	C 0	600UL
788					NDF	02H	+1.18	02H02H			T0042	reso	21H00066	H 4	600PP
789	83	65	0.65	53	MBM	6 04C	+29.55	TEHTEC			B3720	reso	21C00046	C 0	600UL
790	119	65	0.37	84	PLP	9 TSC	+1.51	TSCTSC			M1680	reso	21C00152	C 3	600PP
791	127	65	1.97	69	MBM	6 03H	+28.87	TEHTEC			A9608	reso	21C00054	C 0	580UL
792			0.78	81	MBM	5 03H	+31.66	TEHTEC			A9608	reso	21C00054	C 0	580UL
793	135	65			SVI	1 TSC	+0.19	TSCTSC	0.0		B3720	reso	21C00158	C 3	600PP
794			0.09	82	SVI	2 TSC	+0.19	TSCTSC	0.3		B3720	reso	21C00158	C 3	600PP
795			0.06	93	PID	4 TSC	+0.19	TSCTSC			K2858	rpri	21C00179	C99	600HF
796	137	65	0.70	82	MBM	5 02C	+18.78	TEHTEC			R6452	reso	21C00055	C 0	580UL
797	26	66	0.76	26	SAI	2 TEH	-0.05	TEHTEH	0.2		T0042	reso	21H00005	H 0	600PP
798			0.98	9	SAI	1 TEH	-0.05	TEHTEH	0.2	PWSCC	D3858	reso	21H00005	H 0	600PP
799			0.58	23	SAI	2 TEH	+1.95	TEHTEH	0.2		T0042	reso	21H00005	H 0	600PP
800			0.28	10	SAI	1 TEH	+1.95	TEHTEH	0.4	PWSCC	D3858	reso	21H00005	H 0	600PP
801			0.61	29	SCI	P1 TEH	+16.38	TEHTEH	0.2		T0042	reso	21H00005	H 0	600PP
802			0.40	14	SCI	1 TEH	+16.38	TEHTEH	0.3	PWSCC	D3858	reso	21H00005	H 0	600PP
803			0.87	36	PID	P1 TEH	+16.38	TEHTSH			K7060	reso	21H00020	H99	600PP
804			1.21	31	PID	P1 TEH	+16.38	TEHTSH			K9438	rpri	21H00101	H99	600HF
[illegible]	64	66	0.98	76	MBM	6 01C	+32.50	TEHTEC			B3720	reso	21C00046	C 0	600UL
[illegible]	66	66	0.68	81	MBM	5 02C	+4.48	TEHTEC			B3720	reso	21C00047	C 0	600UL
807	84	66	0.16	83	SAI	2 TSH	+0.55	TSHTSH	0.3		S7752	reso	21H00040	H 0	600PP
808					SAI	1 TSH	+0.55	TSHTSH	0		A9608	reso	21H00040	H 0	600PP
809			0.16	273	PID	4 TSH	+0.55	TSHTSH			F7467	rsec	21H00063	H99	600HF
810	94	66			OBS	DH	-10.85	DHTEC			M9082	rpri	21C00047	C 0	600UL
811	98	66	0.27	78	MBM	5 03H	+18.63	TEHTEC			B3720	reso	21C00047	C 0	600UL
812	122	66	0.37	67	MBM	5 08C	+14.90	TEHTEC			R6452	reso	21C00055	C 0	580UL
813	124	66	0.87	85	DSI	P1 10H	+0.00	TEHTEC			S1848	rpri	21C00054	C 0	580UL
814					NDF	10H	+0.04	10H10H			T0042	reso	21H00066	H 4	600PP
815	130	66	0.38	139	INR	P1 10H	+0.29	TEHTEC			T7451	rsec	21C00055	C 0	580UL
816	132	66	0.65	97	MBM	5 05H	+17.54	TEHTEC			A9608	reso	21C00054	C 0	580UL
817	25	67	2.51	35	SAI	2 TEH	+0.26	TEHTEH	0.2		R6452	reso	21H00006	H 0	600PP
818			1.05	13	SAI	1 TEH	+0.26	TEHTEH	0.4	PWSCC	D3858	reso	21H00006	H 0	600PP
819			4.00	35	PID	4 TEH	+0.26	TEHTEH			P5436	rpri	21H00087	H99	600HF
820	65	67	0.88	74	MBM	6 03H	+21.46	TEHTEC			B3720	reso	21C00046	C 0	600UL
821			0.24	68	MBM	6 05H	+13.38	TEHTEC			B3720	reso	21C00046	C 0	600UL
822			0.34	77	MBM	5 VM	+10.17	TEHTEC			B3720	reso	21C00046	C 0	600UL
823	83	67	0.39	79	MBM	6 02H	+33.66	TEHTEC			B3720	reso	21C00047	C 0	600UL
824	91	67	0.15	82	SAI	2 TSH	+0.99	TSHTSH	0.3		S7752	reso	21H00039	H 0	600PP
825			0.18	95	SAI	1 TSH	+0.99	TSHTSH	0.4		S7752	reso	21H00039	H 0	600PP
826			0.16	128	PID	4 TSH	+0.99	TSHTSH			F7467	rsec	21H00063	H99	600HF
827	107	67	1.56	68	MBM	6 04H	+6.01	TEHTEC			B3720	reso	21C00046	C 0	600UL
828	117	67	1.58		PLP	9 TSC	+1.48	TSCTSC			O1057	rpri	21C00153	C 3	600PP
829	119	67	0.31	87	PLP	9 TSC	+0.56	TSCTSC			M1680	reso	21C00152	C 3	600PP
830	127	67	0.78	134	DSI	P1 10H	+0.00	TEHTEC			S1848	rpri	21C00054	C 0	580UL
					NDF	10H	+0.00	10H10H			T0042	reso	21H00066	H 4	600PP
832	135	67	1.55	86	MBM	5 05H	+1.85	TEHTEC			A9608	reso	21C00054	C 0	580UL
833			2.01	82	MBM	6 06H	+10.54	TEHTEC			A9608	reso	21C00054	C 0	580UL

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
834			1.81	75	MBM	5 06H	+18.19	TEHTEC			A9608	reso	21C00054	C 0	580UL
835	32	68	0.26	75	NQI	P1 TSH	+1.38	TEHTEC			S1848	rpri	21C00017	C 0	600UL
836					NDF	TSH	+1.38	TSHTSH			D3858	reso	21H00007	H 0	600PP
837	68	68	2.26	70	MBM	6 03C	+24.80 TO+30.41	TEHTEC			B3720	reso	21C00046	C 0	600UL
838	88	68	0.31	83	MBM	5 05H	+7.60	TEHTEC			B3720	reso	21C00046	C 0	600UL
839	94	68			OBS	DH	-9.13	DHTEC			H2131	rdnt	21C00046	C 0	600UL
840	104	68	1.03	77	MBM	5 01C	+20.92	TEHTEC			B3720	reso	21C00046	C 0	600UL
841	118	68	0.23	85	PLP	9 TSC	+2.73	TSCTSC			M1680	reso	21C00152	C 3	600PP
842	124	68	0.70	68	MBM	5 08H	+13.87	TEHTEC			A9608	reso	21C00054	C 0	580UL
843			0.71	141	INR	P1 TSC	+1.09	TEHTEC			A9608	reso	21C00054	C 0	580UL
844	29	69	1.93	64	MBM	6 03H	+20.05	TEHTEC			H2131	reso	21C00018	C 0	600UL
845	101	69	0.37	82	MBM	5 VH	+13.60	TEHTEC			B3720	reso	21C00047	C 0	600UL
846	103	69	0.65	77	MBM	5 04H	+17.05	TEHTEC			B3720	reso	21C00046	C 0	600UL
847	66	70	0.43	84	MBM	5 02C	+23.32	TEHTEC			B3720	reso	21C00040	C 0	600UL
848	76	70	0.71	91	MBM	6 04C	+22.84	TEHTEC			A9608	reso	21C00041	C 0	600UL
849	88	70	0.10	120	SCI	P1 TSH	+0.16	TSHTSH	0.3		S7752	reso	21H00040	H 0	600PP
850					SCI	1 TSH	+0.16	TSHTSH	0		A9608	reso	21H00040	H 0	600PP
851			0.10	135	PID	P1 TSH	+0.16	TSHTSH			F7467	rsec	21H00063	H99	600HF
852	100	70	0.13	106	SAI	2 TSH	+0.71	TSHTSH	0.2		S7752	reso	21H00040	H 0	600PP
853					SAI	1 TSH	+0.71	TSHTSH	0		A9608	reso	21H00040	H 0	600PP
[illegible]			0.14	106	PID	4 TSH	+0.71	TSHTSH			F7467	rsec	21H00063	H99	600HF
8[illegible]	102	70			OBS	09H	+0.00	09HTEC			M2655	rsec	21C00040	C 0	600UL
856	112	70	0.31	54	INR	P1 TSH	+1.27	TEHTEC			A9608	reso	21C00041	C 0	600UL
857	126	70	0.21	155	VOL	2 TSH	+4.80	TSHTSH			R6452	reso	21H00050	H 0	600PP
858			1.08	74	MBM	5 TSH	+4.99	TEHTEC			R6452	reso	21C00055	C 0	580UL
859			1.06	87	MBM	6 03H	+24.21	TEHTEC			R6452	reso	21C00055	C 0	580UL
860			0.87	88	MBM	5 05H	+20.90	TEHTEC			R6452	reso	21C00055	C 0	580UL
861	65	71	0.22	95	SAI	1 01H	+0.51	01H01H	0.3		T0042	reso	21H00066	H 4	600PP
862			0.32	83	SAI	2 01H	+0.51	01H01H	0.3		T0042	reso	21H00066	H 4	600PP
863			0.25	116	PID	4 01H	+0.51	01H01H			B6768	rpri	21H00090	H99	600HF
864			0.51	43	DSI	P1 01H	+0.65	TEHTEC			W4892	rpri	21C00041	C 0	600UL
865	91	71	0.68	68	MBM	5 VM	+19.62	TEHTEC			B3720	reso	21C00040	C 0	600UL
866	127	71	0.64	2	IDM	2 TSH	+4.53	TSHTSH			K7060	reso	21H00049	H 0	600PP
867	133	71	0.18	70	PLP	9 TSH	+0.83	TSHTSH			M1680	reso	21H00050	H 0	600PP
868			0.77	6	IDM	2 TSH	+3.74	TSHTSH			M1680	reso	21H00050	H 0	600PP
869	137	71	0.59	67	MBM	6 TSH	+8.63	TEHTEC			R6452	reso	21C00055	C 0	580UL
870	46	72	1.46	83	MBM	5 01H	+24.69	TEHTEC			K7060	reso	21C00084	C 0	600UL
871	74	72	0.46	79	MBM	5 TSH	+15.58	TEHTEC			A9608	reso	21C00041	C 0	600UL
872	88	72	0.65	70	MBM	5 VM	+18.58	TEHTEC			B3720	reso	21C00040	C 0	600UL
873	116	72	0.52	72	MBM	5 02C	+32.20	TEHTEC			B3720	reso	21C00040	C 0	600UL
874	122	72	1.40	72	MBM	6 08H	+5.59	TEHTEC			R6452	reso	21C00055	C 0	580UL
875	128	72	0.66	136	DSI	P1 10H	+0.00	TEHTEC			S1848	rpri	21C00054	C 0	580UL
876					NDF	10H	+0.00	10H10H			T0042	reso	21H00066	H 4	600PP
877	130	72	0.72	97	INR	5 10H	+0.07	TEHTEC			T7451	rsec	21C00055	C 0	580UL
878	132	72	0.21	78	PLP	10 TSH	+1.21	TSHTSH			K9438	rpri	21H00049	H 0	600PP
879	134	72	0.27	78	PLP	9 TSH	+0.61	TSHTSH			M0945	rsec	21H00050	H 0	600PP
	136	72	1.79	17	INR	P1 TSH	+3.61	TEHTEC			A9608	reso	21C00054	C 0	580UL
881			1.45	10	IDM	2 TSH	+3.65	TSHTSH			M1680	reso	21H00157	H 0	600PP
882	138	72	0.82	89	MBM	5 03H	+11.28	TEHTEC			R6452	reso	21C00055	C 0	580UL

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final — PAGE 19

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
883	53	73	0.89	45	MBM	6 01H	+14.94		TEHTEC			K7060	reso	21C00084	C 0	600UL
884	71	73	0.44	64	MBM	5 04H	+3.81		TEHTEC			B3720	reso	21C00040	C 0	600UL
885	77	73	0.72	89	MBM	6 02C	+32.32		TEHTEC			A9608	reso	21C00041	C 0	600UL
886	111	73	1.17	81	MBM	5 05H	+30.27		TEHTEC			B3720	reso	21C00040	C 0	600UL
887	121	73	0.22		IDM	2 TSH	+2.45		TSHTSH			K7060	reso	21H00049	H 0	600PP
888			0.22		IDM	2 TSH	+4.62		TSHTSH			K7060	reso	21H00049	H 0	600PP
889	48	74	0.96	80	MBM	6 03C	+33.75		TEHTEC			K7060	reso	21C00084	C 0	600UL
890	52	74	1.20	58	MBM	6 06H	+15.62		TEHTEC			K7060	reso	21C00084	C 0	600UL
891	62	74	0.68	76	MBM	5 03H	+31.94		TEHTEC			A9608	reso	21C00041	C 0	600UL
892	64	74	2.11	64	MBM	6 01H	+4.52		TEHTEC			B3720	reso	21C00040	C 0	600UL
893	82	74	0.59	84	MBM	6 04C	+12.11		TEHTEC			A9608	reso	21C00041	C 0	600UL
894	88	74	0.11	84	MAI	2 TSH	+0.80	TO+1.19	TSHTSH	0.2		A9608	reso	21H00038	H 0	600PP
895					MAI	1 TSH	+0.80	TO+1.19	TSHTSH	0.0		A9608	reso	21H00038	H 0	600PP
896			0.13	79	PID	4 TSH	+0.80	TO+1.19	TSHTSH			F7467	rsec	21H00063	H99	600HF
897	94	74	0.95	73	MBM	5 TSC	+27.78		TEHTEC			B3720	reso	21C00040	C 0	600UL
898	118	74	0.48	4	IDM	2 TSH	+4.37		TSHTSH			R6452	reso	21H00037	H 0	600PP
899			0.64	74	MBM	5 02H	+11.41		TEHTEC			B3720	reso	21C00040	C 0	600UL
900			0.62	84	MBM	5 02H	+13.46		TEHTEC			B3720	reso	21C00040	C 0	600UL
901			0.59	58	MBM	5 02H	+25.14		TEHTEC			B3720	reso	21C00040	C 0	600UL
902			1.02	74	MBM	5 02H	+28.00		TEHTEC			B3720	reso	21C00040	C 0	600UL
[illegible]			0.54	58	MBM	5 02H	+29.07		TEHTEC			B3720	reso	21C00040	C 0	600UL
[illegible]	120	74	0.65	70	MBM	5 04H	+34.00		TEHTEC			A9608	reso	21C00054	C 0	580UL
905	138	74	0.53	88	MBM	5 06H	+21.93		TEHTEC			R6452	reso	21C00055	C 0	580UL
906	39	75	0.08	117	SAI	2 TSH	+0.71		TSHTSH	0.1		K7060	reso	21H00046	H 0	600PP
907					SAI	1 TSH	+0.71		TSHTSH	0.0		K7060	reso	21H00046	H 0	600PP
908			0.10	64	PID	4 TSH	+0.71		TSHTSH			F7467	rsec	21H00063	H99	600HF
909	75	75	0.49	126	INR	P1 TSH	+1.00		TEHTEC			A9608	reso	21C00040	C 0	600UL
910	97	75	0.09	89	SAI	2 TSH	+0.60		TSHTSH	0.4		R6452	reso	21H00038	H 0	600PP
911					SAI	1 TSH	+0.60		TSHTSH	0.0		R6452	reso	21H00038	H 0	600PP
912			0.11	141	PID	4 TSH	+0.60		TSHTSH			F7467	rsec	21H00063	H99	600HF
913	131	75	0.52	76	MBM	5 01H	+26.70		TEHTEC			A9608	reso	21C00056	C 0	580UL
914	133	75	1.69	76	MBM	6 05H	+6.92		TEHTEC			R6452	reso	21C00057	C 0	580UL
915	72	76	0.09	98	SAI	2 TSH	+5.68		TSHTSH	0.4		R6452	reso	21H00038	H 0	600PP
916					SAI	1 TSH	+5.68		TSHTSH	0.0		R6452	reso	21H00038	H 0	600PP
917			0.11	129	PID	4 TSH	+5.68		TSHTSH			F7467	rsec	21H00063	H99	600HF
918	88	76	0.29	95	SAI	2 TSH	+0.99		TSHTSH	0.5		R6452	reso	21H00038	H 0	600PP
919			0.49	81	SAI	1 TSH	+0.99		TSHTSH	0.4		R6452	reso	21H00038	H 0	600PP
920			0.27	108	PID	4 TSH	+0.99		TSHTSH			F7467	rsec	21H00063	H99	600HF
921	94	76	0.54	85	MBM	5 04H	+22.87		TEHTEC			B3720	reso	21C00040	C 0	600UL
922	130	76	0.50	73	MBM	5 05C	+18.06		TEHTEC			R6452	reso	21C00057	C 0	580UL
923	140	76	3.21	219	NRH	2 TSH	+0.00		TEHTEC			K7060	reso	21C00057	C 0	580UL
924			0.55	77	MBM	5 01H	+8.18		TEHTEC			R6452	reso	21C00057	C 0	580UL
925			0.71	82	MBM	5 09H	+6.47		TEHTEC			R6452	reso	21C00057	C 0	580UL
926	39	77	0.18	99	DSI	P1 02H	-0.21		TEHTEC			M9715	rsec	21C00085	C 0	600UL
927					NDF	02H	-0.21		02H02H			S1848	rpri	21H00092	H 4	600PP
928	71	77	1.12	79	MBM	5 03C	+24.30		TEHTEC			B3720	reso	21C00042	C 0	600UL
	99	77	0.62	83	MBM	5 VC	+8.21		TEHTEC			B3720	reso	21C00040	C 0	600UL
930	103	77	0.66	72	MBM	5 01H	+11.17		TEHTEC			B3720	reso	21C00040	C 0	600UL
931	117	77	0.57	83	MBM	5 07H	+13.81		TEHTEC			A9608	reso	21C00041	C 0	600UL

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
932	129	77	0.49	76	MBM	5	04H +21.49	TEHTEC			A9608	reso	21C00056	C 0	580UL
933	131	77	0.70	66	MBM	6	09H +12.26	TEHTEC			R6452	reso	21C00057	C 0	580UL
934			0.49	77	MBM	6	09H +13.65	TEHTEC			R6452	reso	21C00057	C 0	580UL
935	135	77	0.47	84	MBM	5	05H +11.14	TEHTEC			R6452	reso	21C00057	C 0	580UL
936	42	78			INF	5	06H +20.96	TEHTEC	HR		C3340	reso	21C00085	C 0	600UL
937	80	78	0.09	133	SAI	2	TSH +0.99	TSHTSH	0.2		R6452	reso	21H00038	H 0	600PP
938					SAI	1	TSH +0.99	TSHTSH	0.0		R6452	reso	21H00038	H 0	600PP
939			0.14	145	PID	4	TSH +0.99	TSHTSH			F7467	rsec	21H00063	H99	600HF
940	82	78	1.51	73	MBM	6	TSH +2.63	TEHTEC			B3720	reso	21C00042	C 0	600UL
941	98	78	0.08	117	SAI	2	TSH +0.58	TSHTSH	0.2		R6452	reso	21H00038	H 0	600PP
942					SAI	1	TSH +0.58	TSHTSH	0.0		R6452	reso	21H00038	H 0	600PP
943			0.08	125	PID	4	TSH +0.58	TSHTSH			F7467	rsec	21H00063	H99	600HF
944	104	78	1.25	70	MBM	6	05H +26.87	TEHTEC			B3720	reso	21C00042	C 0	600UL
945	118	78	0.43	54	MBM	6	08H +6.87	TEHTEC			B3720	reso	21C00042	C 0	600UL
946	122	78	0.93	78	MBM	5	07H +10.59	TEHTEC			R6452	reso	21C00057	C 0	580UL
947			0.79	88	MBM	5	09H +8.37	TEHTEC			R6452	reso	21C00057	C 0	580UL
948			0.82	98	DSI	P1	10H +0.11	TEHTEC			K7060	reso	21C00057	C 0	580UL
949					NDF		10H +0.11	10H10H			T7451	rsec	21H00086	H 4	600HF
950			0.98	71	MBM	6	VC +19.60	TEHTEC			R6452	reso	21C00057	C 0	580UL
951	136	78	0.18	74	PLP	9	TSH +0.29	TSHTSH			B3720	reso	21H00157	H 0	600PP
[illegible]	67	79	0.94	73	MBM	5	04H +31.85	TEHTEC			B3720	reso	21C00042	C 0	600UL
9[illegible]	81	79	0.31	91	NQI	P1	TSH +0.89	TEHTEC			W4892	rpri	21C00043	C 0	600UL
954					NDF		TSH +0.89	TSHTSH			H2131	reso	21H00038	H 0	600PP
955	91	79	0.42	58	MBM	6	05C +34.11	TEHTEC			B3720	reso	21C00042	C 0	600UL
956	115	79	0.86	90	INR	6	03H +31.99 TO+34.97	TEHTEC			H2131	reso	21C00042	C 0	600UL
957			0.41	108	MBM	6	03H +36.33	TEHTEC			B3720	reso	21C00042	C 0	600UL
958	137	79	0.17	71	PLP	9	TSH +0.23	TSHTSH			B3720	reso	21H00157	H 0	600PP
959			0.09	72	PLP	9	TSH +0.61	TSHTSH			B3720	reso	21H00157	H 0	600PP
960	106	80	0.18	31	SCI	P1	TSH -0.17	TSHTSH	0.3	PWSCC	A9608	reso	21H00037	H 0	600PP
961					SCI	1	TSH -0.17	TSHTSH	0.0	PWSCC	A9608	reso	21H00037	H 0	600PP
962			0.40	32	PID	P1	TSH -0.17	TSHTSH			F7467	rsec	21H00063	H99	600HF
963	110	80	0.40	73	MBM	5	02H +10.01	TEHTEC			B3720	reso	21C00042	C 0	600UL
964	120	80	1.14	69	MBM	5	08H +10.23	TEHTEC			A9608	reso	21C00056	C 0	580UL
965	128	80	1.54	79	MBM	6	07H +3.37	TEHTEC			A9608	reso	21C00056	C 0	580UL
966			1.44	84	MBM	6	07H +8.98	TEHTEC			A9608	reso	21C00056	C 0	580UL
967			1.15	96	MBM	6	VH +7.99	TEHTEC			A9608	reso	21C00056	C 0	580UL
968	136	80	0.51	28	INR	P1	TSC +1.84	TEHTEC			R6452	reso	21C00057	C 0	580UL
969	39	81	19.54	58	INR	P3	TSH -0.27	TEHTEC			C3340	reso	21C00085	C 0	600UL
970	43	81	0.34	89	MBM	5	01H +30.69	TEHTEC			C3340	reso	21C00085	C 0	600UL
971	57	81	0.36	75	NQI	5	TSH +7.10	TEHTEC			C3340	reso	21C00085	C 0	600UL
972					NDF		TSH +7.10	TSH01H			S1848	rpri	21H00092	H 4	600PP
973			0.50	84	MBM	5	TSC +15.09	TEHTEC			C3340	reso	21C00085	C 0	600UL
974	69	81	0.16	100	VOL	2	TSC +5.57	TSCTSC			H2131	reso	21C00067	C 3	600PP
975			0.59	85	MBM	5	TSC +5.80	TEHTEC			B3720	reso	21C00042	C 0	600UL
976	85	81	0.47	63	MBM	5	TSH +14.71	TEHTEC			A9608	reso	21C00043	C 0	600UL
977	99	81	0.89	81	MBM	5	07H +16.61	TEHTEC			B3720	reso	21C00042	C 0	600UL
	113	81	0.74	84	MBM	6	TSH +30.99	TEHTEC			A9608	reso	21C00043	C 0	600UL
979	123	81	0.98	119	DSI	P1	10H -0.11	TEHTEC			K7060	reso	21C00057	C 0	580UL
980					NDF		10H -0.11	10H10H			T7451	rsec	21H00086	H 4	600HF

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final — PAGE 21

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
981	139	81	0.18	101	WAR	P4	07H +0.87	07HDH			L2157	rpri	21H00158	H 4	560PF
982			0.32		13	P2	07H +1.00	TEHTEC			R6452	reso	21C00057	C 0	580UL
983			0.13	93	WAR	P4	08H +0.99	07HDH			L2157	rpri	21H00158	H 4	560PF
984			0.33	113	WAR	P4	DH +1.80	07HDH			L2157	rpri	21H00158	H 4	560PF
985			0.58		23	P2	DH +1.92	TEHTEC			R9311	rpri	21C00057	C 0	580UL
986	50	82	0.69	87	MBM	5	TSH +14.83	TEHTEC			C3340	reso	21C00085	C 0	600UL
987			0.51	75	MBM	5	01H +18.44	TEHTEC			C3340	reso	21C00085	C 0	600UL
988	80	82	6.64	117	INR	P3	TSC -0.31	TEHTEC			B3720	reso	21C00042	C 0	600UL
989	82	82	1.00	90	MBM	6	04C +9.25	TEHTEC			A9608	reso	21C00043	C 0	600UL
990	108	82	0.66	79	MBM	5	03C +8.26	TEHTEC			B3720	reso	21C00045	C 0	600UL
991	130	82	0.67	61	MBM	6	03H +5.73	TEHTEC			R6452	reso	21C00057	C 0	580UL
992			1.73	90	MBM	5	02C +33.27	TEHTEC			R6452	reso	21C00057	C 0	580UL
993	136	82	0.30	81	PLP	9	TSH +0.13	TSHTSH			M1680	reso	21H00157	H 0	600PP
994	43	83	0.58	74	MBM	5	02H +14.02	TEHTEC			C3340	reso	21C00085	C 0	600UL
995	55	83	3.99	61	INR	P3	TSC -0.06	TEHTEC			C3340	reso	21C00085	C 0	600UL
996	71	83	1.34	75	MBM	5	07C +15.21	TEHTEC			B3720	reso	21C00044	C 0	600UL
997	83	83	0.44	70	MBM	5	TSH +36.90	TEHTEC			B3720	reso	21C00044	C 0	600UL
998	99	83	0.82	73	MBM	5	07H +18.00	TEHTEC			B3720	reso	21C00044	C 0	600UL
999	123	83	0.95	88	DSI	P2	10H +0.18	TEHTEC			D3858	reso	21C00057	C 0	580UL
1000					NDF		10H +0.18	10H10H			H2131	reso	21H00092	H 4	600PP
?	125	83	0.72	117	DSI	P1	10H +0.02	TEHTEC			D3858	reso	21C00056	C 0	580UL
1.					NDF		10H +0.02	10H10H			S1848	rpri	21H00092	H 4	600PP
1003	127	83	0.67	86	MBM	5	07C +4.24	TEHTEC			R6452	reso	21C00057	C 0	580UL
1004	42	84	0.21	134	NQI	P1	TSH +1.45	TEHTEC			K2858	rpri	21C00085	C 0	600UL
1005			0.12	115	SAI	2	TSH +1.58	TSHTSH	0.2		K7060	reso	21H00046	H 0	600PP
1006					SAI	1	TSH +1.58	TSHTSH	0.0		K7060	reso	21H00046	H 0	600PP
1007			0.12	117	PID	4	TSH +1.58	TSHTSH			F7467	rsec	21H00063	H99	600HF
1008	50	84	1.27	87	MBM	6	TSH +11.15	TEHTEC			C3340	reso	21C00086	C 0	600UL
1009	80	84	0.09	73	SAI	2	TSH +0.46	TSHTSH	0.2		R6452	reso	21H00035	H 0	600PP
1010					SAI	1	TSH +0.46	TSHTSH	0.0		R6452	reso	21H00035	H 0	600PP
1011			0.12	62	PID	4	TSH +0.46	TSHTSH			F7467	rsec	21H00063	H99	600HF
1012	82	84	0.55	69	MBM	5	TSH +12.03	TEHTEC			B3720	reso	21C00045	C 0	600UL
1013	98	84			NDF		04H -0.38	04H04H			K7060	reso	21H00086	H 4	600HF
1014			0.48	82	DSI	P1	04H +0.38	TEHTEC			B6768	rpri	21C00045	C 0	600UL
1015	102	84	1.29	57	MBM	6	03H +30.18	TEHTEC			B3720	reso	21C00045	C 0	600UL
1016	118	84	0.57	120	DSI	P1	10H +0.14	TEHTEC			K4444	rsec	21C00044	C 0	600UL
1017					NDF		10H +0.14	10H10H			T0042	reso	21H00066	H 4	600PP
1018	126	84	1.33	72	MBM	6	07H +14.57	TEHTEC			R6452	reso	21C00057	C 0	580UL
1019			2.24	83	MBM	6	02C +25.00	TEHTEC			R6452	reso	21C00057	C 0	580UL
1020	130	84	0.46	86	MBM	6	TSH +5.22	TEHTEC			K7060	reso	21C00057	C 0	580UL
1021			1.53	92	MBM	5	04C +24.26	TEHTEC			K7060	reso	21C00057	C 0	580UL
1022	134	84	0.71	84	MBM	5	07C +13.55	TEHTEC			A9608	reso	21C00056	C 0	580UL
1023	73	85	0.97	63	MBM	6	02H +17.11	TEHTEC			B3720	reso	21C00045	C 0	600UL
1024	89	85	0.73	93	INR	5	01C +22.19	TEHTEC			B6768	rpri	21C00045	C 0	600UL
1025			0.75	95	INR	5	01C +35.68	TEHTEC			B6768	rpri	21C00045	C 0	600UL
1026	93	85	0.94	64	MBM	6	04C +28.01	TEHTEC			B3720	reso	21C00045	C 0	600UL
			0.61	83	MBM	6	03C +29.01	TEHTEC			B3720	reso	21C00045	C 0	600UL
1028	103	85	0.60	82	MBM	5	02H +24.20	TEHTEC			B3720	reso	21C00044	C 0	600UL
1029	117	85	4.13	60	INR	6	02C +9.69 TO+16.67	TEHTEC			B3720	reso	21C00045	C 0	600UL

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
1030	125	85	0.98	83	MBM	5	01C	+35.95		TEHTEC			K7060	resc	21C00057	C 0 580UL
1031	42	86	0.22	40	NQI	P1	TSH	+1.39		TEHTEC			C3340	resc	21C00086	C 0 600UL
1032			0.14	107	SAI	2	TSH	+1.42		TSHTSH	0.2		K7060	resc	21H00048	H 0 600PP
1033					SAI	1	TSH	+1.42		TSHTSH	0.0		K7060	resc	21H00048	H 0 600PP
1034			0.15	123	PID	4	TSH	+1.42		TSHTSH			F7467	rsec	21H00063	H99 600HF
1035	88	86			INF		08H	+3.70	TO+10.69	TEHTEC	HR		B3720	resc	21C00044	C 0 600UL
1036	37	87	0.66	57	MBM	5	01H	+5.69		TEHTEC			C3340	resc	21C00086	C 0 600UL
1037	53	87	1.22	84	MBM	5	03C	+30.32		TEHTEC			C3340	resc	21C00086	C 0 600UL
1038	63	87	0.39	70	MBM	5	VM	+20.83		TEHTEC			B3720	resc	21C00045	C 0 600UL
1039			0.47	77	MBM	5	06C	+19.51		TEHTEC			B3720	resc	21C00045	C 0 600UL
1040	81	87	0.06	80	SAI	2	TSH	+0.55		TSHTSH	0.3		K7060	resc	21H00036	H 0 600PP
1041					SAI	1	TSH	+0.55		TSHTSH	0.0		K7060	resc	21H00036	H 0 600PP
1042			0.14	140	PID	4	TSH	+0.55		TSHTSH			F7467	rsec	21H00063	H99 600HF
1043	125	87	1.02	104	DSI	P1	10H	+0.00		TEHTEC			K7060	resc	21C00057	C 0 580UL
1044					NDF		10H	+0.00		10H10H			C5184	rsec	21H00086	H 4 600HF
1045	36	88	0.62	93	INR	6	05C	+18.59		TEHTEC			K2858	rpri	21C00086	C 0 600UL
1046	46	88	0.67	82	MBM	5	05C	+4.41		TEHTEC			C3340	resc	21C00086	C 0 600UL
1047	66	88	0.18	24	IDM	2	TSC	+5.31		TSCTSC			B3720	resc	21C00143	C 3 600PP
1048	126	88	0.46	92	INR	P1	TSC	+1.94		TEHTEC			R9311	rpri	21C00057	C 0 580UL
1049	130	88	0.83	86	MBM	5	TSC	+2.70		TEHTEC			K7060	resc	21C00057	C 0 580UL
[illegible]			0.37	69	VOL	1	TSC	+2.80		TSCTSC			B3720	resc	21C00155	C 3 600PP
[illegible]	41	89	0.72	85	MBM	5	05C	+1.94		TEHTEC			C3340	resc	21C00086	C 0 600UL
1052			0.63	78	MBM	5	05C	+4.41		TEHTEC			C3340	resc	21C00086	C 0 600UL
1053	81	89	0.07	99	SAI	2	TSH	+0.66		TSHTSH	0.2		K7060	resc	21H00036	H 0 600PP
1054					SAI	1	TSH	+0.66		TSHTSH	0.0		K7060	resc	21H00036	H 0 600PP
1055			0.11	97	PID	4	TSH	+0.66		TSHTSH			F7467	rsec	21H00063	H99 600HF
1056	93	89			SAI	1	TSH	+0.49		TSHTSH	0.0		K7060	resc	21H00036	H 0 600PP
1057			0.14	99	SAI	2	TSH	+0.49		TSHTSH	0.2		K7060	resc	21H00036	H 0 600PP
1058			0.21	68	PID	4	TSH	+0.49		TSHTSH			F7467	rsec	21H00063	H99 600HF
1059			0.83	78	MBM	5	01H	+5.12		TEHTEC			B3720	resc	21C00045	C 0 600UL
1060	99	89	0.48	86	MBM	5	VM	+20.54		TEHTEC			B3720	resc	21C00044	C 0 600UL
1061	121	89	0.28	111	NQI	P1	TSH	+7.91		TEHTEC			A9608	resc	21C00056	C 0 580UL
1062					NDF		TSH	+7.91		01HTSH			K7060	resc	21H00086	H 4 600HF
1063			0.63	73	MBM	6	02H	+26.21		TEHTEC			A9608	resc	21C00056	C 0 580UL
1064	125	89	0.90	81	MBM	5	04H	+24.52		TEHTEC			A9608	resc	21C00056	C 0 580UL
1065	52	90	0.53	84	MBM	6	06C	+19.07		TEHTEC			T0042	resc	21C00086	C 0 600UL
1066	56	90	2.47	86	MBM	5	03H	+25.28		TEHTEC			C3340	resc	21C00086	C 0 600UL
1067			1.04	109	INR	6	05C	+27.55		TEHTEC			K2858	rpri	21C00086	C 0 600UL
1068	68	90	0.76	72	MBM	5	03H	+22.49		TEHTEC			B3720	resc	21C00044	C 0 600UL
1069			0.68	87	MBM	5	03H	+34.71		TEHTEC			B3720	resc	21C00044	C 0 600UL
1070	82	90	0.09	126	MAI	2	TSH	+0.63	TO+1.02	TSHTSH	0.3		K7060	resc	21H00036	H 0 600PP
1071					MAI	1	TSH	+0.63	TO+1.02	TSHTSH	0.0		K7060	resc	21H00036	H 0 600PP
1072			0.13	113	PID	4	TSH	+0.63	TO+1.02	TSHTSH			F7467	rsec	21H00063	H99 600HF
1073	94	90	0.40	74	MBM	5	05C	+9.11		TEHTEC			B3720	resc	21C00045	C 0 600UL
1074	120	90	1.12	79	MBM	5	05C	+25.07		TEHTEC			A9608	resc	21C00056	C 0 580UL
1075	130	90	0.74	87	MBM	5	03H	+16.97		TEHTEC			K7060	resc	21C00057	C 0 580UL
	138	90	0.31	84	PLP	9	TSH	+0.32		TSHTSH			M1680	resc	21H00157	H 0 600PP
1077	140	90	0.25	84	PLP	9	TSH	+0.23		TSHTSH			M1680	resc	21H00157	H 0 600PP
1078	119	91	0.26	5	IDM	2	TSH	+4.90		TSHTSH			R6452	resc	21H00035	H 0 600PP

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final —

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
1079	127	91	0.83	71	MBM	5 DH	+15.72	TEHTEC			K7060	reso	21C00057	C 0	580UL
1080	139	91	0.30	84	PLP	9 TSH	+0.31	TSHTSH			M1680	reso	21H00157	H 0	600PP
1081			0.55	2	IDM	2 TSH	+3.28	TSHTSH			M1680	reso	21H00157	H 0	600PP
1082	38	92	1.07	37	MBM	5 07H	+8.44	TECTEH			H2131	reso	21H00124	C 0	600UL
1083	44	92	0.61	72	MBM	5 TSC	+10.40	TECTEH			A9608	reso	21H00123	C 0	600UL
1084	70	92	0.71	45	MBM	6 01C	+9.76	TEHTEC			R6452	reso	21C00032	C 0	600UL
1085	74	92	0.56	90	INR	5 05H	+20.53	TEHTEC			P5436	rpri	21C00032	C 0	600UL
1086	114	92	0.25	87	PLP	10 TSC	+3.14	TSCTSC			K7060	reso	21C00137	C 3	600PP
1087	116	92	0.27	81	DSI	P1 06C	-0.26	TEHTEC			C5184	rsec	21C00032	C 0	600UL
1088					NDF	06C	-0.26	06C06C			S1848	rpri	21C00072	C 2	600PP
1089			0.68	45	MBM	6 04C	+21.64	04HTEC			R6452	reso	21C00032	C 0	600UL
1090	118	92	1.86	66	MBM	6 05H	+25.56	TEHTEC			B3720	reso	21C00031	C 0	600UL
1091	124	92	0.90	75	MBM	6 08H	+2.46	TEHTEC			A9608	reso	21C00056	C 0	580UL
1092	126	92	0.81	130	DSI	P1 10H	+0.02	TEHTEC			K7060	reso	21C00057	C 0	580UL
1093					NDF	10H	+0.02	10H10H			C5184	rsec	21H00086	H 4	600HF
1094	51	93	1.37	82	MBM	6 03C	+31.98	TECTEH			A9608	reso	21H00123	C 0	600UL
1095	69	93	0.23	23	INR	P1 TSH	+1.11	TEHTEC			P5436	rpri	21C00032	C 0	600UL
1096	73	93	0.40	73	NQI	5 TSH	+13.14	TEHTEC			R6452	reso	21C00032	C 0	600UL
1097					NDF	TSH	+13.14	01HTSH			T0042	reso	21H00066	H 4	600PP
1098	75	93			PRC			01HTSH			T0042	reso	21H00066	H 4	600PP
[illegible]			0.28	92	SAI	2 TSH	+5.45	TSHTSH	0.2		K7060	reso	21H00033	H 0	600PP
1[illegible]			0.22	114	SAI	1 TSH	+5.45	TSHTSH	0.3		K7060	reso	21H00033	H 0	600PP
1101			0.33	101	PID	4 TSH	+5.45	TSHTSH			S0607	rsec	21H00063	H99	600HF
1102			0.46	124	NQI	P1 TSH	+5.61	TEHTEC			J6276	rpri	21C00031	C 0	600UL
1103			0.95	90	MBM	6 05H	+24.73	TEHTEC			B3720	reso	21C00031	C 0	600UL
1104			0.63	79	MBM	5 04C	+34.90	TEHTEC			B3720	reso	21C00031	C 0	600UL
1105	85	93	0.72	69	MBM	6 03C	+17.09	TEHTEC			R6452	reso	21C00032	C 0	600UL
1106	115	93	0.41	84	DSI	P1 09H	+0.15	TEHTEC			J6276	rpri	21C00031	C 0	600UL
1107					NDF	09H	+0.15	09H09H			T0042	reso	21H00066	H 4	600PP
1108	137	93	0.16	76	PLP	9 TSH	+1.48	TSHTSH			M1680	reso	21H00157	H 0	600PP
1109	38	94	1.08	86	MBM	6 03H	+27.97	TECTEH			H2131	reso	21H00124	C 0	600UL
1110	52	94	0.94	93	MBM	6 01C	+17.41	TECTEH			A9608	reso	21H00123	C 0	600UL
1111	78	94	0.20	13	INR	P1 TSH	+1.02	TEHTEC			O1057	rpri	21C00032	C 0	600UL
1112			0.63	69	MBM	6 02C	+35.07	TEHTEC			R6452	reso	21C00032	C 0	600UL
1113			0.87	60	MBM	6 TSC	+30.44	TEHTEC			R6452	reso	21C00032	C 0	600UL
1114	82	94	0.38	47	NQI	P1 TSH	+1.15	TEHTEC			O1057	rpri	21C00032	C 0	600UL
1115					NDF	TSH	+1.15	TSHTSH			H2131	reso	21H00033	H 0	600PP
1116	100	94	0.47	82	MBM	5 03C	+13.97	TEHTEC			B3720	reso	21C00031	C 0	600UL
1117			0.64	83	MBM	5 02C	+17.34	TEHTEC			B3720	reso	21C00031	C 0	600UL
1118			0.69	85	MBM	5 01C	+21.56	TEHTEC			B3720	reso	21C00031	C 0	600UL
1119	138	94	0.15	77	PLP	9 TSH	+1.39	TSHTSH			M1680	reso	21H00157	H 0	600PP
1120	55	95	0.76	84	MBM	5 05H	+12.41	TECTEH			A9608	reso	21H00123	C 0	600UL
1121	69	95	0.12	119	SCI	P1 TSH	+0.30	TSHTSH	0.2		K7060	reso	21H00033	H 0	600PP
1122					SCI	1 TSH	+0.30	TSHTSH	0.0		K7060	reso	21H00033	H 0	600PP
1123			0.12	117	PID	P1 TSH	+0.30	TSHTSH			S0607	rsec	21H00063	H99	600HF
1124	79	95	0.73	181	INR	P1 TSH	+34.93	TEHTEC			B3720	reso	21C00031	C 0	600UL
	117	95	0.89	102	MBM	6 04H	+7.16	TEHTEC			R6452	reso	21C00032	C 0	600UL
1126	129	95	1.44	85	MBM	5 02C	+11.80	TEHTEC			A9608	reso	21C00056	C 0	580UL
1127	46	96	0.71	110	MBM	6 02H	+2.45	TECTEH			A9608	reso	21H00123	C 0	600UL

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
1128	50	96	0.58	80	MBM	5	04C +26.82	TECTEH			A9608	reso	21H00123	C 0	600UL
1129	66	96			INF		07H +14.61	TEHTEC	HR		A9608	reso	21C00034	C 0	600UL
1130			0.45	79	MBM	5	07H +20.58	TEHTEC			A9608	reso	21C00034	C 0	600UL
1131	122	96	0.84	80	NQI	5	TSH +23.49	TEHTEC			K7060	reso	21C00057	C 0	580UL
1132					NDF		TSH +23.49	01HTSH			C5184	rsec	21H00086	H 4	600HF
1133			1.07	83	MBM	5	03H +28.31	TEHTEC			K7060	reso	21C00057	C 0	580UL
1134			0.59	84	MBM	5	04H +25.72	TEHTEC			K7060	reso	21C00057	C 0	580UL
1135			0.74	81	MBM	5	02C +37.64	TEHTEC			K7060	reso	21C00057	C 0	580UL
1136	83	97	0.44	78	MBM	5	02H +31.81	TEHTEC			A9608	reso	21C00034	C 0	600UL
1137	93	97	0.11	92	SAI	2	TSH +0.96	TSHTSH	0.2		K7060	reso	21H00031	H 0	600PP
1138					SAI	1	TSH +0.96	TSHTSH	0.0		K7060	reso	21H00031	H 0	600PP
1139			0.12	96	PID	4	TSH +0.96	TSHTSH			F7467	rsec	21H00063	H99	600HF
1140	97	97	1.75	66	MBM	6	01H +15.38	TEHTEC			R6452	reso	21C00033	C 0	600UL
1141	127	97	2.25	78	MBM	6	TSH +11.26	TEHTEC			C3340	reso	21C00058	C 0	580UL
1142	129	97	0.70	72	MBM	5	01C +29.52	TEHTEC			M1680	reso	21C00059	C 0	580UL
1143	137	97	0.22	77	PLP	9	TSH +0.23	TSHTSH			B3720	reso	21H00157	H 0	600PP
1144			0.27		PLP	9	TSC +0.45	TSCTSC			L2157	rpri	21C00156	C 3	600PP
1145	30	98	0.56	82	MBM	5	01H +6.73	TECTEH			H2131	reso	21H00124	C 0	600UL
1146	32	98	0.41	76	MBM	5	04C +22.28	TECTEH			A9608	reso	21H00123	C 0	600UL
1147	54	98	0.42	81	MBM	5	04C +21.84	TECTEH			A9608	reso	21H00123	C 0	600UL
3	74	98	1.85	73	MBM	6	04H +9.00	TEHTEC			R6452	reso	21C00033	C 0	600UL
1			0.77	43	MBM	6	05H +10.36	TEHTEC			R6452	reso	21C00033	C 0	600UL
1150	76	98	0.25	27	INR	P2	VM +1.91	TEHTEC			B6768	rpri	21C00033	C 0	600UL
1151	82	98	0.27	185	INR	1	07C -1.90 TO+24.08	TEHTEC			G6391	rsec	21C00033	C 0	600UL
1152			0.20	359	INR	1	06C +20.86 TO+23.52	TEHTEC			G6391	rsec	21C00033	C 0	600UL
1153	98	98	0.14	111	SAI	2	TSH +0.89	TSHTSH	0.2		K7060	reso	21H00032	H 0	600PP
1154					SAI	1	TSH +0.89	TSHTSH	0.0		K7060	reso	21H00032	H 0	600PP
1155			0.15	106	PID	4	TSH +0.89	TSHTSH			F7467	rsec	21H00063	H99	600HF
1156	108	98	0.69	84	MBM	5	08C +9.08	TEHTEC			A9608	reso	21C00034	C 0	600UL
1157	112	98	0.45	74	MBM	5	04H +6.86	TEHTEC			K7060	reso	21C00034	C 0	600UL
1158			0.48	85	MBM	5	07H +8.21	TEHTEC			A9608	reso	21C00034	C 0	600UL
1159			0.46	81	MBM	5	07H +16.08	TEHTEC			A9608	reso	21C00034	C 0	600UL
1160			0.55	76	MBM	6	08H +13.28	TEHTEC			A9608	reso	21C00034	C 0	600UL
1161			0.75	56	MBM	6	03C +34.90	TEHTEC			A9608	reso	21C00034	C 0	600UL
1162	124	98	0.69	78	MBM	5	03H +22.47	TEHTEC			C3340	reso	21C00058	C 0	580UL
1163	132	98	0.63	84	MBM	6	03H +29.49	TEHTEC			C3340	reso	21C00058	C 0	580UL
1164	136	98	0.54		PLP	9	TSC +0.62	TSCTSC			L2157	rpri	21C00155	C 3	600PP
1165	85	99	0.49	60	MBM	6	02H +16.32	TEHTEC			R6452	reso	21C00033	C 0	600UL
1166	87	99	0.19	88	SAI	2	TSH +1.49	TSHTSH	0.2		K7060	reso	21H00032	H 0	600PP
1167					SAI	1	TSH +1.49	TSHTSH	0.0		K7060	reso	21H00032	H 0	600PP
1168			0.18	87	PID	4	TSH +1.49	TSHTSH			F7467	rsec	21H00063	H99	600HF
1169	101	99	0.41	127	15	P2	VH -0.82	TEHTEC			W4892	rpri	21C00033	C 0	600UL
1170			0.27	92	WAR	2	VH -0.79	VH VH			R6452	reso	21H00067	H 4	560PF
1171			0.36	81	WAR	P4	VM +2.04	VM VC			C3340	reso	21C00073	C 2	560PF
1172			0.36	124	14	P2	VM +2.11	TEHTEC			G6391	rsec	21C00033	C 0	600UL
1173	115	99	0.90	74	MBM	5	VH +6.26	TEHTEC			A9608	reso	21C00035	C 0	600UL
			0.82	79	MBM	5	VH +8.05	TEHTEC			A9608	reso	21C00035	C 0	600UL
1175	32	100	1.36	87	MBM	5	02C +33.35	TSCTEH			A9608	reso	21H00123	C 0	600UL
1176	38	100	11.92	46	INR	P3	TSH +0.08	TSCTEH			A9608	reso	21H00124	C 0	600UL

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
1177	74	100	0.39	80	MBM	5	04H	+2.85	TEHTEC			A9608	reso	21C00035	C 0 600UL
1178	94	100	0.34	71	INR	P1	TSH	+1.04	TEHTEC			A9608	reso	21C00035	C 0 600UL
1179			2.66	95	MBM	5	04C	+5.94	TEHTEC			A9608	reso	21C00035	C 0 600UL
1180	100	100	0.54	84	MBM	5	03C	+3.23	TEHTEC			R6452	reso	21C00033	C 0 600UL
1181			0.46	74	MBM	5	03C	+6.46	TEHTEC			R6452	reso	21C00033	C 0 600UL
1182			0.89	76	MBM	5	03C	+16.34	TEHTEC			R6452	reso	21C00033	C 0 600UL
1183			0.47	82	MBM	5	03C	+18.76	TEHTEC			R6452	reso	21C00033	C 0 600UL
1184			0.52	90	MBM	5	03C	+19.68	TEHTEC			R6452	reso	21C00033	C 0 600UL
1185			0.39	79	MBM	5	02C	+30.01	TEHTEC			R6452	reso	21C00033	C 0 600UL
1186			0.66	76	MBM	5	02C	+31.76	TEHTEC			R6452	reso	21C00033	C 0 600UL
1187			0.41	82	MBM	5	02C	+32.69	TEHTEC			R6452	reso	21C00033	C 0 600UL
1188			0.38	74	MBM	5	02C	+33.91	TEHTEC			R6452	reso	21C00033	C 0 600UL
1189			0.71	86	MBM	5	02C	+34.62	TEHTEC			R6452	reso	21C00033	C 0 600UL
1190			0.50	74	MBM	5	02C	+35.72	TEHTEC			R6452	reso	21C00033	C 0 600UL
1191	102	100	1.09	95	MBM	5	07H	+11.65	TEHTEC			A9608	reso	21C00035	C 0 600UL
1192	112	100	0.45	83	MBM	6	05C	+5.87	TEHTEC			A9608	reso	21C00035	C 0 600UL
1193			0.34	89	PLP	10	TSC	+2.28	TSCTSC			F7467	rsec	21C00135	C 3 600PP
1194	120	100	0.74	94	MBM	5	VH	+3.90	TEHTEC			C3340	reso	21C00058	C 0 580UL
1195			2.12	89	MBM	5	VH	+13.97	TEHTEC			C3340	reso	21C00058	C 0 580UL
1196			0.86	96	MBM	5	VH	+16.34	TEHTEC			C3340	reso	21C00058	C 0 580UL
[illegible]			0.42	89	MBM	5	VH	+21.79	TEHTEC			C3340	reso	21C00058	C 0 580UL
[illegible]			0.67	100	MBM	5	06C	+22.67	TEHTEC			C3340	reso	21C00058	C 0 580UL
1199	130	100	0.27		PLP	9	TSC	+0.23	TSCTSC			L2157	rpri	21C00156	C 3 600PP
1200	51	101	0.70	74	MBM	5	06H	+2.66	TECTEH			A9608	reso	21H00123	C 0 600UL
1201	59	101	0.32	72	MBM	5	02C	+27.36	TECTEH			A9608	reso	21H00123	C 0 600UL
1202	67	101	4.22	102	INR	P3	TSH	+0.03	TEHTEC			W4892	rpri	21C00033	C 0 600UL
1203	77	101	0.35	19	INR	P1	08H	+0.37	TEHTEC			B1055	rpri	21C00035	C 0 600UL
1204	89	101	1.08	19	INR	P1	03H	-0.64	TEHTEC			B1055	rpri	21C00035	C 0 600UL
1205	93	101	1.86	69	MBM	6	03H	+2.22	TEHTEC			A9608	reso	21C00035	C 0 600UL
1206	97	101	0.36	83	MBM	5	07C	+21.06	TEHTEC			A9608	reso	21C00035	C 0 600UL
1207	103	101	0.56	81	MBM	5	03H	+15.80	TEHTEC			R6452	reso	21C00033	C 0 600UL
1208	119	101	0.77	74	MBM	5	08H	+9.19	TEHTEC			R6452	reso	21C00033	C 0 600UL
1209	129	101	0.58	10	IDM	2	TSH	+3.97	TSHTSH			K7060	reso	21H00054	H 0 600PP
1210	22	102	0.73	75	MBM	5	01H	+9.83	TECTEH			H2131	reso	21H00124	C 0 600UL
1211			0.55	70	MBM	5	01H	+11.89	TECTEH			H2131	reso	21H00124	C 0 600UL
1212			0.24	94	NQI	P1	03H	+5.24	TECTEH			H2131	reso	21H00124	C 0 600UL
1213			0.21	130	VOL	2	03H	+5.24	03H04H			M1680	reso	21H00167	H 4 600PP
1214			0.70	77	MBM	5	03H	+16.63	TECTEH			H2131	reso	21H00124	C 0 600UL
1215			0.60	70	MBM	5	04H	+4.82	TECTEH			H2131	reso	21H00124	C 0 600UL
1216			0.30	80	MBM	5	04H	+5.41	TECTEH			H2131	reso	21H00124	C 0 600UL
1217	36	102	0.51	83	MBM	5	01H	+13.30	TSCTEH			A9608	reso	21H00123	C 0 600UL
1218			0.92	71	MBM	6	04H	+12.89	TSCTEH			A9608	reso	21H00123	C 0 600UL
1219	42	102	0.88	79	MBM	5	01C	+19.49	TSCTEH			H2131	reso	21H00124	C 0 600UL
1220	62	102	0.09	123	SCI	P1	TSH	+0.16	TSHTSH	0.2		K7060	reso	21H00031	H 0 600PP
1221					SCI	1	TSH	+0.16	TSHTSH	0.0		K7060	reso	21H00031	H 0 600PP
1222			0.09	42	PID	P1	TSH	+0.16	TSHTSH			B1055	rpri	21H00068	H99 600HF
	64	102	2.14	104	INR	P3	TSH	+0.42	TEHTEC			C5184	rsec	21C00036	C 0 600UL
1224	72	102	0.85	90	MBM	5	01H	+6.71	TEHTEC			A9608	reso	21C00036	C 0 600UL
1225	74	102	0.28	349	INR	P1	08H	-0.05	TEHTEC			G6391	rsec	21C00037	C 0 600UL

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE	SIZE
1226	80	102	0.10	76	SAI	1	TSH +2.25	TSHTSH	0.1		B3720	reso	21H00031	H	0	600PP	
1227			0.16	113	SAI	2	TSH +2.25	TSHTSH	0.1		K7060	reso	21H00031	H	0	600PP	
1228			0.16	111	PID	4	TSH +2.25	TSHTSH			N0942	rpri	21H00063	H99		600HF	
1229	88	102	0.07	84	SAI	2	TSH +0.47	TSHTSH	0.2		K7060	reso	21H00031	H	0	600PP	
1230					SAI	1	TSH +0.47	TSHTSH	0.0		K7060	reso	21H00031	H	0	600PP	
1231			0.10	112	SAI	2	TSH +1.02	TSHTSH	0.2		K7060	reso	21H00031	H	0	600PP	
1232					SAI	1	TSH +1.02	TSHTSH	0.0		K7060	reso	21H00031	H	0	600PP	
1233			0.14	137	PID	4	TSH +1.02	TSHTSH			N0942	rpri	21H00063	H99		600HF	
1234	92	102	0.56	83	MBM	5	05H +24.01	TEHTEC			A9608	reso	21C00035	C	0	600UL	
1235	100	102	0.28	38	INR	P1	TSH +0.89	TEHTEC			B1055	rpri	21C00035	C	0	600UL	
1236	108	102	0.22	124	INR	P1	01H -0.81	TEHTEC			B1055	rpri	21C00035	C	0	600UL	
1237	130	102	0.34		PLP	9	TSC +0.39	TSCTSC			L2157	rpri	21C00156	C	3	600PP	
1238	23	103	0.74	78	MBM	5	01H +28.28	TECTEH			A9608	reso	21H00123	C	0	600UL	
1239	31	103	0.61	63	MBM	5	TSC +9.18	TSCTEH			A9608	reso	21H00123	C	0	600UL	
1240			0.51	85	MBM	5	TSC +15.21	TSCTEH			A9608	reso	21H00123	C	0	600UL	
1241	45	103	0.16	70	SAI	1	TSH +4.20	TSHTSH	0.2		B3720	reso	21H00154	H	0	600PP	
1242			0.12	99	SAI	2	TSH +4.20	TSHTSH	0.1		B3720	reso	21H00154	H	0	600PP	
1243			0.13	102	PID	4	TSH +4.20	TSHTSH			L7871	rpri	21H00166	H99		600HF	
1244	65	103	0.78	67	MBM	5	TSH +15.42	TEHTEC			A9608	reso	21C00036	C	0	600UL	
1245	67	103	0.51	75	MBM	5	02H +12.60	TEHTEC			B3720	reso	21C00037	C	0	600UL	
[illegible]			0.45	77	MBM	5	03H +1.70	TEHTEC			B3720	reso	21C00037	C	0	600UL	
[illegible]	71	103	1.27	110	INR	P1	TSH +0.00	TEHTEC			W4892	rpri	21C00037	C	0	600UL	
1248	93	103	0.46	69	MBM	6	05H +22.01	TEHTEC			A9608	reso	21C00036	C	0	600UL	
1249	121	103	1.12	47	MBM	6	09H +13.74	TEHTEC			C3340	reso	21C00058	C	0	580UL	
1250			0.82	64	MBM	6	04C +8.05	TEHTEC			C3340	reso	21C00058	C	0	580UL	
1251	129	103			INF	9	TSH +1.08	TSHTSH	HR		S7752	reso	21H00056	H	0	600PP	
1252	40	104	0.76	84	MBM	5	06H +7.77	TSCTEH			A9608	reso	21H00123	C	0	600UL	
1253	72	104	0.62	88	MBM	5	07C +9.27	TEHTEC			B3720	reso	21C00037	C	0	600UL	
1254	86	104	0.12	95	SAI	2	TSH +0.59	TSHTSH	0.2		K7060	reso	21H00033	H	0	600PP	
1255					SAI	1	TSH +0.59	TSHTSH	0.0		K7060	reso	21H00033	H	0	600PP	
1256			0.12	73	PID	4	TSH +0.59	TSHTSH			F7467	rsec	21H00063	H99		600HF	
1257	104	104	0.70	81	MBM	5	01H +25.18	TEHTEC			B3720	reso	21C00037	C	0	600UL	
1258	126	104	0.20	74	PLP	9	TSH +0.54	TSHTSH			G6391	rsec	21H00056	H	0	600PP	
1259	128	104			INF	2	TSH +0.63	TSHTSH	HR		S7752	reso	21H00055	H	0	600PP	
1260	130	104	0.36	76	PLP	9	TSH +0.62	TSHTSH			G6391	rsec	21H00056	H	0	600PP	
1261	21	105	0.69	74	MBM	5	03C +17.23	TECTEH			H2131	reso	21H00124	C	0	600UL	
1262	35	105	0.60	81	MBM	5	02H +17.76	TSCTEH			A9608	reso	21H00123	C	0	600UL	
1263			1.30	76	MBM	5	03H +25.83	TSCTEH			A9608	reso	21H00123	C	0	600UL	
1264	37	105	0.52	76	MBM	5	01C +21.01	TSCTEH			H2131	reso	21H00124	C	0	600UL	
1265			0.55	77	MBM	6	01C +22.27	TSCTEH			H2131	reso	21H00124	C	0	600UL	
1266	61	105	0.80	80	MBM	6	04H +7.05	TEHTEC			B3720	reso	21C00039	C	0	600UL	
1267	65	105	0.60	54	MBM	5	01H +33.22	TEHTEC			B3720	reso	21C00037	C	0	600UL	
1268	87	105	0.36	76	MBM	5	06C +7.42	TEHTEC			A9608	reso	21C00036	C	0	600UL	
1269	113	105	0.83	74	MBM	5	VC +18.74	TEHTEC			B3720	reso	21C00037	C	0	600UL	
1270	125	105	0.55	66	MBM	6	TSC +2.35	TEHTEC			C3340	reso	21C00058	C	0	580UL	
1271	127	105	0.77	68	MBM	5	02H +15.50	TEHTEC			M1680	reso	21C00059	C	0	580UL	
			0.67	80	MBM	5	03H +28.26	TEHTEC			M1680	reso	21C00059	C	0	580UL	
1273	28	106	0.77	71	MBM	5	01H +12.60	TECTEH			A9608	reso	21H00123	C	0	600UL	
1274	42	106	1.35	86	NQI	6	02C +30.65	TSCTEH			H2131	reso	21H00124	C	0	600UL	

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final —

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE	SIZE
1275					NDF	02C	+30.65	02C03C			K7060	reso	21C00179	C	3	600HF	
1276	80	106	0.34	75	SAI	1 TSH	+0.32	TSHTSH	0.4		H2131	reso	21H00034	H	0	600PP	
1277			0.28	100	SAI	2 TSH	+0.32	TSHTSH	0.3		K7060	reso	21H00034	H	0	600PP	
1278			0.28	99	PID	4 TSH	+0.32	TSHTSH			F7467	rsec	21H00063	H	99	600HF	
1279	100	106	0.55	35	DSI	P1 09H	+0.15	TEHTEC			W4892	rpri	21C00037	C	0	600UL	
1280					NDF	09H	+0.15	09H09H			T0042	reso	21H00066	H	4	600PP	
1281			0.68	70	DSI	P1 09C	-0.11	TEHTEC			W4892	rpri	21C00037	C	0	600UL	
1282					NDF	09C	-0.11	09C09C			S0607	rsec	21C00072	C	2	600PP	
1283	124	106	0.98	89	MBM	5 09C	+4.13	TEHTEC			C3340	reso	21C00058	C	0	580UL	
1284	126	106	0.43	58	INR	5 VM	+8.32	TEHTEC			R9311	rpri	21C00059	C	0	580UL	
1285	130	106	0.30	77	PLP	9 TSH	+0.01	TSHTSH			G6391	rsec	21H00056	H	0	600PP	
1286			1.04	81	MBM	6 VC	+21.97	TEHTEC			M1680	reso	21C00059	C	0	580UL	
1287	71	107	1.35	88	MBM	5 05H	+4.59	TEHTEC			B3720	reso	21C00037	C	0	600UL	
1288			1.74	134	MBM	5 06H	+20.69	TEHTEC			B3720	reso	21C00037	C	0	600UL	
1289	75	107	0.13	72	SAI	2 TSH	+2.15	TSHTSH	0.2		K7060	reso	21H00034	H	0	600PP	
1290					SAI	1 TSH	+2.15	TSHTSH	0.0		K7060	reso	21H00034	H	0	600PP	
1291			0.10	130	PID	4 TSH	+2.15	TSHTSH			F7467	rsec	21H00063	H	99	600HF	
1292	113	107	0.60	1	IDM	2 TSH	+5.30	TSHTSH			K7060	reso	21H00033	H	0	600PP	
1293	121	107	0.65	84	MBM	5 TSC	+2.05	TEHTEC			C3340	reso	21C00058	C	0	580UL	
1294	131	107	0.27	77	PLP	9 TSH	+0.23	TSHTSH			G6391	rsec	21H00056	H	0	600PP	
1	26	108	0.79	79	MBM	5 05C	+23.19	TECTEH			H2131	reso	21H00124	C	0	600UL	
1.	108	108	0.38	2	IDM	2 TSH	+1.95	TSHTSH			K7060	reso	21H00033	H	0	600PP	
1297			0.33	356	IDM	2 TSH	+2.65	TSHTSH			T0042	reso	21H00033	H	0	600PP	
1298	128	108	1.16	57	MBM	6 04H	+25.34	TEHTEC			C3340	reso	21C00058	C	0	580UL	
1299	130	108	1.04	84	MBM	5 VH	+11.84	TEHTEC			M1680	reso	21C00059	C	0	580UL	
1300	1	109			OBS	06C	+2.68	06CTEC			A9608	reso	21C00082	C	1	580SF	
1301	15	109	0.31	45	SAI	1 TSH	+1.02	TSHTSH	0.3		H2131	reso	21H00020	H	0	600PP	
1302			0.12	100	SAI	2 TSH	+1.02	TSHTSH	0.3		H2131	reso	21H00020	H	0	600PP	
1303			0.19	139	PID	4 TSH	+1.02	TSHTSH			B1055	rpri	21H00068	H	99	600HF	
1304	37	109	0.72	84	MBM	6 01H	+11.99	TECTEH			K7060	reso	21H00126	C	0	600UL	
1305	59	109	0.52	77	MBM	5 01H	+30.03	TECTEH			R6452	reso	21H00125	C	0	600UL	
1306	87	109	0.57	78	MBM	5 02H	+26.67	TEHTEC			B3720	reso	21C00039	C	0	600UL	
1307	105	109	0.28	7	IDM	2 TSH	+4.40	TSHTSH			K7060	reso	21H00033	H	0	600PP	
1308	4	110	0.43	72	MBM	6 02H	+21.95	06HTEH			C3340	reso	21H00001	H	1	600UL	
1309	10	110			SAI	1 TSH	+1.78	TSHTSH	0.0		A9608	reso	21H00021	H	0	600PP	
1310			0.15	91	SAI	2 TSH	+1.78	TSHTSH	0.2		A9608	reso	21H00021	H	0	600PP	
1311			0.13	57	PID	4 TSH	+1.78	TSHTSH			T0042	reso	21H00068	H	99	600HF	
1312	22	110	0.64	84	MBM	5 02C	+26.36	TECTEH			K7060	reso	21H00126	C	0	600UL	
1313	70	110	0.97	68	MBM	5 02C	+8.96	TEHTEC			B3720	reso	21C00039	C	0	600UL	
1314	80	110	0.11	109	SAI	2 TSH	+0.40	TSHTSH	0.1		K7060	reso	21H00033	H	0	600PP	
1315					SAI	1 TSH	+0.40	TSHTSH	0.0		K7060	reso	21H00033	H	0	600PP	
1316			0.11	144	PID	4 TSH	+0.40	TSHTSH			F7467	rsec	21H00063	H	99	600HF	
1317	98	110	2.60	20	DSI	P1 09H	-0.02	TEHTEC			B3720	reso	21C00039	C	0	600UL	
1318					NDF	09H	-0.02	09H09H			T0042	reso	21H00066	H	4	600PP	
1319	120	110	0.54	81	MBM	5 02H	+25.75	TEHTEC			C3340	reso	21C00058	C	0	580UL	
1320	17	111	0.17	99	SAI	2 TSH	+0.59	TSHTSH	0.5		R6452	reso	21H00021	H	0	600PP	
					SAI	1 TSH	+0.59	TSHTSH	0.0		R6452	reso	21H00021	H	0	600PP	
1322			0.13	290	PID	4 TSH	+0.59	TSHTSH			B1055	rpri	21H00068	H	99	600HF	
1323					SAI	1 TSH	+0.87	TSHTSH	0.0		A9608	reso	21H00021	H	0	600PP	

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
1324		0.10	82	SAI	2	TSH +0.87		TSHTSH	0.2		A9608	reso	21H00021	H 0	600PP
1325	21	0.81	84	MBM	5	01H +36.96		TECTEH			K7060	reso	21H00126	C 0	600UL
1326	35	1.19	86	MBM	5	03H +23.15		TECTEH			K7060	reso	21H00126	C 0	600UL
1327	55	0.75	68	MBM	5	02H +19.71		TECTEH			K7060	reso	21H00126	C 0	600UL
1328		0.44	83	MBM	5	02H +24.35		TECTEH			K7060	reso	21H00126	C 0	600UL
1329		0.37	67	MBM	5	02H +33.13		TECTEH			K7060	reso	21H00126	C 0	600UL
1330	79	0.19	92	MAI	2	TSH +0.42	TO+0.85	TSHTSH	0.2		K7060	reso	21H00029	H 0	600PP
1331				MAI	1	TSH +0.42	TO+0.85	TSHTSH	0.0		K7060	reso	21H00029	H 0	600PP
1332		0.19	102	PID	4	TSH +0.42	TO+0.85	TSHTSH			F7467	rsec	21H00063	H99	600HF
1333	113	0.83	90	MBM	6	VC +12.54		TEHTEC			B3720	reso	21C00039	C 0	600UL
1334	133	0.21	87	PLP	9	TSH +0.34		TSHTSH			M1680	reso	21H00048	H 0	600PP
1335	20	0.12	85	SAI	2	TSH +0.34		TSHTSH	0.2		H2131	reso	21H00020	H 0	600PP
1336				SAI	1	TSH +0.34		TSHTSH	0.0		A9608	reso	21H00020	H 0	600PP
1337		0.09	66	PID	4	TSH +0.34		TSHTSH			J6276	rpri	21H00064	H99	600HF
1338				SAI	1	TSH +0.71		TSHTSH	0.0		A9608	reso	21H00020	H 0	600PP
1339		0.12	92	SAI	2	TSH +0.71		TSHTSH	0.2		H2131	reso	21H00020	H 0	600PP
1340	26	0.08	63	SCI	1	TSH -2.75		TSHTSH	0.2		B3720	reso	21H00154	H 0	600PP
1341		0.28	28	SCI	P1	TSH -2.75		TSHTSH	0.2		B3720	reso	21H00154	H 0	600PP
1342		0.51	30	PID	P1	TSH -2.75		TSHTSH			K2858	rpri	21H00170	H99	600HF
1343	44	0.56	75	MBM	5	TSH +21.89		TECTEH			R6452	reso	21H00125	C 0	600UL
[illegible]	52	0.83	90	MBM	5	04C +19.79		TECTEH			R6452	reso	21H00125	C 0	600UL
[illegible]	54	0.57	69	MBM	5	01H +26.09		TECTEH			K7060	reso	21H00126	C 0	600UL
1346	60	0.73	89	MBM	6	01C +22.47		TECTEH			R6452	reso	21H00125	C 0	600UL
1347	80	0.09	76	SAI	2	TSH +0.69		TSHTSH	0.3		K7060	reso	21H00029	H 0	600PP
1348				SAI	1	TSH +0.69		TSHTSH	0.0		K7060	reso	21H00029	H 0	600PP
1349		0.14	101	PID	4	TSH +0.69		TSHTSH			F7467	rsec	21H00063	H99	600HF
1350	86	0.15	98	SAI	2	TSH +0.55		TSHTSH	0.2		K7060	reso	21H00030	H 0	600PP
1351		0.16	125	SAI	1	TSH +0.55		TSHTSH	0.2		K7060	reso	21H00030	H 0	600PP
1352		0.14	73	PID	4	TSH +0.55		TSHTSH			F7467	rsec	21H00063	H99	600HF
1353	130	0.49	84	PLP	9	TSH +0.18		TSHTSH			M1680	reso	21H00048	H 0	600PP
1354		0.76	8	IDM	2	TSH +2.30		TSHTSH			K7060	reso	21H00048	H 0	600PP
1355		1.17	7	IDM	2	TSH +5.40		TSHTSH			K7060	reso	21H00048	H 0	600PP
1356	1			OBS		06C +5.35		06CTEC			A9608	reso	21C00082	C 1	580SF
1357	19	0.19	72	MAI	2	TSH +0.52		TSHTSH	0.2		H2131	reso	21H00020	H 0	600PP
1358				MAI	1	TSH +0.52		TSHTSH	0.0		A9608	reso	21H00020	H 0	600PP
1359		0.16	77	PID	4	TSH +0.52		TSHTSH			J6276	rpri	21H00064	H99	600HF
1360	23	0.76	88	MBM	5	05H +33.69		TECTEH			R6452	reso	21H00125	C 0	600UL
1361		0.41	114	INR	6	05C +30.80		TECTEH			T7451	rsec	21H00125	C 0	600UL
1362		0.62	81	MBM	5	05C +35.81		TECTEH			R6452	reso	21H00125	C 0	600UL
1363	25	0.16	105	SCI	P1	TSH +0.07		TSHTSH	0.2		B3720	reso	21H00154	H 0	600PP
1364				SCI	1	TSH +0.07		TSHTSH	0.0		B3720	reso	21H00154	H 0	600PP
1365		0.16	100	PID	P1	TSH +0.07		TSHTSH			L7871	rpri	21H00166	H99	600HF
1366	43	1.60	84	MBM	6	TSH +36.84		TECTEH			R6452	reso	21H00125	C 0	600UL
1367		1.31	69	MBM	6	02H +36.53		TECTEH			R6452	reso	21H00125	C 0	600UL
1368	73	1.50	74	MBM	6	06H +1.55		TEHTEC			A9608	reso	21C00038	C 0	600UL
1369	79	0.15	97	MAI	2	TSH +0.34	TO+0.83	TSHTSH	0.5		K7060	reso	21H00029	H 0	600PP
				MAI	1	TSH +0.34	TO+0.83	TSHTSH	0.0		K7060	reso	21H00029	H 0	600PP
1371		0.18	89	PID	4	TSH +0.34	TO+0.83	TSHTSH			F7467	rsec	21H00063	H99	600HF
1372	81	0.12	100	SAI	2	TSH +0.90		TSHTSH	0.2		K7060	reso	21H00030	H 0	600PP

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 10:57

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
1373				SAI	1 TSH	+0.90		TSHTSH	0.0		K7060	reso	21H00030	H 0	600PP
1374			0.17	138 PID	4 TSH	+0.90		TSHTSH			F7467	rsec	21H00063	H99	600HF
1375	83	113	0.93	94 MBM	6 TSH	+26.64		TEHTEC			B3720	reso	21C00039	C 0	600UL
1376	85	113		SAI	1 TSH	+0.71		TSHTSH	0.0		K7060	reso	21H00030	H 0	600PP
1377			0.14	122 NQI	P1 TSH	+0.71		TEHTEC			B1055	rpri	21C00038	C 0	600UL
1378			0.16	53 SAI	2 TSH	+0.71		TSHTSH	0.2		K7060	reso	21H00030	H 0	600PP
1379			0.15	78 PID	4 TSH	+0.71		TSHTSH			F7467	rsec	21H00063	H99	600HF
1380	87	113	0.45	66 MBM	6 VH	+16.04		TEHTEC			B3720	reso	21C00039	C 0	600UL
1381	89	113	0.14	99 MAI	2 TSH	+1.15	TO+1.44	TSHTSH	0.2		K7060	reso	21H00030	H 0	600PP
1382				MAI	1 TSH	+1.15	TO+1.44	TSHTSH	0.0		K7060	reso	21H00030	H 0	600PP
1383			0.15	132 PID	4 TSH	+1.15	TO+1.44	TSHTSH			F7467	rsec	21H00063	H99	600HF
1384	113	113	0.91	80 MBM	6 TSC	+21.61		TEHTEC			A9608	reso	21C00038	C 0	600UL
1385	121	113	0.75	79 MBM	5 TSC	+2.37		TEHTEC			C3340	reso	21C00058	C 0	580UL
1386			0.49	114 INR	P1 TSC	+4.66		TEHTEC			L2157	rpri	21C00058	C 0	580UL
1387	123	113	1.54	90 MBM	6 08C	+21.16		TEHTEC			M1680	reso	21C00059	C 0	580UL
1388	8	114	0.16	39 INR	P1 TSH	+3.49		TEHTEC			R6452	reso	21C00021	C 0	600UL
1389	10	114		SAI	1 TSH	+0.47		TSHTSH	0.0		A9608	reso	21H00021	H 0	600PP
1390			0.08	72 SAI	2 TSH	+0.47		TSHTSH	0.2		A9608	reso	21H00021	H 0	600PP
1391			0.08	90 PID	4 TSH	+0.47		TSHTSH			J6276	rpri	21H00064	H99	600HF
1392	14	114		SAI	1 TSH	+0.18		TSHTSH	0.0		A9608	reso	21H00021	H 0	600PP
[illegible]			0.11	83 SAI	2 TSH	+0.18		TSHTSH	0.2		A9608	reso	21H00021	H 0	600PP
[illegible]				SAI	1 TSH	+0.70		TSHTSH	0.0		R6452	reso	21H00021	H 0	600PP
1395			0.18	80 SAI	2 TSH	+0.70		TSHTSH	0.2		R6452	reso	21H00021	H 0	600PP
1396			0.17	76 PID	4 TSH	+0.70		TSHTSH			N0942	rpri	21H00063	H99	600HF
1397			0.10	90 SAI	2 TSH	+0.98		TSHTSH	0.2		A9608	reso	21H00021	H 0	600PP
1398				SAI	1 TSH	+0.98		TSHTSH	0.0		A9608	reso	21H00021	H 0	600PP
1399	16	114	0.12	68 SAI	2 TSH	+0.29		TSHTSH	0.3		H2131	reso	21H00020	H 0	600PP
1400				SAI	1 TSH	+0.29		TSHTSH	0.0		A9608	reso	21H00020	H 0	600PP
1401			0.11	127 PID	4 TSH	+0.29		TSHTSH			F7467	rsec	21H00063	H99	600HF
1402	20	114	0.16	89 MAI	2 TSH	+0.37		TSHTSH	0.3		H2131	reso	21H00020	H 0	600PP
1403				MAI	1 TSH	+0.37		TSHTSH	0.0		A9608	reso	21H00020	H 0	600PP
1404			0.12	95 PID	4 TSH	+0.37		TSHTSH			F7467	rsec	21H00063	H99	600HF
1405	22	114	0.49	87 MBM	5 05H	+32.81		TECTEH			K7060	reso	21H00126	C 0	600UL
1406	34	114	1.08	75 MBM	5 02H	+11.53		TECTEH			K7060	reso	21H00126	C 0	600UL
1407	76	114	0.35	123 NQI	P1 TSH	+0.69		TEHTEC			B1055	rpri	21C00038	C 0	600UL
1408				NDF	TSH	+0.69		TSHTSH			H2131	reso	21H00029	H 0	600PP
1409	124	114	1.00	76 MBM	5 TSC	+4.50		TEHTEC			C3340	reso	21C00058	C 0	580UL
1410	55	115	0.33	88 NQI	5 04H	+11.51		TECTEH			R6452	reso	21H00125	C 0	600UL
1411				NDF	04H	+11.51		04H05H			T7451	rsec	21H00167	H 4	600PP
1412	65	115	0.28	73 MBM	6 01C	+24.23		TEHTEC			B3720	reso	21C00039	C 0	600UL
1413	89	115		SAI	1 TSH	+0.25		TSHTSH	0.0		K7060	reso	21H00030	H 0	600PP
1414			0.11	97 SAI	2 TSH	+0.25		TSHTSH	0.2		K7060	reso	21H00030	H 0	600PP
1415				MAI	1 TSH	+0.53	TO+0.70	TSHTSH	0.0		K7060	reso	21H00030	H 0	600PP
1416			0.09	75 MAI	2 TSH	+0.53	TO+0.70	TSHTSH	0.2		K7060	reso	21H00030	H 0	600PP
1417			0.14	75 PID	4 TSH	+0.53	TO+0.70	TSHTSH			F7467	rsec	21H00063	H99	600HF
1418			0.23	90 NQI	P1 TSH	+0.71		TEHTEC			B1055	rpri	21C00038	C 0	600UL
	10	116	10.22	51 INR	P3 TSH	+0.31		TEHTEC			A9608	reso	21C00022	C 0	600UL
1420	24	116	0.89	101 INR	6 05C	+36.84		TEHTEC			S1848	rpri	21C00021	C 0	600UL
1421	34	116	0.95	84 MBM	6 03H	+24.95		TEHTEC			R6452	reso	21C00021	C 0	600UL

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final — PAGE 30

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
1422		1.13	77	MBM	6	03C	+21.00	TEHTEC		R6452	reso	21C00021	C 0	600UL
1423	76	0.13	100	SAI	2	TSH	+1.02	TSHTSH	0.2	K7060	reso	21H00030	H 0	600PP
1424				SAI	1	TSH	+1.02	TSHTSH	0.0	K7060	reso	21H00030	H 0	600PP
1425		0.13	85	PID	4	TSH	+1.02	TSHTSH		F7467	rsec	21H00063	H99	600HF
1426	88	0.12	102	SAI	2	TSH	+0.94	TSHTSH	0.2	K7060	reso	21H00030	H 0	600PP
1427				SAI	1	TSH	+0.94	TSHTSH	0.0	K7060	reso	21H00030	H 0	600PP
1428		0.13	134	PID	4	TSH	+0.94	TSHTSH		S0607	rsec	21H00063	H99	600HF
1429	106	1.24	48	MBM	6	TSC	+11.97	TEHTEC		R6452	reso	21C00023	C 0	600UL
1430	112	0.82	69	MBM	6	03H	+25.56	TEHTEC		B3720	reso	21C00024	C 0	600UL
1431	114	0.90	51	MBM	6	TSH	+6.51	TEHTEC		R6452	reso	21C00023	C 0	600UL
1432		1.20	82	MBM	6	01H	+23.44	TEHTEC		R6452	reso	21C00023	C 0	600UL
1433	55	0.96	88	MBM	6	07C	+3.85	TEHTEC		R6452	reso	21C00021	C 0	600UL
1434	85	0.83	87	MBM	6	01H	+10.16	TEHTEC		R6452	reso	21C00023	C 0	600UL
1435	113	0.93	98	MBM	5	04H	+12.93	TEHTEC		B3720	reso	21C00024	C 0	600UL
1436	14			NDF		TSH	+3.63	TSHTSH		D3858	reso	21H00021	H 0	600PP
1437		0.35	121	NQI	P1	TSH	+3.63	TEHTEC		H3464	rpri	21C00020	C 0	600UL
1438		0.95	91	MBM	5	02C	+5.33	TEHTEC		A9608	reso	21C00020	C 0	600UL
1439	68	0.49	71	MBM	6	01C	+6.71	TEHTEC		R6452	reso	21C00023	C 0	600UL
1440	76	0.13	105	SAI	2	TSH	+1.28	TSHTSH	0.2	K7060	reso	21H00030	H 0	600PP
1441				SAI	1	TSH	+1.28	TSHTSH	0.0	K7060	reso	21H00030	H 0	600PP
1		0.11	78	PID	4	TSH	+1.28	TSHTSH		S0607	rsec	21H00063	H99	600HF
1	94	0.87	84	MBM	6	05H	+19.41	TEHTEC		R6452	reso	21C00023	C 0	600UL
1444	96	0.39	125	INR	P1	TSC	+2.51	TEHTEC		B3720	reso	21C00024	C 0	600UL
1445	110	1.51	67	MBM	6	VH	+19.81	TEHTEC		R6452	reso	21C00023	C 0	600UL
1446	25	0.47	64	MBM	5	03H	+7.45	TEHTEC		A9608	reso	21C00022	C 0	600UL
1447	27	0.12	149	WAR	2	VM	+1.95	VM VM		D3858	reso	21C00073	C 2	560PF
1448		0.42	67	15	P2	VM	+2.08	TEHTEC		S1848	rpri	21C00021	C 0	600UL
1449	115	0.99	76	MBM	6	04H	+29.33	TEHTEC		C3340	reso	21C00025	C 0	600UL
1450		1.60	73	MBM	6	08C	+12.78	TEHTEC		C3340	reso	21C00025	C 0	600UL
1451	121	0.48	25	INR	P1	TSC	+1.79	TEHTEC		L2157	rpri	21C00058	C 0	580UL
1452	28	1.18	58	MBM	6	TSH	+32.23	TEHTEC		R6452	reso	21C00021	C 0	600UL
1453	46	0.10	83	SAI	2	TSH	+4.80	TSHTSH	0.2	B3720	reso	21H00156	H 0	600PP
1454				SAI	1	TSH	+4.80	TSHTSH	0.0	B3720	reso	21H00156	H 0	600PP
1455		0.07	92	PID	4	TSH	+4.80	TSHTSH		T7451	rsec	21H00166	H99	600HF
1456	66	0.20	105	SAI	2	TSH	+1.68	TSHTSH	0.2	K7060	reso	21H00030	H 0	600PP
1457		0.19	99	SAI	1	TSH	+1.68	TSHTSH	0.3	K7060	reso	21H00030	H 0	600PP
1458		0.19	107	PID	4	TSH	+1.68	TSHTSH		S0607	rsec	21H00063	H99	600HF
1459	68	0.62	83	MBM	5	03C	+9.93	TEHTEC		C3340	reso	21C00025	C 0	600UL
1460	70			INF		07H	+21.32	TEHTEC	HR	B3720	reso	21C00026	C 0	600UL
1461	114	0.49	83	MBM	5	02C	+28.79	TEHTEC		C3340	reso	21C00025	C 0	600UL
1462	118	1.04	64	MBM	6	02H	+6.57	TEHTEC		C3340	reso	21C00025	C 0	600UL
1463		1.28	87	MBM	6	08H	+8.22	TEHTEC		C3340	reso	21C00025	C 0	600UL
1464	1	0.81	52	NQI	5	05H	+30.90	06HTEH		C3340	reso	21H00001	H 1	600UL
1465				NDF		05H	+30.90	06H05H	I.D. OK	B3720	reso	21H00067	H 4	560PF
1466				NDF		05H	+30.90	06H05H		T0042	reso	21H00066	H 4	600PP
1467	27	0.81	72	MBM	6	TSH	+12.07	TEHTEC		A9608	reso	21C00022	C 0	600UL
		0.34	74	MBM	5	TSH	+34.20	TEHTEC		A9608	reso	21C00022	C 0	600UL
1469	63	0.18	113	SAI	2	TSH	+0.81	TSHTSH	0.3	K7060	reso	21H00030	H 0	600PP
1470		0.25	85	SAI	1	TSH	+0.81	TSHTSH	0.3	K7060	reso	21H00030	H 0	600PP

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 10:57

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE	SIZE
1471		0.20	115	PID	4 TSH	+0.81	TSHTSH			S0607	rsec	21H00063	H99	600HF		
1472	65	121	0.48	77	MBM	5 DH	+25.78	TEHTEC			C3340	reso	21C00025	C 0	600UL	
1473					INF	VM	+21.31	TEHTEC	HR		C3340	reso	21C00025	C 0	600UL	
1474	73	121	0.10	103	MAI	2 TSH	+0.67 TO+0.98	TSHTSH	0.3		K7060	reso	21H00029	H 0	600PP	
1475					MAI	1 TSH	+0.67 TO+0.98	TSHTSH	0.0		K7060	reso	21H00029	H 0	600PP	
1476			0.12	97	PID	4 TSH	+0.67 TO+0.98	TSHTSH			S0607	rsec	21H00063	H99	600HF	
1477	85	121	0.15	101	SAI	2 TSH	+1.30	TSHTSH	0.4		K7060	reso	21H00029	H 0	600PP	
1478					SAI	1 TSH	+1.30	TSHTSH	0.0		K7060	reso	21H00029	H 0	600PP	
1479			0.13	98	PID	4 TSH	+1.30	TSHTSH			S0607	rsec	21H00063	H99	600HF	
1480	89	121	0.11	82	SAI	2 TSH	+0.60	TSHTSH	0.3		K7060	reso	21H00030	H 0	600PP	
1481					SAI	1 TSH	+0.60	TSHTSH	0.0		K7060	reso	21H00030	H 0	600PP	
1482			0.12	97	PID	4 TSH	+0.60	TSHTSH			S0607	rsec	21H00063	H99	600HF	
1483	93	121	0.58	76	MBM	5 VH	+22.17	TEHTEC			B3720	reso	21C00026	C 0	600UL	
1484	111	121	1.09	81	MBM	6 DH	+9.72	TEHTEC			C3340	reso	21C00025	C 0	600UL	
1485	123	121	0.58	76	MBM	5 TSC	+2.35	TEHTEC			C3340	reso	21C00058	C 0	580UL	
1486	125	121			NDF	07H	+21.55	08H07H			K7060	reso	21H00086	H 4	600HF	
1487			0.62	90	NQI	5 07H	+21.96	TEHTEC			M1680	reso	21C00059	C 0	580UL	
1488	2	122			OBS	06C	+2.45	06CTEC			A9608	reso	21C00082	C 1	580SF	
1489	6	122			OBS	06C	+8.47	06CTEC			H2131	reso	21C00020	C 0	600UL	
1490	14	122	0.74	83	MBM	5 TSH	+34.49	TEHTEC			A9608	reso	21C00020	C 0	600UL	
[illegible]	16	122	0.44	71	MBM	6 01H	+23.48	TEHTEC			H2131	reso	21C00019	C 0	600UL	
[illegible]	36	122			NDF	1 VM	-1.13	VM 07H			B3720	reso	21H00169	H 6	560PF	
1493	66	122	0.65	73	NQI	5 TSH	+0.62	TEHTEC			B3720	reso	21C00026	C 0	600UL	
1494					NDF	TSH	+0.62	TSHTSH			D3858	reso	21H00029	H 0	600PP	
1495	72	122	0.11	105	SAI	2 TSH	+0.92	TSHTSH	0.2		K7060	reso	21H00030	H 0	600PP	
1496					SAI	1 TSH	+0.92	TSHTSH	0.0		K7060	reso	21H00030	H 0	600PP	
1497			0.12	123	PID	4 TSH	+0.92	TSHTSH			S0607	rsec	21H00063	H99	600HF	
1498	114	122	1.03	81	MBM	5 02C	+33.51	TEHTEC			B3720	reso	21C00026	C 0	600UL	
1499	27	123	0.31	147	INR	P1 TSC	+1.74	TEHTEC			S1848	rpri	21C00019	C 0	600UL	
1500	31	123	0.49	70	MBM	5 05H	+12.65	TEHTEC			H2131	reso	21C00019	C 0	600UL	
1501	35	123	0.59	87	MBM	6 03C	+25.38	TEHTEC			H2131	reso	21C00019	C 0	600UL	
1502	51	123	0.71	71	MBM	6 04H	+10.16	TEHTEC			H2131	reso	21C00019	C 0	600UL	
1503	55	123	0.95	54	MBM	6 06H	+19.90	TEHTEC			H2131	reso	21C00019	C 0	600UL	
1504	59	123	0.16	95	MAI	2 TSH	+0.80	TSHTSH	0.5		B3720	reso	21H00028	H 0	600PP	
1505			0.22	33	MAI	1 TSH	+0.80	TSHTSH	0.3		B3720	reso	21H00028	H 0	600PP	
1506			0.18	89	PID	4 TSH	+0.80	TSHTSH			S0607	rsec	21H00063	H99	600HF	
1507	69	123	0.08	113	MAI	2 TSH	+0.95	TSHTSH	0.5		R6452	reso	21H00023	H 0	600PP	
1508			0.23	88	MAI	1 TSH	+0.95	TSHTSH	0.7		R6452	reso	21H00023	H 0	600PP	
1509			0.11	93	PID	4 TSH	+0.95	TSHTSH			S0607	rsec	21H00063	H99	600HF	
1510					SAI	1 TSH	+1.67	TSHTSH	0.0		R6452	reso	21H00023	H 0	600PP	
1511			0.08	91	SAI	2 TSH	+1.67	TSHTSH	0.2		B3720	reso	21H00023	H 0	600PP	
1512	77	123	0.91	84	MBM	5 01C	+29.96	TEHTEC			B3720	reso	21C00026	C 0	600UL	
1513	81	123	0.47	78	MBM	5 05H	+22.35	TEHTEC			B3720	reso	21C00026	C 0	600UL	
1514			1.32	76	MBM	5 05H	+25.54	TEHTEC			B3720	reso	21C00026	C 0	600UL	
1515			0.40	83	MBM	5 05H	+35.04	TEHTEC			B3720	reso	21C00026	C 0	600UL	
1516			0.45	80	MBM	5 02C	+14.40	TEHTEC			B3720	reso	21C00026	C 0	600UL	
	101	123	1.80	85	MBM	6 VC	+3.00 TO+4.31	TEHTEC			B3720	reso	21C00026	C 0	600UL	
1518	119	123	0.19	20	IDM	2 TSH	+1.69	TSHTSH	0.3		D3858	reso	21H00023	H 0	600PP	
1519	26	124	0.17	95	SAI	2 TSH	+0.74	TSHTSH	0.5		B3720	reso	21H00028	H 0	600PP	

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final —

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
1520				SAI	1 TSH	+0.74	TSHTSH	0.0		B3720	reso	21H00028	H 0	600PP
1521		0.15	110	PID	4 TSH	+0.74	TSHTSH			S0607	rsec	21H00063	H99	600HF
1522	112	124	1.02	54	MBM 6	02C +3.64	TEHTEC			B3720	reso	21C00028	C 0	600UL
1523	116	124	1.21	57	MBM 5	04H +22.51	TEHTEC			B3720	reso	21C00028	C 0	600UL
1524	11	125	0.42	88	MBM 5	01C +9.40	TEHTEC			A9608	reso	21C00020	C 0	600UL
1525	17	125	0.64	69	MBM 6	TSC +24.45	TEHTEC			H2131	reso	21C00019	C 0	600UL
1526	21	125		SCI	1 TSC	+0.02	TSCTSC	0		R6452	reso	21C00127	C 3	600PP
1527			0.05	124	SCI P1	TSC +0.02	TSCTSC	0.3		R6452	reso	21C00127	C 3	600PP
1528			0.32	30	PID P1	TSC +0.02	TSCTSC			B6768	rpri	21C00139	C99	600HF
1529	43	125	0.75	23	P2	01C +0.52	TEHTEC			H3464	rpri	21C00020	C 0	600UL
1530			0.20	70	WAR 2	01C +0.67	01C01C			D3858	reso	21C00072	C 2	600PP
1531	49	125	0.61	81	MBM 5	02H +25.43	TEHTEC			H2131	reso	21C00019	C 0	600UL
1532	61	125		SAI	1 TSH	+1.26	TSHTSH	0.0		R6452	reso	21H00024	H 0	600PP
1533			0.08	87	SAI 2	TSH +1.26	TSHTSH	0.2		R6452	reso	21H00024	H 0	600PP
1534			0.07	72	PID 4	TSH +1.26	TSHTSH			S0607	rsec	21H00063	H99	600HF
1535			1.26	86	MBM 5	01H +18.95	TEHTEC			B3720	reso	21C00027	C 0	600UL
1536	65	125	0.15	108	MAI 1	TSH +0.65	TSHTSH	0.2		R6452	reso	21H00024	H 0	600PP
1537			0.16	105	MAI 2	TSH +0.65	TSHTSH	0.3		R6452	reso	21H00024	H 0	600PP
1538			0.17	97	PID 4	TSH +0.65	TSHTSH			S0607	rsec	21H00063	H99	600HF
1539			0.16	106	MAI 2	TSH +0.91	TSHTSH	0.2		R6452	reso	21H00024	H 0	600PP
1			0.15	103	MAI 1	TSH +0.91	TSHTSH	0.3		R6452	reso	21H00024	H 0	600PP
1			0.12	104	MAI 2	TSH +1.23 TO+1.58	TSHTSH	0.4		A9608	reso	21H00024	H 0	600PP
1542			0.03	18	MAI 1	TSH +1.23 TO+1.58	TSHTSH	0.4		A9608	reso	21H00024	H 0	600PP
1543			0.53	119	NQI 5	TSH +1.63	TEHTEC			B3720	reso	21C00027	C 0	600UL
1544	73	125	0.39	12	INR P1	TSH +0.94	TEHTEC			L2157	rpri	21C00027	C 0	600UL
1545	87	125	0.62	78	MBM 5	01H +27.96	TEHTEC			B3720	reso	21C00027	C 0	600UL
1546	89	125	0.60	77	MBM 5	06C +15.27	TEHTEC			B3720	reso	21C00028	C 0	600UL
1547			0.39	84	MBM 6	06C +22.62	TEHTEC			B3720	reso	21C00028	C 0	600UL
1548	6	126		SCI	1 TSH	-0.07	TSHTSH	0.0		R6452	reso	21H00021	H 0	600PP
1549			0.16	106	SCI P1	TSH -0.07	TSHTSH	0.6		R6452	reso	21H00021	H 0	600PP
1550			0.15	110	PID P1	TSH -0.07	TSHTSH			S0607	rsec	21H00063	H99	600HF
1551	44	126	0.26	97	NQI P1	TSH +0.52	TEHTEC			H3464	rpri	21C00020	C 0	600UL
1552				NDF	TSH	+0.52	TSHTSH			D3858	reso	21H00027	H 0	600PP
1553	52	126	0.18	97	SAI 2	TSH +0.68	TSHTSH	0.3		B3720	reso	21H00028	H 0	600PP
1554			0.16	65	SAI 1	TSH +0.68	TSHTSH	0.3		B3720	reso	21H00028	H 0	600PP
1555			0.20	114	PID 4	TSH +0.68	TSHTSH			S0607	rsec	21H00063	H99	600HF
1556	54	126	0.21	74	MAI 1	TSH +0.67 TO+1.06	TSHTSH	0.4		K7060	reso	21H00027	H 0	600PP
1557			0.16	117	MAI 2	TSH +0.67 TO+1.06	TSHTSH	0.4		K7060	reso	21H00027	H 0	600PP
1558			0.17	109	PID 4	TSH +0.67 TO+1.06	TSHTSH			S0607	rsec	21H00063	H99	600HF
1559			0.59	66	MBM 5	TSH +27.20	TEHTEC			H2131	reso	21C00019	C 0	600UL
1560	56	126	0.14	101	MAI 2	TSH +0.49 TO+1.38	TSHTSH	0.4		B3720	reso	21H00028	H 0	600PP
1561			0.25	35	MAI 1	TSH +0.49 TO+1.38	TSHTSH	0.3		B3720	reso	21H00028	H 0	600PP
1562			0.17	117	PID 4	TSH +0.49 TO+1.38	TSHTSH			S0607	rsec	21H00063	H99	600HF
1563	76	126	0.40	71	NQI 5	TSH +0.84	TEHTEC			B3720	reso	21C00028	C 0	600UL
1564			0.08	104	SAI 2	TSH +1.21	TSHTSH	0.2		R6452	reso	21H00024	H 0	600PP
1565				SAI	1 TSH	+1.21	TSHTSH	0.0		R6452	reso	21H00024	H 0	600PP
			0.08	129	PID 4	TSH +1.21	TSHTSH			S0607	rsec	21H00063	H99	600HF
1567			0.55	75	MBM 5	02H +10.10	TEHTEC			B3720	reso	21C00028	C 0	600UL
1568	82	126	0.07	122	SAI 2	TSH +0.52	TSHTSH	0.2		R6452	reso	21H00023	H 0	600PP

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final

May 17,1999 10:57

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
1569				SAI	1 TSH	+0.52		TSHTSH	0.0		R6452	reso	21H00023	H 0	600PP
1570			0.08	130 PID	4 TSH	+0.52		TSHTSH			S0607	rsec	21H00063	H99	600HF
1571	102	126	0.82	68 MBM	6 02H	+12.58		TEHTEC			B3720	reso	21C00027	C 0	600UL
1572			0.39	56 16	P2 VH	+1.64		TEHTEC			L2157	rpri	21C00027	C 0	600UL
1573				NDF	VH	+1.64		VH VH			R6452	reso	21H00067	H 4	560PF
1574	116	126	0.85	67 MBM	5 02H	+13.56		TEHTEC			B3720	reso	21C00027	C 0	600UL
1575	1	127		OBS	06C	+2.34		06CTEC			A9608	reso	21C00082	C 1	580SF
1576	7	127	0.70	73 MBM	6 03H	+4.81		TEHTEC			H2131	reso	21C00020	C 0	600UL
1577	13	127	0.64	73 MBM	5 02C	+22.24		TEHTEC			H2131	reso	21C00019	C 0	600UL
1578	35	127	0.65	79 MBM	5 VM	+5.25		TEHTEC			H2131	reso	21C00019	C 0	600UL
1579	37	127	0.15	25 SAI	2 TSH	-0.08		TSHTSH	0.2	PWSCC	B3720	reso	21H00028	H 0	600PP
1580			0.80	17 SAI	1 TSH	-0.08		TSHTSH	0.3	PWSCC	B3720	reso	21H00028	H 0	600PP
1581			0.18	166 PID	4 TSH	-0.08		TSHTSH			N0942	rpri	21H00063	H99	600HF
1582	51	127	0.43	91 MAI	2 TSH	+0.27	TO+0.94	TSHTSH	0.5		B3720	reso	21H00028	H 0	600PP
1583			0.45	90 MAI	1 TSH	+0.27	TO+0.94	TSHTSH	0.4		B3720	reso	21H00028	H 0	600PP
1584			0.39	96 PID	4 TSH	+0.27	TO+0.94	TSHTSH			J6276	rpri	21H00063	H99	600HF
1585	55	127	0.76	140 NQI	P1 TSH	+0.58		TEHTEC			A9608	reso	21C00020	C 0	600UL
1586			0.23	81 MAI	2 TSH	+0.75		TSHTSH	0.5		B3720	reso	21H00028	H 0	600PP
1587			0.27	108 MAI	1 TSH	+0.75		TSHTSH	0.4		B3720	reso	21H00028	H 0	600PP
1588			0.26	84 PID	4 TSH	+0.75		TSHTSH			F7467	rsec	21H00063	H99	600HF
1	67	127	0.09	112 SAI	2 TSH	+0.98		TSHTSH	0.3		R6452	reso	21H00024	H 0	600PP
1				SAI	1 TSH	+0.98		TSHTSH	0.0		R6452	reso	21H00024	H 0	600PP
1591			0.10	128 PID	4 TSH	+0.98		TSHTSH			F7467	rsec	21H00063	H99	600HF
1592	73	127	0.33	62 NQI	5 TSH	+1.12		TEHTEC			B3720	reso	21C00027	C 0	600UL
1593			0.15	113 SAI	2 TSH	+1.14		TSHTSH	0.3		R6452	reso	21H00023	H 0	600PP
1594			0.27	52 SAI	1 TSH	+1.14		TSHTSH	0.3		R6452	reso	21H00023	H 0	600PP
1595			0.20	128 PID	4 TSH	+1.14		TSHTSH			F7467	rsec	21H00063	H99	600HF
1596	89	127	0.39	78 MBM	5 04H	+25.38		TEHTEC			B3720	reso	21C00028	C 0	600UL
1597	99	127	0.64	84 MBM	5 01C	+33.76		TEHTEC			B3720	reso	21C00027	C 0	600UL
1598	2	128	0.24	72 INR	9 TSH	+0.37		TSHTSH			R6452	reso	21H00021	H 0	600PP
1599	52	128	0.22	114 MAI	1 TSH	+0.55	TO+1.07	TSHTSH	0.4		B3720	reso	21H00028	H 0	600PP
1600			0.22	97 MAI	2 TSH	+0.55	TO+1.07	TSHTSH	0.4		B3720	reso	21H00028	H 0	600PP
1601			0.20	129 PID	4 TSH	+0.55	TO+1.07	TSHTSH			F7467	rsec	21H00063	H99	600HF
1602			0.49	135 NQI	P1 TSH	+1.05		TEHTEC			A9608	reso	21C00020	C 0	600UL
1603	60	128	0.23	26 MAI	1 TSH	+0.52	TO+1.05	TSHTSH	0.3		K7060	reso	21H00027	H 0	600PP
1604			0.25	91 MAI	2 TSH	+0.52	TO+1.05	TSHTSH	0.4		K7060	reso	21H00027	H 0	600PP
1605			0.26	98 PID	4 TSH	+0.52	TO+1.05	TSHTSH			F7467	rsec	21H00063	H99	600HF
1606			0.83	128 NQI	P1 TSH	+0.91		TEHTEC			S1848	rpri	21C00019	C 0	600UL
1607				NDF	01H	+0.95		01H01H			T0042	reso	21H00066	H 4	600PP
1608			0.26	109 DSI	P1 01H	+0.95		TEHTEC			S1848	rpri	21C00019	C 0	600UL
1609	96	128	0.55	76 MBM	5 04H	+21.06		TEHTEC			B3720	reso	21C00028	C 0	600UL
1610	1	129	0.44	80 INR	9 TSH	+0.15		TSHTSH			R6452	reso	21H00021	H 0	600PP
1611	3	129	0.36	80 INR	9 TSH	+0.10		TSHTSH			H2131	reso	21H00020	H 0	600PP
1612	53	129	0.28	81 MAI	2 TSH	+0.50	TO+1.11	TSHTSH	0.3		B3720	reso	21H00028	H 0	600PP
1613			0.31	116 MAI	1 TSH	+0.50	TO+1.11	TSHTSH	0.3		B3720	reso	21H00028	H 0	600PP
1614			0.25	84 PID	4 TSH	+0.50	TO+1.11	TSHTSH			F7467	rsec	21H00063	H99	600HF
			0.53	108 NQI	P1 TSH	+0.81		TEHTEC			S1848	rpri	21C00023	C 0	600UL
1616	55	129	0.46	103 NQI	P1 TSH	+0.76		TEHTEC			B3720	reso	21C00024	C 0	600UL
1617			0.18	93 SAI	2 TSH	+0.82		TSHTSH	0.3		K7060	reso	21H00027	H 0	600PP

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE SIZE
1618				SAI	1	TSH	+0.82		TSHTSH	0.0		K7060	reso	21H00027	H 0	600PP
1619		0.16	80	PID	4	TSH	+0.82		TSHTSH			S0607	rsec	21H00063	H99	600HF
1620	57	129		MAI	1	TSH	+0.74	TO+1.06	TSHTSH	0.0		K7060	reso	21H00027	H 0	600PP
1621			0.17	102	MAI	2	TSH	+0.74	TO+1.06	TSHTSH	0.4		K7060	reso	21H00027	H 0	600PP
1622			0.18	106	PID	4	TSH	+0.74	TO+1.06	TSHTSH			F7467	rsec	21H00063	H99	600HF
1623			0.46	71	NQI	P1	TSH	+0.93		TEHTEC			S1848	rpri	21C00023	C 0	600UL
1624	77	129	0.55	85	MBM	6	02C	+27.22		TEHTEC			B3720	reso	21C00028	C 0	600UL
1625			1.19	60	MBM	6	01C	+31.96		TEHTEC			B3720	reso	21C00028	C 0	600UL
1626	79	129	0.25	64	NQI	P1	TSC	+0.90		TEHTEC			L2157	rpri	21C00027	C 0	600UL
1627					NDF		TSC	+0.90		TSCTSC			S7752	reso	21C00072	C 2	600PP
1628	2	130	0.34	82	INR	9	TSH	+0.16		TSHTSH			R6452	reso	21H00021	H 0	600PP
1629	4	130	0.32	74	INR	9	TSH	+0.30		TSHTSH			A9608	reso	21H00020	H 0	600PP
1630	12	130	1.10	72	MBM	6	01H	+36.16		TEHTEC			H2131	reso	21C00019	C 0	600UL
1631			1.27	111	DSI	P1	02H	+1.04		TEHTEC			S1848	rpri	21C00019	C 0	600UL
1632					NDF		02H	+1.04		03H02H	I.D. OK		B3720	reso	21H00067	H 4	560PF
1633					NDF		02H	+1.04		02H02H			T0042	reso	21H00066	H 4	600PP
1634	20	130	0.19	92	MAI	2	TSH	+0.17		TSHTSH	0.2		H2131	reso	21H00020	H 0	600PP
1635					MAI	1	TSH	+0.17		TSHTSH	0.0		A9608	reso	21H00020	H 0	600PP
1636			0.21	91	PID	4	TSH	+0.17		TSHTSH			S0607	rsec	21H00063	H99	600HF
1637	28	130	0.75	84	MBM	6	01C	+13.53		TEHTEC			R6452	reso	21C00023	C 0	600UL
[illegible]	38	130	0.52	78	MBM	6	01H	+6.24		TEHTEC			B3720	reso	21C00024	C 0	600UL
[illegible]			0.53	83	MBM	5	01H	+15.85		TEHTEC			B3720	reso	21C00024	C 0	600UL
1640			0.64	80	MBM	5	02H	+12.21		TEHTEC			B3720	reso	21C00024	C 0	600UL
1641	48	130	0.22	92	MAI	2	TSH	+0.10	TO+1.03	TSHTSH	0.7		K7060	reso	21H00027	H 0	600PP
1642			0.23	70	MAI	1	TSH	+0.10	TO+1.03	TSHTSH	0.5		K7060	reso	21H00027	H 0	600PP
1643			0.26	94	PID	4	TSH	+0.10	TO+1.03	TSHTSH			S0607	rsec	21H00063	H99	600HF
1644	52	130	0.25	97	MAI	2	TSH	+0.30	TO+1.20	TSHTSH	0.5		B3720	reso	21H00028	H 0	600PP
1645			0.35	78	MAI	1	TSH	+0.30	TO+1.20	TSHTSH	0.4		B3720	reso	21H00028	H 0	600PP
1646			0.22	106	PID	4	TSH	+0.30	TO+1.20	TSHTSH			S0607	rsec	21H00063	H99	600HF
1647	58	130	0.18	76	MAI	2	TSH	+0.16		TSHTSH	0.2		B3720	reso	21H00028	H 0	600PP
1648			0.16	119	MAI	1	TSH	+0.16		TSHTSH	0.2		B3720	reso	21H00028	H 0	600PP
1649			0.12	104	PID	4	TSH	+0.16		TSHTSH			S0607	rsec	21H00063	H99	600HF
1650			0.13	108	SAI	2	TSH	+0.97		TSHTSH	0.4		B3720	reso	21H00028	H 0	600PP
1651			0.21	70	SAI	1	TSH	+0.97		TSHTSH	0.4		B3720	reso	21H00028	H 0	600PP
1652			0.20	122	NQI	P1	TSH	+0.97		TEHTEC			B3720	reso	21C00024	C 0	600UL
1653	66	130	0.84	83	NQI	5	TSH	+0.93		TEHTEC			B3720	reso	21C00027	C 0	600UL
1654					NDF		TSH	+0.93		TSHTSH			D3858	reso	21H00023	H 0	600PP
1655	78	130	0.85	53	MBM	6	07H	+23.91		TEHTEC			B3720	reso	21C00028	C 0	600UL
1656	90	130	1.50	48	MBM	6	TSC	+23.97		TEHTEC			B3720	reso	21C00028	C 0	600UL
1657	106	130	0.38	70	MBM	5	04H	+5.73		TEHTEC			B3720	reso	21C00028	C 0	600UL
1658	13	131	0.75	67	MBM	6	05H	+15.31		TEHTEC			H2131	reso	21C00019	C 0	600UL
1659			0.19	99	VOL	2	05H	+15.31		06C05H			T0042	reso	21H00078	H 2	560PF
1660	25	131	0.15	99	MAI	2	TSH	+0.15	TO+0.78	TSHTSH	0.2		K7060	reso	21H00027	H 0	600PP
1661					MAI	1	TSH	+0.15	TO+0.78	TSHTSH	0.0		K7060	reso	21H00027	H 0	600PP
1662			0.15	105	PID	4	TSH	+0.15	TO+0.78	TSHTSH			S0607	rsec	21H00063	H99	600HF
1663	29	131	0.81	79	MBM	6	02C	+7.13		TEHTEC			K4444	rsec	21C00024	C 0	600UL
	4	132	0.44	83	INR	9	TSH	+0.24		TSHTSH			R6452	reso	21H00021	H 0	600PP
1665	8	132	0.68	139	INR	6	TSH	+3.41	TO+4.79	TEHTEC			A9608	reso	21C00020	C 0	600UL
1666	22	132	0.09	89	SAI	2	TSH	+2.98		TSHTSH	0.2		B3720	reso	21H00028	H 0	600PP

ROW	LIN	VOLTS	DEG	PCT	CHN		LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
1667					SAI	1	TSH	+2.98		TSHTSH	0.0		B3720	reso	21H00028	H 0 600PP
1668				0.09	80	PID	4	TSH	+2.98		TSHTSH			S0607	rsec	21H00063 H99 600HF
1669	28	132		0.66	65	MBM	6	TSH	+21.27		TEHTEC			R6452	reso	21C00023 C 0 600UL
1670	46	132		0.37	107	MAI	1	TSH	+0.34	TO+0.95	TSHTSH	0.4		B3720	reso	21H00028 H 0 600PP
1671				0.37	99	MAI	2	TSH	+0.34	TO+0.95	TSHTSH	0.4		B3720	reso	21H00028 H 0 600PP
1672				0.30	100	PID	4	TSH	+0.34	TO+0.95	TSHTSH			S0607	rsec	21H00063 H99 600HF
1673				0.44	74	NQI	P1	TSH	+0.72		TEHTEC			B2860	rpri	21C00024 C 0 600UL
1674	60	132		0.10	71	SAI	2	TSH	+0.73		TSHTSH	0.2		K7060	reso	21H00027 H 0 600PP
1675						SAI	1	TSH	+0.73		TSHTSH	0.0		K7060	reso	21H00027 H 0 600PP
1676				0.17	173	PID	4	TSH	+0.73		TSHTSH			S0607	rsec	21H00063 H99 600HF
1677	62	132		0.11	118	SAI	2	TSH	+0.84		TSHTSH	0.2		R6452	reso	21H00023 H 0 600PP
1678						SAI	1	TSH	+0.84		TSHTSH	0.0		R6452	reso	21H00023 H 0 600PP
1679				0.12	115	PID	4	TSH	+0.84		TSHTSH			S0607	rsec	21H00063 H99 600HF
1680	104	132		0.52	65	MBM	6	04C	+15.56		TEHTEC			B3720	reso	21C00027 C 0 600UL
1681	112	132		0.21	119	VOL	2	TSH	+6.02		TSHTSH			H2131	reso	21H00024 H 0 600PP
1682	1	133				OBS		06C	+3.04		06CTEC			A9608	reso	21C00082 C 1 580SF
1683	3	133		0.19	81	INR	9	TSH	+0.23		TSHTSH			A9608	reso	21H00020 H 0 600PP
1684	9	133		0.21	84	WAR	2	VM	-0.39		06C05H			B3720	reso	21H00078 H 2 560PF
1685				0.59	103	21	P2	VM	-0.34		TEHTEC			P4634	rsec	21C00019 C 0 600UL
1686	27	133		0.14	96	SAI	2	TSH	+1.02		TSHTSH	0.2		B3720	reso	21H00028 H 0 600PP
[illegible]						SAI	1	TSH	+1.02		TSHTSH	0.0		B3720	reso	21H00028 H 0 600PP
[illegible]				0.13	80	PID	4	TSH	+1.02		TSHTSH			S0607	rsec	21H00063 H99 600HF
1689	39	133		0.30	91	MAI	1	TSH	+0.71	TO+1.31	TSHTSH	0.7		K7060	reso	21H00027 H 0 600PP
1690				0.29	108	MAI	2	TSH	+0.71	TO+1.31	TSHTSH	0.7		K7060	reso	21H00027 H 0 600PP
1691				0.30	106	PID	4	TSH	+0.71	TO+1.31	TSHTSH			S0607	rsec	21H00063 H99 600HF
1692				0.68	112	NQI	P1	TSH	+0.92		TEHTEC			P4634	rsec	21C00023 C 0 600UL
1693	53	133		0.20	76	SAI	2	TSH	+0.20		TSHTSH	0.4		K7060	reso	21H00027 H 0 600PP
1694						SAI	1	TSH	+0.20		TSHTSH	0.0		K7060	reso	21H00027 H 0 600PP
1695				0.16	83	PID	4	TSH	+0.20		TSHTSH			S0607	rsec	21H00063 H99 600HF
1696	63	133		0.32	112	NQI	5	TSH	+0.78		TEHTEC			B3720	reso	21C00030 C 0 600UL
1697				0.16	86	SAI	2	TSH	+0.86		TSHTSH	0.2		R6452	reso	21H00023 H 0 600PP
1698						SAI	1	TSH	+0.86		TSHTSH	0.0		R6452	reso	21H00023 H 0 600PP
1699				0.15	87	PID	4	TSH	+0.86		TSHTSH			S0607	rsec	21H00063 H99 600HF
1700	93	133				INF		08H	+2.89		TEHTEC	HR		B3720	reso	21C00029 C 0 600UL
1701				0.71	83	MBM	5	08H	+4.34		TEHTEC			B3720	reso	21C00029 C 0 600UL
1702						INF		08H	+6.21		TEHTEC	HR		B3720	reso	21C00029 C 0 600UL
1703				0.77	75	MBM	6	08H	+9.21		TEHTEC			B3720	reso	21C00029 C 0 600UL
1704	95	133		0.83	69	MBM	6	04C	+26.37		TEHTEC			B3720	reso	21C00030 C 0 600UL
1705	99	133		0.52	77	MBM	5	TSC	+28.17		TEHTEC			B3720	reso	21C00030 C 0 600UL
1706	26	134		0.14	112	MAI	2	TSH	+0.84		TSHTSH	0.5		B3720	reso	21H00028 H 0 600PP
1707						MAI	1	TSH	+0.84		TSHTSH	0.0		B3720	reso	21H00028 H 0 600PP
1708				0.15	133	PID	4	TSH	+0.84		TSHTSH			S0607	rsec	21H00063 H99 600HF
1709	36	134		0.13	89	SAI	2	TSH	+0.62		TSHTSH	0.3		K7060	reso	21H00027 H 0 600PP
1710						SAI	1	TSH	+0.62		TSHTSH	0.0		K7060	reso	21H00027 H 0 600PP
1711				0.15	130	PID	4	TSH	+0.62		TSHTSH			S0607	rsec	21H00063 H99 600HF
1712	54	134		0.10	77	SAI	2	TSH	+0.85		TSHTSH	0.2		K7060	reso	21H00027 H 0 600PP
						SAI	1	TSH	+0.85		TSHTSH	0.0		K7060	reso	21H00027 H 0 600PP
1714				0.08	92	PID	4	TSH	+0.85		TSHTSH			S0607	rsec	21H00063 H99 600HF
1715	62	134				SAI	1	TSH	+0.84		TSHTSH	0.0		R6452	reso	21H00026 H 0 600PP

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
1716			0.10	85	SAI	2	TSH	+0.84	TSHTSH	0.3		R6452	reso	21H00026	H 0	600PP
1717			0.08	88	PID	4	TSH	+0.84	TSHTSH			S0607	rsec	21H00063	H99	600HF
1718			0.40	67	MBM	6	02C	+13.63	TEHTEC			B3720	reso	21C00030	C 0	600UL
1719	64	134	0.12	121	SAI	2	TSH	+0.68	TSHTSH	0.2		A9608	reso	21H00025	H 0	600PP
1720					SAI	1	TSH	+0.68	TSHTSH	0.0		A9608	reso	21H00025	H 0	600PP
1721			0.16	130	PID	4	TSH	+0.68	TSHTSH			S0607	rsec	21H00063	H99	600HF
1722	98	134	1.61	74	MBM	6	08H	+10.85	TEHTEC			B3720	reso	21C00029	C 0	600UL
1723	104	134	0.89	68	MBM	5	03C	+20.86	TEHTEC			B3720	reso	21C00030	C 0	600UL
1724			0.69	76	MBM	6	03C	+30.01	TEHTEC			B3720	reso	21C00030	C 0	600UL
1725	35	135	5.16	33	INR	P3	TSH	+0.08	TEHTEC			B3720	reso	21C00024	C 0	600UL
1726			0.18	91	SAI	2	TSH	+0.84	TSHTSH	0.2		B3720	reso	21H00028	H 0	600PP
1727					SAI	1	TSH	+0.84	TSHTSH	0.0		B3720	reso	21H00028	H 0	600PP
1728			0.16	91	PID	4	TSH	+0.84	TSHTSH			S0607	rsec	21H00063	H99	600HF
1729	37	135	0.20	93	MAI	1	TSH	+0.73 TO+0.92	TSHTSH	0.4		K7060	reso	21H00027	H 0	600PP
1730			0.17	69	MAI	2	TSH	+0.73 TO+0.92	TSHTSH	0.3		K7060	reso	21H00027	H 0	600PP
1731			0.15	88	PID	4	TSH	+0.73 TO+0.92	TSHTSH			S0607	rsec	21H00063	H99	600HF
1732			0.72	150	NQI	P1	TSH	+0.83	TEHTEC			P4634	rsec	21C00023	C 0	600UL
1733	55	135	0.32	101	MAI	2	TSH	+0.65 TO+1.25	TSHTSH	0.5		B3720	reso	21H00028	H 0	600PP
1734			0.23	59	MAI	1	TSH	+0.65 TO+1.25	TSHTSH	0.4		B3720	reso	21H00028	H 0	600PP
1735			0.28	108	PID	4	TSH	+0.65 TO+1.25	TSHTSH			J6276	rpri	21H00063	H99	600HF
[illegible]	79	135	1.82	116	MBM	6	TSH	+25.07 TO+31.20	TEHTEC			B3720	reso	21C00029	C 0	600UL
1			0.39	124	VOL	2	01H	+0.52	01H01H			H2131	reso	21H00066	H 4	600PP
1738			0.61	109	DSI	P1	01H	+0.57	TEHTEC			L2157	rpri	21C00029	C 0	600UL
1739			0.24	112	VOL	2	01H	+3.27	01H01H			H2131	reso	21H00066	H 4	600PP
1740			0.59	81	MBM	5	01H	+3.43	TEHTEC			B3720	reso	21C00029	C 0	600UL
1741	8	136	0.47	65	MBM	5	02H	+20.54	TEHTEC			H2131	reso	21C00019	C 0	600UL
1742	12	136	0.12	101	SAI	2	TSH	+0.52	TSHTSH	0.2		H2131	reso	21H00020	H 0	600PP
1743					SAI	1	TSH	+0.52	TSHTSH	0.0		A9608	reso	21H00020	H 0	600PP
1744			0.12	88	PID	4	TSH	+0.52	TSHTSH			S0607	rsec	21H00063	H99	600HF
1745	20	136	0.07	113	MAI	2	TSH	+1.08	TSHTSH	0.2		H2131	reso	21H00020	H 0	600PP
1746					MAI	1	TSH	+1.08	TSHTSH	0.0		A9608	reso	21H00020	H 0	600PP
1747			0.08	87	PID	4	TSH	+1.08	TSHTSH			S0607	rsec	21H00063	H99	600HF
1748					SAI	1	TSH	+1.42	TSHTSH	0.0		A9608	reso	21H00020	H 0	600PP
1749			0.09	61	SAI	2	TSH	+1.42	TSHTSH	0.2		H2131	reso	21H00020	H 0	600PP
1750	22	136	0.10	105	SAI	2	TSH	+0.95	TSHTSH	0.2		B3720	reso	21H00028	H 0	600PP
1751					SAI	1	TSH	+0.95	TSHTSH	0.0		B3720	reso	21H00028	H 0	600PP
1752			0.09	120	PID	4	TSH	+0.95	TSHTSH			S0607	rsec	21H00063	H99	600HF
1753	24	136	0.16	84	MAI	2	TSH	+0.48 TO+1.01	TSHTSH	0.5		B3720	reso	21H00028	H 0	600PP
1754			0.18	13	MAI	1	TSH	+0.48 TO+1.01	TSHTSH	0.4		B3720	reso	21H00028	H 0	600PP
1755			0.17	122	PID	4	TSH	+0.48 TO+1.01	TSHTSH			S0607	rsec	21H00063	H99	600HF
1756	26	136	0.58	78	MBM	5	01H	+17.69	TEHTEC			K4444	rsec	21C00024	C 0	600UL
1757			0.48	75	MBM	5	02C	+29.26	TEHTEC			K4444	rsec	21C00024	C 0	600UL
1758	30	136	0.62	80	MBM	5	01C	+32.14	TEHTEC			K4444	rsec	21C00024	C 0	600UL
1759			0.49	59	MBM	5	01C	+33.27	TEHTEC			K4444	rsec	21C00024	C 0	600UL
1760	34	136	0.11	83	MAI	2	TSH	+0.55 TO+0.86	TSHTSH	0.2		K7060	reso	21H00027	H 0	600PP
1761					MAI	1	TSH	+0.55 TO+0.86	TSHTSH	0.0		K7060	reso	21H00027	H 0	600PP
			0.07	67	PID	4	TSH	+0.55 TO+0.86	TSHTSH			S0607	rsec	21H00063	H99	600HF
1763	38	136	0.25	53	SAI	1	TSH	+0.70	TSHTSH	0.3		K7060	reso	21H00027	H 0	600PP
1764			0.20	83	SAI	2	TSH	+0.70	TSHTSH	0.3		K7060	reso	21H00027	H 0	600PP

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final —

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
1765			0.17	76	PID	4 TSH	+0.70		TSHTSH			S0607	rsec	21H00063	H99	600HF
1766			0.36	86	NQI	P1 TSH	+0.72		TEHTEC			B3720	reso	21C00024	C 0	600UL
1767	40	136			MAI	1 TSH	+0.50	TO+1.42	TSHTSH	0.0		B3720	reso	21H00028	H 0	600PP
1768			0.16	77	MAI	2 TSH	+0.50	TO+1.42	TSHTSH	0.5		B3720	reso	21H00028	H 0	600PP
1769			0.13	86	PID	4 TSH	+0.50	TO+1.42	TSHTSH			S0607	rsec	21H00063	H99	600HF
1770			0.55	101	NQI	P1 TSH	+0.68		TEHTEC			S1848	rpri	21C00023	C 0	600UL
1771	52	136	0.18	98	MAI	2 TSH	+0.50	TO+1.40	TSHTSH	0.5		B3720	reso	21H00028	H 0	600PP
1772					MAI	1 TSH	+0.50	TO+1.40	TSHTSH	0.0		B3720	reso	21H00028	H 0	600PP
1773			0.11	110	PID	4 TSH	+0.50	TO+1.40	TSHTSH			S0607	rsec	21H00063	H99	600HF
1774	1	137	0.39	18	INR	P1 06C	+0.75		06HTEC			A9608	reso	21C00082	C 1	580SF
1775	9	137	0.71	73	MBM	5 05C	+36.61		TEHTEC			H2131	reso	21C00019	C 0	600UL
1776	17	137	0.16	24	MAI	1 TSH	+1.21	TO+1.90	TSHTSH	0.7		R6452	reso	21H00021	H 0	600PP
1777			0.12	96	MAI	2 TSH	+1.21	TO+1.90	TSHTSH	0.8		R6452	reso	21H00021	H 0	600PP
1778			0.12	114	PID	4 TSH	+1.21	TO+1.90	TSHTSH			S0607	rsec	21H00063	H99	600HF
1779			0.23	47	NQI	P1 TSH	+1.31		TEHTEC			S1848	rpri	21C00019	C 0	600UL
1780	21	137	0.57	61	MBM	5 01H	+11.42		TEHTEC			B3720	reso	21C00024	C 0	600UL
1781	25	137	0.20	110	MAI	2 TSH	+0.23	TO+1.59	TSHTSH	0.4		B3720	reso	21H00028	H 0	600PP
1782			0.15	154	MAI	1 TSH	+0.23	TO+1.59	TSHTSH	0.3		B3720	reso	21H00028	H 0	600PP
1783			0.22	103	PID	4 TSH	+0.23	TO+1.59	TSHTSH			S0607	rsec	21H00063	H99	600HF
1784	27	137	0.10	81	SAI	2 TSH	+0.66		TSHTSH	0.3		K7060	reso	21H00027	H 0	600PP
[illegible]					SAI	1 TSH	+0.66		TSHTSH	0.0		K7060	reso	21H00027	H 0	600PP
1[illegible]			0.08	112	PID	4 TSH	+0.66		TSHTSH			S0607	rsec	21H00063	H99	600HF
1787	45	137	0.23	117	MCI	P1 TSH	+0.07		TSHTSH	0.8		B3720	reso	21H00028	H 0	600PP
1788			0.58	109	MCI	1 TSH	+0.07		TSHTSH	0.8		B3720	reso	21H00028	H 0	600PP
1789			0.26	130	PID	P1 TSH	+0.07		TSHTSH			S0607	rsec	21H00063	H99	600HF
1790	53	137	0.26	86	SAI	2 TSH	+0.86		TSHTSH	0.4		B3720	reso	21H00028	H 0	600PP
1791			0.42	76	SAI	1 TSH	+0.86		TSHTSH	0.4		B3720	reso	21H00028	H 0	600PP
1792			0.22	98	PID	4 TSH	+0.86		TSHTSH			S0607	rsec	21H00063	H99	600HF
1793	63	137	0.68	85	MBM	5 04H	+29.62		TEHTEC			B3720	reso	21C00029	C 0	600UL
1794	79	137	0.93	96	INR	6 TSH	+12.81		TEHTEC			L2157	rpri	21C00029	C 0	600UL
1795					INF	TSH	+34.75		TEHTEC	HR		B3720	reso	21C00029	C 0	600UL
1796			0.78	84	MBM	5 TSH	+36.83		TEHTEC			B3720	reso	21C00029	C 0	600UL
1797			1.03	79	MBM	6 07H	+21.93		TEHTEC			B3720	reso	21C00029	C 0	600UL
1798	83	137	0.25	127	VOL	1 TSH	+3.68		TSHTSH			H2131	reso	21H00025	H 0	600PP
1799			0.73	67	MBM	6 TSH	+3.75		TEHTEC			B3720	reso	21C00029	C 0	600UL
1800			1.20	54	MBM	6 VH	+21.64		TEHTEC			B3720	reso	21C00029	C 0	600UL
1801					INF	VH	+23.11		TEHTEC	HR		B3720	reso	21C00029	C 0	600UL
1802	99	137	0.59	134	NQI	P1 04C	+5.65	TO+7.66	TEHTEC			B3720	reso	21C00029	C 0	600UL
1803					NDF	04C	+5.65	TO+7.66	03C05C			S1848	rpri	21C00072	C 2	600PP
1804			0.42	87	NQI	P1 03C	+31.35	TO+32.69	TEHTEC			B3720	reso	21C00029	C 0	600UL
1805					NDF	03C	+31.35	TO+32.69	03C05C			S1848	rpri	21C00072	C 2	600PP
1806	8	138	0.20	107	SCI	P1 TSC	+0.00		TSCTSC	0.4		B3720	reso	21C00115	C 3	600PP
1807					SCI	1 TSC	+0.00		TSCTSC	0.0		B3720	reso	21C00115	C 3	600PP
1808			0.14	126	PID	P1 TSC	+0.00		TSCTSC			B6768	rpri	21C00139	C99	600HF
1809	24	138	0.14	110	MAI	2 TSH	+0.54	TO+1.43	TSHTSH	0.4		K7060	reso	21H00016	H 0	600PP
1810					MAI	1 TSH	+0.54	TO+1.43	TSHTSH	0.0		K7060	reso	21H00016	H 0	600PP
			0.17	85	PID	4 TSH	+0.54	TO+1.43	TSHTSH			S0607	rsec	21H00063	H99	600HF
1812	32	138	0.48	141	NQI	P1 TSH	+0.70		TEHTEC			T7451	rsec	21C00008	C 0	600UL
1813			0.12	87	MAI	2 TSH	+0.81	TO+1.05	TSHTSH	0.2		K7060	reso	21H00016	H 0	600PP

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final — PAGE 38

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE	SIZE
1814				MAI	1	TSH	+0.81	TO+1.05	TSHTSH	0.0		K7060	reso	21H00016	H 0	600PP	
1815		0.10	81	PID	4	TSH	+0.81	TO+1.05	TSHTSH			S0607	rsec	21H00063	H99	600HF	
1816	34	138	0.39	77	MAI	1	TSH	+0.50		TSHTSH	0.35		B3720	reso	21H00015	H 0	600PP
1817			0.31	95	MAI	2	TSH	+0.50		TSHTSH	0.35		B3720	reso	21H00015	H 0	600PP
1818			0.25	104	PID	4	TSH	+0.50		TSHTSH			S0607	rsec	21H00063	H99	600HF
1819			0.96	92	NQI	5	TSH	+0.54		TEHTEC			B3720	reso	21C00007	C 0	600UL
1820			0.86	79	NQI	5	TSH	+0.93		TEHTEC			B3720	reso	21C00007	C 0	600UL
1821			0.23	93	MAI	2	TSH	+1.19		TSHTSH	0.35		B3720	reso	21H00015	H 0	600PP
1822					MAI	1	TSH	+1.19		TSHTSH	0.00		B3720	reso	21H00015	H 0	600PP
1823	48	138	0.19	98	MAI	2	TSH	+0.65	TO+0.98	TSHTSH	0.2		K7060	reso	21H00016	H 0	600PP
1824					MAI	1	TSH	+0.65	TO+0.98	TSHTSH	0.0		K7060	reso	21H00016	H 0	600PP
1825			0.17	113	PID	4	TSH	+0.65	TO+0.98	TSHTSH			S0607	rsec	21H00063	H99	600HF
1826	60	138	0.88	77	MBM	5	VM	+11.75		TEHTEC			T7451	rsec	21C00008	C 0	600UL
1827			0.73	81	MBM	5	VM	+13.12		TEHTEC			T7451	rsec	21C00008	C 0	600UL
1828			0.47	50	MBM	5	VM	+15.92		TEHTEC			T7451	rsec	21C00008	C 0	600UL
1829	62	138	0.94	91	MBM	5	VM	+26.96		TEHTEC			B3720	reso	21C00014	C 0	600UL
1830	94	138	0.78	84	MBM	6	TSC	+16.90		TEHTEC			B3720	reso	21C00014	C 0	600UL
1831	1	139			OBS		06C	+1.30		06CTEC			C5184	rsec	21C00087	C 1	580SF
1832	17	139	0.85	42	MBM	6	05H	+32.47		TEHTEC			R6452	reso	21C00003	C 0	600UL
1833			0.61	126	INR	6	05H	+34.83		TEHTEC			L7871	rpri	21C00003	C 0	600UL
[illegible]			1.83	82	MBM	6	01C	+19.08		TEHTEC			R6452	reso	21C00003	C 0	600UL
1[illegible]	25	139	0.12	112	MAI	2	TSH	+0.34		TSHTSH	0.25		M1680	reso	21H00015	H 0	600PP
1836					MAI	1	TSH	+0.34		TSHTSH	0.00		M1680	reso	21H00015	H 0	600PP
1837			0.12	123	PID	4	TSH	+0.34		TSHTSH			S0607	rsec	21H00063	H99	600HF
1838	31	139	0.25	78	SAI	1	TSH	+0.65		TSHTSH	0.38		B3720	reso	21H00015	H 0	600PP
1839			0.23	116	SAI	2	TSH	+0.65		TSHTSH	0.32		B3720	reso	21H00015	H 0	600PP
1840			0.21	114	PID	4	TSH	+0.65		TSHTSH			S0607	rsec	21H00063	H99	600HF
1841			0.65	59	NQI	5	TSH	+0.67		TEHTEC			B3720	reso	21C00007	C 0	600UL
1842			0.49	63	NQI	5	TSH	+1.13		TEHTEC			B3720	reso	21C00007	C 0	600UL
1843			0.16	102	MAI	2	TSH	+1.21		TSHTSH	0.16		B3720	reso	21H00015	H 0	600PP
1844			0.24	77	MAI	1	TSH	+1.21		TSHTSH	0.19		B3720	reso	21H00015	H 0	600PP
1845	37	139	0.24	85	SAI	1	TSH	+0.60		TSHTSH	0.41		B3720	reso	21H00015	H 0	600PP
1846			0.20	114	SAI	2	TSH	+0.60		TSHTSH	0.30		B3720	reso	21H00015	H 0	600PP
1847			0.20	110	PID	4	TSH	+0.60		TSHTSH			S0607	rsec	21H00063	H99	600HF
1848			0.33	66	NQI	P1	TSH	+0.62		TEHTEC			M1680	reso	21C00008	C 0	600UL
1849	51	139	0.12	83	SAI	2	TSH	+0.60		TSHTSH	0.33		B3720	reso	21H00015	H 0	600PP
1850					SAI	1	TSH	+0.60		TSHTSH	0.00		B3720	reso	21H00015	H 0	600PP
1851			0.10	116	PID	4	TSH	+0.60		TSHTSH			S0607	rsec	21H00063	H99	600HF
1852	53	139	0.60	96	MBM	5	02C	+22.83		TEHTEC			T7451	rsec	21C00008	C 0	600UL
1853	67	139	1.48	81	MBM	6	06C	+17.04		TEHTEC			B3720	reso	21C00014	C 0	600UL
1854	69	139	0.67	73	MBM	5	05C	+11.56		TEHTEC			B3720	reso	21C00013	C 0	600UL
1855	6	140			OBS		06H	+18.55		05H06H			P5436	rpri	21H00076	H 2	560PF
1856	16	140	0.22	107	MAI	1	TSH	+1.00		TSHTSH	0.4		A9608	reso	21H00011	H 0	600PP
1857			0.21	86	MAI	2	TSH	+1.00		TSHTSH	0.4		A9608	reso	21H00011	H 0	600PP
1858			0.19	83	PID	4	TSH	+1.00		TSHTSH			S0607	rsec	21H00063	H99	600HF
1859			0.40	56	NQI	P1	TSH	+1.07		TEHTEC			B1055	rpri	21C00004	C 0	600UL
			0.92	89	MBM	5	01C	+32.59		TEHTEC			K4444	rsec	21C00004	C 0	600UL
1861	28	140	0.67	55	MBM	5	TSH	+31.10		TEHTEC			K4444	rsec	21C00007	C 0	600UL
1862	32	140	0.08	78	SAI	2	TSH	+0.14		TSHTSH	0.2		K7060	reso	21H00016	H 0	600PP

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE SIZE
1863					SAI	1 TSH	+0.14		TSHTSH	0.2		K7060	reso	21H	00016	H 0	600PP
1864			0.20	106	SAI	2 TSH	+0.61		TSHTSH	0.2		K7060	reso	21H	00016	H 0	600PP
1865					SAI	1 TSH	+0.61		TSHTSH	0.2		K7060	reso	21H	00016	H 0	600PP
1866			0.15	107	PID	4 TSH	+0.61		TSHTSH			S0607	rsec	21H	00063	H99	600HF
1867					SAI	1 TSH	+1.04		TSHTSH	0.2		K7060	reso	21H	00016	H 0	600PP
1868			0.13	106	SAI	2 TSH	+1.04		TSHTSH	0.2		K7060	reso	21H	00016	H 0	600PP
1869	44	140	0.08	94	SAI	2 TSH	+0.15		TSHTSH	0.2		K7060	reso	21H	00016	H 0	600PP
1870					SAI	1 TSH	+0.15		TSHTSH	0.2		K7060	reso	21H	00016	H 0	600PP
1871			0.27	93	SAI	2 TSH	+0.57		TSHTSH	0.3		K7060	reso	21H	00016	H 0	600PP
1872			0.21	70	SAI	1 TSH	+0.57		TSHTSH	0.2		K7060	reso	21H	00016	H 0	600PP
1873			0.22	98	PID	4 TSH	+0.57		TSHTSH			S0607	rsec	21H	00063	H99	600HF
1874	88	140	0.09	19	IDM	2 TSH	+4.05		TSHTSH			D3858	reso	21H	00017	H 0	600PP
1875	94	140	0.52	147	DSI	P1 02H	-0.25		TEHTEC			L2157	rpri	21C	00029	C 0	600UL
1876					NDF	02H	-0.25		02H02H			T0042	reso	21H	00066	H 4	600PP
1877	1	141			OBS	06C	+3.86		06CTEC			A9608	reso	21C	00082	C 1	580SF
1878	11	141			SAI	1 TSH	+0.94		TSHTSH	0.2		M1680	reso	21H	00009	H 0	600PP
1879			0.15	85	SAI	2 TSH	+0.94		TSHTSH	0.2		M1680	reso	21H	00009	H 0	600PP
1880			0.14	96	PID	4 TSH	+0.94		TSHTSH			S0607	rsec	21H	00063	H99	600HF
1881	29	141	1.62	35	MBM	5 TSC	+22.09		TEHTEC			T7451	rsec	21C	00008	C 0	600UL
1882	61	141	1.40	73	MBM	6 04H	+2.47		TEHTEC			N5877	rsec	21C	00013	C 0	600UL
[illegible]	85	141	0.16	46	IDM	2 TSH	+5.07		TSHTSH			D3858	reso	21H	00017	H 0	600PP
[illegible]	12	142			MAI	1 TSH	+0.61	TO+0.91	TSHTSH	0.2		M1680	reso	21H	00009	H 0	600PP
1885			0.15	102	MAI	2 TSH	+0.61	TO+0.91	TSHTSH	0.2		M1680	reso	21H	00009	H 0	600PP
1886			0.14	112	PID	4 TSH	+0.61	TO+0.91	TSHTSH			S0607	rsec	21H	00063	H99	600HF
1887	24	142	0.95	70	MAI	2 TSH	+0.05	TO+1.56	TSHTSH	0.6		R6452	reso	21H	00014	H 0	600PP
1888			0.98	53	MAI	1 TSH	+0.05	TO+1.56	TSHTSH	0.5		R6452	reso	21H	00014	H 0	600PP
1889			0.96	72	PID	4 TSH	+0.05	TO+1.56	TSHTSH			S0607	rsec	21H	00063	H99	600HF
1890	28	142	0.08	108	SAI	2 TSH	+0.96		TSHTSH	0.2		K7060	reso	21H	00016	H 0	600PP
1891					SAI	1 TSH	+0.96		TSHTSH	0.2		K7060	reso	21H	00016	H 0	600PP
1892			0.08	102	PID	4 TSH	+0.96		TSHTSH			S0607	rsec	21H	00063	H99	600HF
1893					SAI	1 TSH	+1.20		TSHTSH	0.2		K7060	reso	21H	00016	H 0	600PP
1894			0.04	88	SAI	2 TSH	+1.20		TSHTSH	0.2		K7060	reso	21H	00016	H 0	600PP
1895	32	142	0.18	107	MAI	2 TSH	+0.57	TO+1.20	TSHTSH	0.3		K7060	reso	21H	00016	H 0	600PP
1896					MAI	1 TSH	+0.57	TO+1.20	TSHTSH	0.2		M1680	reso	21H	00016	H 0	600PP
1897			0.16	118	PID	4 TSH	+0.57	TO+1.20	TSHTSH			S0607	rsec	21H	00063	H99	600HF
1898	36	142	0.65	92	MBM	5 05C	+1.55		TEHTEC			T7451	rsec	21C	00008	C 0	600UL
1899	7	143	0.66	81	MBM	5 05C	+13.56		TEHTEC			K7060	reso	21C	00006	C 0	600UL
1900	17	143	0.44	108	NQI	P1 TSH	+1.15		TEHTEC			B1055	rpri	21C	00004	C 0	600UL
1901			0.14	126	MAI	2 TSH	+1.24		TSHTSH	0.3		A9608	reso	21H	00011	H 0	600PP
1902			0.18	86	MAI	1 TSH	+1.24		TSHTSH	0.3		A9608	reso	21H	00011	H 0	600PP
1903			0.19	122	PID	4 TSH	+1.24		TSHTSH			S0607	rsec	21H	00063	H99	600HF
1904	21	143			SAI	1 TSH	+0.81		TSHTSH	0.2		M1680	reso	21H	00014	H 0	600PP
1905			0.10	101	SAI	2 TSH	+0.81		TSHTSH	0.2		M1680	reso	21H	00014	H 0	600PP
1906			0.11	68	PID	4 TSH	+0.81		TSHTSH			S0607	rsec	21H	00063	H99	600HF
1907			0.89	79	MBM	5 04H	+18.57		TEHTEC			T7451	rsec	21C	00008	C 0	600UL
1908			0.57	78	MBM	5 04C	+7.59		TEHTEC			T7451	rsec	21C	00008	C 0	600UL
			0.49	103	MBM	5 03C	+20.24		TEHTEC			T7451	rsec	21C	00008	C 0	600UL
1910	31	143	0.13	106	SAI	2 TSH	+0.70		TSHTSH	0.2		R6452	reso	21H	00014	H 0	600PP
1911					SAI	1 TSH	+0.70		TSHTSH	0.2		R6452	reso	21H	00014	H 0	600PP

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final —

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
1912			0.14	96	PID	4 TSH	+0.70		TSHTSH			S0607	rsec	21H00063	H99	600HF
1913	35	143	0.16	76	MAI	2 TSH	+0.10	TO+0.70	TSHTSH	0.2		K7060	reso	21H00013	H 0	600PP
1914					MAI	1 TSH	+0.10	TO+0.70	TSHTSH	0.0		K7060	reso	21H00013	H 0	600PP
1915			0.10	81	PID	4 TSH	+0.10	TO+0.70	TSHTSH			S0607	rsec	21H00063	H99	600HF
1916	63	143	0.59	67	MBM	5 04C	+7.26		TEHTEC			N5877	rsec	21C00013	C 0	600UL
1917	83	143	0.08	16	IDM	2 TSH	+2.90		TSHTSH			D3858	reso	21H00017	H 0	600PP
1918	4	144	0.46	44	MBM	6 02H	+24.84		06HTEH			C3340	reso	21H00001	H 1	600UL
1919	32	144	0.76	96	MBM	5 03C	+2.22		TEHTEC			T7451	rsec	21C00008	C 0	600UL
1920	68	144	1.05	101	INR	5 04H	+24.13		TEHTEC			N5877	rsec	21C00013	C 0	600UL
1921			0.29	83	MBM	5 DH	+20.37		TEHTEC			N5877	rsec	21C00013	C 0	600UL
1922	88	144	0.65	77	MBM	5 TSH	+3.21		TEHTEC			N5877	rsec	21C00013	C 0	600UL
1923			0.42	69	VOL	1 TSH	+3.23		TSHTSH			H2131	reso	21H00017	H 0	600PP
1924	15	145	0.06	92	SAI	2 TSH	+0.44		TSHTSH	0.2		A9608	reso	21H00011	H 0	600PP
1925					SAI	1 TSH	+0.44		TSHTSH	0.0		A9608	reso	21H00011	H 0	600PP
1926			0.05	142	MAI	2 TSH	+0.87		TSHTSH	0.2		A9608	reso	21H00011	H 0	600PP
1927					MAI	1 TSH	+0.87		TSHTSH	0.0		A9608	reso	21H00011	H 0	600PP
1928			0.12	140	PID	4 TSH	+0.87		TSHTSH			S0607	rsec	21H00063	H99	600HF
1929			0.52	75	MBM	5 04C	+17.43		TEHTEC			B3720	reso	21C00004	C 0	600UL
1930	17	145	0.24	103	SAI	2 TSH	+0.71		TSHTSH	0.5		M1680	reso	21H00009	H 0	600PP
1931			0.24	133	SAI	1 TSH	+0.71		TSHTSH	0.4		M1680	reso	21H00009	H 0	600PP
[illegible]			0.21	106	PID	4 TSH	+0.71		TSHTSH			S0607	rsec	21H00063	H99	600HF
[illegible]	21	145			SAI	1 TSH	+0.93		TSHTSH	0.0		K7060	reso	21H00013	H 0	600PP
1934			0.10	77	SAI	2 TSH	+0.93		TSHTSH	0.1		K7060	reso	21H00013	H 0	600PP
1935			0.07	73	PID	4 TSH	+0.93		TSHTSH			S0607	rsec	21H00063	H99	600HF
1936			0.08	101	SAI	2 TSH	+1.08		TSHTSH	0.1		K7060	reso	21H00013	H 0	600PP
1937					SAI	1 TSH	+1.08		TSHTSH	0.0		K7060	reso	21H00013	H 0	600PP
1938			1.16	83	MBM	5 03C	+36.05		TEHTEC			T7451	rsec	21C00008	C 0	600UL
1939	23	145			MAI	1 TSH	+0.67		TSHTSH	0.0		R6452	reso	21H00014	H 0	600PP
1940			0.10	80	MAI	2 TSH	+0.67		TSHTSH	0.3		R6452	reso	21H00014	H 0	600PP
1941			0.10	123	PID	4 TSH	+0.67		TSHTSH			S0607	rsec	21H00063	H99	600HF
1942			0.64	88	NQI	5 TSH	+0.69		TEHTEC			B3720	reso	21C00007	C 0	600UL
1943	73	145	0.64	88	MBM	5 TSH	+35.67		TEHTEC			B3720	reso	21C00014	C 0	600UL
1944	93	145	0.39	67	16	P2 VC	-1.04		TEHTEC			B3720	reso	21C00014	C 0	600UL
1945			0.23	95	WAR	P4 VC	-0.93		VM VC			C3340	reso	21C00073	C 2	560PF
1946			2.97	24	NRC	2 TSC	+0.00		TEHTEC			B3720	reso	21C00014	C 0	600UL
1947	12	146	0.18	100	MAI	2 TSH	+0.31	TO+0.84	TSHTSH	0.4		M1680	reso	21H00009	H 0	600PP
1948			0.19	110	MAI	1 TSH	+0.31	TO+0.84	TSHTSH	0.3		H2131	reso	21H00009	H 0	600PP
1949			0.14	111	PID	4 TSH	+0.31	TO+0.84	TSHTSH			S0607	rsec	21H00063	H99	600HF
1950	16	146	0.10	84	SAI	2 TSH	+0.47		TSHTSH	0.2		A9608	reso	21H00011	H 0	600PP
1951			0.09	23	SAI	1 TSH	+0.47		TSHTSH	0.2		A9608	reso	21H00011	H 0	600PP
1952			0.11	99	MAI	2 TSH	+0.75		TSHTSH	0.2		A9608	reso	21H00011	H 0	600PP
1953			0.16	82	MAI	1 TSH	+0.75		TSHTSH	0.2		A9608	reso	21H00011	H 0	600PP
1954			0.12	140	PID	4 TSH	+0.75		TSHTSH			S0607	rsec	21H00063	H99	600HF
1955	20	146	1.73	78	MBM	6 05H	+13.36		TEHTEC			R6452	reso	21C00003	C 0	600UL
1956	24	146			SAI	1 TSH	+0.19		TSHTSH	0.0		R6452	reso	21H00014	H 0	600PP
1957			0.14	79	SAI	2 TSH	+0.19		TSHTSH	0.2		R6452	reso	21H00014	H 0	600PP
			0.72	135	NQI	5 TSH	+0.65		TEHTEC			B3720	reso	21C00007	C 0	600UL
1959			0.11	84	MAI	2 TSH	+0.71		TSHTSH	0.3		R6452	reso	21H00014	H 0	600PP
1960					MAI	1 TSH	+0.71		TSHTSH	0.0		R6452	reso	21H00014	H 0	600PP

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE	SIZE
1961			0.10	110	PID	4	TSH	+0.71		TSHTSH			S0607	rsec	21H00063	H99	600HF	
1962	28	146	0.08	95	SAI	2	TSH	+0.52		TSHTSH	0.3		R6452	reso	21H00014	H 0	600PP	
1963					SAI	1	TSH	+0.52		TSHTSH	0.0		R6452	reso	21H00014	H 0	600PP	
1964			0.07	99	PID	4	TSH	+0.52		TSHTSH			S0607	rsec	21H00063	H99	600HF	
1965	32	146	0.11	97	SAI	2	TSH	+0.16		TSHTSH	0.3		R6452	reso	21H00014	H 0	600PP	
1966					SAI	1	TSH	+0.16		TSHTSH	0.0		R6452	reso	21H00014	H 0	600PP	
1967			0.09	118	PID	4	TSH	+0.16		TSHTSH			S0607	rsec	21H00063	H99	600HF	
1968	5	147	0.40	47	MBM	6	03H	+8.52		06HTEH			C3340	reso	21H00001	H 1	600UL	
1969	11	147	1.18	55	MBM	5	06C	+9.57		TEHTEC			K4444	rsec	21C00004	C 0	600UL	
1970					INF		06C	+11.86		TEHTEC	HR		R6452	reso	21C00004	C 0	600UL	
1971	17	147	0.08	78	SAI	2	TSH	+0.66		TSHTSH	0.3		S7752	reso	21H00011	H 0	600PP	
1972			0.11	53	SAI	1	TSH	+0.66		TSHTSH	0.3		S7752	reso	21H00011	H 0	600PP	
1973			0.07	101	PID	4	TSH	+0.66		TSHTSH			S0607	rsec	21H00063	H99	600HF	
1974	21	147	0.61	27	MBM	5	TSC	+2.25		TEHTEC			T7451	rsec	21C00008	C 0	600UL	
1975	27	147	0.62	85	MBM	5	TSC	+4.87		TEHTEC			N2222	rsec	21C00007	C 0	600UL	
1976	67	147	0.78	38	MBM	5	06C	+7.04		TEHTEC			N5877	rsec	21C00013	C 0	600UL	
1977	2	148	1.75	81	MBM	6	03C	+35.59		05HTEC			A9608	reso	21C00082	C 1	580SF	
1978	12	148	0.24	60	MAI	1	TSH	+0.12	TO+0.46	TSHTSH	0.3		M1680	reso	21H00009	H 0	600PP	
1979			0.25	108	MAI	2	TSH	+0.12	TO+0.46	TSHTSH	0.3		H2131	reso	21H00009	H 0	600PP	
1980			0.26	107	PID	4	TSH	+0.12	TO+0.46	TSHTSH			S0607	rsec	21H00063	H99	600HF	
[illegible]	14	148	0.54	61	MBM	5	01H	+6.67		TEHTEC			B3720	reso	21C00004	C 0	600UL	
1[illegible]	16	148	0.12	108	SAI	2	TSH	+0.18		TSHTSH	0.1		M1680	reso	21H00009	H 0	600PP	
1983			0.11	76	SAI	1	TSH	+0.18		TSHTSH	0.1		M1680	reso	21H00009	H 0	600PP	
1984			0.13	100	PID	4	TSH	+0.18		TSHTSH			S0607	rsec	21H00063	H99	600HF	
1985	18	148	0.19	104	SAI	2	TSH	+0.47		TSHTSH	0.3		A9608	reso	21H00011	H 0	600PP	
1986			0.41	82	SAI	1	TSH	+0.47		TSHTSH	0.3		A9608	reso	21H00011	H 0	600PP	
1987			0.16	86	PID	4	TSH	+0.47		TSHTSH			S0607	rsec	21H00063	H99	600HF	
1988	9	149	1.34	48	SAI	1	VM	-1.45		06C05H	0.8		B3720	reso	21H00074	H 2	560PF	
1989			0.68	100	SAI	2	VM	-1.45		06C05H	0.8		B3720	reso	21H00074	H 2	560PF	
1990			0.54	100	PID	2	VM	-1.45		VM VM			C3340	reso	21H00091	H99	560PF	
1991			1.34	74	DSI	P1	VM	-1.20		TEHTEC			B3720	reso	21C00004	C 0	600UL	
1992	17	149	0.62	88	MBM	5	04H	+29.09		TEHTEC			K4444	rsec	21C00004	C 0	600UL	
1993			0.94	81	MBM	5	04H	+31.66		TEHTEC			K4444	rsec	21C00004	C 0	600UL	
1994	25	149			SAI	1	TSH	+0.17		TSHTSH	0.0		H2131	reso	21H00013	H 0	600PP	
1995			0.12	111	SAI	2	TSH	+0.17		TSHTSH	0.2		K7060	reso	21H00013	H 0	600PP	
1996			0.14	130	PID	4	TSH	+0.17		TSHTSH			S0607	rsec	21H00063	H99	600HF	
1997	31	149	0.59	87	MBM	5	TSH	+28.17		TEHTEC			B3720	reso	21C00009	C 0	600UL	
1998	45	149	0.92	83	MBM	5	03C	+10.26		TEHTEC			B3720	reso	21C00008	C 0	600UL	
1999	65	149	0.71	67	MBM	5	02H	+9.20		TEHTEC			B3720	reso	21C00012	C 0	600UL	
2000	75	149	1.07	95	MBM	6	02H	+24.78		TEHTEC			R6452	reso	21C00011	C 0	600UL	
2001	83	149	0.86	73	MBM	6	05C	+30.17		TEHTEC			R6452	reso	21C00011	C 0	600UL	
2002	85	149	0.40	75	PLP	9	TSC	+0.77		TSCTSC			M1680	reso	21C00123	C 3	600PP	
2003	87	149	0.85	65	MBM	6	06H	+19.54		TEHTEC			R6452	reso	21C00011	C 0	600UL	
2004	8	150	0.16	57	SCI	1	VM	-1.04		06C05H	0.3		M1680	reso	21H00075	H 2	560PF	
2005			0.36	93	SCI	P1	VM	-1.04		06C05H	0.2		M1680	reso	21H00075	H 2	560PF	
2006			0.33	96	PID	P1	VM	-1.04		VM VM			C3340	reso	21H00091	H99	560PF	
	10	150	0.84	81	MBM	5	03H	+20.24		TEHTEC			K4444	rsec	21C00004	C 0	600UL	
2008			2.81	109	INR	6	VM	+0.13		TEHTEC			B1055	rpri	21C00004	C 0	600UL	
2009	46	150	0.77	80	MBM	5	01H	+16.28		TEHTEC			B3720	reso	21C00010	C 0	600UL	

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
2010	64	150	0.58	73	MBM	6	02C	+11.04	TEHTEC			R6452	reso	21C00011	C 0 600UL
2011	66	150	0.35	86	PLP	9	TSC	+0.29	TSCTSC			M1680	reso	21C00123	C 3 600PP
2012	84	150	0.41	74	PLP	9	TSC	+0.78	TSCTSC			M1680	reso	21C00122	C 3 600PP
2013	1	151			OBS		06C	+1.51	06CTEC			A9608	reso	21C00082	C 1 580SF
2014					OBS		06C	+1.58	06CTEC			K2858	rpri	21C00104	H 1 560SF
2015					PID		06C	+1.58	06CTEC	I.D. OK		K7060	reso	21C00104	C99 560SF
2016	9	151	0.33	118	WAR	2	DH	+0.85	06C05H	LOC.OK		B3720	reso	21H00074	H 2 560PF
2017			0.23	133	WAR	2	VM	-1.80	06C05H			B3720	reso	21H00074	H 2 560PF
2018	21	151	0.58	73	MBM	5	04H	+16.90	TEHTEC			B3720	reso	21C00010	C 0 600UL
2019	23	151	1.19	82	MBM	5	05C	+26.53	TEHTEC			B3720	reso	21C00009	C 0 600UL
2020			1.67	89	MBM	6	TSC	+8.49	TEHTEC			B3720	reso	21C00009	C 0 600UL
2021			0.73	108	INR	6	TSC	+12.88	TEHTEC			K2858	rpri	21C00009	C 0 600UL
2022	31	151	0.74	77	MBM	5	01C	+19.14	TEHTEC			B3720	reso	21C00009	C 0 600UL
2023	37	151	0.49	91	MBM	5	02C	+24.13	TEHTEC			B3720	reso	21C00010	C 0 600UL
2024	61	151	0.65	70	MBM	5	TSH	+37.08	TEHTEC			B3720	reso	21C00012	C 0 600UL
2025	78	152	0.66	79	MBM	5	04C	+16.79	TEHTEC			B3720	reso	21C00012	C 0 600UL
2026	17	153	0.48	41	NQI	P1	TSH	+3.22	TEHTEC			L7871	rpri	21C00003	C 0 600UL
2027					NDF		TSH	+3.22	TSHTSH			D3858	reso	21H00009	H 0 600PP
2028	19	153	0.23	82	SVI	1	TSC	+0.09	TSCTSC	0.3		C3340	reso	21C00116	C 3 600PP
2029			0.22	86	SVI	P1	TSC	+0.09	TSCTSC	0.3		C3340	reso	21C00116	C 3 600PP
?			0.16	114	PID	P1	TSC	+0.09	TSCTSC			B6768	rpri	21C00139	C99 600HF
2.	35	153	0.47	73	MBM	5	01H	+13.35	TEHTEC			B3720	reso	21C00009	C 0 600UL
2032	16	154	0.24	102	VOL	2	TSC	+5.02	TSCTSC			B3720	reso	21C00115	C 3 600PP
2033			1.05	74	MBM	6	TSC	+5.13	TEHTEC			R6452	reso	21C00003	C 0 600UL
2034	25	155	1.44	80	MBM	5	02H	+33.66	TEHTEC			B3720	reso	21C00010	C 0 600UL
2035			0.79	74	MBM	5	03H	+10.91	TEHTEC			B3720	reso	21C00010	C 0 600UL
2036			0.85	87	MBM	5	03H	+11.76	TEHTEC			B3720	reso	21C00010	C 0 600UL
2037			0.86	79	MBM	5	03H	+22.75	TEHTEC			B3720	reso	21C00010	C 0 600UL
2038	35	155	0.95	93	INR	6	01C	+30.58	TEHTEC			K2858	rpri	21C00009	C 0 600UL
2039	39	155	0.64	78	MBM	5	TSC	+10.78	TEHTEC			B3720	reso	21C00009	C 0 600UL
2040	24	156	0.86	84	MBM	6	04C	+28.37	TEHTEC			B3720	reso	21C00009	C 0 600UL
2041			1.23	57	MBM	6	04C	+30.36	TEHTEC			B3720	reso	21C00009	C 0 600UL
2042	32	156	0.73	76	MBM	5	05H	+33.41	TEHTEC			B3720	reso	21C00009	C 0 600UL
2043			0.85	83	MBM	5	01C	+33.12	TEHTEC			B3720	reso	21C00009	C 0 600UL
2044	60	156	0.23	72	INR	5	03C	+3.82	TEHTEC			B3720	reso	21C00009	C 0 600UL
2045	9	157	0.58	85	MBM	5	02C	+19.48	TEHTEC			K4444	rsec	21C00004	C 0 600UL
2046	21	157	2.38	89	MBM	6	04C	+30.07	TEHTEC			B3720	reso	21C00010	C 0 600UL
2047	29	157	0.57	29	DSI	P1	02H	+0.31	TEHTEC			M9715	rsec	21C00010	C 0 600UL
2048					NDF		02H	+0.31	02H02H			T0042	reso	21H00066	H 4 600PP
2049	55	157	3.18	54	MBM	6	TSC	+18.31	TEHTEC			B3720	reso	21C00009	C 0 600UL
2050	57	157	0.48	14	INR	P1	TSC	+0.90	TEHTEC			N0942	rpri	21C00010	C 0 600UL
2051	12	158	0.66	71	MBM	6	04C	+16.75	TEHTEC			R6452	reso	21C00003	C 0 600UL
2052	22	158	0.34		PLP	9	TSC	+0.69	TSCTSC			J6276	rpri	21C00118	C 3 600PP
2053	24	158	0.22	81	PLP	9	TSC	+1.10	TSCTSC			C3340	reso	21C00117	C 3 600PP
2054	58	158	0.79	68	MBM	5	01H	+26.26	TEHTEC			B3720	reso	21C00012	C 0 600UL
2055	21	159	0.28	84	PLP	9	TSC	+0.30	TSCTSC			M1680	reso	21C00119	C 3 600PP
	23	159	0.25	87	PLP	9	TSC	+0.66	TSCTSC			C3340	reso	21C00117	C 3 600PP
2057	49	159			OBS		VM	+0.00	VMTEC			B3720	reso	21C00012	C 0 600UL
2058	57	159	0.07	71	PLP	9	TSH	+0.70	TSHTSH			H3464	rpri	21H00013	H 0 600PP

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 10:57

PLANT: CCNPP

UNIT: 2

SG: 21

DATABASE: CCNPP_UNIT2_SG21_0399_Final —

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE	SIZE
2059	6	160			OBS	06H	+15.00	05H06H			B3720	reso	21H00072	H	2	560PF	
2060	24	160	1.13	61	MBM	6 04H	+28.75	TEHTEC			T0042	reso	21C00011	C	0	600UL	
2061			1.84	76	MBM	6 02C	+33.92	TEHTEC			R6452	reso	21C00011	C	0	600UL	
2062	26	160	0.85	89	MBM	5 05C	+26.53	TEHTEC			B3720	reso	21C00012	C	0	600UL	
2063			0.18	74	PLP	9 TSC	+0.20	TSCTSC			M1680	reso	21C00119	C	3	600PP	
2064	36	160	0.52	38	MBM	6 02H	+7.45	TEHTEC			R6452	reso	21C00011	C	0	600UL	
2065	38	160	0.12	90	PLP	9 TSH	+0.58	TSHTSH			H3464	rpri	21H00013	H	0	600PP	
2066	44	160	0.26	74	MBM	6 TSC	+27.75	TEHTEC			R6452	reso	21C00011	C	0	600UL	
2067	43	161	0.56	80	MBM	5 06H	+16.04	TEHTEC			B3720	reso	21C00012	C	0	600UL	
2068	6	162			OBS	VM	+5.45	05HVM			B3720	reso	21H00072	H	2	560PF	
2069	12	162	0.77	92	NQI	5 TSH	+14.10	TEHTEC			R6452	reso	21C00003	C	0	600UL	
2070					NDF	TSH	+14.10	01HTSH	I.D. OK		B3720	reso	21H00067	H	4	560PF	
2071					NDF	TSH	+14.10	01HTSH			T0042	reso	21H00066	H	4	600PP	
2072	16	162	0.25	78	PLP	9 TSC	+0.26	TSCTSC			M1680	reso	21C00122	C	3	600PP	
2073	24	162	0.98	84	MBM	5 05H	+2.01	TEHTEC			B3720	reso	21C00012	C	0	600UL	
2074	38	162	0.14	84	PLP	9 TSH	+0.51	TSHTSH			R4201	rpri	21H00012	H	0	600PP	
2075	15	163	0.30	80	PLP	9 TSC	+0.33	TSCTSC			M1680	reso	21C00122	C	3	600PP	
2076	27	163	0.60	87	MBM	6 02H	+8.46	TEHTEC			R6452	reso	21C00011	C	0	600UL	
2077	29	163	0.29	57	NQI	P1 TSH	+0.73	TEHTEC			M9715	rsec	21C00012	C	0	600UL	
2078					NDF	TSH	+0.73	TSHTSH			D3858	reso	21H00013	H	0	600PP	
[illegible]	39	163	0.86	70	MBM	6 02H	+7.47	TEHTEC			R6452	reso	21C00011	C	0	600UL	
[illegible]	12	164	0.18	106	VOL	2 05H	+7.82	06C05H			M1680	reso	21H00073	H	2	560PF	
2081			0.18	106	VOL	2 05H	+7.82	06C05H	I.D. OK		B3720	reso	21H00071	H	2	560PF	
2082	38	164	0.61	123	20	P2 VM	+1.98	TEHTEC			R6452	reso	21C00011	C	0	600UL	
2083			0.09	29	WAR	2 VM	+1.98	VM VM			D3858	reso	21C00073	C	2	560PF	
2084	2	166			OBS	06C	+2.89	06CTEC			S7752	reso	21C00081	C	1	580SF	
2085	20	166	0.29	81	INR	9 TSH	+0.37	TSHTSH			H2131	reso	21H00009	H	0	600PP	
2086	15	167	0.20	131	DSI	P1 DH	-0.17	TEHTEC			S7752	reso	21C00001	C	0	600UL	
2087					NDF	DH	-0.17	06C05H			F7467	rsec	21H00070	H	2	560PF	

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE	SIZE

QUERY REPORT SUMMARY:

QUERY PARAMETER		ENTRIES	TUBES
0 to 100 Percent		19	17
ADR	Indication Code	0	0
BLG	Indication Code	0	0
CUD	Indication Code	0	0
DEP	Indication Code	0	0
DNI	Indication Code	0	0
DRI	Indication Code	0	0
DSI	Indication Code	45	44
DTI	Indication Code	0	0
ETL	Indication Code	0	0
EXP	Indication Code	0	0
FSA	Indication Code	0	0
FSD	Indication Code	0	0
IDC	Indication Code	0	0
IDM	Indication Code	28	24
INF	Indication Code	18	17
INR	Indication Code	107	104
LDE	Indication Code	0	0
LPI	Indication Code	9	4
MAI	Indication Code	180	87
MBM	Indication Code	729	561
MCI	Indication Code	2	1
MMI	Indication Code	0	0
MSI	Indication Code	2	1
MVI	Indication Code	0	0
NDF	Indication Code	77	68
NQI	Indication Code	79	75
NRC	Indication Code	1	1
NRH	Indication Code	2	2
NSY	Indication Code	0	0
OBS	Indication Code	30	26
PBC	Indication Code	0	0
PID	Indication Code	251	250
PLP	Indication Code	71	69
PPS	Indication Code	0	0
PRC	Indication Code	2	2
PSP	Indication Code	0	0
PTS	Indication Code	0	0
PVN	Indication Code	2	2
SAI	Indication Code	322	146
SCI	Indication Code	32	16
SVI	Indication Code	6	3
UDE	Indication Code	0	0
VOL	Indication Code	50	28
WAR	Indication Code	23	19

TOTAL ENTRIES: 2087

TOTAL TUBES: 1065

6.0 Repair Lists

This section details the tubes removed from service. In SG 21, 250 tubes were plugged and of the 250, 20 tubes required stabilizers. One of the stabilizer installed in SG 21 was a long stabilizer for a circumferential crack in the u-bend of the tube (R8 C150). In SG 22, 203 tubes were plugged and of the 203, 32 tubes required stabilizers.

CCNPP-2 RFO12 Tube Plugging List										TUBE	STAB	LIST
S/G	ROW	COL	H/L	C/L	REASON FOR PLUGGING					QTY	QTY	REV
SG-21	1	21	ROLL	ROLL	SVI	@	TSC	+	0.10	1	0	00
SG-21	25	31	ROLL	ROLL	MAI	@	TSH	+	1.07	2	0	00
SG-21	10	32	ROLL	ROLL	SAI	@	TSH	+	1.08	3	0	00
SG-21	56	32	ROLL	ROLL	SAI	@	TSH	+	0.77	4	0	00
SG-21	43	33	ROLL/STAB	ROLL	SCI	@	TSH	+	0.17	5	1	00
SG-21	55	33	ROLL	ROLL	MAI	@	TSH	+	0.90	6	1	00
SG-21	46	34	ROLL	ROLL	MSI	@	TSH	+	0.37	7	1	00
SG-21	48	34	ROLL	ROLL	MAI	@	TSH	+	0.70	8	1	00
SG-21	17	35	ROLL	ROLL	SAI	@	TSH	+	0.29	9	1	00
					SAI	@	TSH	+	3.16			
SG-21	23	35	ROLL	ROLL	MAI	@	TSH	+	1.19	10	1	00
SG-21	25	35	ROLL	ROLL	SAI	@	TSH	+	1.01	11	1	00
SG-21	57	35	ROLL	ROLL	SAI	@	TSH	+	1.03	12	1	00
SG-21	26	36	ROLL	ROLL	SAI	@	TSH	+	1.40	13	1	00
					SAI	@	TSH	+	1.59			00
SG-21	52	36	ROLL	ROLL	SAI	@	TSH	+	0.88	14	1	00
SG-21	66	36	ROLL	ROLL	SAI	@	TSH	+	1.00	15	1	00
SG-21	23	37	ROLL	ROLL	SAI	@	TSH	+	0.82	16	1	00
SG-21	63	37	ROLL	ROLL	MAI	@	TSH	+	0.69	17	1	00
SG-21	73	37	ROLL	ROLL	MAI	@	TSH	+	0.33	18	1	00
SG-21	16	38	ROLL	ROLL	SAI	@	TSH	+	2.62	19	1	00
SG-21	55	39	ROLL	ROLL	SAI	@	TSH	+	0.61	20	1	00
SG-21	71	39	ROLL	ROLL	SAI	@	TSH	+	0.55	21	1	00
SG-21	22	40	ROLL	ROLL	SAI	@	TSH	+	0.22	22	1	00
SG-21	17	41	ROLL	ROLL	SAI	@	TSH	+	0.49	23	1	00
SG-21	21	41	ROLL	ROLL	SAI	@	TSH	+	0.28	24	1	00
SG-21	65	41	ROLL	ROLL	MAI	@	TSH	+	0.99	25	1	00
SG-21	71	41	ROLL	ROLL	SAI	@	TSH	+	0.83	26	1	00
SG-21	64	42	ROLL	ROLL	SAI	@	TSH	+	0.95	27	1	00
SG-21	25	43	ROLL	ROLL	SAI	@	TSH	+	0.54	28	1	00
SG-21	26	44	ROLL	ROLL	MAI	@	TSH	+	0.50	29	1	00
SG-21	72	44	ROLL	ROLL	MAI	@	TSH	+	0.77	30	1	00
SG-21	82	44	ROLL	ROLL	MAI	@	TSH	+	0.52	31	1	00
SG-21	21	45	ROLL	ROLL	MAI	@	TSH	+	0.13	32	1	00
SG-21	25	45	ROLL	ROLL	MAI	@	TSH	+	0.46	33	1	00
SG-21	81	45	ROLL	ROLL	MAI	@	TSH	+	0.50	34	1	00
SG-21	22	46	ROLL/STAB	ROLL	SCI	@	TSH	+	0.07	35	2	00
SG-21	68	46	ROLL	ROLL	SAI	@	TSH	+	0.58	36	2	00
SG-21	15	47	ROLL	ROLL	MAI	@	TSH	+	0.11	37	2	00

CCNPP-2 RFO12 Tube Plugging List										TUBE	STAB	LIST
S/G	ROW	COL	H/L	C/L	REASON FOR PLUGGING					QTY	QTY	REV
SG-21	70	48	ROLL	ROLL	SAI	@	TSH	+	0.80	38	2	00
SG-21	76	48	ROLL	ROLL	SAI	@	TSH	+	0.77	39	2	00
SG-21	82	48	ROLL	ROLL	MAI	@	TSH	+	0.72	40	2	00
SG-21	84	48	ROLL	ROLL	MAI	@	TSH	+	0.83	41	2	00
SG-21	18	50	ROLL/STAB	ROLL	SCI	@	TSH	+	0.05	42	3	00
SG-21	19	51	ROLL	ROLL	MAI	@	TSH	+	0.30	43	3	00
SG-21	21	51	ROLL	ROLL	MAI	@	TSH	+	0.43	44	3	00
SG-21	18	52	ROLL	ROLL	SAI	@	TSH	+	0.32	45	3	00
					SAI	@	TSH	+	0.90			
SG-21	5	53	ROLL	ROLL	SAI	@	TSH	+	0.64	46	3	00
SG-21	21	53	ROLL	ROLL	MAI	@	TSH	+	0.56	47	3	00
SG-21	75	53	ROLL	ROLL	SAI	@	TSH	+	0.94	48	3	00
SG-21	18	54	ROLL	ROLL	MAI	@	TSH	+	0.15	49	3	00
SG-21	84	54	ROLL	ROLL	SAI	@	TSH	+	0.87	50	3	00
SG-21	17	55	ROLL	ROLL	MAI	@	TSH	+	0.14	51	3	00
SG-21	21	55	ROLL	ROLL	SAI	@	TSH	+	0.59	52	3	00
					SAI	@	TSH	+	0.34			
SG-21	8	56	ROLL	ROLL	SAI	@	TSH	+	1.80	53	3	00
SG-21	15	57	ROLL	ROLL	MAI	@	TSH	+	0.08	54	3	00
SG-21	7	59	ROLL	ROLL	SAI	@	TSH	+	2.87	55	3	00
SG-21	50	60	ROLL	ROLL	SAI	@	TSH	+	1.30	56	3	00
SG-21	86	60	ROLL	ROLL	SAI	@	TSH	+	0.54	57	3	00
SG-21	94	60	ROLL	ROLL	SAI	@	TSH	+	0.57	58	3	00
SG-21	25	63	ROLL/STAB	ROLL	SCI	@	TSH	-	0.05	59	4	00
SG-21	90	64	ROLL	ROLL	MAI	@	TSH	+	0.60	60	4	00
SG-21	26	66	ROLL	ROLL	SAI	@	TEH	-	0.05	61	4	00
					SCI	@	TEH	+	16.38			
					SAI	@	TEH	+	1.95			
SG-21	84	66	ROLL	ROLL	SAI	@	TSH	+	0.55	62	4	00
SG-21	25	67	ROLL	ROLL	SAI	@	TEH	+	0.26	63	4	00
SG-21	91	67	ROLL	ROLL	SAI	@	TSH	+	0.99	64	4	00
SG-21	88	70	ROLL/STAB	ROLL	SCI	@	TSH	+	0.16	65	5	00
SG-21	100	70	ROLL	ROLL	SAI	@	TSH	+	0.71	66	5	00
SG-21	65	71	ROLL	ROLL	SAI	@	01H	+	0.51	67	5	00
SG-21	88	74	ROLL	ROLL	MAI	@	TSH	+	0.80	68	5	00
SG-21	39	75	ROLL	ROLL	SAI	@	TSH	+	0.71	69	5	00
SG-21	97	75	ROLL	ROLL	SAI	@	TSH	+	0.60	70	5	00
SG-21	72	76	ROLL	ROLL	SAI	@	TSH	+	5.68	71	5	00
SG-21	88	76	ROLL	ROLL	SAI	@	TSH	+	0.99	72	5	00
SG-21	80	78	ROLL	ROLL	SAI	@	TSH	+	0.99	73	5	00
SG-21	98	78	ROLL	ROLL	SAI	@	TSH	+	0.58	74	5	00
SG-21	106	80	ROLL/STAB	ROLL	SCI	@	TSH	-	0.17	75	6	00
SG-21	42	84	ROLL	ROLL	SAI	@	TSH	+	1.58	76	6	00
SG-21	80	84	ROLL	ROLL	SAI	@	TSH	+	0.46	77	6	00
SG-21	42	86	ROLL	ROLL	SAI	@	TSH	+	1.42	78	6	00
SG-21	81	87	ROLL	ROLL	SAI	@	TSH	+	0.55	79	6	00

CCNPP-2 RFO12 Tube Plugging List										TUBE	STAB	LIST
S/G	ROW	COL	H/L	C/L	REASON FOR PLUGGING					QTY	QTY	REV
SG-21	81	89	ROLL	ROLL	SAI	@	TSH	+	0.66	80	6	00
SG-21	93	89	ROLL	ROLL	SAI	@	TSH	+	0.49	81	6	00
SG-21	82	90	ROLL	ROLL	MAI	@	TSH	+	0.63	82	6	00
SG-21	75	93	ROLL	ROLL	SAI	@	TSH	+	5.45	83	6	00
SG-21	69	95	ROLL/STAB	ROLL	SCI	@	TSH	+	0.30	84	7	00
SG-21	93	97	ROLL	ROLL	SAI	@	TSH	+	0.96	85	7	00
SG-21	98	98	ROLL	ROLL	SAI	@	TSH	+	0.89	86	7	00
SG-21	87	99	ROLL	ROLL	SAI	@	TSH	+	1.49	87	7	00
SG-21	62	102	ROLL/STAB	ROLL	SCI	@	TSH	+	0.16	88	8	00
SG-21	80	102	ROLL	ROLL	SAI	@	TSH	+	2.25	89	8	00
SG-21	88	102	ROLL	ROLL	SAI	@	TSH	+	1.02	90	8	00
					SAI	@	TSH	+	0.47			
SG-21	86	104	ROLL	ROLL	SAI	@	TSH	+	0.59	91	8	00
SG-21	80	106	ROLL	ROLL	SAI	@	TSH	+	0.32	92	8	00
SG-21	75	107	ROLL	ROLL	SAI	@	TSH	+	2.15	93	8	00
SG-21	15	109	ROLL	ROLL	SAI	@	TSH	+	1.02	94	8	00
SG-21	10	110	ROLL	ROLL	SAI	@	TSH	+	1.78	95	8	00
SG-21	80	110	ROLL	ROLL	SAI	@	TSH	+	0.40	96	8	00
SG-21	17	111	ROLL	ROLL	SAI	@	TSH	+	0.59	97	8	00
					SAI	@	TSH	+	0.87			
SG-21	79	111	ROLL	ROLL	MAI	@	TSH	+	0.42	98	8	00
SG-21	20	112	ROLL	ROLL	SAI	@	TSH	+	0.34	99	8	00
					SAI	@	TSH	+	0.71			
SG-21	80	112	ROLL	ROLL	SAI	@	TSH	+	0.69	100	8	00
SG-21	86	112	ROLL	ROLL	SAI	@	TSH	+	0.55	101	8	00
SG-21	19	113	ROLL	ROLL	MAI	@	TSH	+	0.52	102	8	00
SG-21	79	113	ROLL	ROLL	MAI	@	TSH	+	0.34	103	8	00
SG-21	81	113	ROLL	ROLL	SAI	@	TSH	+	0.90	104	8	00
SG-21	85	113	ROLL	ROLL	SAI	@	TSH	+	0.71	105	8	00
SG-21	89	113	ROLL	ROLL	MAI	@	TSH	+	1.15	106	8	00
SG-21	10	114	ROLL	ROLL	SAI	@	TSH	+	0.47	107	8	00
SG-21	14	114	ROLL	ROLL	SAI	@	TSH	+	0.70	108	8	00
					SAI	@	TSH	+	0.18			
					SAI	@	TSH	+	0.98			
SG-21	16	114	ROLL	ROLL	SAI	@	TSH	+	0.29	109	8	00
SG-21	20	114	ROLL	ROLL	MAI	@	TSH	+	0.37	110	8	00
SG-21	89	115	ROLL	ROLL	SAI	@	TSH	+	0.25	111	8	00
					MAI	@	TSH	+	0.53			
SG-21	76	116	ROLL	ROLL	SAI	@	TSH	+	1.02	112	8	00
SG-21	88	116	ROLL	ROLL	SAI	@	TSH	+	0.94	113	8	00
SG-21	76	118	ROLL	ROLL	SAI	@	TSH	+	1.28	114	8	00
SG-21	66	120	ROLL	ROLL	SAI	@	TSH	+	1.68	115	8	00
SG-21	63	121	ROLL	ROLL	SAI	@	TSH	+	0.81	116	8	00
SG-21	73	121	ROLL	ROLL	MAI	@	TSH	+	0.67	117	8	00
SG-21	85	121	ROLL	ROLL	SAI	@	TSH	+	1.30	118	8	00
SG-21	89	121	ROLL	ROLL	SAI	@	TSH	+	0.6	119	8	00

CCNPP-2 RFO12 Tube Plugging List										TUBE	STAB	LIST
S/G	ROW	COL	H/L	C/L	REASON FOR PLUGGING					QTY	QTY	REV
SG-21	72	122	ROLL	ROLL	SAI	@	TSH	+	0.92	120	8	00
SG-21	59	123	ROLL	ROLL	MAI	@	TSH	+	0.80	121	8	00
SG-21	69	123	ROLL	ROLL	SAI	@	TSH	+	1.67	122	8	00
					MAI	@	TSH	+	0.95			
SG-21	26	124	ROLL	ROLL	SAI	@	TSH	+	0.74	123	8	00
SG-21	21	125	ROLL	ROLL/STAB	SCI	@	TSC	+	0.02	124	9	00
SG-21	61	125	ROLL	ROLL	SAI	@	TSH	+	1.26	125	9	00
SG-21	65	125	ROLL	ROLL	MAI	@	TSH	+	0.91	126	9	00
					MAI	@	TSH	+	0.65			
					MAI	@	TSH	+	1.23			
SG-21	6	126	ROLL/STAB	ROLL	SCI	@	TSH	-	0.07	127	10	00
SG-21	52	126	ROLL	ROLL	SAI	@	TSH	+	0.68	128	10	00
SG-21	54	126	ROLL	ROLL	MAI	@	TSH	+	0.67	129	10	00
SG-21	56	126	ROLL	ROLL	MAI	@	TSH	+	0.49	130	10	00
SG-21	76	126	ROLL	ROLL	SAI	@	TSH	+	1.21	131	10	00
SG-21	82	126	ROLL	ROLL	SAI	@	TSH	+	0.52	132	10	00
SG-21	37	127	ROLL	ROLL	SAI	@	TSH	-	0.08	133	10	00
SG-21	51	127	ROLL	ROLL	MAI	@	TSH	+	0.27	134	10	00
SG-21	55	127	ROLL	ROLL	MAI	@	TSH	+	0.75	135	10	00
SG-21	67	127	ROLL	ROLL	SAI	@	TSH	+	0.98	136	10	00
SG-21	73	127	ROLL	ROLL	SAI	@	TSH	+	1.14	137	10	00
SG-21	52	128	ROLL	ROLL	MAI	@	TSH	+	0.55	138	10	00
SG-21	60	128	ROLL	ROLL	MAI	@	TSH	+	0.52	139	10	00
SG-21	53	129	ROLL	ROLL	MAI	@	TSH	+	0.50	140	10	00
SG-21	55	129	ROLL	ROLL	SAI	@	TSH	+	0.82	141	10	00
SG-21	57	129	ROLL	ROLL	MAI	@	TSH	+	0.74	142	10	00
SG-21	20	130	ROLL	ROLL	MAI	@	TSH	+	0.17	143	10	00
SG-21	48	130	ROLL	ROLL	MAI	@	TSH	+	0.10	144	10	00
SG-21	52	130	ROLL	ROLL	MAI	@	TSH	+	0.30	145	10	00
SG-21	58	130	ROLL	ROLL	MAI	@	TSH	+	0.16	146	10	00
					SAI	@	TSH	+	0.97			
SG-21	25	131	ROLL	ROLL	MAI	@	TSH	+	0.15	147	10	00
SG-21	22	132	ROLL	ROLL	SAI	@	TSH	+	2.98	148	10	00
SG-21	46	132	ROLL	ROLL	MAI	@	TSH	+	0.34	149	10	00
SG-21	60	132	ROLL	ROLL	SAI	@	TSH	+	0.73	150	10	00
SG-21	62	132	ROLL	ROLL	SAI	@	TSH	+	0.84	151	10	00
SG-21	27	133	ROLL	ROLL	SAI	@	TSH	+	1.02	152	10	00
SG-21	39	133	ROLL	ROLL	MAI	@	TSH	+	0.71	153	10	00
SG-21	53	133	ROLL	ROLL	SAI	@	TSH	+	0.20	154	10	00
SG-21	63	133	ROLL	ROLL	SAI	@	TSH	+	0.86	155	10	00
SG-21	26	134	ROLL	ROLL	MAI	@	TSH	+	0.84	156	10	00
SG-21	36	134	ROLL	ROLL	SAI	@	TSH	+	0.62	157	10	00
SG-21	54	134	ROLL	ROLL	SAI	@	TSH	+	0.85	158	10	00
SG-21	62	134	ROLL	ROLL	SAI	@	TSH	+	0.84	159	10	00
SG-21	64	134	ROLL	ROLL	SAI	@	TSH	+	0.68	160	10	00
SG-21	35	135	ROLL	ROLL	SAI	@	TSH	+	0.84	161	10	00

CCNPP-2 RFO12 Tube Plugging List										TUBE	STAB	LIST
S/G	ROW	COL	H/L	C/L	REASON FOR PLUGGING					QTY	QTY	REV
SG-21	37	135	ROLL	ROLL	MAI	@	TSH	+	0.73	162	10	00
SG-21	55	135	ROLL	ROLL	MAI	@	TSH	+	0.65	163	10	00
SG-21	12	136	ROLL	ROLL	SAI	@	TSH	+	0.52	164	10	00
SG-21	20	136	ROLL	ROLL	SAI	@	TSH	+	1.42	165	10	00
					MAI	@	TSH	+	1.08			
SG-21	22	136	ROLL	ROLL	SAI	@	TSH	+	0.95	166	10	00
SG-21	24	136	ROLL	ROLL	MAI	@	TSH	+	0.48	167	10	00
SG-21	34	136	ROLL	ROLL	MAI	@	TSH	+	0.55	168	10	00
SG-21	38	136	ROLL	ROLL	SAI	@	TSH	+	0.70	169	10	00
SG-21	40	136	ROLL	ROLL	MAI	@	TSH	+	0.50	170	10	00
SG-21	52	136	ROLL	ROLL	MAI	@	TSH	+	0.50	171	10	00
SG-21	17	137	ROLL	ROLL	MAI	@	TSH	+	1.21	172	10	00
SG-21	25	137	ROLL	ROLL	MAI	@	TSH	+	0.23	173	10	00
SG-21	27	137	ROLL	ROLL	SAI	@	TSH	+	0.66	174	10	00
SG-21	45	137	ROLL/STAB	ROLL	MCI	@	TSH	+	0.07	175	11	00
SG-21	53	137	ROLL	ROLL	SAI	@	TSH	+	0.86	176	11	00
SG-21	8	138	ROLL	ROLL/STAB	SCI	@	TSC	+	0.00	177	12	00
SG-21	24	138	ROLL	ROLL	MAI	@	TSH	+	0.54	178	12	00
SG-21	32	138	ROLL	ROLL	MAI	@	TSH	+	0.81	179	12	00
SG-21	34	138	ROLL	ROLL	MAI	@	TSH	+	0.50	180	12	00
					MAI	@	TSH	+	1.19			
SG-21	48	138	ROLL	ROLL	MAI	@	TSH	+	0.65	181	12	00
SG-21	25	139	ROLL	ROLL	MAI	@	TSH	+	0.34	182	12	00
SG-21	31	139	ROLL	ROLL	SAI	@	TSH	+	0.65	183	12	00
					MAI	@	TSH	+	1.21			
SG-21	37	139	ROLL	ROLL	SAI	@	TSH	+	0.60	184	12	00
SG-21	51	139	ROLL	ROLL	SAI	@	TSH	+	0.60	185	12	00
SG-21	16	140	ROLL	ROLL	MAI	@	TSH	+	1.00	186	12	00
SG-21	32	140	ROLL	ROLL	SAI	@	TSH	+	0.61	187	12	00
					SAI	@	TSH	+	1.04			
					SAI	@	TSH	+	0.14			
SG-21	44	140	ROLL	ROLL	SAI	@	TSH	+	0.57	188	12	00
					SAI	@	TSH	+	0.15			
SG-21	11	141	ROLL	ROLL	SAI	@	TSH	+	0.94	189	12	00
SG-21	12	142	ROLL	ROLL	MAI	@	TSH	+	0.61	190	12	00
SG-21	24	142	ROLL	ROLL	MAI	@	TSH	+	0.05	191	12	00
SG-21	28	142	ROLL	ROLL	SAI	@	TSH	+	0.96	192	12	00
					SAI	@	TSH	+	1.20			
SG-21	32	142	ROLL	ROLL	MAI	@	TSH	+	0.57	193	12	00
SG-21	17	143	ROLL	ROLL	MAI	@	TSH	+	1.24	194	12	00
SG-21	21	143	ROLL	ROLL	SAI	@	TSH	+	0.81	195	12	00
SG-21	31	143	ROLL	ROLL	SAI	@	TSH	+	0.70	196	12	00
SG-21	35	143	ROLL	ROLL	MAI	@	TSH	+	0.10	197	12	00
SG-21	15	145	ROLL	ROLL	SAI	@	TSH	+	0.44	198	12	00
					MAI	@	TSH	+	0.87			
SG-21	17	145	ROLL	ROLL	SAI	@	TSH	+	0.71	199	12	00

CCNPP-2 RFO12 Tube Plugging List										TUBE	STAB	LIST
S/G	ROW	COL	H/L	C/L	REASON FOR PLUGGING					QTY	QTY	REV
SG-21	21	145	ROLL	ROLL	SAI	@	TSH	+	0.93	200	12	00
					SAI	@	TSH	+	1.08			
SG-21	23	145	ROLL	ROLL	MAI	@	TSH	+	0.67	201	12	00
SG-21	12	146	ROLL	ROLL	MAI	@	TSH	+	0.31	202	12	00
SG-21	16	146	ROLL	ROLL	MAI	@	TSH	+	0.75	203	12	00
					SAI	@	TSH	+	0.47			
SG-21	24	146	ROLL	ROLL	SAI	@	TSH	+	0.19	204	12	00
					MAI	@	TSH	+	0.71			
SG-21	28	146	ROLL	ROLL	SAI	@	TSH	+	0.52	205	12	00
SG-21	32	146	ROLL	ROLL	SAI	@	TSH	+	0.16	206	12	00
SG-21	17	147	ROLL	ROLL	SAI	@	TSH	+	0.66	207	12	00
SG-21	12	148	ROLL	ROLL	MAI	@	TSH	+	0.12	208	12	00
SG-21	16	148	ROLL	ROLL	SAI	@	TSH	+	0.18	209	12	00
SG-21	18	148	ROLL	ROLL	SAI	@	TSH	+	0.47	210	12	00
SG-21	9	149	ROLL	ROLL	SAI	@	VM	-	1.45	211	12	00
SG-21	25	149	ROLL	ROLL	SAI	@	TSH	+	0.17	212	12	00
SG-21	1	151	ROLL	ROLL	OBS	@	06C	+	1.58	213	12	00
SG-21	19	153	ROLL	ROLL	SVI	@	TSC	+	0.09	214	12	00
SG-21	1	1	ROLL	ROLL/STAB	LPI	@	TSC	+	0.65	215	13	01
SG-21	68	12	ROLL	ROLL/STAB	LPI	@	TSC	+	0.38	216	14	01
SG-21	67	13	ROLL	ROLL/STAB	LPI	@	TSC	+	0.12	217	15	01
SG-21	69	13	ROLL	ROLL/STAB	LPI	@	TSC	+	0.26	218	16	01
SG-21					LPI	@	TSC	+	0.42			
SG-21	26	18	ROLL	ROLL	SAI	@	TSH	+	1.52	219	16	01
SG-21	22	20	ROLL	ROLL	MAI	@	TSH	+	0.10	220	16	01
SG-21	24	20	ROLL	ROLL	SAI	@	TSH	+	0.27	221	16	01
SG-21	9	21	ROLL	ROLL	SAI	@	TSH	+	0.45	222	16	01
SG-21	15	21	ROLL	ROLL	SAI	@	TSH	+	0.15	223	16	01
SG-21	14	22	ROLL	ROLL	SAI	@	TSH	+	0.61	224	16	01
SG-21	21	23	ROLL	ROLL	SAI	@	TSH	+	0.72	225	16	01
SG-21	16	24	ROLL	ROLL	SAI	@	TSH	+	0.88	226	16	01
SG-21	22	24	ROLL	ROLL	SAI	@	TSH	+	0.66	227	16	01
SG-21	24	24	ROLL	ROLL	MAI	@	TSH	+	0.64	228	16	01
SG-21	36	24	ROLL	ROLL	MAI	@	TSH	+	0.30	229	16	01
SG-21	21	25	ROLL	ROLL	SAI	@	TSH	+	0.78	230	16	01
SG-21	34	26	ROLL	ROLL	MAI	@	TSH	+	0.50	231	16	01
SG-21	36	26	ROLL	ROLL	MAI	@	TSH	+	0.18	232	16	01
SG-21	40	26	ROLL	ROLL	SAI	@	TSH	+	0.63	233	16	01
SG-21	25	27	ROLL	ROLL	SAI	@	TSH	+	0.78	234	16	01
SG-21	47	27	ROLL	ROLL	SAI	@	TSH	+	0.84	235	16	01
SG-21	48	28	ROLL	ROLL	MAI	@	TSH	+	0.36	236	16	01
SG-21	29	29	ROLL	ROLL	MAI	@	TSH	+	0.43	237	16	01
SG-21	53	29	ROLL	ROLL	SAI	@	TSH	+	0.16	238	16	01
SG-21	54	38	ROLL	ROLL	MAI	@	TSH	+	0.54	239	16	01
SG-21	53	39	ROLL	ROLL	SAI	@	TSH	+	0.48	240	16	01
SG-21	58	40	ROLL	ROLL	SAI	@	TSH	+	0.94	241	16	01
SG-21	58	42	ROLL	ROLL	MAI	@	TSH	+	0.00	242	16	01

CCNPP-2 RFO12 Tube Plugging List										TUBE	STAB	LIST
S/G	ROW	COL	H/L	C/L	REASON FOR PLUGGING					QTY	QTY	REV
SG-21	36	46	ROLL/STAB	ROLL	SCI	@	TSH	+	0.15	243	17	01
SG-21	11	49	ROLL	ROLL	SAI	@	VM	+	0.40	244	17	01
SG-21	135	65	ROLL	ROLL	SVI	@	TSC	+	0.19	245	17	01
SG-21	45	103	ROLL	ROLL	SAI	@	TSH	+	4.20	246	17	01
SG-21	26	112	ROLL/STAB	ROLL	SCI	@	TSH	-	2.75	247	18	01
SG-21	25	113	ROLL/STAB	ROLL	SCI	@	TSH	+	0.07	248	19	01
SG-21	46	120	ROLL	ROLL	SAI	@	TSH	+	4.80	249	19	01
SG-21	8	150	ROLL/LONG STAB	ROLL	SCI	@	VH	-	1.04	250	20	01
							Totals			250	20	

Table 7-2: SG 21 Tubes Removed from Service due to Eggcrate Degradation
(Tube quantity count is continued from Section 6.0)

CCNPP-2 RFO12 Tube Plugging List - EC Degradation						TUBE	STAB	LIST
S/G	ROW	COL	H/L	C/L	REASON FOR PLUGGING	QTY	QTY	REV
SG-21	89	21	ROLL	ROLL	EC Degradation	251	20	2
SG-21	90	22	ROLL	ROLL	EC Degradation	252	20	2
SG-21	90	146	ROLL	ROLL	EC Degradation	253	20	2
SG-21	89	147	ROLL	ROLL	EC Degradation	254	20	2
					Totals	254	20	

Table 7-3: SG 22 Tubes Removed from Service due to Eggcrate Degradation
(Tube quantity count is continued from Section 6.0)

CCNPP-2 RFO12 Tube Plugging List - EC Degradation						TUBE	STAB	LIST
S/G	ROW	COL	H/L	C/L	REASON FOR PLUGGING	QTY	QTY	REV
SG-22	31	3	ROLL	ROLL	EC Degradation	204	32	4
SG-22	32	4	ROLL	ROLL	EC Degradation	205	32	4
SG-22	34	4	ROLL	ROLL	EC Degradation	206	32	4
SG-22	36	4	ROLL	ROLL	EC Degradation	207	32	4
SG-22	38	4	ROLL	ROLL	EC Degradation	208	32	4
SG-22	39	5	ROLL	ROLL	EC Degradation	209	32	4
SG-22	41	5	ROLL	ROLL	EC Degradation	210	32	4
SG-22	43	5	ROLL	ROLL	EC Degradation	211	32	3
SG-22	44	6	ROLL	ROLL	EC Degradation	212	32	3
SG-22	46	6	ROLL	ROLL	EC Degradation	213	32	3
SG-22	48	6	ROLL	ROLL	EC Degradation	214	32	3
SG-22	49	7	ROLL	ROLL	EC Degradation	215	32	3
SG-22	51	7	ROLL	ROLL	EC Degradation	216	32	3
SG-22	53	7	ROLL	ROLL	EC Degradation	217	32	3
SG-22	54	8	ROLL	ROLL	EC Degradation	218	32	3
SG-22	56	8	ROLL	ROLL	EC Degradation	219	32	3
SG-22	57	9	ROLL	ROLL	EC Degradation	220	32	3
SG-22	59	9	ROLL	ROLL	EC Degradation	221	32	3
SG-22	60	10	ROLL	ROLL	EC Degradation	222	32	3
SG-22	62	10	ROLL	ROLL	EC Degradation	223	32	3
SG-22	63	11	ROLL	ROLL	EC Degradation	224	32	3
SG-22	65	11	ROLL	ROLL	EC Degradation	225	32	3
SG-22	67	11	ROLL	ROLL	EC Degradation	226	32	3
SG-22	68	12	ROLL	ROLL	EC Degradation	227	32	3
SG-22	69	13	ROLL	ROLL	EC Degradation	228	32	3
SG-22	71	13	ROLL	ROLL	EC Degradation	229	32	3
SG-22	73	13	ROLL	ROLL	EC Degradation	230	32	3
SG-22	74	14	ROLL	ROLL	EC Degradation	231	32	3
SG-22	75	15	ROLL	ROLL	EC Degradation	232	32	3
SG-22	77	15	ROLL	ROLL	EC Degradation	233	32	3
SG-22	78	16	ROLL	ROLL	EC Degradation	234	32	3

BOBBIN INDICATIONS

UTILITY:	Baltimore Gas & Electric	May 17,1999 12:00
PLANT:	CCNPP	
UNIT:	2	
SG:	22	
DATABASE:	CCNPP_UNIT2_SG22_0399_Final	

****
* INSPECTION SUMMARY QUERY REPORT *
****

* Test Plans included in summary: 3 Total Test Plans in database: 13 *

Test Plan Name:	Probe Type:	Probe Size:	Leg:
1. ROWS 1-5 STRAIGHTS (G65-68)	BOBBIN	600UL	HL
2. ROWS 6-140 F/L (G1-19)	BOBBIN	560SF	CL
3. ROWS 1-5 CANDY CANE (G20-23)	BOBBIN	560SF	CL

****
* EIMS MAIN QUERY PARAMETERS *
****

ROW	ALL
LINE	ALL
VOLTS	ALL
DEGREES	ALL
PERCENT	0 to 100
LOCATION	ALL
ELEVATION	ALL
EXTENT	ALL
UTILITY1	ALL
UTILITY2	ALL
NAME	ALL
EVAL TYPE	ALL
CAL GROUP	ALL
PROBE	ALL
IND. CODES	ADR DNI DRI DSI DTI
	LPI NQI PLP

CHANNELS ALL

BOBBIN INDICATIONS

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 12:00

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE SIZE
1	7	1	0.31	102	16	P2	01H -1.05	TECTEH			L2157	rpri	22H00116	C	0	600UL
2	14	10	0.24	79	DSI	P1	01H -1.06	TECTEH			M9715	rsec	22H00117	C	0	600UL
3	38	10	0.65	102	PLP	8	TSH +1.64	TECTEH			S9098	rpri	22H00117	C	0	600UL
4	66	12	0.35	132	DSI	P1	02C +0.97	TECTEH			S1848	rpri	22H00118	C	0	600UL
5	75	23	0.68	121	28	P2	DC -0.52	TECTEH			D3858	reso	22H00124	C	0	600UL
6	13	25	0.45	76	DSI	P1	03H -0.83	TECTEH			R4201	rpri	22H00125	C	0	600UL
7	53	25	0.53	86	DSI	P1	01H +0.68	TECTEH			S0607	rsec	22H00125	C	0	600UL
8	12	26	0.57	48	DSI	P1	02H +0.09	TECTEH			S1848	rpri	22H00128	C	0	600UL
9	92	26	0.37	83	18	P2	VH +1.25	TECTEH			R4201	rpri	22H00125	C	0	600UL
10	91	29	0.43	92	21	P2	VH -0.97	TECTEH			H2131	reso	22H00128	C	0	600UL
11	95	31	0.25	94	NQI	P1	05H +2.76	TEHTEC			N2222	rsec	22C00110	C	0	600UL
12	92	32	0.18	58	9	P2	VH +0.16	TEHTEC			L2157	rpri	22C00110	C	0	600UL
13	101	33	0.38		16	P2	VH +1.18	TEHTEC			T0042	reso	22C00110	C	0	600UL
14	92	34	0.31	80	DSI	P1	VC -0.70	TEHTEC			R6452	reso	22C00110	C	0	600UL
15	100	34	0.23		9	P2	VH -0.11	TEHTEC			H3333	rsec	22C00110	C	0	600UL
16	37	35	0.67	106	NQI	P1	TSH +0.77	TEHTEC			D4576	rsec	22C00109	C	0	600UL
17	24	36	0.26	110	11	P2	DH +1.51	TEHTEC			P5436	rpri	22C00109	C	0	600UL
18	98	36	0.24	102	10	P2	VC +0.30	TEHTEC			T0042	reso	22C00109	C	0	600UL
19	97	37	0.21	131	8	P2	VH -0.96	TEHTEC			S9098	rpri	22C00108	C	0	600UL
20	101	37	0.27	102	10	P2	VH +0.32	TEHTEC			S9098	rpri	22C00108	C	0	600UL
	103	37	0.44	46	DSI	P1	09H -0.04	TEHTEC			T0042	reso	22C00109	C	0	600UL
			0.96	105	DSI	P1	09C -0.15	TEHTEC			P5436	rpri	22C00109	C	0	600UL
23	98	38	0.62	79	DSI	P1	09C -0.90	TEHTEC			S9098	rpri	22C00108	C	0	600UL
24	37	39	0.28	82	NQI	P1	TSH +6.65	TEHTEC			S9098	rpri	22C00105	C	0	600UL
25	43	39	0.36	159	NQI	P1	TSH +0.61	TEHTEC			T0042	reso	22C00108	C	0	600UL
26	49	39	0.49	154	NQI	P1	TSH +0.61	TEHTEC			N2222	rsec	22C00108	C	0	600UL
27	48	40	0.37	149	NQI	P1	TSH +0.69	TEHTEC			T0042	reso	22C00106	C	0	600UL
28	52	40	0.41	131	NQI	P1	TSH +0.80	TEHTEC			T0042	reso	22C00106	C	0	600UL
29	70	40	0.28	95	NQI	P1	TSC +0.68	TEHTEC			N2222	rsec	22C00105	C	0	600UL
30	96	40	0.26	103	DSI	P1	VC -0.30	TEHTEC			T0042	reso	22C00106	C	0	600UL
31	28	42	0.64	155	NQI	P1	TSH +0.79	TEHTEC			N2222	rsec	22C00105	C	0	600UL
32	15	43	0.21	129	NQI	P1	TSH +1.98	TECTEH			L6066	rsec	22H00143	C	0	600UL
33	17	43	0.23	143	NQI	P1	TSH +1.83	TECTEH			L6066	rsec	22H00143	C	0	600UL
34	23	43	0.40	146	NQI	P1	TSH +2.80	TEHTEC			T0042	reso	22C00106	C	0	600UL
35	31	43	0.22	103	NQI	P1	TSH +0.80	TEHTEC			T0042	reso	22C00106	C	0	600UL
36	30	44	0.47	50	NQI	P1	TSH +2.00	TEHTEC			M2655	rsec	22C00104	C	0	600UL
37	89	45	0.53	109	20	P2	VH +1.37	TEHTEC			H3464	rpri	22C00104	C	0	600UL
38	95	45	0.39	45	DSI	P1	09C +0.00	TEHTEC			R9311	rpri	22C00103	C	0	600UL
39	100	50	0.24	94	11	P2	VH -1.30	TEHTEC			M0945	rsec	22C00057	C	0	600UL
40	61	51	0.52	24	DSI	P1	DH +1.31	TEHTEC			R6452	reso	22C00054	C	0	600UL
41			0.57	141	DSI	P1	DH +1.69	TEHTEC			R6452	reso	22C00054	C	0	600UL
42	10	52	0.74	150	DSI	P1	DH -0.09	TECTEH			K7060	reso	22H00132	C	0	600UL
43	56	52	0.38	41	16	P2	DC -2.12	TEHTEC			D4576	rsec	22C00015	C	0	600UL
44	9	53	0.83	108	NQI	P1	TSH +1.94	TECTEH			L6066	rsec	22H00143	C	0	600UL
45	25	53	0.31	135	12	P2	02C +0.93	TEHTEC			W4892	rpri	22C00018	C	0	600UL
	101	53	0.44		17	P2	DC +1.03	TEHTEC			H2131	reso	22C00055	C	0	600UL
	88	54	0.17	97	DSI	P1	VC -1.24	TECTEH			J6276	rpri	22H00133	C	0	600UL
48	111	55	0.38	62	NQI	5	02H +1.86	TEHTEC			R6452	reso	22C00054	C	0	600UL
49	115	55	0.52	50	DSI	P1	09C +0.02	TEHTEC			B6937	rsec	22C00064	C	0	580UL

BOBBIN INDICATIONS

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 12:00

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE SIZE
50			0.51	47	DSI	P1 09C	+0.09	DH TEC			H2131	reso	22C00054	C	0	600UL
51	25	57	0.46	67	NQI	P1 TSH	+1.02	TEHTEC			W4881	rsec	22C00018	C	0	600UL
52	49	57	0.77	79	DSI	P1 01H	+0.60	TEHTEC			J6276	rpri	22C00018	C	0	600UL
53	8	60	0.23	85	NQI	P1 TSH	+1.66	TECTEH			L6066	rsec	22H00143	C	0	600UL
54	109	63	0.52	83	19	P2 VM	-1.81	TEHTEC			L2157	rpri	22C00053	C	0	600UL
55	54	70	0.98	147	DSI	P1 03H	-0.49	TECTEH			L2157	rpri	22H00136	C	0	600UL
56	89	71	0.90	41	NQI	P1 TSH	+1.30	TEHTEC			R4201	rpri	22C00045	C	0	600UL
57	107	71	0.46	111	DSI	P1 09C	-0.06	TEHTEC			S1848	rpri	22C00044	C	0	600UL
58	33	73	0.85	39	32	P2 DH	+1.66	TECTEH			L2157	rpri	22H00136	C	0	600UL
59	121	73	0.31	90	DSI	P1 07H	+0.43	TEHTEC			A9608	reso	22C00062	C	0	580UL
60	84	74	0.45	143	NQI	P1 TSH	+0.72	TEHTEC			L6066	rsec	22C00044	C	0	600UL
61	105	75	0.42	119	DSI	P1 07H	-0.69	TEHTEC			R4201	rpri	22C00045	C	0	600UL
62	37	77	0.27	57	13	P2 06H	-0.97	TECTEH			L2157	rpri	22H00136	C	0	600UL
63	41	77	0.49	141	NQI	P1 TSH	+1.06	TECTEH			L2157	rpri	22H00136	C	0	600UL
64	36	78	0.67	147	DSI	P1 07H	-1.47	TECTEH			C5184	rsec	22H00135	C	0	600UL
65	85	79	0.68	149	NQI	P1 TSH	+0.73	TEHTEC			R4201	rpri	22C00047	C	0	600UL
66	76	82	0.42	116	NQI	5 TSH	+1.17	TEHTEC			B3720	reso	22C00046	C	0	600UL
67	78	82	0.38	88	NQI	P1 TSH	+1.37	TEHTEC			P4634	rsec	22C00047	C	0	600UL
68	96	82	0.37	120	NQI	P1 TSC	+20.96	TEHTEC			S1848	rpri	22C00046	C	0	600UL
69	81	83	0.47	63	NQI	P1 TSH	+0.95	TEHTEC			R4201	rpri	22C00049	C	0	600UL
70	79	85	0.46	46	NQI	P1 TSH	+1.29	TEHTEC			L2157	rpri	22C00048	C	0	600UL
	99	85	1.25	151	DSI	P1 09C	+0.00	TEHTEC			L2157	rpri	22C00048	C	0	600UL
72	96	86	0.12	132	NQI	P1 TSC	+1.07	TEHTEC			D3858	reso	22C00048	C	0	600UL
73	116	86	0.56	69	NQI	5 VH	+28.73	TEHTEC			B3720	reso	22C00048	C	0	600UL
74	83	87	0.47	51	NQI	P1 TSH	+0.89	TEHTEC			L2157	rpri	22C00048	C	0	600UL
75	87	87	0.59	115	NQI	5 TSH	+0.82	TEHTEC			B3720	reso	22C00048	C	0	600UL
76	36	88	0.33	151	17	P2 DH	+1.62	TECTEH			J6276	rpri	22H00135	C	0	600UL
77	38	90	0.36	131	19	P2 DC	+1.50	TECTEH			C5184	rsec	22H00136	C	0	600UL
78	80	90	0.28	59	NQI	P1 TSH	+1.41	TEHTEC			R4201	rpri	22C00049	C	0	600UL
79	88	90	0.14	88	NQI	P1 TSH	+0.60	TEHTEC			R4201	rpri	22C00049	C	0	600UL
80	137	91	0.58	142	DNI	P1 04C	+11.93	TEHTEC			M2655	rsec	22C00060	C	0	580UL
81	80	92	0.36	123	NQI	P1 TSH	+1.36	TEHTEC			A9608	reso	22C00036	C	0	600UL
82	75	93	0.21	99	NQI	P1 TSH	+5.91	TEHTEC			D4576	rsec	22C00036	C	0	600UL
83	93	93	0.87	147	NQI	P1 TSC	+0.99	TEHTEC			G5937	rsec	22C00037	C	0	600UL
84	80	94	0.60	65	NQI	P1 TSH	+1.04	TEHTEC			N0942	rpri	22C00036	C	0	600UL
85	138	94	0.54	110	25	P2 DH	+1.88	TEHTEC			R4201	rpri	22C00061	C	0	580UL
86	115	95	0.43	78	NQI	P1 09H	+11.83	TEHTEC			D4576	rsec	22C00036	C	0	600UL
87	137	95	0.41	69	NQI	5 TSH	+7.32	TEHTEC			R6452	reso	22C00060	C	0	580UL
88	99	97	0.33	120	NQI	P1 DH	+9.90	TEHTEC			D4576	rsec	22C00038	C	0	600UL
89	102	98	0.33	79	NQI	5 VH	+3.02	TEHTEC			K7060	reso	22C00038	C	0	600UL
90	26	100	0.99	111	36	P2 DH	-1.84	TSCTEH			L2157	rpri	22H00138	C	0	600UL
91			0.46	105	22	P2 VM	+1.76	TSCTEH			B3720	reso	22H00138	C	0	600UL
92	60	100	0.47	143	24	P2 VM	-2.06	TECTEH			M0945	rsec	22H00137	C	0	600UL
93	136	102	0.36	128	NQI	P1 TSH	+12.12	TEHTEC			B2860	rpri	22C00059	C	0	580UL
94	63	107	0.31	107	NQI	P1 TSH	+6.77	TEHTEC			R4201	rpri	22C00041	C	0	600UL
95	87	107	0.42	106	NQI	P1 TSC	+31.44	TEHTEC			R4201	rpri	22C00041	C	0	600UL
	60	108	0.50	87	24	P2 VM	-1.92	TECTEH			W4892	rpri	22H00139	C	0	600UL
97	68	108	0.30	129	NQI	P1 TSH	+0.77	TEHTEC			R4201	rpri	22C00041	C	0	600UL
98	80	108	0.36	133	14	P2 03C	-1.28	TEHTEC			R4201	rpri	22C00041	C	0	600UL

BOBBIN INDICATIONS

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 12:00

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE SIZE
99	42	112	0.20	111	NQI	P1 TSH	+0.75	TECTEH			S1848	rpri	22H00140	C	0	600UL
100	9	113	0.54	98	DSI	P1 02H	+0.49	TEHTEC			W4881	rsec	22C00021	C	0	600UL
101	111	115	0.21	68	NQI	P1 TSH	+2.56	TEHTEC			M1680	reso	22C00042	C	0	600UL
102	31	117	0.81	23	NQI	P1 TSH	+37.74	TEHTEC			R4201	rpri	22C00025	C	0	600UL
103	7	121	0.35	88	NQI	P1 06H	+3.42 TO+5.75	TEHTEC			D4576	rsec	22C00022	C	0	600UL
104	123	121	0.48	129	DSI	P1 09H	+0.00	TEHTEC			B2860	rpri	22C00059	C	0	580UL
105	119	123	0.57	61	DSI	P1 03H	-0.74	TEHTEC			N0942	rpri	22C00056	C	0	600UL
106	113	125	0.41	101	DSI	P1 01H	+0.55	TEHTEC			R4201	rpri	22C00032	C	0	600UL
107	77	129	1.02	66	ADR	6 VH	+10.59 TO+12.56	TEHTEC			L6066	rsec	22C00032	C	0	600UL
108	10	130	1.25	145	DSI	P1 VM	+0.00	TEHTEC			P5436	rpri	22C00022	C	0	600UL
109	9	131	2.76	103	ADR	6 VM	-2.35 TO-1.14	TEHTEC			B3720	reso	22C00021	C	0	600UL
110	25	131	0.66	125	NQI	P1 TSH	+0.98	TEHTEC			M9082	rpri	22C00024	C	0	600UL
111			0.26	94	NQI	P1 TSH	+4.90	TEHTEC			R6452	reso	22C00024	C	0	600UL
112	37	133	0.36	129	NQI	P1 TSH	+0.64	TEHTEC			R6452	reso	22C00024	C	0	600UL
113	39	133	0.46	128	NQI	P1 TSH	+0.64	TEHTEC			W4881	rsec	22C00023	C	0	600UL
114	12	134	0.36	113	NQI	P1 TSH	+0.90	TEHTEC			P5436	rpri	22C00022	C	0	600UL
115	24	134	0.40	66	NQI	P1 TSH	+1.06	TEHTEC			H2131	reso	22C00023	C	0	600UL
116	94	134	0.29	95	DSI	P1 VC	+0.44	TEHTEC			M9082	rpri	22C00035	C	0	600UL
117	24	136	0.26	110	NQI	P1 TSH	+1.01	TEHTEC			S9098	rpri	22C00023	C	0	600UL
118	31	137	0.36	127	NQI	P1 TSH	+0.81	TEHTEC			W4881	rsec	22C00023	C	0	600UL
119	68	138	0.31	71	NQI	5 VM	+13.37	TEHTEC			S7752	reso	22C00011	C	0	600UL
	43	139	1.06	81	NQI	5 01C	+11.89	TEHTEC			R6452	reso	22C00010	C	0	600UL
[illegible]	47	139	0.75	141	21	P2 04C	+0.17	TEHTEC			R6452	reso	22C00010	C	0	600UL
122	81	145	0.28	84	12	P2 05H	+0.54	TEHTEC			M7073	rsec	22C00013	C	0	600UL
123	26	164	0.26	85	10	P2 VM	+0.89	TEHTEC			L2157	rpri	22C00004	C	0	600UL
124	15	167	0.44	90	19	P2 02C	-0.98	TEHTEC			G5937	rsec	22C00001	C	0	600UL

QUERY REPORT SUMMARY:

QUERY PARAMETER	ENTRIES	TUBES
0 to 100 Percent	31	30
ADR Indication Code	2	2
DNI Indication Code	1	1
DRI Indication Code	0	0
DSI Indication Code	30	27
DTI Indication Code	0	0
LPI Indication Code	0	0
NQI Indication Code	59	58
PLP Indication Code	1	1

TOTAL ENTRIES: 124

TOTAL TUBES: 119

RPC SPECIAL INTEREST INDICATIONS

UTILITY:	Baltimore Gas & Electric	May 17,1999 12:01
PLANT:	CCNPP	
UNIT:	2	
SG:	22	
DATABASE:	CCNPP_UNIT2_SG22_0399_Final	

****
* INSPECTION SUMMARY QUERY REPORT *
****

* Test Plans included in summary: 2 Total Test Plans in database: 13 *

Test Plan Name:	Probe Type:	Probe Size:	Leg:
1. HL Bobbin SI (TEH-VM+0.00)	MRPC	600PP	HL
2. CL Bobbin SI (VM+0.01-TEC)	MRPC	600PP	CL

****
* EIMS MAIN QUERY PARAMETERS *
****

ROW	ALL
LINE	ALL
VOLTS	ALL
DEGREES	ALL
PERCENT	NONE
LOCATION	ALL
ELEVATION	ALL
EXTENT	ALL
UTILITY1	ALL
UTILITY2	ALL
NAME	ALL
EVAL TYPE	ALL
CAL GROUP	ALL
PROBE	ALL
IND. CODES	LPI MAI MCI MMI MSI
	MVI SAI SCI SVI

CHANNELS ALL

RPC SPECIAL INTEREST INDICATIONS

UTILITY: Baltimore Gas & Electric

May 17,1999 12:01

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
1	12	26	0.59	37	SAI	3	02H +0.29	02H02H	0.4		A9608	reso	22H00183	H 4	600HF
2			0.44	109	SAI	4	02H +0.29	02H02H	0.4		A9608	reso	22H00183	H 4	600HF
3	49	57	0.25	71	MAI	1	01H +0.65	01H01H	0.4		C3340	reso	22H00065	H 4	600PP
4			0.44	108	MAI	2	01H +0.65	01H01H	0.6		C3340	reso	22H00065	H 4	600PP
5	102	98	0.17	35	SAI	1	VH +2.74	VM VH	0.2		H2131	reso	22H00068	H 4	560PF
6			0.29	104	SAI	2	VH +2.74	VM VH	0.2		H2131	reso	22H00068	H 4	560PF
7	9	113	0.18	98	MAI	1	02H +0.57	02H02H	0.5		R6452	reso	22H00067	H 4	600PP
8			0.39	97	MAI	2	02H +0.57	02H02H	0.5		R6452	reso	22H00067	H 4	600PP

QUERY REPORT SUMMARY:

QUERY PARAMETER		ENTRIES	TUBES
LPI	Indication Code	0	0
MAI	Indication Code	4	2
MCI	Indication Code	0	0
MMI	Indication Code	0	0
MSI	Indication Code	0	0
MVI	Indication Code	0	0
SAI	Indication Code	4	2
SCI	Indication Code	0	0
SVI	Indication Code	0	0

TOTAL ENTRIES: 8

TOTAL TUBES: 4

RPC UBENDS ROWS 1-2 INDICATIONS

UTILITY: Baltimore Gas & Electric May 17,1999 11:58

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

****
* INSPECTION SUMMARY QUERY REPORT *
****

* Test Plans included in summary: 1 Total Test Plans in database: 13 *

Test Plan Name:	Probe Type:	Probe Size:	Leg:
1. 20% ROWS 1-2 UBENDS (G43-46)	MRPC	560PP	CL

****
* EIMS MAIN QUERY PARAMETERS *
****

ROW	ALL
LINE	ALL
VOLTS	ALL
DEGREES	ALL
PERCENT	NONE
LOCATION	ALL
ELEVATION	ALL
EXTENT	ALL
UTILITY1	ALL
UTILITY2	ALL
NAME	ALL
EVAL TYPE	ALL
CAL GROUP	ALL
PROBE	ALL
IND. CODES	LPI MAI MCI MMI MSI MVI SAI SCI SVI

CHANNELS ALL

*** There were no report entries returned by the current sort parameters! ***

RPC H/L STEAM BLANKET REGION INDICATIONS

UTILITY:	Baltimore Gas & Electric	May 17,1999 11:57
PLANT:	CCNPP	
UNIT:	2	
SG:	22	
DATABASE:	CCNPP_UNIT2_SG22_0399_Final	

****
* INSPECTION SUMMARY QUERY REPORT *
****

* Test Plans included in summary: 1 Total Test Plans in database: 13 *

	Test Plan Name:	Probe Type:	Probe Size:	Leg:
1.	100%STEAM BLANKET R6-15(G69-72)	MRPC	540PF	HL

****
* EIMS MAIN QUERY PARAMETERS *
****

ROW	ALL
LINE	ALL
VOLTS	ALL
DEGREES	ALL
PERCENT	NONE
LOCATION	ALL
ELEVATION	ALL
EXTENT	ALL
UTILITY1	ALL
UTILITY2	ALL
NAME	ALL
EVAL TYPE	ALL
CAL GROUP	ALL
PROBE	ALL
IND. CODES	LPI MAI MCI MMI MSI
	MVI SAI SCI SVI

CHANNELS ALL

RPC H/L STEAM BLANKET REGION INDICATIONS

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:57

	ROW	LIN	VOLTS	DEG	PCT	CHN		LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
1	10	130				SAI	1 VM	+0.00	05H06C	0.0		M1680	reso	22H00081	H 2	560PF
2			0.10	92		SAI	2 VM	+0.00	05H06C	0.2		M1680	reso	22H00081	H 2	560PF
3	9	147				SAI	1 VM	-2.94	06C05H	0		H2131	reso	22H00073	H 2	560PF
4			0.16	116		SAI	2 VM	-2.94	06C05H	0.4		H2131	reso	22H00073	H 2	560PF

QUERY REPORT SUMMARY:

QUERY PARAMETER		ENTRIES	TUBES
LPI	Indication Code	0	0
MAI	Indication Code	0	0
MCI	Indication Code	0	0
MMI	Indication Code	0	0
MSI	Indication Code	0	0
MVI	Indication Code	0	0
SAI	Indication Code	4	2
SCI	Indication Code	0	0
SVI	Indication Code	0	0

TOTAL ENTRIES: 4

TOTAL TUBES: 2

RPC C/L TTS INDICATIONS

UTILITY:	Baltimore Gas & Electric	May 17,1999 11:55
PLANT:	CCNPP	
UNIT:	2	
SG:	22	
DATABASE:	CCNPP_UNIT2_SG22_0399_Final	

****
* INSPECTION SUMMARY QUERY REPORT *
****

* Test Plans included in summary: 1 Total Test Plans in database: 13 *

Test Plan Name:	Probe Type:	Probe Size:	Leg:
1. TSC (G24-42)	MRPC	560PF	CL

****
* EIMS MAIN QUERY PARAMETERS *
****

ROW	ALL
LINE	ALL
VOLTS	ALL
DEGREES	ALL
PERCENT	NONE
LOCATION	ALL
ELEVATION	ALL
EXTENT	ALL
UTILITY1	ALL
UTILITY2	ALL
NAME	ALL
EVAL TYPE	ALL
CAL GROUP	ALL
PROBE	ALL
IND. CODES	LPI MAI MCI MMI MSI
	MVI SAI SCI SVI

CHANNELS ALL

RPC C/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:55

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE SIZE
1	1	1	0.25	99	SVI	2	TSC +0.00	TSCTSC	0.3		A9608	reso	22C00179	C	3	600PP
2			0.36	41	SVI	1	TSC +0.00	TSCTSC	0.2		A9608	reso	22C00179	C	3	600PP
3	89	29	0.23	97	SAI	2	TSC +4.22	TSCTSC	0.2		K7060	reso	22C00169	C	3	600PP
4					SAI	1	TSC +4.22	TSCTSC	0.0		K7060	reso	22C00169	C	3	600PP
5	137	67	0.16	65	SVI	2	TSC +0.07	TSCTSC	0.2		S7752	reso	22C00161	C	3	600PP
6					SVI	1	TSC +0.07	TSCTSC	0		S7752	reso	22C00161	C	3	600PP
7	136	68	0.25	102	SVI	2	TSC +0.06	TSCTSC	0.3		S7752	reso	22C00160	C	3	600PP
8			0.34	124	SVI	1	TSC +0.06	TSCTSC	0.3		S7752	reso	22C00160	C	3	600PP
9	138	68	0.17	62	SVI	2	TSC +0.10	TSCTSC	0.2		S7752	reso	22C00161	C	3	600PP
10					SVI	1	TSC +0.10	TSCTSC	0		S7752	reso	22C00161	C	3	600PP
11	128	78	0.18	66	SAI	2	TSC +0.22	TSCTSC	0.2		H2131	reso	22C00112	C	3	600PP
12			0.24	63	SAI	1	TSC +0.22	TSCTSC	0.3		H2131	reso	22C00112	C	3	600PP
13	133	81	0.47	90	MVI	P1	TSC +0.03	TSCTSC	0.5		B3720	reso	22C00081	C	3	600PP
14			0.38	137	MVI	1	TSC +0.03	TSCTSC	0.3		B3720	reso	22C00081	C	3	600PP
15	135	81	0.17	112	SVI	2	TSC +0.20	TSCTSC	0.3		C3340	reso	22C00080	C	3	600PP
16			0.21	40	SVI	1	TSC +0.20	TSCTSC	0.3		C3340	reso	22C00080	C	3	600PP
17	96	86	0.10	73	SAI	2	TSC +1.11	TSCTSC	0.2		S7752	reso	22C00074	C	3	600PP
18					SAI	1	TSC +1.11	TSCTSC	0		S7752	reso	22C00074	C	3	600PP
19	29	99	0.19	102	SCI	P1	TSC +0.04	TSCTSC	0.2		A9608	reso	22C00181	C	3	600PP
20					SCI	1	TSC +0.04	TSCTSC	0		A9608	reso	22C00181	C	3	600PP
21	29	101	0.10	119	SAI	2	TSC +0.15	TSCTSC	0.1		M1680	reso	22C00184	C	3	600PP
22					SAI	1	TSC +0.15	TSCTSC	0.0		M1680	reso	22C00184	C	3	600PP
23	2	124	0.59	72	LPI	2	TSC +0.15	TSCTSC			C3340	reso	22C00137	C	3	600PP
24	27	151	0.18	108	SVI	2	TSC +0.03	TSCTSC	0.3		C3340	reso	22C00066	C	3	600PP
25			0.23	93	SVI	1	TSC +0.03	TSCTSC	0.3		C3340	reso	22C00066	C	3	600PP
26	26	152	0.31	102	SVI	2	TSC +0.02	TSCTSC	0.3		B3720	reso	22C00127	C	3	600PP
27			0.43	129	SVI	1	TSC +0.02	TSCTSC	0.3		B3720	reso	22C00127	C	3	600PP
28	25	153	0.12	86	SVI	2	TSC -0.04	TSCTSC	0.2		B3720	reso	22C00126	C	3	600PP
29			0.07	47	SVI	1	TSC -0.04	TSCTSC	0.2		B3720	reso	22C00126	C	3	600PP
30	11	163	0.12	116	SVI	2	TSC +0.03	TSCTSC	0.3		A9608	reso	22C00128	C	3	600PP
31			0.17	29	SVI	1	TSC +0.03	TSCTSC	0.2		A9608	reso	22C00128	C	3	600PP

QUERY REPORT SUMMARY:

QUERY PARAMETER		ENTRIES	TUBES
LPI	Indication Code	1	1
MAI	Indication Code	0	0
MCI	Indication Code	0	0
MMI	Indication Code	0	0
MSI	Indication Code	0	0
MVI	Indication Code	2	1
SAI	Indication Code	8	4
SCI	Indication Code	2	1
SVI	Indication Code	18	9

TOTAL ENTRIES: 31

TOTAL TUBES: 16

RPC H/L TTS INDICATIONS

UTILITY:	Baltimore Gas & Electric	May 17,1999 11:53
PLANT:	CCNPP	
UNIT:	2	
SG:	22	
DATABASE:	CCNPP_UNIT2_SG22_0399_Final	

****
* INSPECTION SUMMARY QUERY REPORT *
****

* Test Plans included in summary: 1 Total Test Plans in database: 13 *

Test Plan Name:	Probe Type:	Probe Size:	Leg:
1. 100% TSH (G47-64,73)	MRPC	580PP	HL

****
* EIMS MAIN QUERY PARAMETERS *
****

ROW	ALL
LINE	ALL
VOLTS	ALL
DEGREES	ALL
PERCENT	NONE
LOCATION	ALL
ELEVATION	ALL
EXTENT	ALL
UTILITY1	ALL
UTILITY2	ALL
NAME	ALL
EVAL TYPE	ALL
CAL GROUP	ALL
PROBE	ALL
IND. CODES	LPI MAI MCI MMI MSI
	MVI SAI SCI SVI

CHANNELS ALL

RPC H/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric — May 17,1999 11:53

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final — PAGE 1

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
1	22	22			SCI	1 TSH	+0.17		TSHTSH	0		A9608	reso	22H00105	H 0	600PP
2			0.12	100	SCI	P1 TSH	+0.17		TSHTSH	0.2		A9608	reso	22H00105	H 0	600PP
3	21	23			SCI	1 TSH	+0.14		TSHTSH	0		S7752	reso	22H00104	H 0	600PP
4			0.23	114	SCI	P1 TSH	+0.14		TSHTSH	0.4		S7752	reso	22H00104	H 0	600PP
5			0.18	74	SAI	2 TSH	+0.55		TSHTSH	0.2		S7752	reso	22H00104	H 0	600PP
6					SAI	1 TSH	+0.55		TSHTSH	0		S7752	reso	22H00104	H 0	600PP
7	18	24			SCI	1 TSH	+0.10		TSHTSH	0.0		M1680	reso	22H00112	H 0	600PP
8			0.12	93	SCI	P1 TSH	+0.10		TSHTSH	0.2		M1680	reso	22H00112	H 0	600PP
9	24	24			SAI	1 TSH	+0.24		TSHTSH	0		S7752	reso	22H00104	H 0	600PP
10			0.13	87	SAI	2 TSH	+0.24		TSHTSH	0.2		S7752	reso	22H00104	H 0	600PP
11	19	25			SCI	1 TSH	+0.07		TSHTSH	0.0		K7060	reso	22H00111	H 0	600PP
12			0.15	100	SCI	P1 TSH	+0.07		TSHTSH	0.3		K7060	reso	22H00111	H 0	600PP
13	17	27	0.38	97	SCI	1 TSH	+0.13		TSHTSH	0.4		M1680	reso	22H00112	H 0	600PP
14			0.24	120	SCI	P1 TSH	+0.13		TSHTSH	0.7		M1680	reso	22H00112	H 0	600PP
15			0.16	101	SAI	2 TSH	+0.31		TSHTSH	0.3		M1680	reso	22H00112	H 0	600PP
16			0.18	117	SAI	1 TSH	+0.31		TSHTSH	0.5		M1680	reso	22H00112	H 0	600PP
17	31	27	0.20	109	MAI	2 TSH	+0.73		TSHTSH	0.3		B3720	reso	22H00107	H 0	600PP
18			0.33	127	MAI	1 TSH	+0.73		TSHTSH	0.2		S7752	reso	22H00107	H 0	600PP
19	22	28	0.11	37	SAI	1 TSH	+1.04		TSHTSH	0.4		K7060	reso	22H00108	H 0	600PP
20			0.11	118	SAI	2 TSH	+1.04		TSHTSH	0.3		K7060	reso	22H00108	H 0	600PP
	24	28			MAI	1 TSH	+0.85	TO+1.44	TSHTSH	0.0		B3720	reso	22H00107	H 0	600PP
			0.10	90	MAI	2 TSH	+0.85	TO+1.44	TSHTSH	0.2		B3720	reso	22H00107	H 0	600PP
23	42	28	0.27	88	SAI	1 TSH	+0.24		TSHTSH	0.5		K7060	reso	22H00108	H 0	600PP
24			0.32	85	SAI	2 TSH	+0.24		TSHTSH	0.4		K7060	reso	22H00108	H 0	600PP
25	18	30	0.20	50	MCI	1 TSH	+0.09		TSHTSH	0.3		M1680	reso	22H00112	H 0	600PP
26			0.21	118	MCI	P1 TSH	+0.09		TSHTSH	0.4		M1680	reso	22H00112	H 0	600PP
27	42	30			SAI	1 TSH	+0.14		TSHTSH	0.0		K7060	reso	22H00108	H 0	600PP
28			0.07	100	SAI	2 TSH	+0.14		TSHTSH	0.1		K7060	reso	22H00108	H 0	600PP
29	31	31			SAI	1 TSH	+1.36		TSHTSH	0.0		K7060	reso	22H00098	H 0	600PP
30			0.10	102	SAI	2 TSH	+1.36		TSHTSH	0.1		K7060	reso	22H00098	H 0	600PP
31	16	32			MAI	1 TSH	+0.48	TO+0.89	TSHTSH	0.0		K7060	reso	22H00097	H 0	600PP
32			0.11	116	MAI	2 TSH	+0.48	TO+0.89	TSHTSH	0.3		K7060	reso	22H00097	H 0	600PP
33	49	33			SAI	1 TSH	+0.23		TSHTSH	0.0		K7060	reso	22H00097	H 0	600PP
34			0.10	113	SAI	2 TSH	+0.23		TSHTSH	0.2		K7060	reso	22H00097	H 0	600PP
35	12	34			SAI	1 TSH	+1.25		TSHTSH	0.0		K7060	reso	22H00097	H 0	600PP
36			0.10	107	SAI	2 TSH	+1.25		TSHTSH	0.2		K7060	reso	22H00097	H 0	600PP
37	20	34			SAI	1 TSH	+0.69		TSHTSH	0.0		K7060	reso	22H00097	H 0	600PP
38			0.07	65	SAI	2 TSH	+0.69		TSHTSH	0.2		K7060	reso	22H00097	H 0	600PP
39	42	34			MAI	1 TSH	+0.64	TO+1.02	TSHTSH	0.0		K7060	reso	22H00098	H 0	600PP
40			0.14	93	MAI	2 TSH	+0.64	TO+1.02	TSHTSH	0.2		K7060	reso	22H00098	H 0	600PP
41	46	34			SAI	1 TSH	+0.67		TSHTSH	0		H2131	reso	22H00098	H 0	600PP
42			0.07	111	SAI	2 TSH	+0.67		TSHTSH	0.2		H2131	reso	22H00098	H 0	600PP
43	11	35			SAI	1 TSH	+0.49		TSHTSH	0.0		K7060	reso	22H00097	H 0	600PP
44			0.13	91	SAI	2 TSH	+0.49		TSHTSH	0.2		K7060	reso	22H00097	H 0	600PP
45	19	35			SAI	1 TSH	+0.64		TSHTSH	0.0		K7060	reso	22H00097	H 0	600PP
			0.12	97	SAI	2 TSH	+0.64		TSHTSH	0.2		K7060	reso	22H00097	H 0	600PP
	37	35	0.24	126	MAI	1 TSH	+0.84		TSHTSH	0.2		S7752	reso	22H00099	H 0	600PP
48			0.14	99	MAI	2 TSH	+0.84		TSHTSH	0.4		S7752	reso	22H00099	H 0	600PP
49	53	35			MCI	1 TSH	+0.10		TSHTSH	0		S7752	reso	22H00099	H 0	600PP

RPC H/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:53

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
50			0.29	54	MCI	P1	TSH	+0.10		TSHTSH	1.0		D3858	reso	22H00099	H 0 600PP
51	61	35			MAI	1	TSH	+0.05	TO+0.23	TSHTSH	0.0		K7060	reso	22H00098	H 0 600PP
52			0.17	101	MAI	2	TSH	+0.05	TO+0.23	TSHTSH	0.2		K7060	reso	22H00098	H 0 600PP
53	16	36	0.19	68	SAI	1	TSH	+2.06		TSHTSH	0.2		S7752	reso	22H00099	H 0 600PP
54			0.14	123	SAI	2	TSH	+2.06		TSHTSH	0.3		S7752	reso	22H00099	H 0 600PP
55	29	37			SAI	1	TSH	+1.47		TSHTSH	0		S7752	reso	22H00099	H 0 600PP
56			0.18	103	SAI	2	TSH	+1.47		TSHTSH	0.3		S7752	reso	22H00099	H 0 600PP
57	39	37			SAI	1	TSH	+0.60		TSHTSH	0		S7752	reso	22H00100	H 0 600PP
58			0.11	93	SAI	2	TSH	+0.60		TSHTSH	0.2		S7752	reso	22H00100	H 0 600PP
59	41	37			SAI	1	TSH	+0.70		TSHTSH	0		S7752	reso	22H00099	H 0 600PP
60			0.10	91	SAI	2	TSH	+0.70		TSHTSH	0.2		S7752	reso	22H00099	H 0 600PP
61	11	39	0.36	93	SAI	1	TSH	+0.56		TSHTSH	0.3		S7752	reso	22H00099	H 0 600PP
62			0.36	99	SAI	2	TSH	+0.56		TSHTSH	0.2		S7752	reso	22H00099	H 0 600PP
63	43	39	0.18	102	SAI	1	TSH	+0.65		TSHTSH	0.3		S7752	reso	22H00101	H 0 600PP
64			0.16	122	SAI	2	TSH	+0.65		TSHTSH	0.3		S7752	reso	22H00101	H 0 600PP
65	49	39			MAI	1	TSH	+0.53		TSHTSH	0		S7752	reso	22H00101	H 0 600PP
66			0.13	107	MAI	2	TSH	+0.53		TSHTSH	0.2		S7752	reso	22H00101	H 0 600PP
67	55	39			SAI	1	TSH	+0.20		TSHTSH	0		S7752	reso	22H00101	H 0 600PP
68			0.12	80	SAI	2	TSH	+0.20		TSHTSH	0.2		S7752	reso	22H00101	H 0 600PP
69	59	39			SAI	1	TSH	+0.50		TSHTSH	0		S7752	reso	22H00101	H 0 600PP
			0.17	105	SAI	2	TSH	+0.50		TSHTSH	0.2		S7752	reso	22H00101	H 0 600PP
[illegible]	61	39			MAI	1	TSH	+0.09	TO+0.18	TSHTSH	0.0		K7060	reso	22H00096	H 0 600PP
72			0.13	92	MAI	2	TSH	+0.09	TO+0.18	TSHTSH	0.1		K7060	reso	22H00096	H 0 600PP
73	48	40			SAI	1	TSH	+0.69		TSHTSH	0		S7752	reso	22H00101	H 0 600PP
74			0.12	116	SAI	2	TSH	+0.69		TSHTSH	0.2		S7752	reso	22H00101	H 0 600PP
75	52	40			SAI	1	TSH	+0.80		TSHTSH	0		S7752	reso	22H00099	H 0 600PP
76			0.18	77	SAI	2	TSH	+0.80		TSHTSH	0.2		S7752	reso	22H00099	H 0 600PP
77	19	41			SAI	1	TSH	+2.88		TSHTSH	0		S7752	reso	22H00099	H 0 600PP
78			0.17	116	SAI	2	TSH	+2.88		TSHTSH	0.2		S7752	reso	22H00099	H 0 600PP
79	25	41	0.17	87	SAI	1	TSH	+0.62		TSHTSH	0.3		S7752	reso	22H00101	H 0 600PP
80			0.14	92	SAI	2	TSH	+0.62		TSHTSH	0.2		S7752	reso	22H00101	H 0 600PP
81	49	41			SAI	1	TSH	+0.85		TSHTSH	0		S7752	reso	22H00101	H 0 600PP
82			0.10	82	SAI	2	TSH	+0.85		TSHTSH	0.2		S7752	reso	22H00101	H 0 600PP
83	24	42	0.16	43	SAI	1	TSH	+0.24		TSHTSH	0.3		S7752	reso	22H00099	H 0 600PP
84			0.20	79	SAI	2	TSH	+0.24		TSHTSH	0.3		S7752	reso	22H00099	H 0 600PP
85	28	42			MSI	1	TSH	+0.12	TO+1.03	TSHTSH	0		S7752	reso	22H00099	H 0 600PP
86			0.18	95	MSI	2	TSH	+0.12	TO+1.03	TSHTSH	0.2		S7752	reso	22H00099	H 0 600PP
87	30	42	0.16	75	SAI	1	TSH	+0.47		TSHTSH	0.2		S7752	reso	22H00101	H 0 600PP
88			0.12	123	SAI	2	TSH	+0.47		TSHTSH	0.3		S7752	reso	22H00101	H 0 600PP
89	15	43	0.30	56	SAI	1	TSH	+2.33		TSHTSH	0.2		S7752	reso	22H00099	H 0 600PP
90			0.22	76	SAI	2	TSH	+2.33		TSHTSH	0.2		S7752	reso	22H00099	H 0 600PP
91	17	43			SAI	1	TSH	+2.15		TSHTSH	0		S7752	reso	22H00101	H 0 600PP
92			0.11	96	SAI	2	TSH	+2.15		TSHTSH	0.2		S7752	reso	22H00101	H 0 600PP
93					SAI	1	TSH	+3.26		TSHTSH	0		S7752	reso	22H00101	H 0 600PP
94			0.14	103	SAI	2	TSH	+3.26		TSHTSH	0.2		S7752	reso	22H00101	H 0 600PP
[illegible]	23	43	0.32	50	SAI	1	TSH	+0.21		TSHTSH	0.3		S7752	reso	22H00101	H 0 600PP
[illegible]			0.21	86	SAI	2	TSH	+0.21		TSHTSH	0.2		S7752	reso	22H00101	H 0 600PP
97			0.22	104	SAI	2	TSH	+3.06		TSHTSH	0.3		S7752	reso	22H00101	H 0 600PP
98			0.35	119	SAI	1	TSH	+3.06		TSHTSH	0.3		S7752	reso	22H00101	H 0 600PP

RPC H/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:53

	ROW	LIN	VOLTS	DEG	PCT	CHN		LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
99			0.09	121	SAI	2	TSH	+3.66		TSHTSH	0.2		S7752	reso	22H00101	H 0	600PP
100					SAI	1	TSH	+3.66		TSHTSH	0		S7752	reso	22H00101	H 0	600PP
101	31	43	0.19	61	SAI	1	TSH	+0.77		TSHTSH	0.3		S7752	reso	22H00101	H 0	600PP
102			0.11	81	SAI	2	TSH	+0.77		TSHTSH	0.3		S7752	reso	22H00101	H 0	600PP
103	69	43			SAI	1	TSH	+0.20		TSHTSH	0.0		K7060	reso	22H00095	H 0	600PP
104			0.09	111	SAI	2	TSH	+0.20		TSHTSH	0.2		K7060	reso	22H00095	H 0	600PP
105			0.13	105	SAI	2	TSH	+2.18		TSHTSH	0.4		K7060	reso	22H00095	H 0	600PP
106					SAI	1	TSH	+2.18		TSHTSH	0.0		K7060	reso	22H00095	H 0	600PP
107	79	43			SAI	1	TSH	+0.12		TSHTSH	0.0		K7060	reso	22H00095	H 0	600PP
108			0.26	110	SAI	2	TSH	+0.12		TSHTSH	0.2		K7060	reso	22H00095	H 0	600PP
109	62	44			MAI	1	TSH	+0.15	TO+0.78	TSHTSH	0.0		K7060	reso	22H00096	H 0	600PP
110			0.13	122	MAI	2	TSH	+0.15	TO+0.78	TSHTSH	0.2		K7060	reso	22H00096	H 0	600PP
111	68	44			SAI	1	TSH	+0.40		TSHTSH	0.0		K7060	reso	22H00095	H 0	600PP
112			0.11	114	SAI	2	TSH	+0.40		TSHTSH	0.3		K7060	reso	22H00095	H 0	600PP
113	29	45			MAI	1	TSH	+0.48		TSHTSH	0		S7752	reso	22H00099	H 0	600PP
114			0.21	90	MAI	2	TSH	+0.48		TSHTSH	0.2		S7752	reso	22H00099	H 0	600PP
115	53	45			MAI	1	TSH	+0.54		TSHTSH	0		S7752	reso	22H00099	H 0	600PP
116			0.14	112	MAI	2	TSH	+0.54		TSHTSH	0.2		S7752	reso	22H00099	H 0	600PP
117	67	45			SAI	1	TSH	+0.42		TSHTSH	0.0		K7060	reso	22H00096	H 0	600PP
118			0.15	108	SAI	2	TSH	+0.42		TSHTSH	0.2		K7060	reso	22H00096	H 0	600PP
[illegible]	77	45			MCI	1	TSH	+0.05		TSHTSH	0.0		M1680	reso	22H00095	H 0	600PP
[illegible]			0.12	108	MCI	P1	TSH	+0.05		TSHTSH	1.4		D3858	reso	22H00095	H 0	600PP
121	90	46			SCI	1	TSH	+0.12		TSHTSH	0.0		K7060	reso	22H00096	H 0	600PP
122			0.16	86	SCI	P1	TSH	+0.12		TSHTSH	0.7		K7060	reso	22H00096	H 0	600PP
123	29	47			SAI	1	TSH	+0.51		TSHTSH	0		S7752	reso	22H00102	H 0	600PP
124			0.11	90	SAI	2	TSH	+0.51		TSHTSH	0.2		S7752	reso	22H00102	H 0	600PP
125	87	47	0.43	115	MCI	1	TSH	+0.06		TSHTSH	0.6		K7060	reso	22H00096	H 0	600PP
126			0.36	105	MCI	P1	TSH	+0.06		TSHTSH	0.6		K7060	reso	22H00096	H 0	600PP
127	89	47	0.56	32	MCI	1	TSH	+0.06		TSHTSH	1.0		H2131	reso	22H00095	H 0	600PP
128			0.37	94	MCI	P1	TSH	+0.06		TSHTSH	1.2		H2131	reso	22H00095	H 0	600PP
129	95	47	0.21	145	SCI	1	TSH	+0.04		TSHTSH	0.4		K7060	reso	22H00095	H 0	600PP
130			0.16	106	SCI	P1	TSH	+0.04		TSHTSH	0.6		K7060	reso	22H00095	H 0	600PP
131	29	49	0.51	59	SAI	1	TSH	+0.41		TSHTSH	0.3		S7752	reso	22H00004	H 0	600PP
132			0.14	94	SAI	2	TSH	+0.41		TSHTSH	0.3		S7752	reso	22H00004	H 0	600PP
133	22	50			SAI	1	TSH	+0.30		TSHTSH	0.0		A9608	reso	22H00004	H 0	600PP
134			0.09	86	SAI	2	TSH	+0.30		TSHTSH	0.2		S7752	reso	22H00004	H 0	600PP
135	86	50			SAI	1	TSH	+0.15		TSHTSH	0		S7752	reso	22H00043	H 0	600PP
136			0.17	109	SAI	2	TSH	+0.15		TSHTSH	0.2		S7752	reso	22H00043	H 0	600PP
137	90	50	0.20	68	SAI	1	TSH	+0.27		TSHTSH	0.3		S7752	reso	22H00042	H 0	600PP
138			0.19	98	SAI	2	TSH	+0.27		TSHTSH	0.3		S7752	reso	22H00042	H 0	600PP
139	25	51			SCI	1	TSH	+0.04		TSHTSH	0.0		A9608	reso	22H00004	H 0	600PP
140			0.19	100	SCI	P1	TSH	+0.04		TSHTSH	0.4		S7752	reso	22H00004	H 0	600PP
141	18	52			SAI	1	TSH	+2.96		TSHTSH	0		S7752	reso	22H00103	H 0	600PP
142			0.15	106	SAI	2	TSH	+2.96		TSHTSH	0.1		S7752	reso	22H00103	H 0	600PP
143	92	52			SCI	1	TSH	+0.11		TSHTSH	0		A9608	reso	22H00042	H 0	600PP
4			0.20	99	SCI	P1	TSH	+0.11		TSHTSH	0.5		A9608	reso	22H00042	H 0	600PP
5	9	53	0.89	97	SAI	1	TSH	+2.34		TSHTSH	0.7		S7752	reso	22H00103	H 0	600PP
146			0.84	101	SAI	2	TSH	+2.34		TSHTSH	0.7		S7752	reso	22H00103	H 0	600PP
147	29	53	0.35	90	SCI	1	TSH	+0.02		TSHTSH	0.4		S7752	reso	22H00004	H 0	600PP

RPC H/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:53

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
148			0.16	76	SCI	P1	TSH	+0.02		TSHTSH	0.3		S7752	reso	22H00004	H 0 600PP
149	88	54	0.23	93	SCI	1	TSH	+0.04		TSHTSH	0.4		S7752	reso	22H00044	H 0 600PP
150			0.20	72	SCI	P1	TSH	+0.04		TSHTSH	0.3		S7752	reso	22H00044	H 0 600PP
151	8	60			SAI	1	TSH	+2.07		TSHTSH	0		S7752	reso	22H00102	H 0 600PP
152			0.15	119	SAI	2	TSH	+2.07		TSHTSH	0.2		S7752	reso	22H00102	H 0 600PP
153	24	60	0.20	15	SCI	1	TSH	-0.44		TSHTSH	0.3	PWSCC	C3340	reso	22H00005	H 0 600PP
154			0.25	28	SCI	P1	TSH	-0.44		TSHTSH	0.2	PWSCC	C3340	reso	22H00005	H 0 600PP
155	35	61	0.11	7	SAI	1	TSH	-0.66		TSHTSH	0.3	PWSCC	C3340	reso	22H00005	H 0 600PP
156			0.21	20	SAI	2	TSH	-0.66		TSHTSH	0.2	PWSCC	C3340	reso	22H00005	H 0 600PP
157	34	68	0.20	38	MAI	1	TSH	+1.60		TSHTSH	0.4		C3340	reso	22H00008	H 0 600PP
158			0.25	73	MAI	2	TSH	+1.60		TSHTSH	0.4		C3340	reso	22H00008	H 0 600PP
159	63	69			MAI	1	TSH	+0.30	TO+0.88	TSHTSH	0.0		K7060	reso	22H00048	H 0 600PP
160			0.20	133	MAI	2	TSH	+0.30	TO+0.88	TSHTSH	0.2		K7060	reso	22H00048	H 0 600PP
161	41	71	0.28	89	MAI	1	TSH	+1.80	TO+3.22	TSHTSH	0.3		C3340	reso	22H00007	H 0 600PP
162			0.17	104	MAI	2	TSH	+1.80	TO+3.22	TSHTSH	0.2		C3340	reso	22H00007	H 0 600PP
163	85	71			SAI	1	TSH	+0.53		TSHTSH	0.0		K7060	reso	22H00051	H 0 600PP
164			0.10	107	SAI	2	TSH	+0.53		TSHTSH	0.3		K7060	reso	22H00051	H 0 600PP
165	84	72			SAI	1	TSH	+0.79		TSHTSH	0.0		K7060	reso	22H00051	H 0 600PP
166			0.15	88	SAI	2	TSH	+0.79		TSHTSH	0.2		K7060	reso	22H00051	H 0 600PP
167	84	74	0.41	104	SAI	1	TSH	+0.94		TSHTSH	0.4		T0042	reso	22H00037	H 0 600PP
[illegible]			0.21	111	SAI	2	TSH	+0.94		TSHTSH	0.4		T0042	reso	22H00037	H 0 600PP
	43	75			SAI	1	TSH	+2.57		TSHTSH	0.0		K7060	reso	22H00050	H 0 600PP
170			0.23	110	SAI	2	TSH	+2.57		TSHTSH	0.2		K7060	reso	22H00050	H 0 600PP
171	85	75			SAI	1	TSH	+0.59		TSHTSH	0.0		R6452	reso	22H00039	H 0 600PP
172			0.11	103	SAI	2	TSH	+0.59		TSHTSH	0.3		T0042	reso	22H00039	H 0 600PP
173	41	77	0.26	52	MAI	1	TSH	+1.37		TSHTSH	0.5		K7060	reso	22H00051	H 0 600PP
174			0.30	97	MAI	2	TSH	+1.37		TSHTSH	0.4		K7060	reso	22H00051	H 0 600PP
175	78	80	0.19	143	SAI	1	TSH	+1.49		TSHTSH	0.3		T0042	reso	22H00039	H 0 600PP
176			0.11	97	SAI	2	TSH	+1.49		TSHTSH	0.3		T0042	reso	22H00039	H 0 600PP
177	76	82			SAI	1	TSH	+1.33		TSHTSH	0		T0042	reso	22H00038	H 0 600PP
178			0.12	104	SAI	2	TSH	+1.33		TSHTSH	0.3		T0042	reso	22H00038	H 0 600PP
179	78	82			SAI	1	TSH	+1.93		TSHTSH	0.0		R6452	reso	22H00039	H 0 600PP
180			0.10	92	SAI	2	TSH	+1.93		TSHTSH	0.2		T0042	reso	22H00039	H 0 600PP
181	81	83	0.19	118	SAI	1	TSH	+0.98		TSHTSH	0.3		T0042	reso	22H00039	H 0 600PP
182			0.14	76	SAI	2	TSH	+0.98		TSHTSH	0.3		T0042	reso	22H00039	H 0 600PP
183	70	84	0.36	119	SAI	1	TSH	+1.86		TSHTSH	0.2		T0042	reso	22H00039	H 0 600PP
184			0.17	95	SAI	2	TSH	+1.86		TSHTSH	0.3		T0042	reso	22H00039	H 0 600PP
185			0.11	131	SAI	2	TSH	+2.55		TSHTSH	0.2		T0042	reso	22H00039	H 0 600PP
186					SAI	1	TSH	+2.55		TSHTSH	0.0		R6452	reso	22H00039	H 0 600PP
187	79	85			SAI	1	TSH	+0.79		TSHTSH	0		T0042	reso	22H00040	H 0 600PP
188			0.12	89	SAI	2	TSH	+0.79		TSHTSH	0.4		T0042	reso	22H00040	H 0 600PP
189	42	86			SAI	1	TSH	+0.95		TSHTSH	0.0		K7060	reso	22H00051	H 0 600PP
190			0.15	119	SAI	2	TSH	+0.95		TSHTSH	0.3		K7060	reso	22H00051	H 0 600PP
191	84	86			MAI	1	TSH	+0.48	TO+1.06	TSHTSH	0		T0042	reso	22H00040	H 0 600PP
192			0.13	92	MAI	2	TSH	+0.48	TO+1.06	TSHTSH	0.4		T0042	reso	22H00040	H 0 600PP
[illegible]	90	86	0.18	96	SAI	1	TSH	+0.65		TSHTSH	0.2		T0042	reso	22H00041	H 0 600PP
[illegible]			0.21	92	SAI	2	TSH	+0.65		TSHTSH	0.2		T0042	reso	22H00041	H 0 600PP
195	69	87	0.32	80	SAI	1	TSH	+2.25		TSHTSH	0.5		T0042	reso	22H00041	H 0 600PP
196			0.19	91	SAI	2	TSH	+2.25		TSHTSH	0.5		T0042	reso	22H00041	H 0 600PP

RPC H/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:53

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
197	83	87	0.24	43	MAI	1 TSH	+0.55	TO+1.07	TSHTSH	0.4		T0042	reso	22H00040	H 0	600PP
198			0.18	101	MAI	2 TSH	+0.55	TO+1.07	TSHTSH	0.4		T0042	reso	22H00040	H 0	600PP
199	87	87	0.40	81	SAI	1 TSH	+0.94		TSHTSH	0.4		T0042	reso	22H00040	H 0	600PP
200			0.29	100	SAI	2 TSH	+0.94		TSHTSH	0.4		T0042	reso	22H00040	H 0	600PP
201	81	89			SAI	1 TSH	+1.48		TSHTSH	0		T0042	reso	22H00040	H 0	600PP
202			0.13	71	SAI	2 TSH	+1.48		TSHTSH	0.2		T0042	reso	22H00040	H 0	600PP
203	80	90	0.33	39	SAI	1 TSH	+1.36		TSHTSH	0.6		R6452	reso	22H00040	H 0	600PP
204			0.16	113	SAI	2 TSH	+1.36		TSHTSH	0.4		R6452	reso	22H00040	H 0	600PP
205	88	90	0.29	64	SAI	1 TSH	+0.65		TSHTSH	0.3		T0042	reso	22H00041	H 0	600PP
206			0.32	100	SAI	2 TSH	+0.65		TSHTSH	0.4		T0042	reso	22H00041	H 0	600PP
207	42	92	0.14	16	SAI	2 TSH	-1.29		TSHTSH	0.2	PWSCC	M1680	reso	22H00051	H 0	600PP
208			0.17	14	SAI	1 TSH	-1.29		TSHTSH	0.2	PWSCC	H2131	reso	22H00051	H 0	600PP
209	62	92			SAI	1 TSH	+4.25		TSHTSH	0		S7752	reso	22H00043	H 0	600PP
210			0.09	124	SAI	2 TSH	+4.25		TSHTSH	0.2		S7752	reso	22H00043	H 0	600PP
211	80	92			MAI	1 TSH	+0.77	TO+1.74	TSHTSH	0		A9608	reso	22H00042	H 0	600PP
212			0.20	104	MAI	2 TSH	+0.77	TO+1.74	TSHTSH	0.2		A9608	reso	22H00042	H 0	600PP
213	80	94	0.62	63	MSI	1 TSH	+0.50	TO+1.71	TSHTSH	0.4		S7752	reso	22H00042	H 0	600PP
214			0.38	84	MSI	2 TSH	+0.50	TO+1.71	TSHTSH	0.7		S7752	reso	22H00042	H 0	600PP
215	78	96			SAI	1 TSH	+1.06		TSHTSH	0		A9608	reso	22H00042	H 0	600PP
216			0.12	120	SAI	2 TSH	+1.06		TSHTSH	0.2		S7752	reso	22H00042	H 0	600PP
7	80	96			SAI	1 TSH	+1.04		TSHTSH	0		A9608	reso	22H00042	H 0	600PP
.			0.14	96	SAI	2 TSH	+1.04		TSHTSH	0.2		S7752	reso	22H00042	H 0	600PP
219			0.13	88	SAI	2 TSH	+1.48		TSHTSH	0.3		S7752	reso	22H00042	H 0	600PP
220					SAI	1 TSH	+1.48		TSHTSH	0		A9608	reso	22H00042	H 0	600PP
221	79	97			SAI	1 TSH	+0.73		TSHTSH	0		T0042	reso	22H00037	H 0	600PP
222			0.17	60	SAI	2 TSH	+0.73		TSHTSH	0.3		T0042	reso	22H00037	H 0	600PP
223			0.15	63	SAI	2 TSH	+1.16		TSHTSH	0.4		T0042	reso	22H00037	H 0	600PP
224			0.36	99	SAI	1 TSH	+1.16		TSHTSH	0.3		T0042	reso	22H00037	H 0	600PP
225	79	99			SAI	1 TSH	+0.91		TSHTSH	0		C3340	reso	22H00035	H 0	600PP
226			0.12	76	SAI	2 TSH	+0.91		TSHTSH	0.2		C3340	reso	22H00035	H 0	600PP
227	54	102	0.20	29	MAI	1 TSH	+0.13	TO+0.52	TSHTSH	0.2		B3720	reso	22H00176	H 0	600PP
228			0.16	81	MAI	2 TSH	+0.13	TO+0.52	TSHTSH	0.2		B3720	reso	22H00176	H 0	600PP
229	56	102			MAI	1 TSH	+0.36	TO+0.94	TSHTSH	0.0		B3720	reso	22H00175	H 0	600PP
230			0.23	99	MAI	2 TSH	+0.36	TO+0.94	TSHTSH	0.5		B3720	reso	22H00175	H 0	600PP
231	48	104			MAI	1 TSH	+0.36	TO+1.00	TSHTSH	0.0		B3720	reso	22H00175	H 0	600PP
232			0.13	114	MAI	2 TSH	+0.36	TO+1.00	TSHTSH	0.3		B3720	reso	22H00175	H 0	600PP
233	54	104	0.28	37	MAI	1 TSH	+0.07	TO+1.04	TSHTSH	0.2		B3720	reso	22H00176	H 0	600PP
234			0.14	118	MAI	2 TSH	+0.07	TO+1.04	TSHTSH	0.3		B3720	reso	22H00176	H 0	600PP
235	60	104			MAI	1 TSH	+0.17	TO+0.53	TSHTSH	0.0		B3720	reso	22H00175	H 0	600PP
236			0.14	136	MAI	2 TSH	+0.17	TO+0.53	TSHTSH	0.3		B3720	reso	22H00175	H 0	600PP
237	36	106	0.72	26	SAI	2 TSH	-2.64		TSHTSH	0.2	PWSCC	B3720	reso	22H00177	H 0	600PP
238			0.52	14	SAI	1 TSH	-2.62		TSHTSH	0.3	PWSCC	B3720	reso	22H00177	H 0	600PP
239	49	107	0.53	78	SAI	1 TSH	+0.24		TSHTSH	0.5		M1680	reso	22H00176	H 0	600PP
240			0.36	77	SAI	2 TSH	+0.24		TSHTSH	0.4		M1680	reso	22H00176	H 0	600PP
241	65	107			SAI	1 TSH	+0.78		TSHTSH	0		C3340	reso	22H00034	H 0	600PP
42			0.12	117	SAI	2 TSH	+0.78		TSHTSH	0.2		C3340	reso	22H00034	H 0	600PP
3	50	108	0.33	109	SAI	1 TSH	+0.66		TSHTSH	0.3		B3720	reso	22H00176	H 0	600PP
244			0.25	97	SAI	2 TSH	+0.66		TSHTSH	0.4		B3720	reso	22H00176	H 0	600PP
245	93	109	0.49	54	MAI	1 TSH	+2.48		TSHTSH	0.6		C3340	reso	22H00034	H 0	600PP

RPC H/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric — May 17,1999 11:53

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final — PAGE 6

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
246			0.27	97	MAI	2	TSH	+2.48		TSHTSH	0.5		C3340	reso	22H00034	H 0 600PP
247	42	110			MAI	1	TSH	+0.34	TO+0.90	TSHTSH	0.0		B3720	reso	22H00176	H 0 600PP
248			0.19	101	MAI	2	TSH	+0.34	TO+0.90	TSHTSH	0.2		B3720	reso	22H00176	H 0 600PP
249	46	110			SAI	1	TSH	+0.60		TSHTSH	0.0		B3720	reso	22H00176	H 0 600PP
250			0.21	109	SAI	2	TSH	+0.60		TSHTSH	0.2		B3720	reso	22H00176	H 0 600PP
251	48	110	0.10	29	MAI	1	TSH	+0.10	TO+0.92	TSHTSH	0.2		B3720	reso	22H00175	H 0 600PP
252			0.19	99	MAI	2	TSH	+0.10	TO+0.92	TSHTSH	0.3		B3720	reso	22H00175	H 0 600PP
253	29	111			MAI	1	TSH	+0.10	TO+0.60	TSHTSH	0.0		B3720	reso	22H00176	H 0 600PP
254			0.13	110	MAI	2	TSH	+0.10	TO+0.60	TSHTSH	0.3		B3720	reso	22H00176	H 0 600PP
255	31	111	0.22	96	MAI	1	TSH	+0.08	TO+0.68	TSHTSH	0.3		B3720	reso	22H00175	H 0 600PP
256			0.19	93	MAI	2	TSH	+0.08	TO+0.68	TSHTSH	0.3		B3720	reso	22H00175	H 0 600PP
257	39	111	0.43	36	MAI	1	TSH	+0.30	TO+0.96	TSHTSH	0.3		B3720	reso	22H00175	H 0 600PP
258			0.30	107	MAI	2	TSH	+0.30	TO+0.96	TSHTSH	0.3		B3720	reso	22H00175	H 0 600PP
259	45	111			SAI	1	TSH	+0.87		TSHTSH	0.0		B3720	reso	22H00176	H 0 600PP
260			0.13	100	SAI	2	TSH	+0.87		TSHTSH	0.2		B3720	reso	22H00176	H 0 600PP
261	42	112	0.51	63	MAI	1	TSH	+0.27	TO+0.91	TSHTSH	0.5		B3720	reso	22H00176	H 0 600PP
262			0.28	92	MAI	2	TSH	+0.27	TO+0.91	TSHTSH	0.5		B3720	reso	22H00176	H 0 600PP
263	31	113	0.21	74	SAI	1	TSH	+0.22		TSHTSH	0.2		B3720	reso	22H00175	H 0 600PP
264			0.20	86	SAI	2	TSH	+0.22		TSHTSH	0.3		B3720	reso	22H00175	H 0 600PP
265	35	113			MAI	1	TSH	+0.09	TO+0.56	TSHTSH	0.0		B3720	reso	22H00178	H 0 600PP
[illegible]			0.17	90	MAI	2	TSH	+0.09	TO+0.56	TSHTSH	0.2		B3720	reso	22H00178	H 0 600PP
[illegible]	43	113			MAI	1	TSH	+1.07	TO+2.27	TSHTSH	0.0		B3720	reso	22H00178	H 0 600PP
268			0.11	81	MAI	2	TSH	+1.07	TO+2.27	TSHTSH	0.3		B3720	reso	22H00178	H 0 600PP
269	36	114			MAI	1	TSH	+0.45	TO+1.14	TSHTSH	0.0		B3720	reso	22H00177	H 0 600PP
270			0.13	70	MAI	2	TSH	+0.45	TO+1.14	TSHTSH	0.2		B3720	reso	22H00177	H 0 600PP
271	56	114			SAI	1	TSH	+0.91		TSHTSH	0.0		M1680	reso	22H00177	H 0 600PP
272			0.11	135	SAI	2	TSH	+0.91		TSHTSH	0.2		M1680	reso	22H00177	H 0 600PP
273	86	116	0.13	107	SAI	2	TSH	+0.24		TSHTSH	0.2		C3340	reso	22H00032	H 0 600PP
274					SAI	1	TSH	+0.24		TSHTSH	0		H2131	reso	22H00032	H 0 600PP
275	81	119			MCI	1	TSH	+0.05		TSHTSH	0		T0042	reso	22H00031	H 0 600PP
276			0.09	107	MCI	P1	TSH	+0.05		TSHTSH	0.3		D3858	reso	22H00031	H 0 600PP
277	85	119			SAI	1	TSH	+0.25		TSHTSH	0		C3340	reso	22H00032	H 0 600PP
278			0.12	117	SAI	2	TSH	+0.25		TSHTSH	0.2		C3340	reso	22H00032	H 0 600PP
279	91	119	0.23	40	SAI	1	TSH	+0.23		TSHTSH	0.3		T0042	reso	22H00031	H 0 600PP
280			0.41	92	SAI	2	TSH	+0.23		TSHTSH	0.2		T0042	reso	22H00031	H 0 600PP
281	14	120	0.22	47	MAI	1	TSH	+1.70		TSHTSH	0.3		C3340	reso	22H00030	H 0 600PP
282			0.15	111	MAI	2	TSH	+1.70		TSHTSH	0.6		C3340	reso	22H00030	H 0 600PP
283	81	121			SCI	1	TSH	+0.22		TSHTSH	0		T0042	reso	22H00031	H 0 600PP
284			0.12	46	SCI	P1	TSH	+0.22		TSHTSH	0.2		T0042	reso	22H00031	H 0 600PP
285	87	121	0.70	55	SCI	1	TSH	+0.17		TSHTSH	0.5		T0042	reso	22H00031	H 0 600PP
286			0.29	79	SCI	P1	TSH	+0.17		TSHTSH	0.3		T0042	reso	22H00031	H 0 600PP
287	89	121	0.15	60	SCI	1	TSH	+0.14		TSHTSH	0.2		C3340	reso	22H00032	H 0 600PP
288			0.24	82	SCI	P1	TSH	+0.14		TSHTSH	0.4		C3340	reso	22H00032	H 0 600PP
289	77	123			SCI	1	TSH	+0.10		TSHTSH	0.0		K7060	reso	22H00054	H 0 600PP
290			0.13	94	SCI	P1	TSH	+0.10		TSHTSH	0.3		K7060	reso	22H00054	H 0 600PP
[illegible]	68	124	0.17	62	SAI	1	TSH	+0.29		TSHTSH	0.2		R6452	reso	22H00021	H 0 600PP
[illegible]			0.14	117	SAI	2	TSH	+0.29		TSHTSH	0.3		R6452	reso	22H00021	H 0 600PP
293	76	124			SCI	1	TSH	+0.10		TSHTSH	0.0		R6452	reso	22H00021	H 0 600PP
294			0.22	85	SCI	P1	TSH	+0.10		TSHTSH	0.6		R6452	reso	22H00021	H 0 600PP

RPC H/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric — May 17,1999 11:53

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final — PAGE 7

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG	PROBE SIZE
295	73	125			SCI	1	TSH +0.12		TSHTSH	0.0		R6452	reso	22H00022	H 0	600PP
296			0.22	93	SCI	P1	TSH +0.12		TSHTSH	0.5		R6452	reso	22H00022	H 0	600PP
297			0.20	84	MAI	2	TSH +0.57	TO+1.55	TSHTSH	0.4		M1680	reso	22H00022	H 0	600PP
298					MAI	1	TSH +0.57	TO+1.55	TSHTSH	0.0		M1680	reso	22H00022	H 0	600PP
299	78	126			SAI	1	TSH +0.33		TSHTSH	0.0		A9608	reso	22H00021	H 0	600PP
300			0.11	70	SAI	2	TSH +0.33		TSHTSH	0.2		A9608	reso	22H00021	H 0	600PP
301	75	127	0.13	153	MCI	1	TSH +0.13		TSHTSH	0.3		C3340	reso	22H00024	H 0	600PP
302			0.25	100	MCI	P1	TSH +0.13		TSHTSH	0.4		H2131	reso	22H00024	H 0	600PP
303	76	128	0.63	128	SCI	1	TSH +0.06		TSHTSH	0.5		K7060	reso	22H00023	H 0	600PP
304			0.36	106	SCI	P1	TSH +0.06		TSHTSH	0.5		K7060	reso	22H00023	H 0	600PP
305	23	129			SAI	1	TSH +0.58		TSHTSH	0.0		M1680	reso	22H00027	H 0	600PP
306			0.12	102	SAI	2	TSH +0.58		TSHTSH	0.2		M1680	reso	22H00027	H 0	600PP
307	65	129			MCI	1	TSH +0.06		TSHTSH	0.0		K7060	reso	22H00023	H 0	600PP
308			0.11	88	MCI	P1	TSH +0.06		TSHTSH	0.3		K7060	reso	22H00023	H 0	600PP
309	75	129	0.23	146	MCI	1	TSH +0.11		TSHTSH	0.5		C3340	reso	22H00024	H 0	600PP
310			0.18	104	MCI	P1	TSH +0.11		TSHTSH	0.4		C3340	reso	22H00024	H 0	600PP
311	25	131	0.28	96	MAI	1	TSH +0.54	TO+1.36	TSHTSH	0.5		A9608	reso	22H00028	H 0	600PP
312			0.38	101	MAI	2	TSH +0.54	TO+1.36	TSHTSH	0.6		A9608	reso	22H00028	H 0	600PP
313			0.31	107	SAI	2	TSH +5.08		TSHTSH	0.5		S7752	reso	22H00028	H 0	600PP
314			0.41	107	SAI	1	TSH +5.08		TSHTSH	0.4		S7752	reso	22H00028	H 0	600PP
[illegible]			0.08	133	SAI	2	TSH +5.47		TSHTSH	0.3		S7752	reso	22H00028	H 0	600PP
					SAI	1	TSH +5.47		TSHTSH	0.0		S7752	reso	22H00028	H 0	600PP
317	35	131			SAI	1	TSH +1.23		TSHTSH	0.0		M1680	reso	22H00027	H 0	600PP
318			0.16	92	SAI	2	TSH +1.23		TSHTSH	0.2		M1680	reso	22H00027	H 0	600PP
319	37	131			SAI	1	TSH +0.15		TSHTSH	0		A9608	reso	22H00028	H 0	600PP
320			0.15	97	SAI	2	TSH +0.15		TSHTSH	0.2		S7752	reso	22H00028	H 0	600PP
321	47	131	0.15	110	MAI	1	TSH +0.11	TO+0.47	TSHTSH	0.2		M1680	reso	22H00027	H 0	600PP
322			0.15	86	MAI	2	TSH +0.11	TO+0.47	TSHTSH	0.3		M1680	reso	22H00027	H 0	600PP
323	22	132	0.14	24	MAI	1	TSH +0.39	TO+1.15	TSHTSH	0.4		A9608	reso	22H00028	H 0	600PP
324			0.16	103	MAI	2	TSH +0.39	TO+1.15	TSHTSH	0.5		A9608	reso	22H00028	H 0	600PP
325	24	132			MAI	1	TSH +0.87		TSHTSH	0.0		M1680	reso	22H00027	H 0	600PP
326			0.13	102	MAI	2	TSH +0.87		TSHTSH	0.2		M1680	reso	22H00027	H 0	600PP
327	36	132	0.19	59	MAI	1	TSH +0.68		TSHTSH	0.2		M1680	reso	22H00027	H 0	600PP
328			0.22	89	MAI	2	TSH +0.68		TSHTSH	0.3		M1680	reso	22H00027	H 0	600PP
329	37	133			MAI	1	TSH +0.69		TSHTSH	0		A9608	reso	22H00028	H 0	600PP
330			0.13	98	MAI	2	TSH +0.69		TSHTSH	0.2		S7752	reso	22H00028	H 0	600PP
331	39	133	0.40	76	MAI	1	TSH +0.67		TSHTSH	0.6		M1680	reso	22H00027	H 0	600PP
332			0.20	99	MAI	2	TSH +0.67		TSHTSH	0.7		M1680	reso	22H00027	H 0	600PP
333	12	134	0.23	90	SAI	1	TSH +0.73		TSHTSH	0.3		S7752	reso	22H00028	H 0	600PP
334			0.20	113	SAI	2	TSH +0.73		TSHTSH	0.4		S7752	reso	22H00028	H 0	600PP
335	18	134			SAI	1	TSH +0.54		TSHTSH	0.0		M1680	reso	22H00027	H 0	600PP
336			0.12	105	SAI	2	TSH +0.54		TSHTSH	0.3		M1680	reso	22H00027	H 0	600PP
337	24	134			MAI	1	TSH +1.43		TSHTSH	0.0		M1680	reso	22H00027	H 0	600PP
338			0.12	89	MAI	2	TSH +1.43		TSHTSH	0.2		M1680	reso	22H00027	H 0	600PP
339	38	134	0.12	44	SAI	1	TSH +0.52		TSHTSH	0.2		S7752	reso	22H00028	H 0	600PP
[illegible]			0.13	124	SAI	2	TSH +0.52		TSHTSH	0.4		S7752	reso	22H00028	H 0	600PP
[illegible]	42	134	0.31	42	SAI	1	TSH +0.15		TSHTSH	0.3		S7752	reso	22H00028	H 0	600PP
342			0.32	83	SAI	2	TSH +0.15		TSHTSH	0.3		S7752	reso	22H00028	H 0	600PP
343	102	134	0.09	70	SCI	1	TSH +0.00		TSHTSH	0.2		C3340	reso	22H00026	H 0	600PP

RPC H/L TTS INDICATIONS

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:53

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE SIZE
344			0.15	115	SCI	P1	TSH	+0.00		TSHTSH	0.2		C3340	reso	22H00026	H 0	600PP
345	13	135			SAI	1	TSH	+1.24		TSHTSH	0		A9608	reso	22H00028	H 0	600PP
346			0.11	111	SAI	2	TSH	+1.24		TSHTSH	0.1		S7752	reso	22H00028	H 0	600PP
347	23	135			MAI	1	TSH	+0.90	TO+1.72	TSHTSH	0.0		M1680	reso	22H00027	H 0	600PP
348			0.18	96	MAI	2	TSH	+0.90	TO+1.72	TSHTSH	0.3		M1680	reso	22H00027	H 0	600PP
349	31	135			SAI	1	TSH	+1.44		TSHTSH	0.0		K7060	reso	22H00054	H 0	600PP
350			0.20	116	SAI	2	TSH	+1.44		TSHTSH	0.2		K7060	reso	22H00054	H 0	600PP
351	39	135	0.22	101	SAI	1	TSH	+0.69		TSHTSH	0.4		S7752	reso	22H00028	H 0	600PP
352			0.20	108	SAI	2	TSH	+0.69		TSHTSH	0.4		S7752	reso	22H00028	H 0	600PP
353	45	135	0.64	58	MCI	1	TSH	+0.18		TSHTSH	0.4		S7752	reso	22H00028	H 0	600PP
354			0.19	97	MCI	P1	TSH	+0.18		TSHTSH	0.4		S7752	reso	22H00028	H 0	600PP
355	24	136	0.35	55	MAI	1	TSH	+0.64	TO+1.45	TSHTSH	0.2		A9608	reso	22H00028	H 0	600PP
356			0.24	110	MAI	2	TSH	+0.64	TO+1.45	TSHTSH	0.3		A9608	reso	22H00028	H 0	600PP
357	28	136	0.28	73	MAI	1	TSH	+1.08		TSHTSH	0.6		S7752	reso	22H00028	H 0	600PP
358			0.29	108	MAI	2	TSH	+1.08		TSHTSH	0.7		S7752	reso	22H00028	H 0	600PP
359	40	136			SAI	1	TSH	+0.13		TSHTSH	0.0		K7060	reso	22H00054	H 0	600PP
360			0.08	136	SAI	2	TSH	+0.13		TSHTSH	0.2		K7060	reso	22H00054	H 0	600PP
361					MAI	1	TSH	+0.51		TSHTSH	0.0		K7060	reso	22H00054	H 0	600PP
362			0.19	97	MAI	2	TSH	+0.51		TSHTSH	0.3		K7060	reso	22H00054	H 0	600PP
363	56	136			SAI	1	TSH	+0.72		TSHTSH	0.0		M1680	reso	22H00027	H 0	600PP
			0.12	98	SAI	2	TSH	+0.72		TSHTSH	0.2		M1680	reso	22H00027	H 0	600PP
[illegible]	21	137	0.42	55	SAI	1	TSH	+0.79		TSHTSH	0.3		S7752	reso	22H00028	H 0	600PP
366			0.15	73	SAI	2	TSH	+0.79		TSHTSH	0.4		S7752	reso	22H00028	H 0	600PP
367	27	137	0.33	90	MAI	1	TSH	+0.78		TSHTSH	0.4		S7752	reso	22H00028	H 0	600PP
368			0.28	108	MAI	2	TSH	+0.78		TSHTSH	0.5		S7752	reso	22H00028	H 0	600PP
369	31	137			MAI	1	TSH	+0.92		TSHTSH	0		A9608	reso	22H00028	H 0	600PP
370			0.22	89	MAI	2	TSH	+0.92		TSHTSH	0.3		S7752	reso	22H00028	H 0	600PP
371	37	137			MAI	1	TSH	+0.45		TSHTSH	0		A9608	reso	22H00028	H 0	600PP
372			0.16	96	MAI	2	TSH	+0.45		TSHTSH	0.2		S7752	reso	22H00028	H 0	600PP
373	39	137	0.25	75	SAI	1	TSH	+0.44		TSHTSH	0.4		M1680	reso	22H00027	H 0	600PP
374			0.25	100	SAI	2	TSH	+0.44		TSHTSH	0.4		M1680	reso	22H00027	H 0	600PP
375	16	138	0.11	111	SAI	2	TSH	+0.16		TSHTSH	0.2		C3340	reso	22H00011	H 0	600PP
376					SAI	1	TSH	+0.16		TSHTSH	0		H2131	reso	22H00011	H 0	600PP
377			0.18	104	SAI	2	TSH	+0.54		TSHTSH	0.4		C3340	reso	22H00011	H 0	600PP
378			0.10	51	SAI	1	TSH	+0.54		TSHTSH	0.2		C3340	reso	22H00011	H 0	600PP
379			0.07	127	SAI	1	TSH	+2.99		TSHTSH	0.2		C3340	reso	22H00011	H 0	600PP
380			0.18	105	SAI	2	TSH	+2.99		TSHTSH	0.3		C3340	reso	22H00011	H 0	600PP
381	28	138	0.05	92	MAI	1	TSH	+0.44	TO+1.33	TSHTSH	0.2		A9608	reso	22H00019	H 0	600PP
382			0.17	91	MAI	2	TSH	+0.44	TO+1.33	TSHTSH	0.2		A9608	reso	22H00019	H 0	600PP
383	19	139	0.22	85	SAI	1	TSH	+0.58		TSHTSH	0.2		C3340	reso	22H00011	H 0	600PP
384			0.20	74	SAI	2	TSH	+0.58		TSHTSH	0.2		C3340	reso	22H00011	H 0	600PP
385	27	139	0.18	103	SAI	2	TSH	+0.94		TSHTSH	0.2		A9608	reso	22H00019	H 0	600PP
386					SAI	1	TSH	+0.94		TSHTSH	0.0		H2131	reso	22H00019	H 0	600PP
387	35	139			SAI	1	TSH	+0.35		TSHTSH	0.0		R6452	reso	22H00020	H 0	600PP
388			0.16	110	SAI	2	TSH	+0.35		TSHTSH	0.3		R6452	reso	22H00020	H 0	600PP
9			0.12	115	SAI	2	TSH	+0.61		TSHTSH	0.2		R6452	reso	22H00020	H 0	600PP
J					SAI	1	TSH	+0.61		TSHTSH	0.0		R6452	reso	22H00020	H 0	600PP
391	15	141	0.11	95	SAI	2	TSH	+1.86		TSHTSH	0.2		C3340	reso	22H00011	H 0	600PP
392					SAI	1	TSH	+1.86		TSHTSH	0		H2131	reso	22H00011	H 0	600PP

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG	PROBE	SIZE

QUERY REPORT SUMMARY:

QUERY PARAMETER		ENTRIES	TUBES
LPI	Indication Code	0	0
MAI	Indication Code	102	51
MCI	Indication Code	20	10
MMI	Indication Code	0	0
MSI	Indication Code	4	2
MVI	Indication Code	0	0
SAI	Indication Code	226	102
SCI	Indication Code	40	20
SVI	Indication Code	0	0

TOTAL ENTRIES: 392
TOTAL TUBES: 180

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

May 17,1999 11:46

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

****
* INSPECTION SUMMARY QUERY REPORT *
****

* All Test Plans in the database are included in summary: 13 *

Test Plan Name:	Probe Type:	Probe Size:	Leg:
1. 100% TSH (G47-64,73)	MRPC	580PP	HL
2. ROWS 6-140 F/L (G1-19)	BOBBIN	560SF	CL
3. ROWS 1-5 STRAIGHTS (G65-68)	BOBBIN	600UL	HL
4. ROWS 1-5 CANDY CANE (G20-23)	BOBBIN	560SF	CL
5. HL Prev DNT/DNG=>5Volt (G74-92)	MRPC	600PP	HL
6. TSC (G24-42)	MRPC	560PF	CL
7. 20% ROWS 1-2 UBENDS (G43-46)	MRPC	560PP	CL
8. 100%STEAM BLANKET R6-15(G69-72)	MRPC	540PF	HL
9. CL Prev DNT/DNG=>5Volt (G93-111	MRPC	600PP	CL
10. HL Bobbin SI (TEH-VM+0.00)	MRPC	600PP	HL
11. CL Bobbin SI (VM+0.01-TEC)	MRPC	600PP	CL
12. HL "NEW" DNT/DNG=>5V (G154-172)	MRPC	600PP	HL
13. CL "NEW" DNG/DNT=>5V (G173-191)	MRPC	560PF	CL

****
* EIMS MAIN QUERY PARAMETERS *
****

ROW	ALL				
LINE	ALL				
VOLTS	ALL				
DEGREES	ALL				
PERCENT	0 to 100				
LOCATION	ALL				
ELEVATION	ALL				
EXTENT	ALL				
UTILITY1	ALL				
UTILITY2	ALL				
NAME	ALL				
EVAL TYPE	ALL				
CAL GROUP	ALL				
PROBE	ALL				
IND. CODES	ADR	BLG	CUD	DEP	DNI
	DRI	DSI	DTI	ETL	EXP
	FSA	FSD	IDC	IDM	INF
	INR	LDE	LPI	MAI	MBM
	MCI	MMI	MSI	MVI	NDF
	NQI	NRC	NRH	NSY	OBS
	PBC	PID	PLP	PPS	PRC
	PSP	PTS	PVN	SAI	SCI
	SVI	UDE	VOL	WAR	
CHANNELS	ALL				

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 11:46

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final — PAGE 1

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
1	1	1	0.25	99	SVI	2 TSC	+0.00	TSCTSC	0.3		A9608	reso	22C00179	C 3
2			0.36	41	SVI	1 TSC	+0.00	TSCTSC	0.2		A9608	reso	22C00179	C 3
3			0.18	109	PID	4 TSC	+0.00	TSCTSC			J6276	rpri	22C00189	C99
4	7	1	0.31	102	16	P2 01H	-1.05	TECTEH			L2157	rpri	22H00116	C 0
5					NDF	01H	-1.05	01H01H			L7871	rpri	22H00183	H 4
6	15	1	0.15	93	WAR	P4 06H	-0.16	06C05H			S7752	reso	22H00158	H 2
7			0.17	66	WAR	P4 06H	+0.87	06C05H			S7752	reso	22H00158	H 2
8	1	3			OBS	06H	+9.20	06H06H			L6066	rsec	22H00146	C 4
9	7	3			OBS	05H	+8.96	05H05H			A9608	reso	22H00154	H 2
10					OBS	VM	-5.33	06CVM			A9608	reso	22H00154	H 2
11	15	3	0.42	80	MBM	5 01C	+3.93	TECTEH			K7060	reso	22H00116	C 0
12			0.74	80	MBM	5 TSC	+11.70	TECTEH			K7060	reso	22H00116	C 0
13	4	4			OBS	06C	+0.00	06CTEC			B1055	rpri	22C00162	C 1
14	24	4	0.47	78	MBM	5 05H	+29.24	TECTEH			K7060	reso	22H00116	C 0
15	1	5			OBS	06C	+0.00	06CTEC			B1055	rpri	22C00162	C 1
16	27	5			INF	TSC	+0.26	TSCTSC	HR		B3720	reso	22C00178	C 3
17	16	6	0.12	69	PLP	9 TSH	+0.17	TSHTSH			M1680	reso	22H00113	H 0
18	22	6	0.23	72	PLP	10 TSH	+0.45	TSHTSH			K7060	reso	22H00108	H 0
19	30	6	0.67	84	MBM	5 04C	+13.94	TECTEH			A9608	reso	22H00118	C 0
20			0.82	83	MBM	5 03C	+6.57	TECTEH			A9608	reso	22H00118	C 0
[illegible]			0.36	60	MBM	5 03C	+18.87	TECTEH			A9608	reso	22H00118	C 0
[illegible]			0.37	88	MBM	6 03C	+20.76	TECTEH			A9608	reso	22H00118	C 0
23			0.16	83	MBM	5 03C	+22.56	TECTEH			A9608	reso	22H00118	C 0
24			0.38	74	MBM	5 03C	+26.49	TECTEH			A9608	reso	22H00118	C 0
25			0.24	76	MBM	5 03C	+31.38	TECTEH			A9608	reso	22H00118	C 0
26			0.40	62	MBM	5 02C	+35.38	TECTEH			A9608	reso	22H00118	C 0
27	42	6	0.47	118	MBM	6 06H	+9.36	TECTEH			A9608	reso	22H00118	C 0
28			5.34	8	PVN	P1 02C	+8.41	TECTEH			L2157	rpri	22H00118	C 0
29	1	7			OBS	06C	+0.00	06CTEC			B1055	rpri	22C00162	C 1
30	5	7	0.77	85	MBM	5 05H	+13.90	06HTEH			A9608	reso	22H00141	H 1
31	7	7			OBS	VM	-5.89	06CVM			A9608	reso	22H00155	H 2
32					OBS	VM	-5.29	06CVM			W4892	rpri	22H00156	H 2
33	25	7	0.56	72	MBM	5 01C	+8.33	TECTEH			A9608	reso	22H00117	C 0
34	39	7	0.20	70	MBM	5 01H	+7.85	TECTEH			A9608	reso	22H00118	C 0
35			0.41	87	MBM	5 DH	+8.08	TECTEH			A9608	reso	22H00118	C 0
36	27	9	0.31	87	MBM	5 05H	+33.78	TECTEH			A9608	reso	22H00117	C 0
37	39	9	0.68	69	MBM	5 03H	+23.44	TECTEH			A9608	reso	22H00117	C 0
38			0.57	92	MBM	6 05C	+7.71	TECTEH			A9608	reso	22H00117	C 0
39			0.45	62	MBM	6 05C	+9.20	TECTEH			A9608	reso	22H00117	C 0
40			0.88	81	MBM	6 05C	+36.71	TECTEH			A9608	reso	22H00117	C 0
41	14	10	0.24	79	DSI	P1 01H	-1.06	TECTEH			M9715	rsec	22H00117	C 0
42					NDF	01H	-1.06	01H01H			A9608	reso	22H00183	H 4
43	38	10	0.54	83	PLP	9 TSH	+1.44	TSHTSH			L6066	rsec	22H00107	H 0
44			0.65	102	PLP	8 TSH	+1.64	TECTEH			S9098	rpri	22H00117	C 0
45	42	10	0.79	92	MBM	6 TSC	+30.49	TECTEH			A9608	reso	22H00117	C 0
46	1	11			OBS	06C	+0.00	06CTEC			B1055	rpri	22C00162	C 1
	7	11	0.57	91	MBM	5 04H	+18.32	TECTEH			A9608	reso	22H00118	C 0
48	39	11	0.59	91	PLP	9 TSH	+1.20	TSHTSH			L6066	rsec	22H00107	H 0
49	43	11	0.44	83	MBM	6 02C	+15.27	TECTEH			A9608	reso	22H00118	C 0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:46

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
50	6	12			OBS	TEH	+0.00	TEHTEH			L2157	rpri	22H00114	H 0
51	52	12	0.50	83	MBM	5 04H	+9.56	TECTEH			A9608	reso	22H00117	C 0
52			0.59	69	MBM	6 06H	+15.83	TECTEH			A9608	reso	22H00117	C 0
53	56	12	0.51	79	PLP	9 TSH	+0.29	TSHTSH			L6066	rsec	22H00109	H 0
54	66	12	0.35	132	DSI	P1 02C	+0.97	TECTEH			S1848	rpri	22H00118	C 0
55			0.17	109	WAR	P4 02C	+0.98	02C02C			J6276	rpri	22C00194	C 5
56	1	13	0.65		PLP	9 TSC	+0.49	TSCTSC			O1057	rpri	22C00176	C 3
57	39	13	0.68	75	MBM	5 VM	+6.91	TECTEH			A9608	reso	22H00118	C 0
58			0.28	80	MBM	5 TSC	+28.62	TECTEH			A9608	reso	22H00118	C 0
59	2	14	1.15	62	MBM	6 05H	+27.88	06HTEH			A9608	reso	22H00142	H 1
60	6	14	0.08	98	INR	P1 TSC	+2.52	TECTEH			M1680	reso	22H00133	C 0
61	24	14	0.77	83	MBM	5 TSC	+12.68	TECTEH			R6452	reso	22H00119	C 0
62	26	14	0.39	85	MBM	6 03H	+27.51	TECTEH			H2131	reso	22H00120	C 0
63	30	14	0.51	64	MBM	5 05C	+20.30	TECTEH			K7060	reso	22H00134	C 0
64	1	15			OBS	06C	+0.00	06CTEC			B1055	rpri	22C00162	C 1
65	15	15	0.18	75	WAR	P4 VM	+0.00	06C05H			J6276	rpri	22H00153	H 2
66	27	15	0.97	66	MBM	6 04H	+25.08	TECTEH			H2131	reso	22H00120	C 0
67	57	15	0.67	86	MBM	5 04C	+9.59	TECTEH			R6452	reso	22H00119	C 0
68	77	15	0.67	86	MBM	6 01H	+21.34	TECTEH			R6452	reso	22H00119	C 0
69	42	16	0.66	69	MBM	5 06C	+11.81	TECTEH			H2131	reso	22H00120	C 0
[illegible]	70	16	0.69	87	MBM	5 03C	+31.91	TECTEH			H2131	reso	22H00120	C 0
71	65	17	0.41	89	MBM	5 04C	+8.38	TECTEH			R6452	reso	22H00119	C 0
72			0.71	69	MBM	5 03C	+17.61	TECTEH			B3720	reso	22H00119	C 0
73			0.90	75	MBM	5 03C	+29.45	TECTEH			R6452	reso	22H00119	C 0
74	69	17	0.24	85	MBM	6 02C	+27.01	TECTEH			R6452	reso	22H00119	C 0
75	6	18	0.31	76	MBM	5 TSC	+11.15	TECTEH			H2131	reso	22H00120	C 0
76	46	18	0.72	79	MBM	5 03H	+16.93	TECTEH			H2131	reso	22H00120	C 0
77	54	18			OBS	TSC	-21.13	TSCTEH			H2131	reso	22H00120	C 0
78					OBS	TSC	-19.77	TSCTEH			M1680	reso	22H00133	C 0
79					OBS	TEC	+0.00	TECTEC			O1057	rpri	22C00176	C 3
80	68	18	0.51	91	MBM	5 05H	+7.52	TECTEH			R6452	reso	22H00119	C 0
81			0.86	87	MBM	6 01C	+26.29	TECTEH			R6452	reso	22H00119	C 0
82			0.29	75	MBM	6 01C	+31.58	TECTEH			R6452	reso	22H00119	C 0
83	1	19			OBS	06C	+0.00	06CTEC			B1055	rpri	22C00162	C 1
84	25	19	0.57	72	MBM	5 02C	+27.54	TECTEH			R6452	reso	22H00119	C 0
85	1	21			OBS	06C	+0.00	06CTEC			B1055	rpri	22C00162	C 1
86	89	21	1.04	69	MBM	5 08C	+22.04	TECTEH			H2131	reso	22H00122	C 0
87	91	21	0.38	78	MBM	5 08H	+18.10	TECTEH			H2131	reso	22H00122	C 0
88	2	22	0.38	97	MBM	5 04C	+15.73	06HTEC			A9608	reso	22C00162	C 1
89			0.84	79	MBM	5 04C	+22.38	06HTEC			A9608	reso	22C00162	C 1
90			0.60	86	MBM	5 04C	+28.77	06HTEC			A9608	reso	22C00162	C 1
91	4	22	0.89	102	MBM	5 02C	+24.11	06HTEC			A9608	reso	22C00162	C 1
92	20	22	0.43	65	MBM	5 02C	+6.05	TECTEH			H2131	reso	22H00122	C 0
93	22	22	0.12	100	SCI	P1 TSH	+0.17	TSHTSH	0.2		A9608	reso	22H00105	H 0
94					SCI	1 TSH	+0.17	TSHTSH	0		A9608	reso	22H00105	H 0
95			0.37	79	PID	P1 TSH	+0.17	TSHTSH			B1055	rpri	22H00172	H99
	60	22	6.34	12	PVN	P1 03C	+4.64	TECTEH			R4201	rpri	22H00122	C 0
[illegible]	92	22	3.92	210	NRC	2 TSC	+0.00	TECTEH			R4201	rpri	22H00122	C 0
98	1	23			OBS	06C	+0.00	06CTEC			B1055	rpri	22C00162	C 1

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 11:46

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final — PAGE 3

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
99	21	23	0.23	114	SCI	P1 TSH	+0.14	TSHTSH	0.4		S7752	reso	22H00104	H 0
100					SCI	1 TSH	+0.14	TSHTSH	0		S7752	reso	22H00104	H 0
101			0.21	153	PID	P1 TSH	+0.14	TSHTSH			F7467	rsec	22H00172	H99
102					SAI	1 TSH	+0.55	TSHTSH	0		S7752	reso	22H00104	H 0
103			0.18	74	SAI	2 TSH	+0.55	TSHTSH	0.2		S7752	reso	22H00104	H 0
104	75	23	0.50	93	WAR	P4 DC	-0.57	DC 08C			J6276	rpri	22C00194	C 5
105			0.68	121	28	P2 DC	-0.52	TECTEH			D3858	reso	22H00124	C 0
106			0.35	88	WAR	P4 DC	-0.26	DC 08C			J6276	rpri	22C00194	C 5
107					INF	DC	+0.31	DC 08C	HR		R6452	reso	22C00194	C 5
108					INF	DC	+1.64	TECTEH	HR		R6452	reso	22H00124	C 0
109					INF	DC	+1.76	DC 08C	HR		R6452	reso	22C00194	C 5
110	8	24	0.58	73	MBM	6 TSH	+24.36	TECTEH			A9608	reso	22H00126	C 0
111	18	24			SCI	1 TSH	+0.10	TSHTSH	0.0		M1680	reso	22H00112	H 0
112			0.12	93	SCI	P1 TSH	+0.10	TSHTSH	0.2		M1680	reso	22H00112	H 0
113			0.10	100	PID	P1 TSH	+0.10	TSHTSH			B1055	rpri	22H00172	H99
114	24	24	0.13	87	SAI	2 TSH	+0.24	TSHTSH	0.2		S7752	reso	22H00104	H 0
115					SAI	1 TSH	+0.24	TSHTSH	0		S7752	reso	22H00104	H 0
116			0.12	106	PID	4 TSH	+0.24	TSHTSH			B1055	rpri	22H00172	H99
117	26	24	1.55	72	MBM	5 VM	+2.45	TECTEH			A9608	reso	22H00126	C 0
118	84	24	3.15	83	MBM	6 VH	+21.00	TECTEH			H2131	reso	22H00122	C 0
[illegible]	13	25	0.45	76	DSI	P1 03H	-0.83	TECTEH			R4201	rpri	22H00125	C 0
[illegible]					NDF	03H	-0.83	03H03H			A9608	reso	22H00183	H 4
121	19	25	0.15	100	SCI	P1 TSH	+0.07	TSHTSH	0.3		K7060	reso	22H00111	H 0
122					SCI	1 TSH	+0.07	TSHTSH	0.0		K7060	reso	22H00111	H 0
123			0.11	103	PID	P1 TSH	+0.07	TSHTSH			B1055	rpri	22H00172	H99
124	27	25	0.68	79	MBM	6 05C	+14.95	TECTEH			A9608	reso	22H00126	C 0
125	53	25	0.53	86	DSI	P1 01H	+0.68	TECTEH			S0607	rsec	22H00125	C 0
126					NDF	01H	+0.68	01H01H			A9608	reso	22H00183	H 4
127	69	25	0.79	82	MBM	5 06H	+20.93	TECTEH			A9608	reso	22H00125	C 0
128	83	25	0.64	81	MBM	5 03H	+10.36	TECTEH			A9608	reso	22H00126	C 0
129	12	26	0.57	48	DSI	P1 02H	+0.09	TECTEH			S1848	rpri	22H00128	C 0
130			0.59	37	SAI	3 02H	+0.29	02H02H	0.4		A9608	reso	22H00183	H 4
131			0.44	109	SAI	4 02H	+0.29	02H02H	0.4		A9608	reso	22H00183	H 4
132			0.38	111	PID	4 02H	+0.29	02H02H			K2858	rpri	22H00189	H99
133	66	26	0.56	78	MBM	5 04H	+11.08	TECTEH			H2131	reso	22H00128	C 0
134	92	26	0.37	83	18	P2 VH	+1.25	TECTEH			R4201	rpri	22H00125	C 0
135			0.32	94	WAR	P4 VH	+1.25	VH VH			A9608	reso	22H00184	H 4
136	96	26	1.62	84	MBM	6 02C	+7.46	TECTEH			A9608	reso	22H00125	C 0
137	1	27			OBS	06C	+0.00	06CTEC			B1055	rpri	22C00162	C 1
138	17	27	0.24	120	SCI	P1 TSH	+0.13	TSHTSH	0.7		M1680	reso	22H00112	H 0
139			0.38	97	SCI	1 TSH	+0.13	TSHTSH	0.4		M1680	reso	22H00112	H 0
140			0.25	130	PID	P1 TSH	+0.13	TSHTSH			B1055	rpri	22H00172	H99
141			0.18	117	SAI	1 TSH	+0.31	TSHTSH	0.5		M1680	reso	22H00112	H 0
142			0.16	101	SAI	2 TSH	+0.31	TSHTSH	0.3		M1680	reso	22H00112	H 0
143	27	27	0.49	83	MBM	5 05H	+12.63	TECTEH			A9608	reso	22H00127	C 0
144	31	27	0.20	109	MAI	2 TSH	+0.73	TSHTSH	0.3		B3720	reso	22H00107	H 0
			0.33	127	MAI	1 TSH	+0.73	TSHTSH	0.2		S7752	reso	22H00107	H 0
146			0.16	93	PID	4 TSH	+0.73	TSHTSH			B1055	rpri	22H00172	H99
147			1.79	87	MBM	5 04C	+19.58	TECTEH			M1680	reso	22H00133	C 0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:46

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
148	39	27	1.11	81	MBM	5	04C	+37.23	TECTEH			A9608	reso	22H00127	C 0
149	77	27	0.73	78	MBM	5	01H	+25.91	TECTEH			A9608	reso	22H00127	C 0
150	97	27	0.15	83	INR	P1	09C	+0.00	TECTEH			A9608	reso	22H00127	C 0
151	22	28	0.11	118	SAI	2	TSH	+1.04	TSHTSH	0.3		K7060	reso	22H00108	H 0
152			0.11	37	SAI	1	TSH	+1.04	TSHTSH	0.4		K7060	reso	22H00108	H 0
153			0.11	85	PID	4	TSH	+1.04	TSHTSH			B1055	rpri	22H00172	H99
154	24	28	0.10	90	MAI	2	TSH	+0.85 TO+1.44	TSHTSH	0.2		B3720	reso	22H00107	H 0
155					MAI	1	TSH	+0.85 TO+1.44	TSHTSH	0.0		B3720	reso	22H00107	H 0
156			0.10	113	PID	4	TSH	+0.85 TO+1.44	TSHTSH			B1055	rpri	22H00172	H99
157	42	28	0.32	85	SAI	2	TSH	+0.24	TSHTSH	0.4		K7060	reso	22H00108	H 0
158			0.27	88	SAI	1	TSH	+0.24	TSHTSH	0.5		K7060	reso	22H00108	H 0
159			0.17	120	PID	4	TSH	+0.24	TSHTSH			B1055	rpri	22H00172	H99
160	1	29			OBS		06C	+0.00	06CTEC			A9608	reso	22C00162	C 1
161	15	29	0.78	81	MBM	5	02C	+30.61	TECTEH			A9608	reso	22H00127	C 0
162	89	29	0.23	97	SAI	2	TSC	+4.22	TSCTSC	0.2		K7060	reso	22C00169	C 3
163					SAI	1	TSC	+4.22	TSCTSC	0.0		K7060	reso	22C00169	C 3
164			0.20	103	PID	4	TSC	+4.22	TSCTSC			J6276	rpri	22C00189	C99
165	91	29	0.43	92	21	P2	VH	-0.97	TECTEH			H2131	reso	22H00128	C 0
166			0.40	79	WAR	P4	VH	-0.97	VH VH			A9608	reso	22H00184	H 4
167	18	30	0.21	118	MCI	P1	TSH	+0.09	TSHTSH	0.4		M1680	reso	22H00112	H 0
[illegible]			0.20	50	MCI	1	TSH	+0.09	TSHTSH	0.3		M1680	reso	22H00112	H 0
[illegible]			0.25	130	PID	P1	TSH	+0.09	TSHTSH			B1055	rpri	22H00172	H99
170	42	30	0.07	100	SAI	2	TSH	+0.14	TSHTSH	0.1		K7060	reso	22H00108	H 0
171					SAI	1	TSH	+0.14	TSHTSH	0.0		K7060	reso	22H00108	H 0
172			0.06	113	PID	4	TSH	+0.14	TSHTSH			B1055	rpri	22H00172	H99
173	52	30	0.93	124	INR	5	TSH	+13.86	TECTEH			M2655	rsec	22H00128	C 0
174			0.40	85	MBM	5	04C	+7.89	TECTEH			H2131	reso	22H00128	C 0
175	58	30	1.73	89	MBM	5	07H	+27.80	TECTEH			A9608	reso	22H00127	C 0
176			0.05	90	INR	P2	DH	-1.93	TECTEH			B3720	reso	22H00127	C 0
177	62	30	0.46	74	MBM	5	TSH	+33.77	TECTEH			A9608	reso	22H00127	C 0
178	100	30	0.99	82	MBM	6	04H	+36.84	TECTEH			H2131	reso	22H00128	C 0
179			0.68	74	MBM	5	TSC	+13.22	TECTEH			H2131	reso	22H00128	C 0
180	102	30	0.61	75	MBM	5	06H	+5.10	TECTEH			A9608	reso	22H00127	C 0
181	104	30	0.63	82	MBM	5	02C	+34.22	TECTEH			H2131	reso	22H00128	C 0
182	1	31	0.14	66	PLP	9	TSH	+0.15	TSHTSH			C5184	rsec	22H00098	H 0
183	13	31	2.24	88	MBM	6	05C	+4.86	TECTEH			C3340	reso	22H00130	C 0
184	31	31	0.10	102	SAI	2	TSH	+1.36	TSHTSH	0.1		K7060	reso	22H00098	H 0
185					SAI	1	TSH	+1.36	TSHTSH	0.0		K7060	reso	22H00098	H 0
186			0.09	134	PID	4	TSH	+1.36	TSHTSH			B1055	rpri	22H00172	H99
187	57	31	0.60	72	MBM	5	04C	+14.59	TEHTEC			R6452	reso	22C00111	C 0
188	83	31	1.94	84	MBM	5	01H	+19.05	TEHTEC			R6452	reso	22C00110	C 0
189			0.62	65	MBM	5	03H	+17.04	TEHTEC			R6452	reso	22C00110	C 0
190	95	31	0.25	94	NQI	P1	05H	+2.76	TEHTEC			N2222	rsec	22C00110	C 0
191					NDF		05H	+2.76	05H06H			A9608	reso	22H00183	H 4
192	2	32			OBS		05C	+28.47	05CTEC			A9608	reso	22C00162	C 1
193					PSP		TSC	+0.00	05CTEC			R6452	reso	22C00162	C 1
					PID		TSC	+0.00	TSCTEC			A9608	reso	22C00197	C99
195	16	32	0.11	116	MAI	2	TSH	+0.48 TO+0.89	TSHTSH	0.3		K7060	reso	22H00097	H 0
196					MAI	1	TSH	+0.48 TO+0.89	TSHTSH	0.0		K7060	reso	22H00097	H 0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 11:46

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final — PAGE 5

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG
197			0.09	140	PID	4 TSH	+0.48	TO+0.89	TSHTSH			B1055	rpri	22H00172	H99	
198	30	32	1.37	79	MBM	6 01C	+13.43		TEHTEC			R6452	reso	22C00111	C 0	
199	52	32	0.49	72	MBM	5 03H	+15.77		TEHTEC			R6452	reso	22C00110	C 0	
200			0.65	111	INR	5 03H	+25.37		TEHTEC			L2157	rpri	22C00110	C 0	
201			1.09	65	MBM	6 01C	+34.55		TEHTEC			R6452	reso	22C00110	C 0	
202			0.93	70	MBM	6 TSC	+26.28		TEHTEC			R6452	reso	22C00110	C 0	
203	92	32			INF	DH	+0.00		TEHTEC	HR		T0042	reso	22C00110	C 0	
204			0.18	58	9	P2 VH	+0.16		TEHTEC			L2157	rpri	22C00110	C 0	
205			0.17	75	WAR	P4 VH	+0.16		VH VH			A9608	reso	22H00184	H 4	
206	1	33	0.92	75	MBM	5 TSH	+33.89		06HTEH			A9608	reso	22H00142	H 1	
207					OBS	06C	+0.00		06CTEC			B1055	rpri	22C00162	C 1	
208	9	33	3.39	146	INR	6 VM	-3.33	TO-1.42	TECTEH			R4201	rpri	22H00129	C 0	
209	39	33	0.61	79	MBM	5 02C	+18.18		TEHTEC			R6452	reso	22C00110	C 0	
210	49	33	0.10	113	SAI	2 TSH	+0.23		TSHTSH	0.2		K7060	reso	22H00097	H 0	
211					SAI	1 TSH	+0.23		TSHTSH	0.0		K7060	reso	22H00097	H 0	
212			0.11	92	PID	4 TSH	+0.23		TSHTSH			B1055	rpri	22H00172	H99	
213	57	33	0.52	126	INR	5 TSH	+5.76		TEHTEC			L2157	rpri	22C00110	C 0	
214	73	33	0.48	70	MBM	6 02C	+6.75		TEHTEC			R6452	reso	22C00110	C 0	
215	97	33	2.67	94	INR	6 04H	+5.87		TEHTEC			R6452	reso	22C00110	C 0	
216	101	33	0.24	99	WAR	P4 VH	+1.12		VH VH			A9608	reso	22H00184	H 4	
[illegible]			0.38		16	P2 VH	+1.18		TEHTEC			T0042	reso	22C00110	C 0	
[illegible]	103	33	0.74	94	INR	6 03H	+28.79		TEHTEC			S9098	rpri	22C00111	C 0	
219	12	34			SAI	1 TSH	+1.25		TSHTSH	0.0		K7060	reso	22H00097	H 0	
220			0.10	107	SAI	2 TSH	+1.25		TSHTSH	0.2		K7060	reso	22H00097	H 0	
221			0.10	75	PID	4 TSH	+1.25		TSHTSH			B1055	rpri	22H00172	H99	
222	20	34	0.07	65	SAI	2 TSH	+0.69		TSHTSH	0.2		K7060	reso	22H00097	H 0	
223					SAI	1 TSH	+0.69		TSHTSH	0.0		K7060	reso	22H00097	H 0	
224			0.05	67	PID	4 TSH	+0.69		TSHTSH			B1055	rpri	22H00172	H99	
225	38	34			OBS	06C	+14.36		06CTEC			R6452	reso	22C00111	C 0	
226	42	34	0.14	93	MAI	2 TSH	+0.64	TO+1.02	TSHTSH	0.2		K7060	reso	22H00098	H 0	
227					MAI	1 TSH	+0.64	TO+1.02	TSHTSH	0.0		K7060	reso	22H00098	H 0	
228			0.11	109	PID	4 TSH	+0.64	TO+1.02	TSHTSH			B1055	rpri	22H00172	H99	
229	44	34	0.82	63	MBM	6 05H	+32.84		TEHTEC			R6452	reso	22C00110	C 0	
230	46	34	0.07	111	SAI	2 TSH	+0.67		TSHTSH	0.2		H2131	reso	22H00098	H 0	
231					SAI	1 TSH	+0.67		TSHTSH	0		H2131	reso	22H00098	H 0	
232			0.07	109	PID	4 TSH	+0.67		TSHTSH			B1055	rpri	22H00172	H99	
233	52	34	0.52	67	MBM	5 03H	+27.18		TEHTEC			R6452	reso	22C00110	C 0	
234			1.01	69	MBM	5 02C	+31.51		TEHTEC			R6452	reso	22C00110	C 0	
235	90	34	0.58	81	MBM	5 04H	+17.71		TEHTEC			R6452	reso	22C00111	C 0	
236			1.27	88	MBM	5 05H	+34.95		TEHTEC			R6452	reso	22C00111	C 0	
237	92	34	0.19	99	WAR	P4 VC	-0.97		VC VC			J6276	rpri	22C00194	C 5	
238			0.31	80	DSI	P1 VC	-0.70		TEHTEC			R6452	reso	22C00110	C 0	
239			0.20	89	WAR	P4 VC	-0.60		VC VC			J6276	rpri	22C00194	C 5	
240					INF	VC	+0.73		VC VC	HR		R6452	reso	22C00194	C 5	
241					INF	VC	+1.09		VC VC	HR		R6452	reso	22C00194	C 5	
242	100	34	0.23		9	P2 VH	-0.11		TEHTEC			H3333	rsec	22C00110	C 0	
			0.19	88	WAR	P4 VH	-0.11		VH VH			A9608	reso	22H00184	H 4	
244	112	34	0.60	65	MBM	5 03H	+27.89		TEHTEC			R6452	reso	22C00110	C 0	
245	11	35			SAI	1 TSH	+0.49		TSHTSH	0.0		K7060	reso	22H00097	H 0	

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:46

	ROW	LIN	VOLTS	DEG	PCT	CHN		LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG
246			0.13	91	SAI	2	TSH	+0.49		TSHTSH	0.2		K7060	reso	22H00097	H	0
247			0.10	108	PID	4	TSH	+0.49		TSHTSH			B1055	rpri	22H00172	H99	
248	19	35	0.12	97	SAI	2	TSH	+0.64		TSHTSH	0.2		K7060	reso	22H00097	H	0
249					SAI	1	TSH	+0.64		TSHTSH	0.0		K7060	reso	22H00097	H	0
250			0.12	148	PID	4	TSH	+0.64		TSHTSH			B1055	rpri	22H00172	H99	
251	37	35	0.67	106	NQI	P1	TSH	+0.77		TEHTEC			D4576	rsec	22C00109	C	0
252			0.14	99	MAI	2	TSH	+0.84		TSHTSH	0.4		S7752	reso	22H00099	H	0
253			0.24	126	MAI	1	TSH	+0.84		TSHTSH	0.2		S7752	reso	22H00099	H	0
254			0.18	120	PID	4	TSH	+0.84		TSHTSH			F7467	rsec	22H00172	H99	
255	39	35	0.37	79	MBM	5	02H	+5.34		TEHTEC			T0042	reso	22C00109	C	0
256	53	35			MCI	1	TSH	+0.10		TSHTSH	0		S7752	reso	22H00099	H	0
257			0.29	54	MCI	P1	TSH	+0.10		TSHTSH	1.0		D3858	reso	22H00099	H	0
258			0.15	94	PID	P1	TSH	+0.10		TSHTSH			B1055	rpri	22H00172	H99	
259			0.44	81	MBM	5	02C	+15.11		TEHTEC			T0042	reso	22C00109	C	0
260	61	35	0.17	101	MAI	2	TSH	+0.05	TO+0.23	TSHTSH	0.2		K7060	reso	22H00098	H	0
261					MAI	1	TSH	+0.05	TO+0.23	TSHTSH	0.0		K7060	reso	22H00098	H	0
262			0.16	93	PID	4	TSH	+0.05	TO+0.23	TSHTSH			B1055	rpri	22H00172	H99	
263	69	35	1.04	88	MBM	5	01C	+17.72		TEHTEC			K7060	reso	22C00108	C	0
264	71	35	0.38	85	MBM	5	03H	+6.07		TEHTEC			T0042	reso	22C00109	C	0
265			1.00	61	MBM	6	06H	+12.80		TEHTEC			T0042	reso	22C00109	C	0
[illegible]			0.60	85	MBM	6	07C	+16.83		TEHTEC			T0042	reso	22C00109	C	0
[illegible]	87	35	1.14	83	MBM	5	07H	+6.66		TEHTEC			T0042	reso	22C00109	C	0
268	107	35	0.82	55	MBM	6	08H	+16.69		TEHTEC			T0042	reso	22C00109	C	0
269	16	36	0.14	123	SAI	2	TSH	+2.06		TSHTSH	0.3		S7752	reso	22H00099	H	0
270			0.19	68	SAI	1	TSH	+2.06		TSHTSH	0.2		S7752	reso	22H00099	H	0
271			0.19	122	PID	4	TSH	+2.06		TSHTSH			B1055	rpri	22H00172	H99	
272	24	36	0.26	110	11	P2	DH	+1.51		TEHTEC			P5436	rpri	22C00109	C	0
273			0.13	33	WAR	P4	DH	+1.57		DH DH			A9608	reso	22H00185	H	4
274	30	36	0.56	95	MBM	5	05C	+5.50		TEHTEC			K7060	reso	22C00108	C	0
275			0.83	57	MBM	5	04C	+27.51		TEHTEC			K7060	reso	22C00108	C	0
276			1.17	105	MBM	5	04C	+34.76		TEHTEC			K7060	reso	22C00108	C	0
277	64	36			OBS		DC	+11.38		DCTEH			S1848	rpri	22H00144	C	0
278					OBS		07C	+23.01		07CTEC			S9098	rpri	22C00108	C	0
279	98	36	0.19	107	WAR	P4	VC	+0.16		VC VC			J6276	rpri	22C00194	C	5
280			0.24	102	10	P2	VC	+0.30		TEHTEC			T0042	reso	22C00109	C	0
281	110	36	0.46	74	MBM	5	03C	+24.32		TEHTEC			T0042	reso	22C00109	C	0
282	112	36	0.40	69	MBM	5	02H	+2.83		TEHTEC			K7060	reso	22C00108	C	0
283	1	37			OBS		06C	+0.00		06CTEC			B1055	rpri	22C00162	C	1
284	15	37	0.33	108	VOL	2	01C	+0.59		01C01C			B3720	reso	22C00194	C	5
285			0.70	76	MBM	5	01C	+0.62		TECTEH			B3720	reso	22H00130	C	0
286	29	37	0.18	103	SAI	2	TSH	+1.47		TSHTSH	0.3		S7752	reso	22H00099	H	0
287					SAI	1	TSH	+1.47		TSHTSH	0		S7752	reso	22H00099	H	0
288			0.19	98	PID	4	TSH	+1.47		TSHTSH			B1055	rpri	22H00172	H99	
289	39	37	0.11	93	SAI	2	TSH	+0.60		TSHTSH	0.2		S7752	reso	22H00100	H	0
290					SAI	1	TSH	+0.60		TSHTSH	0		S7752	reso	22H00100	H	0
291			0.09	146	PID	4	TSH	+0.60		TSHTSH			B1055	rpri	22H00172	H99	
	41	37			SAI	1	TSH	+0.70		TSHTSH	0		S7752	reso	22H00099	H	0
293			0.10	91	SAI	2	TSH	+0.70		TSHTSH	0.2		S7752	reso	22H00099	H	0
294			0.10	116	PID	4	TSH	+0.70		TSHTSH			B1055	rpri	22H00172	H99	

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:46

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
295			0.92	85	MBM	5	04H	+24.29	TEHTEC			T0042	reso	22C00109	C 0
296	47	37	0.48	77	MBM	5	VM	+8.21	TEHTEC			T0042	reso	22C00109	C 0
297	65	37			OBS		TSH	-21.00	TSHTEC			K7060	reso	22C00108	C 0
298	69	37	0.71	77	MBM	5	02C	+23.06	TEHTEC			K7060	reso	22C00108	C 0
299	89	37	0.89	65	MBM	6	04H	+23.22	TEHTEC			K7060	reso	22C00108	C 0
300			0.44	85	MBM	5	06H	+6.75	TEHTEC			K7060	reso	22C00108	C 0
301	95	37	1.94	56	MBM	6	VH	+21.17	TEHTEC			T0042	reso	22C00109	C 0
302	97	37	0.21	131	8	P2	VH	-0.96	TEHTEC			S9098	rpri	22C00108	C 0
303			0.20	104	WAR	P4	VH	-0.96	VH VH			A9608	reso	22H00184	H 4
304	101	37	0.27	102	10	P2	VH	+0.32	TEHTEC			S9098	rpri	22C00108	C 0
305			0.22	91	WAR	2	VH	+0.33	VH VH			K2858	rpri	22H00188	H 5
306	103	37	1.33	86	MBM	6	07H	+14.36	TEHTEC			T0042	reso	22C00109	C 0
307			0.44	46	DSI	P1	09H	-0.04	TEHTEC			T0042	reso	22C00109	C 0
308					NDF		09H	-0.04	09H09H			A9608	reso	22H00183	H 4
309					NDF		09H	-0.04	09H09H	ID OK		B3720	reso	22H00184	H 4
310			0.96	105	DSI	P1	09C	-0.15	TEHTEC			P5436	rpri	22C00109	C 0
311					NDF		09C	-0.15	09C09C			B3720	reso	22C00194	C 5
312			1.02	65	MBM	5	08C	+10.58	TEHTEC			T0042	reso	22C00109	C 0
313	109	37	1.28	66	MBM	6	TSH	+31.78	TEHTEC			K7060	reso	22C00108	C 0
314	98	38	0.62	79	DSI	P1	09C	-0.90	TEHTEC			S9098	rpri	22C00108	C 0
[illegible]					NDF		09C	-0.90	09C09C			B3720	reso	22C00194	C 5
[illegible]	104	38	0.69	84	MBM	5	06H	+13.12	TEHTEC			T0042	reso	22C00109	C 0
317			1.28	66	MBM	5	VH	+24.98	TEHTEC			T0042	reso	22C00109	C 0
318	110	38	2.35	77	MBM	6	03C	+13.51	TEHTEC			K7060	reso	22C00108	C 0
319			1.56	87	MBM	6	03C	+20.22	TEHTEC			K7060	reso	22C00108	C 0
320			4.07	76	MBM	6	03C	+37.78	TEHTEC			K7060	reso	22C00108	C 0
321	11	39	0.36	93	SAI	1	TSH	+0.56	TSHTSH	0.3		S7752	reso	22H00099	H 0
322			0.36	99	SAI	2	TSH	+0.56	TSHTSH	0.2		S7752	reso	22H00099	H 0
323			0.31	100	PID	4	TSH	+0.56	TSHTSH			B1055	rpri	22H00172	H99
324	37	39	0.28	82	NQI	P1	TSH	+6.65	TEHTEC			S9098	rpri	22C00105	C 0
325					NDF		TSH	+6.65	TSH01H			A9608	reso	22H00183	H 4
326	43	39	0.36	159	NQI	P1	TSH	+0.61	TEHTEC			T0042	reso	22C00108	C 0
327			0.16	122	SAI	2	TSH	+0.65	TSHTSH	0.3		S7752	reso	22H00101	H 0
328			0.18	102	SAI	1	TSH	+0.65	TSHTSH	0.3		S7752	reso	22H00101	H 0
329			0.19	129	PID	4	TSH	+0.65	TSHTSH			B1055	rpri	22H00172	H99
330	49	39			MAI	1	TSH	+0.53	TSHTSH	0		S7752	reso	22H00101	H 0
331			0.13	107	MAI	2	TSH	+0.53	TSHTSH	0.2		S7752	reso	22H00101	H 0
332			0.14	123	PID	4	TSH	+0.53	TSHTSH			B1055	rpri	22H00172	H99
333			0.49	154	NQI	P1	TSH	+0.61	TEHTEC			N2222	rsec	22C00108	C 0
334	55	39	0.12	80	SAI	2	TSH	+0.20	TSHTSH	0.2		S7752	reso	22H00101	H 0
335					SAI	1	TSH	+0.20	TSHTSH	0		S7752	reso	22H00101	H 0
336			0.07	96	PID	4	TSH	+0.20	TSHTSH			B1055	rpri	22H00172	H99
337	59	39	0.17	105	SAI	2	TSH	+0.50	TSHTSH	0.2		S7752	reso	22H00101	H 0
338					SAI	1	TSH	+0.50	TSHTSH	0		S7752	reso	22H00101	H 0
339			0.16	111	PID	4	TSH	+0.50	TSHTSH			B1055	rpri	22H00172	H99
340	61	39	0.13	92	MAI	2	TSH	+0.09 TO+0.18	TSHTSH	0.1		K7060	reso	22H00096	H 0
					MAI	1	TSH	+0.09 TO+0.18	TSHTSH	0.0		K7060	reso	22H00096	H 0
342			0.11	85	PID	4	TSH	+0.09 TO+0.18	TSHTSH			B1055	rpri	22H00172	H99
343	85	39	0.91	68	MBM	5	01H	+11.13	TEHTEC			D3858	reso	22C00107	C 0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:46

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
344	101	39	8.13	3	PVN	P1 VC	+9.96	TEHTEC			D3858	reso	22C00107	C 0
345	109	39	0.36	81	MBM	5 08H	+4.77	TEHTEC			D3858	reso	22C00107	C 0
346	115	39	1.22	49	MBM	6 05H	+6.78	TEHTEC			K7060	reso	22C00108	C 0
347	4	40	6.36	9	PVN	P1 TSH	+8.74	06HTEH			L6066	rsec	22H00141	H 1
348	38	40	0.69	81	MBM	5 02H	+20.32	TEHTEC			T0042	reso	22C00106	C 0
349			0.56	73	MBM	5 02H	+26.94	TEHTEC			T0042	reso	22C00106	C 0
350			0.40	79	MBM	5 02H	+37.02	TEHTEC			H2131	reso	22C00106	C 0
351	48	40	0.37	149	NQI	P1 TSH	+0.69	TEHTEC			T0042	reso	22C00106	C 0
352					SAI	1 TSH	+0.69	TSHTSH	0		S7752	reso	22H00101	H 0
353			0.12	116	SAI	2 TSH	+0.69	TSHTSH	0.2		S7752	reso	22H00101	H 0
354			0.08	88	PID	4 TSH	+0.69	TSHTSH			B1055	rpri	22H00172	H99
355	52	40	0.41	131	NQI	P1 TSH	+0.80	TEHTEC			T0042	reso	22C00106	C 0
356					SAI	1 TSH	+0.80	TSHTSH	0		S7752	reso	22H00099	H 0
357			0.18	77	SAI	2 TSH	+0.80	TSHTSH	0.2		S7752	reso	22H00099	H 0
358			0.22	121	PID	4 TSH	+0.80	TSHTSH			B1055	rpri	22H00172	H99
359	70	40	0.28	95	NQI	P1 TSC	+0.68	TEHTEC			N2222	rsec	22C00105	C 0
360					NDF	TSC	+0.68	TSCTSC			R6452	reso	22C00168	C 3
361	72	40	0.62	87	MBM	5 04H	+24.04	TEHTEC			T0042	reso	22C00106	C 0
362	96	40	0.16	103	WAR	P4 VC	-0.69	VC VC			J6276	rpri	22C00194	C 5
363			0.26	103	DSI	P1 VC	-0.30	TEHTEC			T0042	reso	22C00106	C 0
[illegible]	106	40	1.08	82	MBM	5 05H	+28.55	TEHTEC			T0042	reso	22C00105	C 0
[illegible]	1	41			OBS	06C	+3.38	06CTEC			M1680	reso	22C00094	C 1
366	19	41	0.17	116	SAI	2 TSH	+2.88	TSHTSH	0.2		S7752	reso	22H00099	H 0
367					SAI	1 TSH	+2.88	TSHTSH	0		S7752	reso	22H00099	H 0
368			0.17	108	PID	4 TSH	+2.88	TSHTSH			B1055	rpri	22H00172	H99
369	25	41	0.14	92	SAI	2 TSH	+0.62	TSHTSH	0.2		S7752	reso	22H00101	H 0
370			0.17	87	SAI	1 TSH	+0.62	TSHTSH	0.3		S7752	reso	22H00101	H 0
371			0.12	99	PID	4 TSH	+0.62	TSHTSH			B1055	rpri	22H00172	H99
372	37	41	0.95	81	MBM	5 02H	+31.54	TEHTEC			T0042	reso	22C00105	C 0
373	49	41	0.10	82	SAI	2 TSH	+0.85	TSHTSH	0.2		S7752	reso	22H00101	H 0
374					SAI	1 TSH	+0.85	TSHTSH	0		S7752	reso	22H00101	H 0
375			0.06	98	PID	4 TSH	+0.85	TSHTSH			B1055	rpri	22H00172	H99
376	83	41	0.70	78	MBM	6 07C	+16.82	TEHTEC			T0042	reso	22C00106	C 0
377	85	41	0.30	83	MBM	5 04H	+10.55	TEHTEC			T0042	reso	22C00105	C 0
378	91	41	0.54	37	MBM	6 01H	+15.96	TEHTEC			T0042	reso	22C00106	C 0
379			0.80	89	MBM	6 03C	+29.38	TEHTEC			T0042	reso	22C00106	C 0
380	115	41	0.54	73	MBM	6 VM	+26.36	TEHTEC			T0042	reso	22C00106	C 0
381	14	42			OBS	05H	+35.51	05HTEH			S1848	rpri	22H00130	C 0
382					OBS	05H	+37.07	05HTEH			S1848	rpri	22H00144	C 0
383	24	42	0.20	79	SAI	2 TSH	+0.24	TSHTSH	0.3		S7752	reso	22H00099	H 0
384			0.16	43	SAI	1 TSH	+0.24	TSHTSH	0.3		S7752	reso	22H00099	H 0
385			0.17	85	PID	4 TSH	+0.24	TSHTSH			B1055	rpri	22H00172	H99
386	28	42			MSI	1 TSH	+0.12 TO+1.03	TSHTSH	0		S7752	reso	22H00099	H 0
387			0.18	95	MSI	2 TSH	+0.12 TO+1.03	TSHTSH	0.2		S7752	reso	22H00099	H 0
388			0.17	99	PID	4 TSH	+0.12 TO+1.03	TSHTSH			B1055	rpri	22H00172	H99
389			0.64	155	NQI	P1 TSH	+0.79	TEHTEC			N2222	rsec	22C00105	C 0
	30	42	0.12	123	SAI	2 TSH	+0.47	TSHTSH	0.3		S7752	reso	22H00101	H 0
391			0.16	75	SAI	1 TSH	+0.47	TSHTSH	0.2		S7752	reso	22H00101	H 0
392			0.17	130	PID	4 TSH	+0.47	TSHTSH			B1055	rpri	22H00172	H99

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:46

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
393	102	42	0.35		PLP	9 TSC	+0.20	TSCTSC			J6276	rpri	22C00167	C 3
394	104	42	0.34	131	INR	P1 02H	-0.12	TEHTEC			S9098	rpri	22C00106	C 0
395	112	42	0.89	86	MBM	6 02H	+24.44	TEHTEC			T0042	reso	22C00106	C 0
396			0.74	83	MBM	6 02H	+29.81	TEHTEC			T0042	reso	22C00106	C 0
397			0.85	71	MBM	6 03H	+1.84	TEHTEC			T0042	reso	22C00106	C 0
398			0.68	75	MBM	5 03H	+13.13	TEHTEC			T0042	reso	22C00106	C 0
399			0.42	49	MBM	6 03H	+24.09	TEHTEC			T0042	reso	22C00106	C 0
400			1.11	66	MBM	6 03H	+29.54	TEHTEC			T0042	reso	22C00106	C 0
401			0.81	61	MBM	6 04H	+1.76	TEHTEC			T0042	reso	22C00106	C 0
402			0.55	84	MBM	6 04H	+7.23	TEHTEC			T0042	reso	22C00106	C 0
403	116	42	0.53	24	INR	P1 TSH	+1.40	TEHTEC			B3720	reso	22C00106	C 0
404			0.26	129	INR	P1 TSH	+2.53	TEHTEC			T0042	reso	22C00106	C 0
405	15	43	0.21	129	NQI	P1 TSH	+1.98	TECTEH			L6066	rsec	22H00143	C 0
406			0.22	76	SAI	2 TSH	+2.33	TSHTSH	0.2		S7752	reso	22H00099	H 0
407			0.30	56	SAI	1 TSH	+2.33	TSHTSH	0.2		S7752	reso	22H00099	H 0
408			0.14	101	PID	4 TSH	+2.33	TSHTSH			B1055	rpri	22H00172	H99
409	17	43	0.23	143	NQI	P1 TSH	+1.83	TECTEH			L6066	rsec	22H00143	C 0
410			0.11	96	SAI	2 TSH	+2.15	TSHTSH	0.2		S7752	reso	22H00101	H 0
411					SAI	1 TSH	+2.15	TSHTSH	0		S7752	reso	22H00101	H 0
412			0.14	103	SAI	2 TSH	+3.26	TSHTSH	0.2		S7752	reso	22H00101	H 0
[illegible]					SAI	1 TSH	+3.26	TSHTSH	0		S7752	reso	22H00101	H 0
[illegible]			0.13	99	PID	4 TSH	+3.26	TSHTSH			B1055	rpri	22H00172	H99
415			0.81	89	MBM	6 02C	+11.64	TECTEH			A9608	reso	22H00143	C 0
416	23	43	0.32	50	SAI	1 TSH	+0.21	TSHTSH	0.3		S7752	reso	22H00101	H 0
417			0.21	86	SAI	2 TSH	+0.21	TSHTSH	0.2		S7752	reso	22H00101	H 0
418			0.14	82	PID	4 TSH	+0.21	TSHTSH			B1055	rpri	22H00172	H99
419			0.40	146	NQI	P1 TSH	+2.80	TEHTEC			T0042	reso	22C00106	C 0
420			0.35	119	SAI	1 TSH	+3.06	TSHTSH	0.3		S7752	reso	22H00101	H 0
421			0.22	104	SAI	2 TSH	+3.06	TSHTSH	0.3		S7752	reso	22H00101	H 0
422					SAI	1 TSH	+3.66	TSHTSH	0		S7752	reso	22H00101	H 0
423			0.09	121	SAI	2 TSH	+3.66	TSHTSH	0.2		S7752	reso	22H00101	H 0
424	31	43	0.19	61	SAI	1 TSH	+0.77	TSHTSH	0.3		S7752	reso	22H00101	H 0
425			0.11	81	SAI	2 TSH	+0.77	TSHTSH	0.3		S7752	reso	22H00101	H 0
426			0.11	89	PID	4 TSH	+0.77	TSHTSH			B1055	rpri	22H00172	H99
427			0.22	103	NQI	P1 TSH	+0.80	TEHTEC			T0042	reso	22C00106	C 0
428	41	43	0.55	9	INR	P1 TSH	+0.90	TEHTEC			S9098	rpri	22C00105	C 0
429	61	43	0.42	83	MBM	6 02H	+15.79	TEHTEC			T0042	reso	22C00105	C 0
430			0.53	86	MBM	6 06H	+20.56	TEHTEC			T0042	reso	22C00105	C 0
431	69	43	0.09	111	SAI	2 TSH	+0.20	TSHTSH	0.2		K7060	reso	22H00095	H 0
432					SAI	1 TSH	+0.20	TSHTSH	0.0		K7060	reso	22H00095	H 0
433			0.11	130	PID	4 TSH	+0.20	TSHTSH			B1055	rpri	22H00172	H99
434					SAI	1 TSH	+2.18	TSHTSH	0.0		K7060	reso	22H00095	H 0
435			0.13	105	SAI	2 TSH	+2.18	TSHTSH	0.4		K7060	reso	22H00095	H 0
436	79	43	0.26	110	SAI	2 TSH	+0.12	TSHTSH	0.2		K7060	reso	22H00095	H 0
437					SAI	1 TSH	+0.12	TSHTSH	0.0		K7060	reso	22H00095	H 0
438			0.27	92	PID	4 TSH	+0.12	TSHTSH			B1055	rpri	22H00172	H99
	85	43	0.68	79	MBM	5 03C	+34.42	TEHTEC			T0042	reso	22C00106	C 0
440	91	43	0.58	65	MBM	6 01H	+7.72	TEHTEC			T0042	reso	22C00105	C 0
441	103	43	0.33	74	MBM	5 VM	+12.00	TEHTEC			T0042	reso	22C00105	C 0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:46

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
442	105	43	0.86	79	MBM	5 VH	+22.44	TEHTEC			T0042	reso	22C00106	C 0
443	121	43	4.29	212	NRC	2 TSC	+0.00	TECTEH			M1680	reso	22H00133	C 0
444			0.49	159	INR	P1 TEC	+13.09 TO+17.07	TECTEH			J6276	rpri	22H00133	C 0
445	6	44	0.53	83	MBM	5 TSC	+21.47	TECTEH			C3340	reso	22H00130	C 0
446	30	44	0.47	50	NQI	P1 TSH	+2.00	TEHTEC			M2655	rsec	22C00104	C 0
447					NDF	2 TSH	+2.00	TSHTSH			S7752	reso	22H00101	H 0
448	54	44	0.42	79	MBM	5 07H	+3.72	TEHTEC			K7060	reso	22C00104	C 0
449	62	44	0.13	122	MAI	2 TSH	+0.15 TO+0.78	TSHTSH	0.2		K7060	reso	22H00096	H 0
450					MAI	1 TSH	+0.15 TO+0.78	TSHTSH	0.0		K7060	reso	22H00096	H 0
451			0.09	137	PID	4 TSH	+0.15 TO+0.78	TSHTSH			B1055	rpri	22H00172	H99
452	68	44	0.11	114	SAI	2 TSH	+0.40	TSHTSH	0.3		K7060	reso	22H00095	H 0
453					SAI	1 TSH	+0.40	TSHTSH	0.0		K7060	reso	22H00095	H 0
454			0.15	121	PID	4 TSH	+0.40	TSHTSH			B1055	rpri	22H00172	H99
455	86	44	0.21	84	MBM	5 05H	+17.81	TEHTEC			C3340	reso	22C00103	C 0
456	88	44	0.49	106	MBM	5 03H	+7.89	TEHTEC			K7060	reso	22C00104	C 0
457			0.67	103	MBM	5 03H	+8.96	TEHTEC			K7060	reso	22C00104	C 0
458			1.02	83	MBM	5 04H	+24.15	TEHTEC			K7060	reso	22C00104	C 0
459	96	44	5.75	189	INR	P1 TSH	+13.16	TEHTEC			K7060	reso	22C00104	C 0
460	98	44	0.51	84	MBM	5 07H	+21.36	TECTEH			A9608	reso	22H00143	C 0
461					OBS	P1 DH	-11.33	DHTEC			C3340	reso	22C00103	C 0
[illegible]	100	44	0.49	124	MBM	5 06C	+15.76	TEHTEC			K7060	reso	22C00104	C 0
[illegible]	102	44			OBS	P1 DH	-13.91	DHTEC			C3340	reso	22C00103	C 0
464	104	44	0.76	86	MBM	5 03C	+18.18	TEHTEC			K7060	reso	22C00104	C 0
465	116	44	0.78	82	MBM	5 03C	+15.74	TEHTEC			K7060	reso	22C00104	C 0
466	19	45	0.68	58	MBM	5 02H	+36.42	TECTEH			B3720	reso	22H00129	C 0
467	29	45	0.21	90	MAI	2 TSH	+0.48	TSHTSH	0.2		S7752	reso	22H00099	H 0
468					MAI	1 TSH	+0.48	TSHTSH	0		S7752	reso	22H00099	H 0
469			0.14	88	PID	4 TSH	+0.48	TSHTSH			B1055	rpri	22H00172	H99
470	53	45	0.14	112	MAI	2 TSH	+0.54	TSHTSH	0.2		S7752	reso	22H00099	H 0
471					MAI	1 TSH	+0.54	TSHTSH	0		S7752	reso	22H00099	H 0
472			0.08	115	PID	4 TSH	+0.54	TSHTSH			B1055	rpri	22H00172	H99
473	67	45	0.15	108	SAI	2 TSH	+0.42	TSHTSH	0.2		K7060	reso	22H00096	H 0
474					SAI	1 TSH	+0.42	TSHTSH	0.0		K7060	reso	22H00096	H 0
475			0.14	95	PID	4 TSH	+0.42	TSHTSH			B1055	rpri	22H00172	H99
476	77	45	0.12	108	MCI	P1 TSH	+0.05	TSHTSH	1.4		D3858	reso	22H00095	H 0
477					MCI	1 TSH	+0.05	TSHTSH	0.0		M1680	reso	22H00095	H 0
478			0.11	111	PID	P1 TSH	+0.05	TSHTSH			B1055	rpri	22H00172	H99
479	89	45	0.53	109	20	P2 VH	+1.37	TEHTEC			H3464	rpri	22C00104	C 0
480			0.28	83	WAR	P4 VH	+1.37	VH VH			A9608	reso	22H00185	H 4
481	95	45	0.39	45	DSI	P1 09C	+0.00	TEHTEC			R9311	rpri	22C00103	C 0
482					NDF	09C	+0.00	09C09C			B3720	reso	22C00194	C 5
483	121	45	0.68	168	INR	P1 09H	+0.45	TECTEH			M1680	reso	22H00133	C 0
484			3.12	212	NRC	2 TSC	+0.00	TECTEH			M1680	reso	22H00133	C 0
485	90	46	0.16	86	SCI	P1 TSH	+0.12	TSHTSH	0.7		K7060	reso	22H00096	H 0
486					SCI	1 TSH	+0.12	TSHTSH	0.0		K7060	reso	22H00096	H 0
487			0.08	88	PID	P1 TSH	+0.12	TSHTSH			B1055	rpri	22H00172	H99
	122	46	1.39	86	MBM	6 03H	+29.34	TECTEH			M1680	reso	22H00133	C 0
489	21	47	0.87	84	MBM	5 01H	+18.73	TEHTEC			K7060	reso	22C00104	C 0
490	29	47	0.11	90	SAI	2 TSH	+0.51	TSHTSH	0.2		S7752	reso	22H00102	H 0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:46

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
491					SAI	1 TSH	+0.51	TSHTSH	0		S7752	reso	22H00102	H 0
492			0.10	92	PID	4 TSH	+0.51	TSHTSH			B1055	rpri	22H00172	H99
493	37	47	0.96	86	MBM	5 01C	+19.13	TEHTEC			C3340	reso	22C00103	C 0
494	75	47	1.22	93	MBM	5 TSC	+1.00	TEHTEC			K7060	reso	22C00104	C 0
495	87	47	0.36	105	MCI	P1 TSH	+0.06	TSHTSH	0.6		K7060	reso	22H00096	H 0
496			0.43	115	MCI	1 TSH	+0.06	TSHTSH	0.6		K7060	reso	22H00096	H 0
497			0.25	116	PID	P1 TSH	+0.06	TSHTSH			B1055	rpri	22H00172	H99
498	89	47	0.37	94	MCI	P1 TSH	+0.06	TSHTSH	1.2		H2131	reso	22H00095	H 0
499			0.56	32	MCI	1 TSH	+0.06	TSHTSH	1.0		H2131	reso	22H00095	H 0
500			0.19	53	PID	4 TSH	+0.06	TSHTSH			B1055	rpri	22H00172	H99
501	95	47	0.16	106	SCI	P1 TSH	+0.04	TSHTSH	0.6		K7060	reso	22H00095	H 0
502			0.21	145	SCI	1 TSH	+0.04	TSHTSH	0.4		K7060	reso	22H00095	H 0
503			0.14	109	PID	P1 TSH	+0.04	TSHTSH			B1055	rpri	22H00172	H99
504	99	47	1.18	78	MBM	5 07C	+2.47	TEHTEC			K7060	reso	22C00104	C 0
505			1.26	80	MBM	5 07C	+3.38	TEHTEC			K7060	reso	22C00104	C 0
506	105	47	0.34	85	MBM	5 04C	+2.92	TEHTEC			C3340	reso	22C00103	C 0
507	115	47	0.54	78	MBM	5 03H	+37.39	TEHTEC			K7060	reso	22C00104	C 0
508	121	47	1.76	30	NRC	2 TSC	+0.00	TECTEH			M1680	reso	22H00133	C 0
509	100	48	0.79	4	INR	P1 TSH	+25.05	TEHTEC			S9098	rpri	22C00057	C 0
510	102	48	0.72	73	MBM	5 03C	+27.78	TEHTEC			H2131	reso	22C00056	C 0
	114	48	0.63	79	MBM	5 03H	+24.34	TEHTEC			H2131	reso	22C00056	C 0
5.	116	48	1.01	78	MBM	5 05C	+34.83	TEHTEC			R6452	reso	22C00057	C 0
513	120	48	1.39	75	MBM	6 04C	+25.37	TEHTEC			A9608	reso	22C00064	C 0
514			0.63	86	MBM	5 01C	+7.40	TEHTEC			A9608	reso	22C00064	C 0
515			0.58	81	MBM	5 TSC	+7.99	TEHTEC			A9608	reso	22C00064	C 0
516	29	49	0.14	94	SAI	2 TSH	+0.41	TSHTSH	0.3		S7752	reso	22H00004	H 0
517			0.51	59	SAI	1 TSH	+0.41	TSHTSH	0.3		S7752	reso	22H00004	H 0
518			0.15	102	PID	4 TSH	+0.41	TSHTSH			L2157	rpri	22H00063	H99
519	39	49	0.66	92	INR	6 02H	+15.07	TEHTEC			R4201	rpri	22C00015	C 0
520	113	49	1.71	9	INR	P1 09H	+0.12	TEHTEC			H2131	reso	22C00056	C 0
521	121	49	4.40	32	NRC	2 TSC	+0.00	TEHTEC			B6937	rsec	22C00064	C 0
522	12	50	2.60	76	MBM	6 04H	+9.50	TECTEH			B3720	reso	22H00129	C 0
523	16	50	0.51	58	MBM	5 02C	+11.07	TECTEH			B3720	reso	22H00129	C 0
524	22	50	0.09	86	SAI	2 TSH	+0.30	TSHTSH	0.2		S7752	reso	22H00004	H 0
525					SAI	1 TSH	+0.30	TSHTSH	0.0		A9608	reso	22H00004	H 0
526			0.08	80	PID	4 TSH	+0.30	TSHTSH			L2157	rpri	22H00063	H99
527	62	50	0.87	86	MBM	6 02C	+6.72	TEHTEC			R6452	reso	22C00057	C 0
528	68	50	0.90	70	MBM	5 DH	+9.37	TEHTEC			H2131	reso	22C00056	C 0
529	86	50	0.17	109	SAI	2 TSH	+0.15	TSHTSH	0.2		S7752	reso	22H00043	H 0
530					SAI	1 TSH	+0.15	TSHTSH	0		S7752	reso	22H00043	H 0
531			0.20	119	PID	4 TSH	+0.15	TSHTSH			L2157	rpri	22H00063	H99
532	90	50	0.19	98	SAI	2 TSH	+0.27	TSHTSH	0.3		S7752	reso	22H00042	H 0
533			0.20	68	SAI	1 TSH	+0.27	TSHTSH	0.3		S7752	reso	22H00042	H 0
534			0.12	98	PID	4 TSH	+0.27	TSHTSH			L2157	rpri	22H00063	H99
535	100	50	0.18	85	WAR	P4 VH	-1.41	VH VH			H2131	reso	22H00068	H 4
536			0.24	94	11	P2 VH	-1.30	TEHTEC			M0945	rsec	22C00057	C 0
	118	50	1.36	73	MBM	6 04H	+5.37	TEHTEC			H2131	reso	22C00056	C 0
538	120	50	1.20	70	MBM	6 05H	+13.15	TEHTEC			A9608	reso	22C00064	C 0
539	5	51	1.28	104	MBM	5 04H	-0.47	06HTEH			C3340	reso	22H00002	H 1

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:46

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG
540	9	51	0.29	140	PPS	P1 VM	-1.40	06C05H			B3720	reso	22H00163	H	2
541			1.86	141	INR	6 VM	-1.27 TO-0.72	TECTEH			R4201	rpri	22H00129	C	0
542	25	51	0.19	100	SCI	P1 TSH	+0.04	TSHTSH	0.4		S7752	reso	22H00004	H	0
543					SCI	1 TSH	+0.04	TSHTSH	0.0		A9608	reso	22H00004	H	0
544			0.20	140	PID	P1 TSH	+0.04	TSHTSH			L2157	rpri	22H00063	H99	
545	27	51	0.53	64	MBM	6 05C	+5.06	TEHTEC			C3340	reso	22C00016	C	0
546	39	51	0.38	72	MBM	5 06H	+13.85	TEHTEC			W4381	rsec	22C00016	C	0
547	61	51	0.52	24	DSI	P1 DH	+1.31	TEHTEC			R6452	reso	22C00054	C	0
548			0.57	141	DSI	P1 DH	+1.69	TEHTEC			R6452	reso	22C00054	C	0
549			0.50	87	WAR	P4 DH	+1.85	DH DH			H2131	reso	22H00068	H	4
550	73	51	0.56	50	MBM	6 VM	+8.35	TEHTEC			R6452	reso	22C00054	C	0
551	85	51	0.30	59	MBM	6 02C	+16.27	TEHTEC			R6452	reso	22C00054	C	0
552	101	51	1.64	77	MBM	5 08H	+6.80	TEHTEC			H2131	reso	22C00055	C	0
553			1.03	79	MBM	5 03C	+27.51	TEHTEC			H2131	reso	22C00055	C	0
554			1.26	70	MBM	6 03C	+32.69	TEHTEC			H2131	reso	22C00055	C	0
555	121	51	6.08	24	NRC	2 TSC	+0.00	TEHTEC			H2131	reso	22C00065	C	0
556	2	52	0.54	87	MBM	5 TSH	+13.71	06HTEH			C3340	reso	22H00002	H	1
557	4	52	1.15	77	MBM	5 04C	+12.48	06HTEC			M1680	reso	22C00094	C	1
558	10	52	0.74	150	DSI	P1 DH	-0.09	TECTEH			K7060	reso	22H00132	C	0
559			0.34	45	NDF	2 DH	-0.09	06C05H			R6452	reso	22H00164	H	2
[illegible]	14	52	0.24	77	VOL	2 06C	-14.60	06C05H			B3720	reso	22H00163	H	2
[illegible]			1.46	82	MBM	5 05C	+4.21	TECTEH			K7060	reso	22H00132	C	0
562			0.79	74	MBM	6 05C	+16.73	TECTEH			K7060	reso	22H00132	C	0
563			0.84	80	MBM	5 05C	+20.44	TECTEH			K7060	reso	22H00132	C	0
564			1.18	98	MBM	6 05C	+23.09	TECTEH			K7060	reso	22H00132	C	0
565			0.98	83	MBM	5 05C	+24.72	TECTEH			K7060	reso	22H00132	C	0
566			1.53	86	MBM	5 04C	+10.28	TECTEH			K7060	reso	22H00132	C	0
567			1.61	64	MBM	6 04C	+14.76	TECTEH			K7060	reso	22H00132	C	0
568			0.62	81	MBM	5 04C	+19.59	TECTEH			K7060	reso	22H00132	C	0
569			0.99	95	MBM	6 04C	+23.60	TECTEH			K7060	reso	22H00132	C	0
570			0.59	94	MBM	6 03C	+35.24	TECTEH			K7060	reso	22H00132	C	0
571	18	52	0.15	106	SAI	2 TSH	+2.96	TSHTSH	0.1		S7752	reso	22H00103	H	0
572					SAI	1 TSH	+2.96	TSHTSH	0		S7752	reso	22H00103	H	0
573			0.11	107	PID	4 TSH	+2.96	TSHTSH			B1055	rpri	22H00172	H99	
574	56	52	0.38	41	16	P2 DC	-2.12	TEHTEC			D4876	rsec	22C00015	C	0
575			0.16	106	WAR	P4 DC	-1.99	DC DC			A9608	reso	22C00087	C	5
576	86	52	0.53	85	MBM	5 01H	+30.52	TEHTEC			H2131	reso	22C00055	C	0
577	92	52	0.20	99	SCI	P1 TSH	+0.11	TSHTSH	0.5		A9608	reso	22H00042	H	0
578					SCI	1 TSH	+0.11	TSHTSH	0		A9608	reso	22H00042	H	0
579			0.14	107	PID	P1 TSH	+0.11	TSHTSH			L2157	rpri	22H00063	H99	
580	114	52	0.89	84	MBM	5 07H	+24.98	TEHTEC			H2131	reso	22C00055	C	0
581	122	52	0.79	69	MBM	5 06H	+5.99	TEHTEC			H2131	reso	22C00065	C	0
582	9	53	0.83	108	NQI	P1 TSH	+1.94	TECTEH			L6066	rsec	22H00143	C	0
583			0.89	97	SAI	1 TSH	+2.34	TSHTSH	0.7		S7752	reso	22H00103	H	0
584			0.84	101	SAI	2 TSH	+2.34	TSHTSH	0.7		S7752	reso	22H00103	H	0
585			0.48	107	PID	4 TSH	+2.34	TSHTSH			B1055	rpri	22H00172	H99	
	23	53	1.09	75	MBM	6 03H	+14.82	TEHTEC			R4201	rpri	22C00017	C	0
587			0.79	87	MBM	6 03H	+16.21	TEHTEC			R4201	rpri	22C00017	C	0
588			0.96	61	MBM	6 03H	+17.70	TEHTEC			R4201	rpri	22C00017	C	0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 11:46

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final — PAGE 13

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
589	25	53	0.31	135	12	P2 02C	+0.93	TEHTEC			W4892	rpri	22C00018	C 0
590			0.23	111	WAR	2 02C	+0.93	02C02C			S7752	resc	22C00085	C 5
591	29	53	0.16	76	SCI	P1 TSH	+0.02	TSHTSH	0.3		S7752	resc	22H00004	H 0
592			0.35	90	SCI	1 TSH	+0.02	TSHTSH	0.4		S7752	resc	22H00004	H 0
593			0.14	100	PID	P1 TSH	+0.02	TSHTSH			B3720	resc	22H00063	H99
594	39	53	0.57	78	MBM	5 TSH	+20.86	TEHTEC			B3720	resc	22C00015	C 0
595			0.59	78	MBM	5 04H	+19.78	TEHTEC			B3720	resc	22C00015	C 0
596	43	53	1.00	79	MBM	5 03C	+11.08	TEHTEC			B3720	resc	22C00015	C 0
597	101	53	0.44		17	P2 DC	+1.03	TEHTEC			H2131	resc	22C00055	C 0
598			0.32	64	WAR	P4 DC	+1.25	DC DC			A9608	resc	22C00087	C 5
599	121	53	0.59	3	IDM	2 TSC	-1.80	TECTSC			B3720	resc	22C00081	C 3
600			5.72	16	NRC	2 TSC	+0.00	TEHTEC			R4201	rpri	22C00065	C 0
601	125	53	0.62	79	MBM	6 05H	+13.68	TEHTEC			H2131	resc	22C00065	C 0
602	129	53	0.99	65	MBM	5 TSH	+5.53	TEHTEC			H2131	resc	22C00065	C 0
603	8	54	0.43	101	INR	5 01H	+4.63	TECTEH			M1680	reso	22H00131	C 0
604			0.73	52	MBM	6 01H	+14.20	TECTEH			M1680	reso	22H00131	C 0
605	16	54	1.28	182	INR	P1 06H	+8.36	TECTEH			M1680	reso	22H00131	C 0
606	88	54	0.23	93	SCI	1 TSH	+0.04	TSHTSH	0.4		S7752	reso	22H00044	H 0
607			0.20	72	SCI	P1 TSH	+0.04	TSHTSH	0.3		S7752	reso	22H00044	H 0
608			0.15	90	PID	P1 TSH	+0.04	TSHTSH			L2157	rpri	22H00063	H99
[illegible]			0.15	114	WAR	P4 VC	-1.61	VC DC			J6276	rpri	22C00194	C 5
61[illegible]			0.17	97	DSI	P1 VC	-1.24	TECTEH			J6276	rpri	22H00133	C 0
611	92	54	0.49	82	MBM	6 04H	+25.80	TEHTEC			H2131	resc	22C00055	C 0
612	98	54	1.58	87	MBM	5 02C	+20.89	TEHTEC			R6452	resc	22C00054	C 0
613	102	54	0.88	75	MBM	6 04C	+18.43	TEHTEC			R6452	resc	22C00054	C 0
614	118	54	0.39	77	MBM	5 06H	+17.86	TEHTEC			R6452	resc	22C00054	C 0
615	120	54	11.69	183	INR	P1 09H	+0.41	TEHTEC			B1055	rpri	22C00064	C 0
616	7	55	1.96	86	MBM	5 01H	+20.30	TECTEH			K7060	resc	22H00132	C 0
617			1.03	83	MBM	5 01H	+21.91	TECTEH			K7060	resc	22H00132	C 0
618	67	55	0.54	90	MBM	5 01H	+7.38	TEHTEC			R6452	resc	22C00054	C 0
619	85	55	0.47	86	MBM	5 03H	+20.51	TEHTEC			H2131	resc	22C00055	C 0
620	89	55	1.07	86	MBM	5 05C	+11.02	TEHTEC			H2131	reso	22C00055	C 0
621	111	55	0.38	62	NQI	5 02H	+1.86	TEHTEC			R6452	reso	22C00054	C 0
622					NDF	02H	+1.86	03H02H			S1848	rpri	22H00066	H 4
623	115	55			OBS	DH	-25.00	DHTEC			H2131	resc	22C00054	C 0
624			0.52	50	DSI	P1 09C	+0.02	TEHTEC			B6937	rsec	22C00064	C 0
625					NDF	09C	+0.02	09C09C			M9082	rpri	22C00085	C 5
626			0.51	47	DSI	P1 09C	+0.09	DH TEC			H2131	resc	22C00054	C 0
627					NDF	09C	+0.09	09C09C			M9082	rpri	22C00085	C 5
628	121	55	1.26	65	MBM	5 06C	+9.39	TEHTEC			A9608	resc	22C00064	C 0
629			4.43	23	NRC	2 TSC	+0.00	TEHTEC			B6937	rsec	22C00064	C 0
630	131	55	0.93	75	MBM	5 TSH	+22.64	TEHTEC			H2131	resc	22C00065	C 0
631	42	56	0.49	88	MBM	5 02H	+12.32	TEHTEC			B3720	resc	22C00018	C 0
632	80	56	0.44	83	MBM	6 04H	+7.78	TEHTEC			R6452	resc	22C00054	C 0
633	84	56	0.41	83	MBM	5 03H	+16.14	TEHTEC			R6452	resc	22C00054	C 0
634	96	56	0.72	79	MBM	5 07H	+21.67	TEHTEC			R6452	resc	22C00054	C 0
	108	56	0.56	88	MBM	5 03C	+28.34	TEHTEC			H2131	resc	22C00055	C 0
636	110	56	0.53	71	MBM	5 01H	+24.35	TEHTEC			T0042	resc	22C00054	C 0
637	120	56	0.58	65	MBM	5 04C	+22.08	TEHTEC			H2131	resc	22C00065	C 0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:46

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
638	25	57	0.46	67	NQI	P1 TSH	+1.02	TEHTEC			W4881	rsec	22C00018	C 0
639					NDF	TSH	+1.02	TSHTSH			H2131	reso	22H00006	H 0
640	49	57	0.77	79	DSI	P1 01H	+0.60	TEHTEC			J6276	rpri	22C00018	C 0
641			0.25	71	MAI	1 01H	+0.65	01H01H	0.4		C3340	reso	22H00065	H 4
642			0.44	108	MAI	2 01H	+0.65	01H01H	0.6		C3340	reso	22H00065	H 4
643			0.41	103	PID	4 01H	+0.65	01H01H			O1057	rpri	22H00092	H99
644	67	57	1.04	78	MBM	5 01H	+24.07	TEHTEC			R6452	reso	22C00054	C 0
645	77	57	1.08	74	MBM	6 03C	+16.35	TEHTEC			H2131	reso	22C00055	C 0
646	87	57	0.47	98	INR	6 TSC	+18.77	TEHTEC			N0942	rpri	22C00054	C 0
647	89	57	1.69	57	MBM	6 03C	+3.04	TEHTEC			H2131	reso	22C00055	C 0
648	121	57	0.55	64	MBM	5 04C	+32.82	TEHTEC			H2131	reso	22C00065	C 0
649			5.12	24	NRC	2 TSC	+0.00	TEHTEC			R4201	rpri	22C00065	C 0
650	129	57	0.60	77	MBM	5 03C	+4.89	TEHTEC			H2131	reso	22C00065	C 0
651	26	58	1.10	83	MBM	5 03H	+23.40	TEHTEC			B3720	reso	22C00018	C 0
652	62	58	0.88	70	MBM	5 07H	+21.41	TEHTEC			T0042	reso	22C00053	C 0
653	102	58			OBS	P1 DH	-17.49	DHTEC			L2157	rpri	22C00053	C 0
654	114	58	0.89	79	MBM	6 06H	+7.16	TEHTEC			T0042	reso	22C00053	C 0
655	11	59	0.72	73	MBM	6 03C	+8.70	TECTEH			M1680	reso	22H00131	C 0
656	13	59	0.69	80	MBM	5 02C	+6.86	TECTEH			K7060	reso	22H00132	C 0
657	77	59	1.56	57	MBM	6 07C	+20.51	TEHTEC			T0042	reso	22C00053	C 0
6[illegible]	93	59	0.31	61	MBM	5 TSC	+12.62	TEHTEC			T0042	reso	22C00053	C 0
6[illegible]			0.47	71	MBM	6 TSC	+34.30	TEHTEC			T0042	reso	22C00053	C 0
660			0.62	65	MBM	6 TSC	+35.24	TEHTEC			T0042	reso	22C00053	C 0
661	117	59	0.53	84	MBM	5 05C	+5.51	TEHTEC			T0042	reso	22C00053	C 0
662			0.47	84	MBM	5 04C	+10.63	TEHTEC			T0042	reso	22C00053	C 0
663			1.18	85	MBM	5 02C	+19.36	TEHTEC			T0042	reso	22C00053	C 0
664			0.65	86	MBM	5 TSC	+14.24	TEHTEC			T0042	reso	22C00053	C 0
665			0.69	66	MBM	6 TSC	+25.40	TEHTEC			T0042	reso	22C00053	C 0
666	121	59	4.97	27	NRC	2 TSC	+0.00	TEHTEC			R4201	rpri	22C00065	C 0
667	8	60	0.23	85	NQI	P1 TSH	+1.66	TECTEH			L6066	rsec	22H00143	C 0
668					SAI	1 TSH	+2.07	TSHTSH	0		S7752	reso	22H00102	H 0
669			0.15	119	SAI	2 TSH	+2.07	TSHTSH	0.2		S7752	reso	22H00102	H 0
670			0.23	129	PID	4 TSH	+2.07	TSHTSH			F7467	rsec	22H00172	H99
671	24	60	0.25	28	SCI	P1 TSH	-0.44	TSHTSH	0.2	PWSCC	C3340	reso	22H00005	H 0
672			0.20	15	SCI	1 TSH	-0.44	TSHTSH	0.3	PWSCC	C3340	reso	22H00005	H 0
673			0.51	27	PID	P1 TSH	-0.44	TSHTSH			B3720	reso	22H00063	H99
674	54	60	2.76	60	INR	P3 TSH	+0.08	TEHTEC			B3720	reso	22C00018	C 0
675	62	60	0.22	80	MBM	5 05H	+16.50	TEHTEC			T0042	reso	22C00053	C 0
676			0.49	64	MBM	5 05H	+17.69	TEHTEC			T0042	reso	22C00053	C 0
677	126	60	0.55	5	INR	P1 TSH	+0.82	TEHTEC			R4201	rpri	22C00065	C 0
678	7	61	0.66	90	MBM	6 TSC	+35.63	TECTEH			K7060	reso	22H00132	C 0
679	35	61	0.21	20	SAI	2 TSH	-0.66	TSHTSH	0.2	PWSCC	C3340	reso	22H00005	H 0
680			0.11	7	SAI	1 TSH	-0.66	TSHTSH	0.3	PWSCC	C3340	reso	22H00005	H 0
681			0.55	22	PID	4 TSH	-0.66	TSHTSH			L2157	rpri	22H00063	H99
682	55	61	1.92	100	INR	P3 TSH	-0.06	TEHTEC			B3720	reso	22C00017	C 0
683	81	61	0.64	78	MBM	5 06C	+7.06	TEHTEC			T0042	reso	22C00053	C 0
			1.15	62	MBM	6 06C	+15.08	TEHTEC			T0042	reso	22C00053	C 0
685	83	61	0.69	64	MBM	5 TSH	+7.25	TEHTEC			T0042	reso	22C00052	C 0
686	85	61	0.81	85	MBM	5 05H	+4.45	TEHTEC			T0042	reso	22C00053	C 0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 11:46

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final — PAGE 15

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
687			0.77	56	MBM	6 06C	+11.04	TEHTEC			T0042	reso	22C00053	C 0
688	87	61	1.07	70	MBM	6 03H	+22.03	TEHTEC			T0042	reso	22C00052	C 0
689			1.36	75	MBM	6 02C	+24.69	TEHTEC			T0042	reso	22C00052	C 0
690	89	61	0.61	70	MBM	6 07H	+11.75	TEHTEC			T0042	reso	22C00053	C 0
691			1.18	66	MBM	6 08H	+6.16	TEHTEC			T0042	reso	22C00053	C 0
692			0.50	76	MBM	5 VH	+19.48	TEHTEC			T0042	reso	22C00053	C 0
693	121	61	5.54	23	NRC	2 TSC	+0.00	TEHTEC			B6937	rsec	22C00064	C 0
694	26	62	0.62	85	MBM	5 03C	+12.36	TEHTEC			B3720	reso	22C00018	C 0
695	58	62	2.98	107	INR	P3 TSH	+0.10	TEHTEC			B3720	reso	22C00018	C 0
696	82	62	0.63	75	MBM	5 01H	+35.51	TEHTEC			T0042	reso	22C00053	C 0
697			0.57	61	MBM	5 01H	+36.41	TEHTEC			T0042	reso	22C00053	C 0
698			1.61	76	MBM	6 04H	+6.82	TEHTEC			T0042	reso	22C00053	C 0
699			0.74	72	MBM	6 05H	+9.98	TEHTEC			T0042	reso	22C00053	C 0
700			0.44	79	MBM	5 05H	+33.13	TEHTEC			T0042	reso	22C00053	C 0
701			0.38	83	MBM	5 05H	+34.22	TEHTEC			T0042	reso	22C00053	C 0
702			0.45	69	MBM	5 05H	+37.36	TEHTEC			T0042	reso	22C00053	C 0
703			0.85	84	MBM	5 07H	+14.73	TEHTEC			T0042	reso	22C00053	C 0
704					INF	5 DH	+19.47	TEHTEC	HR		T0042	reso	22C00053	C 0
705			2.05	75	MBM	6 VH	+13.25	TEHTEC			T0042	reso	22C00053	C 0
706			0.46	80	MBM	5 VH	+18.79	TEHTEC			T0042	reso	22C00053	C 0
[illegible]			1.16	63	MBM	6 07C	+5.63	TEHTEC			T0042	reso	22C00053	C 0
70[illegible]			1.60	81	MBM	6 03C	+10.25	TEHTEC			T0042	reso	22C00053	C 0
709			1.57	82	MBM	6 03C	+30.95	TEHTEC			T0042	reso	22C00053	C 0
710			1.16	78	MBM	6 TSC	+18.56	TEHTEC			T0042	reso	22C00053	C 0
711	96	62	0.50	70	MBM	6 01C	+20.98	TEHTEC			T0042	reso	22C00052	C 0
712			0.28	71	MBM	5 01C	+24.87	TEHTEC			T0042	reso	22C00052	C 0
713	108	62	0.88	85	MBM	6 06C	+2.11	TEHTEC			T0042	reso	22C00052	C 0
714	110	62	0.97	83	MBM	5 04H	+20.38	TEHTEC			T0042	reso	22C00053	C 0
715			0.63	80	MBM	5 04H	+21.83	TEHTEC			T0042	reso	22C00053	C 0
716			1.25	85	MBM	5 05C	+15.13	TEHTEC			T0042	reso	22C00053	C 0
717			0.57	68	MBM	6 05C	+31.79	TEHTEC			T0042	reso	22C00053	C 0
718	126	62	0.48	73	MBM	6 02C	+3.82	TEHTEC			H2131	reso	22C00065	C 0
719	41	63	0.72	91	MBM	5 05C	+5.98	TEHTEC			C3340	reso	22C00020	C 0
720	53	63	1.03	55	MBM	5 VM	+0.94	TEHTEC			C3340	reso	22C00020	C 0
721	77	63	0.60	79	MBM	5 05H	+20.60	TEHTEC			T0042	reso	22C00053	C 0
722			0.51	72	MBM	5 07H	+22.85	TEHTEC			T0042	reso	22C00053	C 0
723			0.53	55	MBM	5 06C	+8.46	TEHTEC			T0042	reso	22C00053	C 0
724	79	63	1.37	69	MBM	6 07H	+23.26	TEHTEC			T0042	reso	22C00052	C 0
725			1.47	59	MBM	6 05C	+1.91	TEHTEC			T0042	reso	22C00052	C 0
726	83	63	0.69	84	MBM	5 04C	+2.41	TEHTEC			T0042	reso	22C00052	C 0
727	85	63	0.68	81	MBM	5 04C	+31.84	TEHTEC			T0042	reso	22C00053	C 0
728	97	63	0.27	79	MBM	5 02H	+33.74	TEHTEC			T0042	reso	22C00053	C 0
729	101	63	1.59	72	MBM	6 05H	+10.18	TEHTEC			T0042	reso	22C00053	C 0
730	109	63	0.52	83	19	P2 VM	-1.81	TEHTEC			L2157	rpri	22C00053	C 0
731			0.44	86	WAR	P4 VM	-1.81	VC VM			H2131	reso	22H00068	H 4
732	121	63	3.98	27	NRC	2 TSC	+0.00	TEHTEC			B6937	rsec	22C00064	C 0
	123	63	0.91	85	MBM	5 DH	+20.00	TEHTEC			H2131	reso	22C00065	C 0
734	125	63	0.80	86	MBM	5 02H	+15.68	TEHTEC			A9608	reso	22C00064	C 0
735	135	63	0.51		PLP	9 TSH	+0.47	TSHTSH			B6768	rpri	22H00179	H 0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:46

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
736		0.56		PLP	9 TSH	+0.93	TSHTSH			B6768	rpri	22H00179	H 0
737	56		64	INR	P3 TSH	+0.10	TEHTEC			D4576	rsec	22C00019	C 0
738	58	5.52	64	51 INR	P3 TSH	+0.14	TEHTEC			C3340	reso	22C00020	C 0
739	72	0.52	64	65 MBM	5 02H	+20.75	TEHTEC			B3720	reso	22C00051	C 0
740		0.58		76 MBM	5 05H	+13.42	TEHTEC			B3720	reso	22C00051	C 0
741	84	0.95	64	87 MBM	5 05H	+10.37	TEHTEC			B3720	reso	22C00051	C 0
742		0.63		74 MBM	6 05C	+25.61	TEHTEC			B3720	reso	22C00051	C 0
743	100	0.49	64	88 MBM	5 04H	+27.07	TEHTEC			B3720	reso	22C00051	C 0
744		0.65		82 MBM	5 05H	+15.01	TEHTEC			B3720	reso	22C00051	C 0
745	108	0.44	64	83 MBM	5 03C	+17.63	TEHTEC			B3720	reso	22C00051	C 0
746	126	1.09	64	84 MBM	5 07H	+7.18	TEHTEC			H2131	reso	22C00065	C 0
747		1.45		63 MBM	6 03C	+26.16	TEHTEC			H2131	reso	22C00065	C 0
748	132	0.81	64	1 IDM	2 TSH	+3.87	TSHTSH			B3720	reso	22H00179	H 0
749	134	0.93	64	PLP	9 TSH	+0.53	TSHTSH			B3720	reso	22H00179	H 0
750	136	1.05	64	PLP	9 TSH	+1.00	TSHTSH			B6768	rpri	22H00179	H 0
751		2.64		82 MBM	6 VH	+25.15	TEHTEC			H2131	reso	22C00065	C 0
752	45	0.78	65	94 MBM	5 05C	+11.96	TEHTEC			C3340	reso	22C00020	C 0
753	87	0.67	65	82 MBM	6 04C	+36.17	TEHTEC			B3720	reso	22C00050	C 0
754	109	0.45	65	86 MBM	5 VM	+18.06	TEHTEC			B3720	reso	22C00051	C 0
755	111	0.31	65	67 MBM	5 03H	+18.44	TEHTEC			K7060	reso	22C00096	C 0
7	121	5.15	65	22 NRC	2 TSC	+0.00	TEHTEC			R4201	rpri	22C00065	C 0
7	135	0.27	65	PLP	9 TSH	+0.12	TSHTSH			B6768	rpri	22H00179	H 0
758	137	0.33	65	PLP	9 TSH	+0.21	TSHTSH			B6768	rpri	22H00179	H 0
759	68	0.45	66	75 MBM	5 03C	+6.35	TEHTEC			B3720	reso	22C00050	C 0
760	76	0.42	66	84 MBM	5 01H	+28.47	TEHTEC			B3720	reso	22C00050	C 0
761	86	0.56	66	77 MBM	5 VM	+19.14	TEHTEC			B3720	reso	22C00051	C 0
762	104	0.62	66	77 MBM	5 VC	+4.33	TEHTEC			B3720	reso	22C00050	C 0
763	110	0.56	66	77 MBM	5 04C	+5.24	TEHTEC			B3720	reso	22C00051	C 0
764		1.39		82 MBM	5 03C	+23.92	TEHTEC			B3720	reso	22C00051	C 0
765		1.08		81 MBM	5 03C	+27.80	TEHTEC			B3720	reso	22C00051	C 0
766		0.56		80 MBM	5 02C	+24.96	TEHTEC			B3720	reso	22C00051	C 0
767	134	0.23	66	PLP	9 TSH	+0.11	TSHTSH			B6768	rpri	22H00179	H 0
768	31	1.35	67	81 MBM	6 01C	+28.94	TEHTEC			C3340	reso	22C00019	C 0
769	77	0.81	67	79 MBM	5 05H	+31.01	TEHTEC			B3720	reso	22C00051	C 0
770		0.38		87 MBM	5 01C	+23.71	TEHTEC			B3720	reso	22C00051	C 0
771	81	0.50	67	71 MBM	5 03C	+26.73	TEHTEC			B3720	reso	22C00051	C 0
772		0.51		68 MBM	5 02C	+21.18	TEHTEC			B3720	reso	22C00051	C 0
773	89	0.54	67	89 MBM	5 04H	+8.31	TEHTEC			B3720	reso	22C00051	C 0
774	111	0.65	67	81 MBM	5 04H	+31.37	TEHTEC			B3720	reso	22C00050	C 0
775	121	6.11	67	19 NRC	2 TSC	+0.00	TEHTEC			R4201	rpri	22C00065	C 0
776	135	0.64	67	79 MBM	5 03C	+22.95	TEHTEC			A9608	reso	22C00064	C 0
777	137	0.16	67	65 SVI	2 TSC	+0.07	TSCTSC	0.2		S7752	reso	22C00161	C 3
778				SVI	1 TSC	+0.07	TSCTSC	0		S7752	reso	22C00161	C 3
779		0.18		41 PID	4 TSC	+0.07	TSCTSC			J6276	rpri	22C00189	C99
780	26	0.48	68	86 MBM	5 01C	+10.61	TEHTEC			C3340	reso	22C00020	C 0
781	34	0.25	68	73 MAI	2 TSH	+1.60	TSHTSH	0.4		C3340	reso	22H00008	H 0
		0.20		38 MAI	1 TSH	+1.60	TSHTSH	0.4		C3340	reso	22H00008	H 0
783		0.22		120 PID	4 TSH	+1.60	TSHTSH			L2157	rpri	22H00063	H99
784	54	0.66	68	INR	6 02H	+31.37	TEHTEC			D4576	rsec	22C00020	C 0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 11:46

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final — PAGE 17

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
785	64	68	1.29	69	MBM	6	03H	+17.78	TEHTEC			B3720	reso	22C00050	C 0
786	88	68	0.38	87	MBM	5	07H	+14.38	TEHTEC			B3720	reso	22C00050	C 0
787			0.54	46	MBM	6	02C	+32.40	TEHTEC			B3720	reso	22C00050	C 0
788	118	68			INF		07H	+11.29	TEHTEC	HR		M1680	reso	22C00051	C 0
789	120	68	0.58	78	MBM	5	03C	+22.22	TEHTEC			A9608	reso	22C00064	C 0
790	136	68	0.25	102	SVI	2	TSC	+0.06	TSCTSC	0.3		S7752	reso	22C00160	C 3
791			0.34	124	SVI	1	TSC	+0.06	TSCTSC	0.3		S7752	reso	22C00160	C 3
792			0.27	124	PID	4	TSC	+0.06	TSCTSC			J6276	rpri	22C00189	C99
793	138	68	0.17	62	SVI	2	TSC	+0.10	TSCTSC	0.2		S7752	reso	22C00161	C 3
794					SVI	1	TSC	+0.10	TSCTSC	0		S7752	reso	22C00161	C 3
795			0.12	110	PID	4	TSC	+0.10	TSCTSC			J6276	rpri	22C00189	C99
796	47	69	1.50	82	MBM	6	05C	+2.48	TEHTEC			C3340	reso	22C00019	C 0
797	57	69	0.63	99	MBM	5	03H	+34.37	TEHTEC			C3340	reso	22C00020	C 0
798	63	69	0.20	133	MAI	2	TSH	+0.30 TO+0.88	TSHTSH	0.2		K7060	reso	22H00048	H 0
799					MAI	1	TSH	+0.30 TO+0.88	TSHTSH	0.0		K7060	reso	22H00048	H 0
800			0.16	126	PID	4	TSH	+0.30 TO+0.88	TSHTSH			L2157	rpri	22H00063	H99
801	85	69	0.63	87	MBM	5	TSH	+25.75	TEHTEC			B3720	reso	22C00051	C 0
802	111	69	1.11	78	MBM	6	03H	+14.23	TEHTEC			B3720	reso	22C00050	C 0
803			0.34	78	MBM	5	03H	+17.51	TEHTEC			B3720	reso	22C00050	C 0
804	113	69	0.93	79	MBM	5	04H	+13.38	TEHTEC			B3720	reso	22C00051	C 0
[illegible]	121	69	4.03	30	NRC	2	TSC	+0.00	TEHTEC			B6937	rsec	22C00064	C 0
8[illegible]	127	69	0.70	75	MBM	6	05H	+11.63	TEHTEC			A9608	reso	22C00064	C 0
807	52	70	0.47	86	MBM	5	02C	+17.39	TECTEH			K7060	reso	22H00135	C 0
808	54	70	0.62	76	MBM	5	01H	+29.44	TECTEH			A9608	reso	22H00136	C 0
809			0.84	75	MBM	5	01H	+34.43	TECTEH			A9608	reso	22H00136	C 0
810			1.13	84	MBM	5	02H	+23.30	TECTEH			A9608	reso	22H00136	C 0
811			0.32	123	WAR	4	03H	-0.50	03H03H			A9608	reso	22H00183	H 4
812			0.98	147	DSI	P1	03H	-0.49	TECTEH			L2157	rpri	22H00136	C 0
813	56	70	1.19	49	MBM	5	03H	+5.15	TECTEH			K7060	reso	22H00135	C 0
814			0.96	43	MBM	5	03H	+8.21	TECTEH			K7060	reso	22H00135	C 0
815			0.82	45	MBM	5	03H	+10.36	TECTEH			K7060	reso	22H00135	C 0
816	64	70	0.45	148	INR	P1	TSH	+1.62	TEHTEC			B3720	reso	22C00044	C 0
817	82	70	0.66	81	MBM	5	TSH	+8.33	TEHTEC			B3720	reso	22C00045	C 0
818	106	70	0.67	86	MBM	5	03H	+20.10	TEHTEC			B3720	reso	22C00045	C 0
819	136	70	0.23		PLP	9	TSH	+0.21	TSHTSH			B6768	rpri	22H00179	H 0
820			0.38		PLP	9	TSH	+0.93	TSHTSH			B6768	rpri	22H00179	H 0
821	138	70	1.18		PLP	9	TSH	+0.89	TSHTSH			B6768	rpri	22H00179	H 0
822	41	71	0.17	104	MAI	2	TSH	+1.80 TO+3.22	TSHTSH	0.2		C3340	reso	22H00007	H 0
823			0.28	89	MAI	1	TSH	+1.80 TO+3.22	TSHTSH	0.3		C3340	reso	22H00007	H 0
824			0.12	92	PID	4	TSH	+1.80 TO+3.22	TSHTSH			L2157	rpri	22H00063	H99
825	61	71	1.12	83	MBM	6	03H	+2.94	TEHTEC			B3720	reso	22C00045	C 0
826			1.33	85	MBM	6	03H	+8.54	TEHTEC			B3720	reso	22C00045	C 0
827	69	71	3.17	114	INR	P3	TSH	+0.08	TEHTEC			B3720	reso	22C00045	C 0
828			0.44	69	MBM	6	01H	+20.89	TEHTEC			B3720	reso	22C00045	C 0
829			0.99	76	MBM	6	TSC	+12.07	TEHTEC			B3720	reso	22C00045	C 0
830	79	71	1.43	75	MBM	6	TSH	+21.95	TEHTEC			B3720	reso	22C00044	C 0
			0.58	64	MBM	5	01H	+5.71	TEHTEC			B3720	reso	22C00044	C 0
832			0.79	65	MBM	5	01H	+8.25	TEHTEC			B3720	reso	22C00044	C 0
833			0.48	59	MBM	5	01H	+12.80	TEHTEC			B3720	reso	22C00044	C 0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:46

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
834			0.52	78	MBM	5 01H	+13.71	TEHTEC			B3720	reso	22C00044	C 0
835			0.44	85	MBM	5 02H	+5.01	TEHTEC			B3720	reso	22C00044	C 0
836			0.64	75	MBM	5 02C	+32.73	TEHTEC			B3720	reso	22C00044	C 0
837	85	71	0.10	107	SAI	2 TSH	+0.53	TSHTSH	0.3		K7060	reso	22H00051	H 0
838					SAI	1 TSH	+0.53	TSHTSH	0.0		K7060	reso	22H00051	H 0
839			0.14	92	PID	4 TSH	+0.53	TSHTSH			O1057	rpri	22H00092	H99
840	89	71	0.90	41	NQI	P1 TSH	+1.30	TEHTEC			R4201	rpri	22C00045	C 0
841					NDF	TSH	+1.30	TSHTSH			A9608	reso	22H00051	H 0
842	97	71	0.61	78	MBM	6 01C	+6.30	TEHTEC			B3720	reso	22C00045	C 0
843	103	71	0.60	72	MBM	5 04H	+30.69	TEHTEC			B3720	reso	22C00044	C 0
844	107	71	0.85	81	MBM	6 07H	+21.24	TEHTEC			B3720	reso	22C00044	C 0
845			0.46	111	DSI	P1 09C	-0.06	TEHTEC			S1848	rpri	22C00044	C 0
846					NDF	09C	-0.06	09C09C			S7752	reso	22C00085	C 5
847	111	71	0.93	84	MBM	6 01C	+14.95	TEHTEC			B3720	reso	22C00044	C 0
848	121	71	4.90	20	NRC	2 TSC	-0.02	TEHTEC			B1055	rpri	22C00064	C 0
849	133	71	0.25	82	PLP	9 TSH	+0.35	TSHTSH			L7773	rpri	22H00059	H 0
850			0.59	78	MBM	5 03H	+29.88	TEHTEC			H2131	reso	22C00063	C 0
851	135	71	0.49		PLP	9 TSH	+0.37	TSHTSH			B6768	rpri	22H00179	H 0
852			0.79		PLP	9 TSH	+0.70	TSHTSH			B6768	rpri	22H00179	H 0
853	84	72	0.15	88	SAI	2 TSH	+0.79	TSHTSH	0.2		K7060	reso	22H00051	H 0
8[illegible]					SAI	1 TSH	+0.79	TSHTSH	0.0		K7060	reso	22H00051	H 0
8[illegible]			0.12	97	PID	4 TSH	+0.79	TSHTSH			L2157	rpri	22H00063	H99
856	106	72	0.60	82	MBM	5 09C	+6.61	TEHTEC			B3720	reso	22C00045	C 0
857	122	72	1.21	61	MBM	5 05H	+22.67	TEHTEC			K7060	reso	22C00096	C 0
858	132	72			INF	03H	+4.19	TEHTEC	HR		A9608	reso	22C00062	C 0
859	136	72	0.99		PLP	9 TSH	+0.59	TSHTSH			B6768	rpri	22H00179	H 0
860	138	72	0.75		PLP	9 TSH	+0.39	TSHTSH			B6768	rpri	22H00179	H 0
861	33	73	0.85	39	32	P2 DH	+1.66	TECTEH			L2157	rpri	22H00136	C 0
862			0.40	105	WAR	P4 DH	+1.66	DH DH			A9608	reso	22H00185	H 4
863	53	73	0.64	91	MBM	5 01C	+11.73	TECTEH			A9608	reso	22H00136	C 0
864	65	73	2.21	38	INR	6 02H	+12.62 TO+35.77	TEHTEC			H2131	reso	22C00045	C 0
865			1.82	41	INR	6 04H	+5.08 TO+27.71	TEHTEC			B3720	reso	22C00045	C 0
866			3.32	67	INR	6 04C	+16.86 TO+34.13	TEHTEC			B3720	reso	22C00045	C 0
867			3.17	57	INR	6 01C	+6.10 TO+24.49	TEHTEC			B3720	reso	22C00045	C 0
868	91	73	0.87	78	MBM	5 TSC	+7.87	TEHTEC			B3720	reso	22C00044	C 0
869	97	73	0.92	77	MBM	6 03H	+20.61	TEHTEC			B3720	reso	22C00045	C 0
870	121	73	1.27	82	MBM	5 05H	+32.47	TEHTEC			A9608	reso	22C00062	C 0
871					NDF	07H	+0.43	07H07H			R6452	reso	22H00067	H 4
872			0.31	90	DSI	P1 07H	+0.43	TEHTEC			A9608	reso	22C00062	C 0
873			4.26	24	NRC	2 TSC	+0.00	TEHTEC			S0607	rsec	22C00062	C 0
874	137	73	0.42		PLP	9 TSH	+0.30	TSHTSH			B6768	rpri	22H00179	H 0
875	76	74	0.59	80	MBM	5 03C	+9.13	TEHTEC			B3720	reso	22C00044	C 0
876			0.60	86	MBM	5 02C	+17.87	TEHTEC			B3720	reso	22C00044	C 0
877	78	74	0.59	73	MBM	6 02C	+29.40	TEHTEC			B3720	reso	22C00045	C 0
878	84	74	0.45	143	NQI	P1 TSH	+0.72	TEHTEC			L6066	rsec	22C00044	C 0
879			0.21	111	SAI	2 TSH	+0.94	TSHTSH	0.4		T0042	reso	22H00037	H 0
			0.41	104	SAI	1 TSH	+0.94	TSHTSH	0.4		T0042	reso	22H00037	H 0
881			0.31	116	PID	4 TSH	+0.94	TSHTSH			L2157	rpri	22H00063	H99
882	94	74	0.92	84	MBM	5 03C	+26.71	TEHTEC			B3720	reso	22C00044	C 0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:46

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
883	104	74	0.69	78	MBM	5	01H	+31.46	TEHTEC			B3720	reso	22C00045	C 0
884	130	74	2.23	60	MBM	6	08C	+6.66	TEHTEC			H2131	reso	22C00063	C 0
885	132	74	2.21	83	MBM	6	09H	+3.47	TEHTEC			A9608	reso	22C00062	C 0
886	136	74	0.49		PLP	9	TSH	+0.25	TSHTSH			B6768	rpri	22H00179	H 0
887					INF		TSH	+2.67	TSHTSH	HR		B3720	reso	22H00179	H 0
888	138	74	0.48		PLP	9	TSH	+0.13	TSHTSH			B6768	rpri	22H00179	H 0
889	43	75	0.23	110	SAI	2	TSH	+2.57	TSHTSH	0.2		K7060	reso	22H00050	H 0
890					SAI	1	TSH	+2.57	TSHTSH	0.0		K7060	reso	22H00050	H 0
891			0.23	119	PID	4	TSH	+2.57	TSHTSH			L2157	rpri	22H00063	H99
892	51	75	0.34	62	MBM	5	01H	+19.59	TECTEH			A9608	reso	22H00136	C 0
893			0.58	76	MBM	5	04C	+17.99	TECTEH			A9608	reso	22H00136	C 0
894	85	75	0.11	103	SAI	2	TSH	+0.59	TSHTSH	0.3		T0042	reso	22H00039	H 0
895					SAI	1	TSH	+0.59	TSHTSH	0.0		R6452	reso	22H00039	H 0
896			0.09	115	PID	4	TSH	+0.59	TSHTSH			L2157	rpri	22H00063	H99
897	105	75	0.23	123	VOL	P1	07H	-0.75	07H07H			C3340	reso	22H00094	H 4
898			0.42	119	DSI	P1	07H	-0.69	TEHTEC			R4201	rpri	22C00045	C 0
899	107	75	0.72	86	MBM	5	05C	+3.59	TEHTEC			B3720	reso	22C00044	C 0
900	115	75	0.46	78	MBM	5	04C	+28.64	TEHTEC			B3720	reso	22C00044	C 0
901	119	75	6.51	80	MBM	6	04H	+4.64	TEHTEC			B3720	reso	22C00044	C 0
902	121	75	4.96	21	NRC	2	TSC	+0.00	TEHTEC			S0607	rsec	22C00062	C 0
[illegible]	135	75	0.31	84	PLP	9	TSH	+0.13	TSHTSH			L7773	rpri	22H00057	H 0
904	137	75	0.36		PLP	9	TSH	+0.38	TSHTSH			B6768	rpri	22H00179	H 0
905					INF		TSH	+1.46	TSHTSH	HR		B3720	reso	22H00179	H 0
906	139	75	0.36		PLP	9	TSH	+0.30	TSHTSH			B6768	rpri	22H00179	H 0
907	68	76	0.74	44	INR	P1	TSH	+1.03	TEHTEC			K7060	reso	22C00044	C 0
908	104	76	0.49	13	INR	P1	08H	+3.16 TO+20.32	TEHTEC			R4201	rpri	22C00045	C 0
909	134	76	0.36	264	PLP	9	TSH	+0.15	TSHTSH			L7773	rpri	22H00057	H 0
910	37	77	0.27	57	13	P2	06H	-0.97	TECTEH			L2157	rpri	22H00136	C 0
911			0.26	128	WAR	4	06H	-0.97	06H06H			A9608	reso	22H00183	H 4
912	41	77	0.49	141	NQI	P1	TSH	+1.06	TECTEH			L2157	rpri	22H00136	C 0
913			0.30	97	MAI	2	TSH	+1.37	TSHTSH	0.4		K7060	reso	22H00051	H 0
914			0.26	52	MAI	1	TSH	+1.37	TSHTSH	0.5		K7060	reso	22H00051	H 0
915			0.27	108	PID	4	TSH	+1.37	TSHTSH			L2157	rpri	22H00063	H99
916			1.28	60	MBM	6	03C	+16.18	TECTEH			A9608	reso	22H00136	C 0
917	65	77	0.53	79	MBM	5	01C	+26.27	TEHTEC			B3720	reso	22C00046	C 0
918	71	77	0.36	133	INR	P1	TSH	+0.89	TEHTEC			T0042	reso	22C00047	C 0
919	107	77	2.44	85	MBM	6	03H	+6.12	TEHTEC			B3720	reso	22C00046	C 0
920			0.55	62	MBM	6	03H	+31.11	TEHTEC			B3720	reso	22C00046	C 0
921			0.87	86	MBM	5	04H	+2.88	TEHTEC			B3720	reso	22C00046	C 0
922	109	77	1.13	75	MBM	5	09C	+13.72	TEHTEC			T0042	reso	22C00047	C 0
923	121	77	5.49	22	NRC	2	TSC	+0.00	TEHTEC			S0607	rsec	22C00062	C 0
924	137	77	0.40		PLP	9	TSH	+0.18	TSHTSH			B6768	rpri	22H00179	H 0
925	139	77	0.25		PLP	9	TSH	+0.11	TSHTSH			B6768	rpri	22H00179	H 0
926	36	78	0.67	147	DSI	P1	07H	-1.47	TECTEH			C5184	rsec	22H00135	C 0
927					NDF		07H	-1.47	07H07H			A9608	reso	22H00183	H 4
928	58	78	0.33	70	MBM	5	04C	+7.76	TECTEH			A9608	reso	22H00136	C 0
	62	78	0.61	80	MBM	5	01C	+12.62	TEHTEC			T0042	reso	22C00047	C 0
930	72	78	0.42	83	MBM	5	02H	+10.00	TEHTEC			B3720	reso	22C00046	C 0
931			0.61	86	MBM	5	04H	+31.84	TEHTEC			B3720	reso	22C00046	C 0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 11:46

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final —

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
932			0.55	83	MBM	5	05H	+10.43	TEHTEC			B3720	reso	22C00046	C 0
933			0.39	81	MBM	5	05H	+13.29	TEHTEC			B3720	reso	22C00046	C 0
934			0.53	87	MBM	5	05H	+15.38	TEHTEC			B3720	reso	22C00046	C 0
935			0.46	80	MBM	5	05H	+16.05	TEHTEC			B3720	reso	22C00046	C 0
936			0.78	74	MBM	5	05H	+23.06	TEHTEC			B3720	reso	22C00046	C 0
937			0.39	83	MBM	5	04C	+4.65	TEHTEC			B3720	reso	22C00046	C 0
938	80	78	0.99	81	MBM	5	03H	+14.32	TEHTEC			B3720	reso	22C00046	C 0
939	126	78	0.61	51	INR	P1	09C	+0.00	TEHTEC			R6452	reso	22C00061	C 0
940	128	78	0.18	66	SAI	2	TSC	+0.22	TSCTSC	0.2		H2131	reso	22C00112	C 3
941			0.24	63	SAI	1	TSC	+0.22	TSCTSC	0.3		H2131	reso	22C00112	C 3
942			0.21	62	PID	2	TSC	+0.22	TSCTSC			B3720	reso	22C00123	C99
943	138	78	0.51	79	MBM	5	TSH	+12.09	TEHTEC			R6452	reso	22C00061	C 0
944	140	78	0.60	79	MBM	5	05C	+3.30	TEHTEC			R6452	reso	22C00061	C 0
945	69	79	0.27	107	INR	P1	TSH	+1.73	TEHTEC			T0042	reso	22C00047	C 0
946			0.28	111	INR	P1	TSH	+1.75	TEHTEC			T0042	reso	22C00047	C 0
947	75	79	0.62	79	MBM	5	07C	+8.13	TEHTEC			B3720	reso	22C00046	C 0
948	85	79	0.68	149	NQI	P1	TSH	+0.73	TEHTEC			R4201	rpri	22C00047	C 0
949					NDF		TSH	+0.73	TSHTSH			A9608	reso	22H00039	H 0
950	91	79	0.70	88	MBM	5	04H	+23.13	TEHTEC			B3720	reso	22C00046	C 0
951	103	79	0.50	86	MBM	5	03H	+11.66	TEHTEC			B3720	reso	22C00046	C 0
[illegible]			0.66	88	MBM	6	08H	+19.38	TEHTEC			B3720	reso	22C00046	C 0
953	105	79	0.58	68	MBM	5	05H	+22.90	TEHTEC			T0042	reso	22C00047	C 0
954	109	79	0.92	84	MBM	5	08H	+10.77	TEHTEC			T0042	reso	22C00047	C 0
955	119	79	0.69	78	MBM	5	02C	+26.55	TEHTEC			B3720	reso	22C00046	C 0
956	121	79	1.17	92	INR	6	10H	+3.19	TEHTEC			B1055	rpri	22C00060	C 0
957			4.42	22	NRC	2	TSC	-0.04	TEHTEC			B1055	rpri	22C00060	C 0
958	123	79	0.31	80	MBM	5	02H	+32.17	TEHTEC			R6452	reso	22C00061	C 0
959			0.70	74	MBM	5	03H	+12.90	TEHTEC			R6452	reso	22C00061	C 0
960			0.63	92	MBM	5	VM	+13.43	TEHTEC			R6452	reso	22C00061	C 0
961	78	80	0.11	97	SAI	2	TSH	+1.49	TSHTSH	0.3		T0042	reso	22H00039	H 0
962			0.19	143	SAI	1	TSH	+1.49	TSHTSH	0.3		T0042	reso	22H00039	H 0
963			0.09	96	PID	4	TSH	+1.49	TSHTSH			L2157	rpri	22H00063	H99
964	80	80	0.71	75	MBM	5	03C	+25.14	TEHTEC			B3720	reso	22C00046	C 0
965	98	80	0.38	65	MBM	5	09H	+3.36	TEHTEC			T0042	reso	22C00047	C 0
966	138	80	1.28	90	MBM	5	02C	+36.23	TEHTEC			R6452	reso	22C00061	C 0
967	140	80	4.84	63	INR	P3	TSH	+0.29	TEHTEC			R6452	reso	22C00061	C 0
968	121	81	4.15	26	NRC	2	TSC	+0.00	TEHTEC			B1055	rpri	22C00060	C 0
969	133	81	0.47	90	MVI	P1	TSC	+0.03	TSCTSC	0.5		B3720	reso	22C00081	C 3
970			0.38	137	MVI	1	TSC	+0.03	TSCTSC	0.3		B3720	reso	22C00081	C 3
971			0.46	108	PID	P1	TSC	+0.03	TSCTSC			M9082	rpri	22C00095	C99
972	135	81	0.17	112	SVI	2	TSC	+0.20	TSCTSC	0.3		C3340	reso	22C00080	C 3
973			0.21	40	SVI	1	TSC	+0.20	TSCTSC	0.3		C3340	reso	22C00080	C 3
974			0.16	138	PID	4	TSC	+0.20	TSCTSC			M9082	rpri	22C00095	C99
975	139	81	6.33	7	INR	P3	TSC	-0.30	TEHTEC			R4201	rpri	22C00061	C 0
976	76	82	0.42	116	NQI	5	TSH	+1.17	TEHTEC			B3720	reso	22C00046	C 0
977			0.12	104	SAI	2	TSH	+1.33	TSHTSH	0.3		T0042	reso	22H00038	H 0
					SAI	1	TSH	+1.33	TSHTSH	0		T0042	reso	22H00038	H 0
979			0.10	100	PID	4	TSH	+1.33	TSHTSH			L2157	rpri	22H00063	H99
980	78	82	0.38	88	NQI	P1	TSH	+1.37	TEHTEC			P4634	rsec	22C00047	C 0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:46

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
981			0.10	92	SAI	2 TSH	+1.93	TSHTSH	0.2		T0042	reso	22H00039	H 0
982					SAI	1 TSH	+1.93	TSHTSH	0.0		R6452	reso	22H00039	H 0
983			0.11	77	PID	4 TSH	+1.93	TSHTSH			L2157	rpri	22H00063	H99
984			0.11	86	INR	P1 01H	+0.88	TEHTEC			T0042	reso	22C00047	C 0
985			1.57	93	MBM	5 05C	+29.71	TEHTEC			T0042	reso	22C00047	C 0
986	96	82	0.37	120	NQI	P1 TSC	+20.96	TEHTEC			S1848	rpri	22C00046	C 0
987					NDF	TSC	+20.96	01CTSC			D3858	reso	22C00085	C 5
988	104	82	0.39	93	INR	5 07H	+7.61	TEHTEC			S1848	rpri	22C00046	C 0
989	106	82	0.86	83	MBM	5 06C	+14.97	TEHTEC			T0042	reso	22C00047	C 0
990	120	82	0.56	83	MBM	5 07H	+15.14	TEHTEC			R6452	reso	22C00060	C 0
991	124	82	0.40	81	MBM	5 01H	+11.77	TEHTEC			R6452	reso	22C00060	C 0
992	132	82	0.72	87	MBM	5 10H	+4.63	TEHTEC			R6452	reso	22C00060	C 0
993	138	82			INF	TSH	+0.22	TSHTSH	HR		B3720	reso	22H00179	H 0
994			0.25		PLP	9 TSH	+0.40	TSHTSH			B3720	reso	22H00179	H 0
995	140	82	7.05	57	INR	P3 TSH	+0.41	TEHTEC			A9608	reso	22C00061	C 0
996	81	83	0.47	63	NQI	P1 TSH	+0.95	TEHTEC			R4201	rpri	22C00049	C 0
997			0.14	76	SAI	2 TSH	+0.98	TSHTSH	0.3		T0042	reso	22H00039	H 0
998			0.19	118	SAI	1 TSH	+0.98	TSHTSH	0.3		T0042	reso	22H00039	H 0
999			0.08	114	PID	4 TSH	+0.98	TSHTSH			L2157	rpri	22H00063	H99
1000	91	83	1.02	84	MBM	6 VH	+3.32	TEHTEC			B3720	reso	22C00048	C 0
1'	109	83	1.46	86	MBM	5 04H	+7.13	TEHTEC			T0042	reso	22C00049	C 0
1			0.75	88	MBM	5 04H	+24.20	TEHTEC			T0042	reso	22C00049	C 0
1003			0.42	84	MBM	5 04H	+28.01	TEHTEC			T0042	reso	22C00049	C 0
1004			0.37	84	MBM	5 07H	+20.43	TEHTEC			T0042	reso	22C00049	C 0
1005	111	83	1.49	66	MBM	6 03H	+25.59	TEHTEC			B3720	reso	22C00048	C 0
1006			0.81	83	MBM	5 03H	+26.44	TEHTEC			B3720	reso	22C00048	C 0
1007	121	83	4.10	23	NRC	2 TSC	+0.02	TEHTEC			B1055	rpri	22C00060	C 0
1008	129	83	0.54	71	MBM	5 VC	+9.43	TEHTEC			R6452	reso	22C00061	C 0
1009	133	83	0.28	72	MBM	5 09H	+9.63	TEHTEC			R6452	reso	22C00061	C 0
1010	135	83	0.42	90	PLP	9 TSH	+0.27	TSHTSH			W4881	rsec	22H00057	H 0
1011	137	83	0.34		PLP	9 TSH	+0.37	TSHTSH			B6768	rpri	22H00179	H 0
1012			0.57		PLP	9 TSH	+0.81	TSHTSH			B6768	rpri	22H00179	H 0
1013	42	84	1.16	74	MBM	6 01C	+24.91	TECTEH			A9608	reso	22H00136	C 0
1014	52	84	0.34	82	MBM	5 03H	+25.12	TECTEH			K7060	reso	22H00135	C 0
1015	54	84	1.33	78	MBM	6 03C	+23.05	TECTEH			A9608	reso	22H00136	C 0
1016	62	84	0.26	101	INR	P1 VM	-1.41	TEHTEC			T0042	reso	22C00049	C 0
1017	70	84	0.36	119	SAI	1 TSH	+1.86	TSHTSH	0.2		T0042	reso	22H00039	H 0
1018			0.17	95	SAI	2 TSH	+1.86	TSHTSH	0.3		T0042	reso	22H00039	H 0
1019			0.19	96	PID	4 TSH	+1.86	TSHTSH			L2157	rpri	22H00063	H99
1020			0.11	131	SAI	2 TSH	+2.55	TSHTSH	0.2		T0042	reso	22H00039	H 0
1021					SAI	1 TSH	+2.55	TSHTSH	0.0		R6452	reso	22H00039	H 0
1022			1.28	73	MBM	5 02H	+19.94	TEHTEC			T0042	reso	22C00049	C 0
1023	96	84	0.28	72	MBM	5 03H	+17.77	TEHTEC			B3720	reso	22C00048	C 0
1024	126	84	0.52	76	MBM	5 07H	+18.24	TEHTEC			R6452	reso	22C00061	C 0
1025	140	84	0.74	44	MBM	6 02H	+21.65	TEHTEC			R6452	reso	22C00061	C 0
1026			1.38	85	MBM	5 03H	+18.71	TEHTEC			R6452	reso	22C00061	C 0
	65	85	0.73	84	MBM	5 03H	+8.16	TEHTEC			T0042	reso	22C00049	C 0
1028	79	85			SAI	1 TSH	+0.79	TSHTSH	0		T0042	reso	22H00040	H 0
1029			0.12	89	SAI	2 TSH	+0.79	TSHTSH	0.4		T0042	reso	22H00040	H 0

ROW	LIN		VOLTS	DEG	PCT	CHN		LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG
1030			0.09	74	PID	4	TSH	+0.79		TSHTSH			L2157	rpri	22H00063	H99	
1031			0.46	46	NQI	P1	TSH	+1.29		TEHTEC			L2157	rpri	22C00048	C 0	
1032	99	85	0.95	62	MBM	6	VH	+10.98		TEHTEC			B3720	reso	22C00048	C 0	
1033			1.25	151	DSI	P1	09C	+0.00		TEHTEC			L2157	rpri	22C00048	C 0	
1034					NDF		09C	+0.00		09C09C			M9082	rpri	22C00085	C 5	
1035	107	85	0.62	79	MBM	5	04C	+25.50		TEHTEC			B3720	reso	22C00048	C 0	
1036	121	85	4.90	27	NRC	2	TSC	-0.06		TEHTEC			B6937	rsec	22C00060	C 0	
1037	42	86	0.15	119	SAI	2	TSH	+0.95		TSHTSH	0.3		K7060	reso	22H00051	H 0	
1038					SAI	1	TSH	+0.95		TSHTSH	0.0		K7060	reso	22H00051	H 0	
1039			0.17	127	PID	4	TSH	+0.95		TSHTSH			L2157	rpri	22H00063	H99	
1040	70	86	0.52	112	INR	P1	TSH	+1.76		TEHTEC			T0042	reso	22C00049	C 0	
1041	74	86	0.82	85	MBM	5	TSH	+11.99		TEHTEC			T0042	reso	22C00049	C 0	
1042	84	86			MAI	1	TSH	+0.48	TO+1.06	TSHTSH	0		T0042	reso	22H00040	H 0	
1043			0.13	92	MAI	2	TSH	+0.48	TO+1.06	TSHTSH	0.4		T0042	reso	22H00040	H 0	
1044			0.09	124	PID	4	TSH	+0.48	TO+1.06	TSHTSH			L2157	rpri	22H00063	H99	
1045			0.68	67	INR	P1	TSH	+5.85		TEHTEC			B3720	reso	22C00048	C 0	
1046	90	86	0.21	92	SAI	2	TSH	+0.65		TSHTSH	0.2		T0042	reso	22H00041	H 0	
1047			0.18	96	SAI	1	TSH	+0.65		TSHTSH	0.2		T0042	reso	22H00041	H 0	
1048			0.18	104	PID	4	TSH	+0.65		TSHTSH			L2157	rpri	22H00063	H99	
1049	96	86	0.12	132	NQI	P1	TSC	+1.07		TEHTEC			D3858	reso	22C00048	C 0	
[illegible]			0.10	73	SAI	2	TSC	+1.11		TSCTSC	0.2		S7752	reso	22C00074	C 3	
1051					SAI	1	TSC	+1.11		TSCTSC	0		S7752	reso	22C00074	C 3	
1052			0.09	75	PID	4	TSC	+1.11		TSCTSC			M9082	rpri	22C00083	C99	
1053	116	86	0.62	82	MBM	5	02H	+13.61		TEHTEC			B3720	reso	22C00048	C 0	
1054			0.66	63	MBM	6	DH	+11.30		TEHTEC			B3720	reso	22C00048	C 0	
1055			0.56	69	NQI	5	VH	+28.73		TEHTEC			B3720	reso	22C00048	C 0	
1056					NDF		VH	+28.73		VH VM			O1057	rpri	22H00093	H 4	
1057					OBS		VM	-15.03		VMVM			H2131	reso	22H00069	H 4	
1058	136	86	0.89		PLP	9	TSH	+0.56		TSHTSH			B6768	rpri	22H00179	H 0	
1059	138	86	0.40		PLP	9	TSH	+0.36		TSHTSH			B6768	rpri	22H00179	H 0	
1060	140	86	0.54	78	MBM	5	TSH	+5.24		TEHTEC			R6452	reso	22C00061	C 0	
1061	37	87	0.41	74	MBM	5	01C	+27.29		TECTEH			A9608	reso	22H00136	C 0	
1062	69	87	0.18	74	INR	P1	TSH	+1.37		TEHTEC			T0042	reso	22C00049	C 0	
1063			0.19	91	SAI	2	TSH	+2.25		TSHTSH	0.5		T0042	reso	22H00041	H 0	
1064			0.32	80	SAI	1	TSH	+2.25		TSHTSH	0.5		T0042	reso	22H00041	H 0	
1065			0.21	96	PID	4	TSH	+2.25		TSHTSH			L2157	rpri	22H00063	H99	
1066	75	87	3.18	263	INR	P3	TSH	+0.02		TEHTEC			L2157	rpri	22C00048	C 0	
1067	77	87	0.73	76	MBM	6	03H	+36.71		TEHTEC			T0042	reso	22C00049	C 0	
1068	79	87			INF		08H	+4.31		TEHTEC	HR		B3720	reso	22C00048	C 0	
1069	83	87	0.24	43	MAI	1	TSH	+0.55	TO+1.07	TSHTSH	0.4		T0042	reso	22H00040	H 0	
1070			0.18	101	MAI	2	TSH	+0.55	TO+1.07	TSHTSH	0.4		T0042	reso	22H00040	H 0	
1071			0.17	107	PID	4	TSH	+0.55	TO+1.07	TSHTSH			L2157	rpri	22H00063	H99	
1072			0.47	51	NQI	P1	TSH	+0.89		TEHTEC			L2157	rpri	22C00048	C 0	
1073	87	87	0.59	115	NQI	5	TSH	+0.82		TEHTEC			B3720	reso	22C00048	C 0	
1074			0.29	100	SAI	2	TSH	+0.94		TSHTSH	0.4		T0042	reso	22H00040	H 0	
1075			0.40	81	SAI	1	TSH	+0.94		TSHTSH	0.4		T0042	reso	22H00040	H 0	
			0.28	110	PID	4	TSH	+0.94		TSHTSH			L2157	rpri	22H00063	H99	
1077	89	87	1.08	89	MBM	5	03H	+19.18		TEHTEC			T0042	reso	22C00049	C 0	
1078	101	87	1.02	82	MBM	5	TSH	+3.84		TEHTEC			T0042	reso	22C00049	C 0	

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
1079	121	87	3.80	16	NRC 2	TSC +0.00	TEHTEC			B1055	rpri	22C00060	C 0
1080	36	88	0.36	98	WAR P4	DH +1.61	DH DH			A9608	reso	22H00185	H 4
1081			0.33	151	17 P2	DH +1.62	TECTEH			J6276	rpri	22H00135	C 0
1082	46	88	0.54	85	MBM 5	03C +28.78	TECTEH			A9608	reso	22H00136	C 0
1083	48	88	0.50	100	INR 5	05C +16.98	TECTEH			J6276	rpri	22H00135	C 0
1084	66	88	1.00	88	MBM 5	04C +29.91	TEHTEC			T0042	reso	22C00049	C 0
1085			0.74	76	MBM 5	02C +25.33	TEHTEC			T0042	reso	22C00049	C 0
1086	92	88	2.23	81	MBM 6	TSH +33.80	TEHTEC			H2131	reso	22C00049	C 0
1087			0.75	79	MBM 6	05H +14.53	TEHTEC			T0042	reso	22C00049	C 0
1088	122	88	1.09	87	MBM 5	09C +2.31	TEHTEC			R6452	reso	22C00061	C 0
1089			1.30	95	MBM 5	09C +6.51	TEHTEC			R6452	reso	22C00061	C 0
1090			0.67	91	MBM 5	07C +10.40	TEHTEC			R6452	reso	22C00061	C 0
1091			1.16	83	MBM 5	07C +16.58	TEHTEC			R6452	reso	22C00061	C 0
1092			0.80	77	MBM 5	06C +10.27	TEHTEC			R6452	reso	22C00061	C 0
1093			0.88	93	MBM 5	03C +15.25	TEHTEC			R6452	reso	22C00061	C 0
1094			0.96	92	MBM 5	02C +36.91	TEHTEC			R6452	reso	22C00061	C 0
1095	134	88	0.46	85	MBM 5	VH +25.15	TEHTEC			H2131	reso	22C00061	C 0
1096	138	88	0.74	81	MBM 5	VH +5.86	TEHTEC			R6452	reso	22C00061	C 0
1097			1.25	69	MBM 6	VH +6.95	TEHTEC			R6452	reso	22C00061	C 0
1098	81	89	0.13	71	SAI 2	TSH +1.48	TSHTSH	0.2		T0042	reso	22H00040	H 0
[illegible]					SAI 1	TSH +1.48	TSHTSH	0		T0042	reso	22H00040	H 0
[illegible]			0.07	82	PID 4	TSH +1.48	TSHTSH			L2157	rpri	22H00063	H99
1101	107	89	0.83	85	MBM 6	05H +6.40	TEHTEC			B3720	reso	22C00048	C 0
1102	111	89	0.77	77	MBM 5	08H +11.25	TEHTEC			K7060	reso	22C00096	C 0
1103	113	89	0.86	75	MBM 5	08H +15.85	TEHTEC			T0042	reso	22C00049	C 0
1104	121	89	4.22	28	NRC 2	TSC +0.00	TEHTEC			B1055	rpri	22C00060	C 0
1105	38	90	0.36	131	19 P2	DC +1.50	TECTEH			C5184	rsec	22H00136	C 0
1106			0.28	113	WAR P4	DC +1.58	DC DC			J6276	rpri	22C00194	C 5
1107			0.40	78	MBM 5	TSC +23.45	TECTEH			A9608	reso	22H00136	C 0
1108	64	90	2.18	15	INR P3	TSH -0.08	TEHTEC			R4201	rpri	22C00049	C 0
1109	72	90	0.99	56	MBM 6	03H +19.22	TEHTEC			T0042	reso	22C00049	C 0
1110	80	90	0.33	39	SAI 1	TSH +1.36	TSHTSH	0.6		R6452	reso	22H00040	H 0
1111			0.16	113	SAI 2	TSH +1.36	TSHTSH	0.4		R6452	reso	22H00040	H 0
1112			0.16	103	PID 4	TSH +1.36	TSHTSH			L2157	rpri	22H00063	H99
1113			0.28	59	NQI P1	TSH +1.41	TEHTEC			R4201	rpri	22C00049	C 0
1114	88	90	0.14	88	NQI P1	TSH +0.60	TEHTEC			R4201	rpri	22C00049	C 0
1115			0.32	100	SAI 2	TSH +0.65	TSHTSH	0.4		T0042	reso	22H00041	H 0
1116			0.29	64	SAI 1	TSH +0.65	TSHTSH	0.3		T0042	reso	22H00041	H 0
1117			0.31	96	PID 4	TSH +0.65	TSHTSH			L2157	rpri	22H00063	H99
1118	126	90	0.80	83	MBM 5	04C +30.96	TEHTEC			R6452	reso	22C00061	C 0
1119	128	90	0.51	65	MBM 5	09H +8.67	TEHTEC			R6452	reso	22C00060	C 0
1120	111	91	0.67	75	MBM 6	06C +14.28	TEHTEC			R6452	reso	22C00036	C 0
1121	121	91	0.82	79	MBM 5	04H +26.43	TEHTEC			R6452	reso	22C00060	C 0
1122			0.68	90	MBM 5	04H +31.51	TEHTEC			R6452	reso	22C00060	C 0
1123			4.16	25	NRC 2	TSC +0.00	TEHTEC			B1055	rpri	22C00060	C 0
1124	137	91	0.58	142	DNI P1	04C +11.93	TEHTEC			M2655	rsec	22C00060	C 0
					NDF	04C +11.93	05C04C			M9082	rpri	22C00085	C 5
1126	139	91	1.91	81	MBM 6	04H +6.15	TEHTEC			R6452	reso	22C00061	C 0
1127	42	92	0.17	14	SAI 1	TSH -1.29	TSHTSH	0.2	PWSCC	H2131	reso	22H00051	H 0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 11:46

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final —

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
1128			0.14	16	SAI 2	TSH -1.29		TSHTSH	0.2	PWSCC	M1680	reso	22H00051	H 0
1129			0.38	16	PID 4	TSH -1.29		TSHTSH			L2157	rpri	22H00063	H99
1130	62	92	0.09	124	SAI 2	TSH +4.25		TSHTSH	0.2		S7752	reso	22H00043	H 0
1131					SAI 1	TSH +4.25		TSHTSH	0		S7752	reso	22H00043	H 0
1132			0.09	129	PID 4	TSH +4.25		TSHTSH			L2157	rpri	22H00063	H99
1133	80	92			MAI 1	TSH +0.77	TO+1.74	TSHTSH	0		A9608	reso	22H00042	H 0
1134			0.20	104	MAI 2	TSH +0.77	TO+1.74	TSHTSH	0.2		A9608	reso	22H00042	H 0
1135			0.13	92	PID 4	TSH +0.77	TO+1.74	TSHTSH			L2157	rpri	22H00063	H99
1136			0.36	123	NQI P1	TSH +1.36		TEHTEC			A9608	reso	22C00036	C 0
1137	120	92	0.48	88	MBM 5	VM +24.90		TEHTEC			R6452	reso	22C00060	C 0
1138	122	92	0.70	87	INR 5	04H +5.25		TEHTEC			R4201	rpri	22C00061	C 0
1139			1.68	80	MBM 6	04H +14.32		TEHTEC			R6452	reso	22C00061	C 0
1140			0.86	61	MBM 6	04H +18.77		TEHTEC			R6452	reso	22C00061	C 0
1141	140	92	0.70		PLP 9	TSH +0.28		TSHTSH			B6768	rpri	22H00179	H 0
1142	67	93	0.88	77	MBM 5	03H +27.22		TEHTEC			R6452	reso	22C00036	C 0
1143	75	93	0.21	99	NQI P1	TSH +5.91		TEHTEC			D4576	rsec	22C00036	C 0
1144					NDF	TSH +5.91		01HTSH			S1848	rpri	22H00066	H 4
1145	93	93			PRC			TSCTSC			S7752	reso	22C00114	C 3
1146			0.87	147	NQI P1	TSC +0.99		TEHTEC			G5937	rsec	22C00037	C 0
1147					NDF 2	TSC +0.99		TSCTSC			C3340	reso	22C00084	C 5
[illegible]	121	93	4.02	15	NRC 2	TSC +0.00		TEHTEC			B1055	rpri	22C00060	C 0
1[illegible]	139	93	0.69		PLP 9	TSH +0.31		TSHTSH			B6768	rpri	22H00179	H 0
1150	36	94	0.52	92	MBM 5	01H +21.81		TECTEH			A9608	reso	22H00137	C 0
1151	38	94	0.60	105	MBM 5	04H +2.95		TECTEH			A9608	reso	22H00138	C 0
1152	46	94	0.91	92	MBM 6	06C +17.13		TECTEH			A9608	reso	22H00138	C 0
1153			0.50	65	MBM 5	06C +18.88		TECTEH			A9608	reso	22H00138	C 0
1154	64	94	0.55	85	MBM 5	TSH +30.93		TEHTEC			R6452	reso	22C00036	C 0
1155	72	94	1.66	30	MBM 5	TSC +5.54		TEHTEC			R6452	reso	22C00037	C 0
1156	80	94	0.62	63	MSI 1	TSH +0.50	TO+1.71	TSHTSH	0.4		S7752	reso	22H00042	H 0
1157			0.38	84	MSI 2	TSH +0.50	TO+1.71	TSHTSH	0.7		S7752	reso	22H00042	H 0
1158			0.34	96	PID 4	TSH +0.50	TO+1.71	TSHTSH			L2157	rpri	22H00063	H99
1159			0.60	65	NQI P1	TSH +1.04		TEHTEC			N0942	rpri	22C00036	C 0
1160	120	94	0.82	86	MBM 5	05C +29.18		TEHTEC			R6452	reso	22C00060	C 0
1161			0.54	84	MBM 5	05C +30.60		TEHTEC			R6452	reso	22C00060	C 0
1162	138	94	0.54	110	25 P2	DH +1.88		TEHTEC			R4201	rpri	22C00061	C 0
1163			0.49	120	WAR 2	DH +1.99		DH DH			M1680	reso	22H00182	H 4
1164	45	95	0.64	77	MBM 5	03H +8.15		TECTEH			A9608	reso	22H00138	C 0
1165	53	95	0.77	69	MBM 5	05C +36.99		TECTEH			A9608	reso	22H00138	C 0
1166	61	95	0.42	78	MBM 5	01H +31.04		TEHTEC			R6452	reso	22C00037	C 0
1167	67	95	0.32	90	VOL P1	TSC +2.25		TSCTSC			M9082	rpri	22C00139	C 3
1168			1.58	73	MBM 6	TSC +2.38		TEHTEC			R6452	reso	22C00036	C 0
1169	89	95	0.84	75	MBM 5	01H +14.51		TEHTEC			R6452	reso	22C00037	C 0
1170	103	95	0.88	76	MBM 5	TSH +17.72		TEHTEC			R6452	reso	22C00036	C 0
1171	115	95	0.43	78	NQI P1	09H +11.83		TEHTEC			D4576	rsec	22C00036	C 0
1172					NDF	09H +11.83		DH 09H			O1057	rpri	22H00069	H 4
1173	121	95	6.78	27	NRC 2	TSC +0.00		TEHTEC			B1055	rpri	22C00060	C 0
	129	95	0.76	90	INR 5	05H +20.42		TEHTEC			R6452	reso	22C00060	C 0
1175			1.47	85	MBM 5	06H +19.86		TEHTEC			R6452	reso	22C00060	C 0
1176	137	95	0.41	69	NQI 5	TSH +7.32		TEHTEC			R6452	reso	22C00060	C 0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:46

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG
1177				NDF	TSH	+7.32	TSHTSH			B3720	reso	22H00180	H	4
1178	74	96	0.24	119	INR P2	04H	+0.92	TEHTEC			G5937	rsec	22C00039	C 0
1179	78	96	0.12	120	SAI 2	TSH	+1.06	TSHTSH	0.2		S7752	reso	22H00042	H 0
1180					SAI 1	TSH	+1.06	TSHTSH	0		A9608	reso	22H00042	H 0
1181			0.08	117	PID 4	TSH	+1.06	TSHTSH			L2157	rpri	22H00063	H99
1182	80	96	0.14	96	SAI 2	TSH	+1.04	TSHTSH	0.2		S7752	reso	22H00042	H 0
1183					SAI 1	TSH	+1.04	TSHTSH	0		A9608	reso	22H00042	H 0
1184			0.11	105	PID 4	TSH	+1.04	TSHTSH			L2157	rpri	22H00063	H99
1185					SAI 1	TSH	+1.48	TSHTSH	0		A9608	reso	22H00042	H 0
1186			0.13	88	SAI 2	TSH	+1.48	TSHTSH	0.3		S7752	reso	22H00042	H 0
1187	116	96	1.87	88	MBM 5	08C	+15.05	TEHTEC			R6452	reso	22C00037	C 0
1188	126	96	0.72	186	INR P1	TSH	+1.91	TEHTEC			R4201	rpri	22C00061	C 0
1189			0.13	100	VOL 2	TSH	+2.12	TSHTSH	HR		H2131	reso	22H00057	H 0
1190	128	96	0.82	59	MBM 6	VH	+5.85	TEHTEC			R6452	reso	22C00060	C 0
1191	138	96	0.62	74	MBM 5	08C	+12.80	TEHTEC			R6452	reso	22C00061	C 0
1192	37	97	1.38	82	MBM 5	01H	+11.38	TECTEH			A9608	reso	22H00137	C 0
1193			0.84	80	MBM 5	01H	+14.68	TECTEH			A9608	reso	22H00137	C 0
1194	39	97	0.74	85	MBM 5	01C	+27.43	TECTEH			A9608	reso	22H00138	C 0
1195			0.75	65	MBM 5	01C	+28.63	TECTEH			A9608	reso	22H00138	C 0
1196	77	97	0.62	76	MBM 5	TSH	+22.33	TEHTEC			M1680	reso	22C00039	C 0
[illegible]	79	97	0.17	60	SAI 2	TSH	+0.73	TSHTSH	0.3		T0042	reso	22H00037	H 0
[illegible]					SAI 1	TSH	+0.73	TSHTSH	0		T0042	reso	22H00037	H 0
1199			0.17	56	PID 4	TSH	+0.73	TSHTSH			L2157	rpri	22H00063	H99
1200			0.36	99	SAI 1	TSH	+1.16	TSHTSH	0.3		T0042	reso	22H00037	H 0
1201			0.15	63	SAI 2	TSH	+1.16	TSHTSH	0.4		T0042	reso	22H00037	H 0
1202	97	97	1.62	83	MBM 6	03H	+9.70	TEHTEC			M1680	reso	22C00039	C 0
1203	99	97	0.33	120	NQI P1	DH	+9.90	TEHTEC			D4576	rsec	22C00038	C 0
1204					NDF	DH	+9.90	VH DH			O1057	rpri	22H00068	H 4
1205	121	97	4.77	16	NRC 2	TSC	+0.00	TEHTEC			B1055	rpri	22C00060	C 0
1206	133	97	0.69	84	MBM 6	06C	+3.17	TEHTEC			R6452	reso	22C00061	C 0
1207	46	98	0.72	61	MBM 5	01C	+5.48	TECTEH			A9608	reso	22H00138	C 0
1208			1.13	72	MBM 5	01C	+7.64	TECTEH			A9608	reso	22H00138	C 0
1209	54	98	0.78	81	MBM 5	05C	+5.25	TECTEH			A9608	reso	22H00138	C 0
1210	80	98	0.86	74	MBM 5	02H	+20.40	TEHTEC			M1680	reso	22C00039	C 0
1211	102	98	0.17	35	SAI 1	VH	+2.74	VM VH	0.2		H2131	reso	22H00068	H 4
1212			0.29	104	SAI 2	VH	+2.74	VM VH	0.2		H2131	reso	22H00068	H 4
1213			0.28	104	PID 2	VH	+2.74	DH VM			O1057	rpri	22H00093	H99
1214			0.33	79	NQI 5	VH	+3.02	TEHTEC			K7060	reso	22C00038	C 0
1215			0.38	58	MBM 5	04C	+18.13	TEHTEC			K7060	reso	22C00038	C 0
1216	104	98	1.15	88	MBM 5	07H	+7.43	TEHTEC			M1680	reso	22C00039	C 0
1217	116	98	5.75	41	INR P3	TSC	-0.11	TEHTEC			M1680	reso	22C00039	C 0
1218	29	99	0.19	102	SCI P1	TSC	+0.04	TSCTSC	0.2		A9608	reso	22C00181	C 3
1219					SCI 1	TSC	+0.04	TSCTSC	0		A9608	reso	22C00181	C 3
1220			0.23	145	PID P1	TSC	+0.04	TSCTSC			J6276	rpri	22C00189	C99
1221	77	99	0.56	86	MBM 5	04H	+35.11	TEHTEC			M1680	reso	22C00039	C 0
1222	79	99			SAI 1	TSH	+0.91	TSHTSH	0		C3340	reso	22H00035	H 0
			0.12	76	SAI 2	TSH	+0.91	TSHTSH	0.2		C3340	reso	22H00035	H 0
1224			0.10	71	PID 4	TSH	+0.91	TSHTSH			L2157	rpri	22H00063	H99
1225			0.71	69	MBM 5	02C	+22.26	TEHTEC			K7060	reso	22C00038	C 0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 11:46

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final —

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG
1226		0.91	74	MBM	6	01C +24.28	TEHTEC			K7060	reso	22C00038	C	0
1227	111	0.88	71	MBM	5	02C +20.58	TEHTEC			M1680	reso	22C00039	C	0
1228	121	6.11	20	NRC	2	TSC +0.00	TEHTEC			B1055	rpri	22C00058	C	0
1229	133	0.72	73	MBM	6	06H +17.06	TEHTEC			T0042	reso	22C00059	C	0
1230	26	0.99	111	36	P2	DH -1.84	TSCTEH			L2157	rpri	22H00138	C	0
1231		0.77	82	WAR	P4	DH -1.76	DH DH			A9608	reso	22H00185	H	4
1232		0.46	105	22	P2	VM +1.76	TSCTEH			B3720	reso	22H00138	C	0
1233		0.35	101	WAR	P4	VM +2.29	VM DC			J6276	rpri	22C00194	C	5
1234	60	0.47	143	24	P2	VM -2.06	TECTEH			M0945	rsec	22H00137	C	0
1235		0.47	91	WAR	P4	VM -2.06	DH VM			A9608	reso	22H00185	H	4
1236	96	0.54	72	MBM	5	04H +35.13	TEHTEC			M1680	reso	22C00039	C	0
1237	100	0.83	82	MBM	6	04C +31.73	TEHTEC			M1680	reso	22C00039	C	0
1238	136	0.78	95	MBM	6	07H +16.70	TEHTEC			A9608	reso	22C00058	C	0
1239	29	0.10	119	SAI	2	TSC +0.15	TSCTSC	0.1		M1680	reso	22C00184	C	3
1240				SAI	1	TSC +0.15	TSCTSC	0.0		M1680	reso	22C00184	C	3
1241		0.12	127	PID	4	TSC +0.15	TSCTSC			J6276	rpri	22C00189	C	99
1242	59	0.97	76	MBM	6	01C +26.92	TECTEH			A9608	reso	22H00137	C	0
1243	67	1.41	75	MBM	5	TSH +14.70	TEHTEC			K7060	reso	22C00038	C	0
1244	81	1.18	74	MBM	6	03H +33.64	TEHTEC			M1680	reso	22C00039	C	0
1245		2.22	75	MBM	6	06H +15.15	TEHTEC			M1680	reso	22C00039	C	0
[illegible]	109	1.93	85	MBM	6	04H +32.36	TEHTEC			M1680	reso	22C00039	C	0
1[illegible]		1.63	54	MBM	6	04H +36.65	TEHTEC			M1680	reso	22C00039	C	0
1248	111	0.41	75	MBM	5	02H +13.11	TEHTEC			K7060	reso	22C00038	C	0
1249	121	4.00	25	NRC	2	TSC +0.00	TEHTEC			D4576	rsec	22C00058	C	0
1250	125	0.92	64	MBM	6	04C +30.45	TEHTEC			T0042	reso	22C00059	C	0
1251	54	0.16	81	MAI	2	TSH +0.13 TO+0.52	TSHTSH	0.2		B3720	reso	22H00176	H	0
1252		0.20	29	MAI	1	TSH +0.13 TO+0.52	TSHTSH	0.2		B3720	reso	22H00176	H	0
1253		0.15	95	PID	4	TSH +0.13 TO+0.52	TSHTSH			K2858	rpri	22H00183	H	99
1254	56	0.23	99	MAI	2	TSH +0.36 TO+0.94	TSHTSH	0.5		B3720	reso	22H00175	H	0
1255				MAI	1	TSH +0.36 TO+0.94	TSHTSH	0.0		B3720	reso	22H00175	H	0
1256		0.16	116	PID	4	TSH +0.36 TO+0.94	TSHTSH			K2858	rpri	22H00183	H	99
1257	68	0.78	59	MBM	6	03C +15.00	TEHTEC			B3720	reso	22C00040	C	0
1258	112	0.69	79	MBM	5	03C +23.45	TEHTEC			M1680	reso	22C00041	C	0
1259	114	1.75	69	MBM	6	07C +16.53	TEHTEC			B3720	reso	22C00040	C	0
1260		1.65	84	MBM	6	05C +4.74	TEHTEC			B3720	reso	22C00040	C	0
1261		1.32	78	MBM	6	04C +21.68	TEHTEC			B3720	reso	22C00040	C	0
1262		1.22	65	MBM	6	03C +25.73	TEHTEC			B3720	reso	22C00040	C	0
1263		1.55	80	MBM	6	03C +34.72	TEHTEC			B3720	reso	22C00040	C	0
1264	136	0.36	128	NQI	P1	TSH +12.12	TEHTEC			B2860	rpri	22C00059	C	0
1265		0.26	105	VOL	4	TSH +12.12	01HTSH			M1680	reso	22H00180	H	4
1266		1.11	61	MBM	6	02H +30.65	TEHTEC			T0042	reso	22C00059	C	0
1267	53			OBS		TEC +0.00	TECTEC			B3720	reso	22C00184	C	3
1268				OBS		TEC +0.00	TECTEC			A9608	reso	22C00197	C	0
1269	93			INF		VH +17.13	TEHTEC	HR		B3720	reso	22C00040	C	0
1270		0.86	86	MBM	5	VH +18.29	TEHTEC			B3720	reso	22C00040	C	0
1271	115	0.88	69	MBM	5	07H +7.25	TEHTEC			M1680	reso	22C00041	C	0
	121	4.39	15	NRC	2	TSC +0.00	TEHTEC			B1055	rpri	22C00058	C	0
1273	127	1.02	81	MBM	6	05H +23.88	TEHTEC			A9608	reso	22C00058	C	0
1274	48	0.13	114	MAI	2	TSH +0.36 TO+1.00	TSHTSH	0.3		B3720	reso	22H00175	H	0

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG
1275					MAI	1 TSH	+0.36	TO+1.00	TSHTSH	0.0		B3720	reso	22H00175	H	0
1276			0.17	129	PID	4 TSH	+0.36	TO+1.00	TSHTSH			K2858	rpri	22H00183	H	99
1277	54	104	0.14	118	MAI	2 TSH	+0.07	TO+1.04	TSHTSH	0.3		B3720	reso	22H00176	H	0
1278			0.28	37	MAI	1 TSH	+0.07	TO+1.04	TSHTSH	0.2		B3720	reso	22H00176	H	0
1279			0.14	126	PID	4 TSH	+0.07	TO+1.04	TSHTSH			K2858	rpri	22H00183	H	99
1280	60	104			MAI	1 TSH	+0.17	TO+0.53	TSHTSH	0.0		B3720	reso	22H00175	H	0
1281			0.14	136	MAI	2 TSH	+0.17	TO+0.53	TSHTSH	0.3		B3720	reso	22H00175	H	0
1282			0.20	143	PID	4 TSH	+0.17	TO+0.53	TSHTSH			K2858	rpri	22H00183	H	99
1283	84	104	0.91	73	MBM	5 01H	+34.97		TEHTEC			M1680	reso	22C00041	C	0
1284	132	104	1.41	83	MBM	6 TSH	+9.39		TEHTEC			A9608	reso	22C00058	C	0
1285	39	105	0.71	82	MBM	5 TSH	+13.08		TSCTEH			A9608	reso	22H00137	C	0
1286			1.75	82	INR	P3 TSC	-0.16		TSCTEH			A9608	reso	22H00137	C	0
1287	81	105	0.97	89	MBM	5 03H	+12.71		TEHTEC			M1680	reso	22C00041	C	0
1288	83	105	0.61	74	MBM	5 03C	+8.36		TEHTEC			B3720	reso	22C00040	C	0
1289	91	105	0.49	69	MBM	5 05H	+15.34		TEHTEC			B3720	reso	22C00040	C	0
1290	95	105	0.56	80	MBM	5 02H	+32.93		TEHTEC			B3720	reso	22C00040	C	0
1291	97	105	2.30	87	MBM	6 VH	+24.91		TEHTEC			M1680	reso	22C00041	C	0
1292			1.43	106	INR	6 VM	+20.06		TEHTEC			M1680	reso	22C00041	C	0
1293			0.56	83	MBM	5 VM	+21.00		TEHTEC			M1680	reso	22C00041	C	0
1294	121	105	4.16	24	NRC	2 TSC	+0.00		TEHTEC			D4576	rsec	22C00058	C	0
[illegible]	129	105	0.87	78	MBM	5 05H	+19.57		TEHTEC			A9608	reso	22C00058	C	0
1[illegible]	36	106	0.72	26	SAI	2 TSH	-2.64		TSHTSH	0.2	PWSCC	B3720	reso	22H00177	H	0
1297			1.70	22	PID	4 TSH	-2.64		TSHTSH			K2858	rpri	22H00183	H	99
1298			0.52	14	SAI	1 TSH	-2.62		TSHTSH	0.3	PWSCC	B3720	reso	22H00177	H	0
1299	82	106			INF	VM	+23.17		TEHTEC	HR		B3720	reso	22C00040	C	0
1300	84	106	0.63	78	MBM	5 01H	+35.73		TEHTEC			M1680	reso	22C00041	C	0
1301	124	106	0.67	84	MBM	5 02H	+24.50		TEHTEC			A9608	reso	22C00058	C	0
1302	130	106	0.60	84	MBM	5 03H	+33.99		TEHTEC			T0042	reso	22C00059	C	0
1303	41	107	0.56	89	MBM	5 01C	+12.83		TSCTEH			S7752	reso	22H00139	C	0
1304	49	107	0.36	77	SAI	2 TSH	+0.24		TSHTSH	0.4		M1680	reso	22H00176	H	0
1305			0.53	78	SAI	1 TSH	+0.24		TSHTSH	0.5		M1680	reso	22H00176	H	0
1306			0.36	84	PID	4 TSH	+0.24		TSHTSH			K2858	rpri	22H00183	H	99
1307	61	107	2.10	65	MBM	5 01C	+27.30		TEHTEC			M1680	reso	22C00043	C	0
1308	63	107	0.31	107	NQI	P1 TSH	+6.77		TEHTEC			R4201	rpri	22C00041	C	0
1309					NDF	TSH	+6.77		TSHTSH			A9608	reso	22H00183	H	4
1310	65	107	0.12	117	SAI	2 TSH	+0.78		TSHTSH	0.2		C3340	reso	22H00034	H	0
1311					SAI	1 TSH	+0.78		TSHTSH	0		C3340	reso	22H00034	H	0
1312			0.07	148	PID	4 TSH	+0.78		TSHTSH			L2157	rpri	22H00063	H	99
1313	83	107	0.73	80	MBM	6 VM	+9.38		TEHTEC			H2131	reso	22C00056	C	0
1314	87	107	0.42	106	NQI	P1 TSC	+31.44		TEHTEC			R4201	rpri	22C00041	C	0
1315					NDF	2 TSC	+31.44		01CTSC			C3340	reso	22C00084	C	5
1316	95	107	1.14	86	MBM	5 06H	+20.27		TEHTEC			M1680	reso	22C00041	C	0
1317	121	107	2.92	24	NRC	2 TSC	+0.00		TEHTEC			D4576	rsec	22C00058	C	0
1318	123	107	0.92	80	MBM	5 05H	+15.57		TEHTEC			A9608	reso	22C00058	C	0
1319	133	107	1.45	75	MBM	6 02H	+29.30		TEHTEC			A9608	reso	22C00058	C	0
1320			2.68	88	MBM	6 03H	+2.96		TEHTEC			A9608	reso	22C00058	C	0
	50	108	0.25	97	SAI	2 TSH	+0.66		TSHTSH	0.4		B3720	reso	22H00176	H	0
1322			0.33	109	SAI	1 TSH	+0.66		TSHTSH	0.3		B3720	reso	22H00176	H	0
1323			0.22	105	PID	4 TSH	+0.66		TSHTSH			K2858	rpri	22H00183	H	99

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 11:46

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final — PAGE 28

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG
1324	60	108	0.50	87	24	P2 VM	-1.92		TECTEH			W4892	rpri	22H00139	C	0
1325			0.29	88	WAR	P4 VM	-1.92		DH VM			A9608	reso	22H00185	H	4
1326	68	108	0.30	129	NQI	P1 TSH	+0.77		TEHTEC			R4201	rpri	22C00041	C	0
1327					NDF	TSH	+0.77		TSHTSH			A9608	reso	22H00034	H	0
1328	80	108	0.90	72	MBM	5 07C	+12.17		TEHTEC			M1680	reso	22C00041	C	0
1329			0.36	133	14	P2 03C	-1.28		TEHTEC			R4201	rpri	22C00041	C	0
1330			0.06	107	VOL	2 03C	-1.28		03C03C			C3340	reso	22C00084	C	5
1331	100	108	1.10	89	MBM	6 VH	+7.02		TEHTEC			M1680	reso	22C00041	C	0
1332	124	108	1.05	88	MBM	6 VH	+5.41		TEHTEC			A9608	reso	22C00058	C	0
1333			1.07	80	MBM	6 VM	+13.04		TEHTEC			A9608	reso	22C00058	C	0
1334	7	109	0.72	46	MBM	6 01C	+25.38		TEHTEC			R6452	reso	22C00024	C	0
1335	65	109	1.02	82	MBM	5 06H	+13.48		TEHTEC			B3720	reso	22C00040	C	0
1336	73	109	0.83	78	MBM	5 02H	+4.02		TEHTEC			B3720	reso	22C00040	C	0
1337	93	109	0.27	97	MAI	2 TSH	+2.48		TSHTSH	0.5		C3340	reso	22H00034	H	0
1338			0.49	54	MAI	1 TSH	+2.48		TSHTSH	0.6		C3340	reso	22H00034	H	0
1339			0.17	82	PID	4 TSH	+2.48		TSHTSH			L2157	rpri	22H00063	H	99
1340	101	109	0.76	79	MBM	5 VH	+10.31		TEHTEC			A9608	reso	22C00042	C	0
1341			1.03	93	MBM	5 VM	+11.26		TEHTEC			A9608	reso	22C00042	C	0
1342			0.56	70	MBM	5 VM	+16.23		TEHTEC			A9608	reso	22C00042	C	0
1343	121	109	3.73	25	NRC	2 TSC	+0.00		TEHTEC			D4576	rsec	22C00058	C	0
[illegible]	6	110	1.29	37	MBM	6 05H	+17.70		TEHTEC			R6452	reso	22C00024	C	0
[illegible]			0.33	105	VOL	2 05H	+18.10		05H06C			S9098	rpri	22H00087	H	2
1346	42	110			MAI	1 TSH	+0.34	TO+0.90	TSHTSH	0.0		B3720	reso	22H00176	H	0
1347			0.19	101	MAI	2 TSH	+0.34	TO+0.90	TSHTSH	0.2		B3720	reso	22H00176	H	0
1348			0.14	88	PID	4 TSH	+0.34	TO+0.90	TSHTSH			K2858	rpri	22H00183	H	99
1349	46	110	0.21	109	SAI	2 TSH	+0.60		TSHTSH	0.2		B3720	reso	22H00176	H	0
1350					SAI	1 TSH	+0.60		TSHTSH	0.0		B3720	reso	22H00176	H	0
1351			0.26	118	PID	4 TSH	+0.60		TSHTSH			K2858	rpri	22H00183	H	99
1352	48	110	0.19	99	MAI	2 TSH	+0.10	TO+0.92	TSHTSH	0.3		B3720	reso	22H00175	H	0
1353			0.10	29	MAI	1 TSH	+0.10	TO+0.92	TSHTSH	0.2		B3720	reso	22H00175	H	0
1354			0.19	113	PID	4 TSH	+0.10	TO+0.92	TSHTSH			K2858	rpri	22H00183	H	99
1355	72	110	1.31	74	MBM	6 TSC	+26.84		TEHTEC			A9608	reso	22C00042	C	0
1356	76	110	0.66	88	MBM	5 05C	+14.43		TEHTEC			A9608	reso	22C00042	C	0
1357			0.64	87	MBM	5 05C	+31.59		TEHTEC			A9608	reso	22C00042	C	0
1358	86	110	0.56	71	MBM	5 02H	+20.19		TEHTEC			M1680	reso	22C00043	C	0
1359			0.83	85	MBM	6 03H	+26.20		TEHTEC			M1680	reso	22C00043	C	0
1360			0.68	82	MBM	6 03H	+33.84		TEHTEC			M1680	reso	22C00043	C	0
1361	100	110	0.58	82	MBM	5 02H	+5.01		TEHTEC			A9608	reso	22C00042	C	0
1362			0.41	86	MBM	5 04H	+5.13		TEHTEC			A9608	reso	22C00042	C	0
1363	104	110	0.65	89	MBM	5 03C	+25.42		TEHTEC			A9608	reso	22C00042	C	0
1364	116	110	0.52	88	MBM	5 04C	+14.81		TEHTEC			A9608	reso	22C00042	C	0
1365	29	111			MAI	1 TSH	+0.10	TO+0.60	TSHTSH	0.0		B3720	reso	22H00176	H	0
1366			0.13	110	MAI	2 TSH	+0.10	TO+0.60	TSHTSH	0.3		B3720	reso	22H00176	H	0
1367			0.13	120	PID	4 TSH	+0.10	TO+0.60	TSHTSH			K2858	rpri	22H00183	H	99
1368			1.46	1	IDM	2 TSC	+2.88		TSCTSC			B3720	reso	22C00184	C	3
1369	31	111	0.19	93	MAI	2 TSH	+0.08	TO+0.68	TSHTSH	0.3		B3720	reso	22H00175	H	0
[illegible]			0.22	96	MAI	1 TSH	+0.08	TO+0.68	TSHTSH	0.3		B3720	reso	22H00175	H	0
1371			0.18	111	PID	4 TSH	+0.08	TO+0.68	TSHTSH			K2858	rpri	22H00183	H	99
1372	39	111	0.30	107	MAI	2 TSH	+0.30	TO+0.96	TSHTSH	0.3		B3720	reso	22H00175	H	0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 11:46

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final —

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG
1373			0.43	36	MAI	1	TSH	+0.30 TO+0.96	TSHTSH	0.3		B3720	reso	22H00175	H	0
1374			0.28	116	PID	4	TSH	+0.30 TO+0.96	TSHTSH			K2858	rpri	22H00183	H99	
1375	45	111	0.13	100	SAI	2	TSH	+0.87	TSHTSH	0.2		B3720	reso	22H00176	H	0
1376					SAI	1	TSH	+0.87	TSHTSH	0.0		B3720	reso	22H00176	H	0
1377			0.13	132	PID	4	TSH	+0.87	TSHTSH			K2858	rpri	22H00183	H99	
1378	75	111	0.50	72	MBM	5	03C	+31.43	TEHTEC			M1680	reso	22C00043	C	0
1379	81	111	0.63	106	MBM	5	VH	+4.15	TEHTEC			A9608	reso	22C00042	C	0
1380	95	111	0.96	88	MBM	6	TSH	+14.32	TEHTEC			M1680	reso	22C00043	C	0
1381	99	111	0.95	80	MBM	5	03H	+23.85	TEHTEC			M1680	reso	22C00043	C	0
1382	103	111	0.80	86	MBM	5	05H	+6.15	TEHTEC			M1680	reso	22C00043	C	0
1383			0.67	74	MBM	5	05H	+17.29	TEHTEC			M1680	reso	22C00043	C	0
1384	111	111	1.83	97	INR	5	07C	+10.39	TEHTEC			M1680	reso	22C00043	C	0
1385	117	111	0.68	81	MBM	5	05C	+7.02	02HTEC			A9608	reso	22C00042	C	0
1386			0.66	85	MBM	5	05C	+7.12	TEHTEC			H2131	reso	22C00056	C	0
1387	121	111	4.62	23	NRC	2	TSC	+0.00	TEHTEC			D4576	rsec	22C00058	C	0
1388	28	112	0.70	64	MBM	5	01H	+12.40	TECTEH			R6452	reso	22H00140	C	0
1389			0.59	88	MBM	5	01H	+16.59	TECTEH			R6452	reso	22H00140	C	0
1390			1.45	89	MBM	5	03H	+6.82	TECTEH			R6452	reso	22H00140	C	0
1391			0.55	81	MBM	5	03H	+8.04	TECTEH			R6452	reso	22H00140	C	0
1392	42	112	0.51	63	MAI	1	TSH	+0.27 TO+0.91	TSHTSH	0.5		B3720	reso	22H00176	H	0
[illegible]			0.28	92	MAI	2	TSH	+0.27 TO+0.91	TSHTSH	0.5		B3720	reso	22H00176	H	0
[illegible]			0.27	103	PID	4	TSH	+0.27 TO+0.91	TSHTSH			K2858	rpri	22H00183	H99	
1395			0.20	111	NQI	P1	TSH	+0.75	TECTEH			S1848	rpri	22H00140	C	0
1396	78	112	0.42	78	MBM	5	04H	+23.72	TEHTEC			A9608	reso	22C00042	C	0
1397	88	112	0.68	66	MBM	5	01C	+7.38	TEHTEC			M1680	reso	22C00043	C	0
1398	90	112	0.59	83	MBM	5	VH	+15.69	TEHTEC			A9608	reso	22C00042	C	0
1399	108	112	1.81	90	MBM	5	04H	+13.98	TEHTEC			M1680	reso	22C00043	C	0
1400			1.51	81	MBM	5	04H	+18.95	TEHTEC			M1680	reso	22C00043	C	0
1401			0.95	86	MBM	5	09C	+5.11	TEHTEC			M1680	reso	22C00043	C	0
1402	114	112	0.50	81	MBM	5	02H	+7.80	TEHTEC			A9608	reso	22C00042	C	0
1403	9	113	0.54	98	DSI	P1	02H	+0.49	TEHTEC			W4881	rsec	22C00021	C	0
1404			0.18	98	MAI	1	02H	+0.57	02H02H	0.5		R6452	reso	22H00067	H	4
1405			0.39	97	MAI	2	02H	+0.57	02H02H	0.5		R6452	reso	22H00067	H	4
1406			0.37	95	PID	4	02H	+0.57	02H02H			O1057	rpri	22H00092	H99	
1407	31	113	0.20	86	SAI	2	TSH	+0.22	TSHTSH	0.3		B3720	reso	22H00175	H	0
1408			0.21	74	SAI	1	TSH	+0.22	TSHTSH	0.2		B3720	reso	22H00175	H	0
1409			0.14	93	PID	4	TSH	+0.22	TSHTSH			K2858	rpri	22H00183	H99	
1410	35	113	0.17	90	MAI	2	TSH	+0.09 TO+0.56	TSHTSH	0.2		B3720	reso	22H00178	H	0
1411					MAI	1	TSH	+0.09 TO+0.56	TSHTSH	0.0		B3720	reso	22H00178	H	0
1412			0.13	96	PID	4	TSH	+0.09 TO+0.56	TSHTSH			K2858	rpri	22H00183	H99	
1413	43	113	0.11	81	MAI	2	TSH	+1.07 TO+2.27	TSHTSH	0.3		B3720	reso	22H00178	H	0
1414					MAI	1	TSH	+1.07 TO+2.27	TSHTSH	0.0		B3720	reso	22H00178	H	0
1415			0.16	93	PID	4	TSH	+1.07 TO+2.27	TSHTSH			A9608	reso	22H00183	H99	
1416	83	113	0.54	73	MBM	5	02H	+15.97	TEHTEC			M1680	reso	22C00042	C	0
1417	91	113	0.92	80	MBM	5	02H	+7.79	TEHTEC			M1680	reso	22C00042	C	0
1418	95	113	0.67	85	MBM	6	TSH	+23.94	TEHTEC			M1680	reso	22C00042	C	0
	119	113	1.06	84	MBM	5	VM	+13.34	TEHTEC			M1680	reso	22C00042	C	0
1420	121	113	5.11	29	NRC	2	TSC	+0.00	TEHTEC			B2860	rpri	22C00059	C	0
1421	123	113	0.45	61	MBM	5	05H	+9.77	TEHTEC			A9608	reso	22C00058	C	0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

May 17,1999 11:46

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

	ROW	LIN	VOLTS	DEG	PCT	CHN		LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG
1422			0.85	74	MBM	5	TSC	+34.92		TEHTEC			A9608	reso	22C00058	C	0
1423	36	114	0.13	70	MAI	2	TSH	+0.45	TO+1.14	TSHTSH	0.2		B3720	reso	22H00177	H	0
1424					MAI	1	TSH	+0.45	TO+1.14	TSHTSH	0.0		B3720	reso	22H00177	H	0
1425			0.11	96	PID	4	TSH	+0.45	TO+1.14	TSHTSH			K2858	rpri	22H00183	H	99
1426	38	114			OBS		DH	+12.62		DHTEH			R6452	reso	22H00140	C	0
1427	56	114	0.23	67	INR	P1	TSH	+0.90		TECTEH			A9608	reso	22H00139	C	0
1428			0.11	135	SAI	2	TSH	+0.91		TSHTSH	0.2		M1680	reso	22H00177	H	0
1429					SAI	1	TSH	+0.91		TSHTSH	0.0		M1680	reso	22H00177	H	0
1430			0.18	136	PID	4	TSH	+0.91		TSHTSH			K2858	rpri	22H00183	H	99
1431	82	114	0.47	85	MBM	6	06C	+5.04		TEHTEC			M1680	reso	22C00042	C	0
1432	88	114	1.30	88	MBM	6	VH	+17.17		TEHTEC			M1680	reso	22C00043	C	0
1433	126	114	0.65	88	MBM	6	02C	+37.04		TEHTEC			A9608	reso	22C00058	C	0
1434			0.75	73	MBM	6	01C	+33.59		TEHTEC			A9608	reso	22C00058	C	0
1435	1	115			OBS		06C	+3.37		06CTEC			M1680	reso	22C00093	C	1
1436	97	115	0.59	76	MBM	5	01C	+23.83		TEHTEC			M1680	reso	22C00043	C	0
1437	103	115	0.64	79	MBM	5	05H	+25.77		TEHTEC			M1680	reso	22C00042	C	0
1438			1.42	74	MBM	6	05H	+32.54		TEHTEC			M1680	reso	22C00042	C	0
1439			0.81	76	MBM	6	06H	+3.84		TEHTEC			M1680	reso	22C00042	C	0
1440			0.80	80	MBM	6	06H	+9.03		TEHTEC			M1680	reso	22C00042	C	0
1441			0.66	76	MBM	6	06H	+14.20		TEHTEC			M1680	reso	22C00042	C	0
[illegible]			0.96	66	MBM	6	08H	+3.97		TEHTEC			M1680	reso	22C00042	C	0
[illegible]	111	115	0.21	68	NQI	P1	TSH	+2.56		TEHTEC			M1680	reso	22C00042	C	0
1444					NDF		TSH	+2.56		TSHTSH			A9608	reso	22H00031	H	0
1445	115	115	0.47	81	MBM	5	01H	+14.03		TEHTEC			M1680	reso	22C00042	C	0
1446			0.43	87	MBM	5	06H	+10.91		TEHTEC			M1680	reso	22C00042	C	0
1447	121	115	1.10	62	MBM	5	05C	+1.34		TEHTEC			T0042	reso	22C00059	C	0
1448			4.84	29	NRC	2	TSC	+0.00		TEHTEC			B2860	rpri	22C00059	C	0
1449	18	116	1.41	65	MBM	5	TSC	+36.76		TEHTEC			K7060	reso	22C00022	C	0
1450	76	116	0.38	73	MBM	5	TSH	+14.92		TEHTEC			B3720	reso	22C00029	C	0
1451	86	116			SAI	1	TSH	+0.24		TSHTSH	0		H2131	reso	22H00032	H	0
1452			0.13	107	SAI	2	TSH	+0.24		TSHTSH	0.2		C3340	reso	22H00032	H	0
1453			0.08	102	PID	4	TSH	+0.24		TSHTSH			L2157	rpri	22H00063	H	99
1454	120	116	0.99	89	MBM	6	06H	+11.32		TEHTEC			T0042	reso	22C00059	C	0
1455	11	117	14.78	54	INR	P3	TSC	-0.08		TEHTEC			K7060	reso	22C00022	C	0
1456	31	117	0.81	23	NQI	P1	TSH	+37.74		TEHTEC			R4201	rpri	22C00025	C	0
1457					NDF		TSH	+37.74		01HTSH			L7871	rpri	22H00195	H	4
1458	39	117	0.66	3	IDM	2	TSH	+1.32		TSHTSH			B3720	reso	22H00177	H	0
1459	79	117	0.67	77	MBM	5	06H	+7.42		TEHTEC			B3720	reso	22C00030	C	0
1460			0.56	83	MBM	5	06H	+12.36		TEHTEC			B3720	reso	22C00030	C	0
1461	117	117	0.54	83	MBM	5	TSC	+33.94		TEHTEC			B3720	reso	22C00030	C	0
1462	121	117	5.56	29	NRC	2	TSC	+0.00		TEHTEC			B2860	rpri	22C00059	C	0
1463	48	118	0.65	63	MBM	5	07H	+12.06		TEHTEC			A9608	reso	22C00025	C	0
1464			1.11	68	MBM	5	07H	+15.77		TEHTEC			A9608	reso	22C00025	C	0
1465	66	118	0.99	75	MBM	5	TSH	+16.44		TEHTEC			B3720	reso	22C00031	C	0
1466			0.48	89	MBM	5	TSH	+19.34		TEHTEC			B3720	reso	22C00031	C	0
1467	78	118	1.25	82	MBM	6	VH	+12.82		TEHTEC			B3720	reso	22C00031	C	0
			1.25	73	MBM	5	03C	+8.30		TEHTEC			B3720	reso	22C00031	C	0
1469			0.88	86	MBM	5	01C	+23.47		TEHTEC			B3720	reso	22C00031	C	0
1470	90	118	0.71	74	MBM	5	02H	+4.59		TEHTEC			B3720	reso	22C00030	C	0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 11:46

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final — PAGE 31

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
1471		1.55	57	MBM	5	06H	+19.10	TEHTEC			B3720	reso	22C00030	C 0
1472	112	1.29	64	MBM	6	06H	+19.11	TEHTEC			B3720	reso	22C00031	C 0
1473	1	0.53	78	MBM	5	03C	+33.02	06HTEC			M1680	reso	22C00093	C 1
1474	13			OBS		06H	+19.23	05H06H			C3340	reso	22H00086	H 2
1475	81	0.09	107	MCI	P1	TSH	+0.05	TSHTSH	0.3		D3858	reso	22H00031	H 0
1476				MCI	1	TSH	+0.05	TSHTSH	0		T0042	reso	22H00031	H 0
1477		0.13	146	PID	P1	TSH	+0.05	TSHTSH			L2157	rpri	22H00063	H99
1478	85	0.12	117	SAI	2	TSH	+0.25	TSHTSH	0.2		C3340	reso	22H00032	H 0
1479				SAI	1	TSH	+0.25	TSHTSH	0		C3340	reso	22H00032	H 0
1480		0.14	123	PID	4	TSH	+0.25	TSHTSH			L2157	rpri	22H00063	H99
1481	91	0.23	40	SAI	1	TSH	+0.23	TSHTSH	0.3		T0042	reso	22H00031	H 0
1482		0.41	92	SAI	2	TSH	+0.23	TSHTSH	0.2		T0042	reso	22H00031	H 0
1483		0.36	86	PID	4	TSH	+0.23	TSHTSH			L2157	rpri	22H00063	H99
1484		0.69	79	MBM	5	03H	+25.52	TEHTEC			B3720	reso	22C00030	C 0
1485	111	1.46	82	MBM	6	04H	+6.07	TEHTEC			B3720	reso	22C00030	C 0
1486		0.64	81	MBM	5	04H	+12.61	TEHTEC			B3720	reso	22C00030	C 0
1487	121	5.46	25	NRC	2	TSC	+0.00	TEHTEC			B2860	rpri	22C00059	C 0
1488	4	0.30	82	PLP	9	TSC	+0.43	TSCTSC			M1680	reso	22C00136	C 3
1489	14	0.22	47	MAI	1	TSH	+1.70	TSHTSH	0.3		C3340	reso	22H00030	H 0
1490		0.15	111	MAI	2	TSH	+1.70	TSHTSH	0.6		C3340	reso	22H00030	H 0
[illegible]		0.17	116	PID	4	TSH	+1.70	TSHTSH			L2157	rpri	22H00063	H99
[illegible]	54	3.76	61	MBM	6	TSH	+28.40	TEHTEC			R6452	reso	22C00026	C 0
1493	74	0.68	77	MBM	5	05H	+15.78	TEHTEC			B3720	reso	22C00031	C 0
1494	118	0.64	78	MBM	5	01H	+8.82	TEHTEC			B3720	reso	22C00030	C 0
1495	124	2.19	57	MBM	6	TSC	+26.76	TEHTEC			T0042	reso	22C00059	C 0
1496	126	0.63	74	MBM	5	TSH	+13.57	TEHTEC			A9608	reso	22C00058	C 0
1497	1			OBS		06C	+1.41	06CTEC			M1680	reso	22C00093	C 1
1498	5	1.48	49	MBM	6	03H	+27.50	06HTEH			S7752	reso	22H00001	H 1
1499	7	0.35	88	NQI	P1	06H	+3.42 TO+5.75	TEHTEC			D4576	rsec	22C00022	C 0
1500				NDF		06H	+3.42 TO+5.75	05H06C			F7467	rsec	22H00085	H 2
1501	81	0.12	46	SCI	P1	TSH	+0.22	TSHTSH	0.2		T0042	reso	22H00031	H 0
1502				SCI	1	TSH	+0.22	TSHTSH	0		T0042	reso	22H00031	H 0
1503		0.18	60	PID	P1	TSH	+0.22	TSHTSH			L2157	rpri	22H00063	H99
1504	87	0.29	79	SCI	P1	TSH	+0.17	TSHTSH	0.3		T0042	reso	22H00031	H 0
1505		0.70	55	SCI	1	TSH	+0.17	TSHTSH	0.5		T0042	reso	22H00031	H 0
1506		0.24	80	PID	P1	TSH	+0.17	TSHTSH			L2157	rpri	22H00063	H99
1507	89	0.24	82	SCI	P1	TSH	+0.14	TSHTSH	0.4		C3340	reso	22H00032	H 0
1508		0.15	60	SCI	1	TSH	+0.14	TSHTSH	0.2		C3340	reso	22H00032	H 0
1509		0.17	101	PID	P1	TSH	+0.14	TSHTSH			L2157	rpri	22H00063	H99
1510	93	0.42	77	MBM	5	02H	+22.34	TEHTEC			B3720	reso	22C00031	C 0
1511	97	0.67	84	MBM	5	06C	+8.14	TEHTEC			B3720	reso	22C00031	C 0
1512	101	1.21	39	MBM	6	03C	+19.68	TEHTEC			B3720	reso	22C00031	C 0
1513		0.88	70	MBM	6	03C	+22.33	TEHTEC			B3720	reso	22C00031	C 0
1514	107	1.24	68	MBM	5	01C	+34.45	TEHTEC			B3720	reso	22C00030	C 0
1515	121	7.45	28	NRC	2	TSC	+0.00	TEHTEC			B2860	rpri	22C00059	C 0
1516	123	0.48	129	DSI	P1	09H	+0.00	TEHTEC			B2860	rpri	22C00059	C 0
				NDF	2	09H	+0.00	09H09H			L2157	rpri	22H00065	H 4
1518	6	0.18	124	VOL	2	04H	+7.78	04H06C			C3340	reso	22H00084	H 2
1519	16	0.15	127	VOL	2	TSC	+2.61	TSCTSC			M1680	reso	22C00136	C 3

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric — May 17,1999 11:46

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final —

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG
1520	70	122	1.25	93	INR 5	TSH +19.70	TEHTEC			P4634	rsec	22C00031	C	0
1521			1.91	142	INR 6	04H +3.05	TEHTEC			P4634	rsec	22C00031	C	0
1522	124	122			OBS	TEH +0.00	TEHTEH			A9608	reso	22H00054	H	0
1523					OBS	TEH +0.00	TEHTEH			A9608	reso	22H00055	H	0
1524	1	123	0.08	85	PLP 9	TSH +0.12	TSHTSH			K7060	reso	22H00030	H	0
1525	3	123	0.18	85	PLP 9	TSH +0.58	TSHTSH			K7060	reso	22H00029	H	0
1526	25	123	1.29	92	INR 6	05H +24.33	TEHTEC			R9311	rpri	22C00026	C	0
1527	75	123	0.53	86	MBM 5	03C +6.56	TEHTEC			B3720	reso	22C00030	C	0
1528	77	123			SCI 1	TSH +0.10	TSHTSH	0.0		K7060	reso	22H00054	H	0
1529			0.13	94	SCI P1	TSH +0.10	TSHTSH	0.3		K7060	reso	22H00054	H	0
1530			0.14	81	PID P1	TSH +0.10	TSHTSH			L2157	rpri	22H00063	H	99
1531	119	123	0.57	61	DSI P1	03H -0.74	TEHTEC			N0942	rpri	22C00056	C	0
1532					NDF 2	03H -0.74	03H03H			C3340	reso	22H00094	H	4
1533	2	124	0.59	72	LPI 2	TSC +0.15	TSCTSC			C3340	reso	22C00137	C	3
1534			0.35	67	PID 4	TSC +0.15	TSCTSC			J6276	rpri	22C00196	C	99
1535	12	124			OBS 2	06H +7.84	05H06H			M1680	reso	22H00081	H	2
1536	24	124	0.63	78	MBM 6	04H +2.67	TEHTEC			R6452	reso	22C00026	C	0
1537			0.88	74	MBM 6	04H +19.22	TEHTEC			R6452	reso	22C00026	C	0
1538	68	124	0.14	117	SAI 2	TSH +0.29	TSHTSH	0.3		R6452	reso	22H00021	H	0
1539			0.17	62	SAI 1	TSH +0.29	TSHTSH	0.2		R6452	reso	22H00021	H	0
			0.13	126	PID 4	TSH +0.29	TSHTSH			L2157	rpri	22H00063	H	99
1541	76	124	0.22	85	SCI P1	TSH +0.10	TSHTSH	0.6		R6452	reso	22H00021	H	0
1542					SCI 1	TSH +0.10	TSHTSH	0.0		R6452	reso	22H00021	H	0
1543			0.20	100	PID P1	TSH +0.10	TSHTSH			L2157	rpri	22H00063	H	99
1544	122	124	1.36	84	MBM 5	07C +11.22	TEHTEC			A9608	reso	22C00058	C	0
1545	3	125			OBS	06C +5.59	06CTEC			M1680	reso	22C00093	C	1
1546	5	125	0.37	57	PLP 9	TSC +2.25	TSCTSC			L6066	rsec	22C00137	C	3
1547	73	125	0.22	93	SCI P1	TSH +0.12	TSHTSH	0.5		R6452	reso	22H00022	H	0
1548					SCI 1	TSH +0.12	TSHTSH	0.0		R6452	reso	22H00022	H	0
1549			0.17	94	PID P1	TSH +0.12	TSHTSH			L2157	rpri	22H00063	H	99
1550					MAI 1	TSH +0.57 TO+1.55	TSHTSH	0.0		M1680	reso	22H00022	H	0
1551			0.20	84	MAI 2	TSH +0.57 TO+1.55	TSHTSH	0.4		M1680	reso	22H00022	H	0
1552	85	125	1.41	80	MBM 6	03H +32.02	TEHTEC			B3720	reso	22C00033	C	0
1553	101	125	0.90	85	MBM 5	02C +21.66	TEHTEC			B3720	reso	22C00032	C	0
1554	113	125	0.41	101	DSI P1	01H +0.55	TEHTEC			R4201	rpri	22C00032	C	0
1555					NDF 2	01H +0.55	01H01H			L2157	rpri	22H00065	H	4
1556	121	125	5.43	23	NRC 2	TSC +0.00	TEHTEC			D4576	rsec	22C00058	C	0
1557	10	126			OBS	06C +8.12	06CTEC			P5436	rpri	22C00022	C	0
1558	46	126			OBS	TEH +0.00	TEHTEH			M1680	reso	22H00025	H	0
1559					OBS	TSH -29.72	TSHTEC			R4201	rpri	22C00025	C	0
1560					OBS	TSH -29.08	TSHTEC			B6768	rpri	22C00034	C	0
1561	78	126	0.11	70	SAI 2	TSH +0.33	TSHTSH	0.2		A9608	reso	22H00021	H	0
1562					SAI 1	TSH +0.33	TSHTSH	0.0		A9608	reso	22H00021	H	0
1563			0.08	57	PID 4	TSH +0.33	TSHTSH			L2157	rpri	22H00063	H	99
1564	82	126	0.60	76	MBM 5	01H +9.19	TEHTEC			B3720	reso	22C00032	C	0
1565	96	126	0.72	62	MBM 5	VM +11.67	TEHTEC			B3720	reso	22C00033	C	0
6	98	126	0.61	55	MBM 5	02C +7.17	TEHTEC			B3720	reso	22C00032	C	0
1567	104	126	1.57	88	MBM 5	03H +9.76	TEHTEC			B3720	reso	22C00033	C	0
1568	3	127	0.51	82	PLP 9	TSH +0.40	TSHTSH			S7752	reso	22H00028	H	0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:46

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
1569	55	127	0.65	91	MBM 5	02H +19.56	TEHTEC			A9608	reso	22C00025	C 0
1570	57	127	0.49	80	MBM 5	04H +8.56	TEHTEC			A9608	reso	22C00025	C 0
1571	75	127	0.25	100	MCI P1	TSH +0.13	TSHTSH	0.4		H2131	reso	22H00024	H 0
1572			0.13	153	MCI 1	TSH +0.13	TSHTSH	0.3		C3340	reso	22H00024	H 0
1573			0.21	86	PID P1	TSH +0.13	TSHTSH			L2157	rpri	22H00063	H99
1574	77	127	0.75	85	MBM 6	03C +30.12	TEHTEC			B3720	reso	22C00033	C 0
1575	93	127	1.28	46	MBM 6	TSH +14.68	TEHTEC			B3720	reso	22C00033	C 0
1576	95	127	1.08	87	MBM 5	01H +18.49	TEHTEC			B3720	reso	22C00032	C 0
1577	117	127	2.54	84	MBM 6	04C +33.66	TEHTEC			B3720	reso	22C00033	C 0
1578	2	128	0.43	83	PLP 9	TSH +0.20	TSHTSH			S7752	reso	22H00028	H 0
1579	76	128	0.63	128	SCI 1	TSH +0.06	TSHTSH	0.5		K7060	reso	22H00023	H 0
1580			0.36	106	SCI P1	TSH +0.06	TSHTSH	0.5		K7060	reso	22H00023	H 0
1581			0.38	85	PID P1	TSH +0.06	TSHTSH			L2157	rpri	22H00063	H99
1582			0.54	84	MBM 5	07H +8.21	TEHTEC			B3720	reso	22C00032	C 0
1583	1	129	0.40	84	PLP 9	TSH +0.19	TSHTSH			S7752	reso	22H00028	H 0
1584					OBS	05C +31.43	05CTEC			M1680	reso	22C00093	C 1
1585	23	129	0.12	102	SAI 2	TSH +0.58	TSHTSH	0.2		M1680	reso	22H00027	H 0
1586					SAI 1	TSH +0.58	TSHTSH	0.0		M1680	reso	22H00027	H 0
1587			0.10	106	PID 4	TSH +0.58	TSHTSH			L2157	rpri	22H00063	H99
1588	65	129	0.11	88	MCI P1	TSH +0.06	TSHTSH	0.3		K7060	reso	22H00023	H 0
[illegible]					MCI 1	TSH +0.06	TSHTSH	0.0		K7060	reso	22H00023	H 0
[illegible]			0.13	104	PID P1	TSH +0.06	TSHTSH			L2157	rpri	22H00063	H99
1591	75	129	0.18	104	MCI P1	TSH +0.11	TSHTSH	0.4		C3340	reso	22H00024	H 0
1592			0.23	146	MCI 1	TSH +0.11	TSHTSH	0.5		C3340	reso	22H00024	H 0
1593			0.18	101	PID P1	TSH +0.11	TSHTSH			L2157	rpri	22H00063	H99
1594	77	129	1.02	66	ADR 6	VH +10.59 TO+12.56	TEHTEC			L6066	rsec	22C00032	C 0
1595			0.31	130	VOL 2	VH +11.44 TO+12.81	VM VH			H2131	reso	22H00069	H 4
1596	83	129	0.42	25	INR P1	TSH +2.58	TEHTEC			R9311	rpri	22C00033	C 0
1597			0.50	57	MBM 6	03H +31.88	TEHTEC			B3720	reso	22C00033	C 0
1598			0.47	45	MBM 6	04C +23.40	TEHTEC			B3720	reso	22C00033	C 0
1599	87	129	1.14	76	MBM 5	TSH +9.29	TEHTEC			B3720	reso	22C00033	C 0
1600	101	129	0.71	69	MBM 6	02H +5.45	TEHTEC			B3720	reso	22C00032	C 0
1601	10	130	1.25	145	DSI P1	VM +0.00	TEHTEC			P5436	rpri	22C00022	C 0
1602					SAI 1	VM +0.00	05H06C	0.0		M1680	reso	22H00081	H 2
1603			0.10	92	SAI 2	VM +0.00	05H06C	0.2		M1680	reso	22H00081	H 2
1604			0.22	112	PID 2	VM +0.00	05H06C			A9608	reso	22H00091	H99
1605	110	130	0.68	72	MBM 5	03H +22.17	TEHTEC			T0042	reso	22C00034	C 0
1606	112	130	0.62	85	MBM 5	TSH +8.63	TEHTEC			R6452	reso	22C00035	C 0
1607			0.46	84	MBM 6	TSH +13.89	TEHTEC			R6452	reso	22C00035	C 0
1608			0.50	74	MBM 5	TSH +16.60	TEHTEC			R6452	reso	22C00035	C 0
1609	7	131	2.18	149	INR 6	06H +9.85	TEHTEC			P5436	rpri	22C00022	C 0
1610	9	131	2.76	103	ADR 6	VM -2.35 TO-1.14	TEHTEC			B3720	reso	22C00021	C 0
1611					NDF	VM -2.35 TO-1.14	06C05H			H2131	reso	22H00080	H 2
1612	11	131	0.47	67	MBM 5	02C +32.96	TEHTEC			K7060	reso	22C00022	C 0
1613	15	131	0.78	75	MBM 5	TSH +16.22	TEHTEC			K7060	reso	22C00022	C 0
1614			0.44	91	MBM 5	TSH +19.96	TEHTEC			K7060	reso	22C00022	C 0
			0.35	76	MBM 5	TSH +32.83	TEHTEC			K7060	reso	22C00022	C 0
1616			0.81	82	MBM 5	TSH +34.17	TEHTEC			K7060	reso	22C00022	C 0
1617			0.63	89	MBM 5	TSH +37.58	TEHTEC			K7060	reso	22C00022	C 0

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:46

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG
1618			0.72	82	MBM	5	01H	+5.16	TEHTEC			K7060	reso	22C00022	C	0
1619	17	131	0.37	63	MBM	5	TSH	+29.66	TEHTEC			B3720	reso	22C00021	C	0
1620			0.31	89	MBM	5	TSH	+30.77	TEHTEC			B3720	reso	22C00021	C	0
1621	25	131	0.28	96	MAI	1	TSH	+0.54 TO+1.36	TSHTSH	0.5		A9608	reso	22H00028	H	0
1622			0.38	101	MAI	2	TSH	+0.54 TO+1.36	TSHTSH	0.6		A9608	reso	22H00028	H	0
1623			0.23	109	PID	4	TSH	+0.54 TO+1.36	TSHTSH			L2157	rpri	22H00063	H99	
1624			0.66	125	NQI	P1	TSH	+0.98	TEHTEC			M9082	rpri	22C00024	C	0
1625			0.26	94	NQI	P1	TSH	+4.90	TEHTEC			R6452	reso	22C00024	C	0
1626			0.31	107	SAI	2	TSH	+5.08	TSHTSH	0.5		S7752	reso	22H00028	H	0
1627			0.41	107	SAI	1	TSH	+5.08	TSHTSH	0.4		S7752	reso	22H00028	H	0
1628			0.08	133	SAI	2	TSH	+5.47	TSHTSH	0.3		S7752	reso	22H00028	H	0
1629					SAI	1	TSH	+5.47	TSHTSH	0.0		S7752	reso	22H00028	H	0
1630	35	131	0.16	92	SAI	2	TSH	+1.23	TSHTSH	0.2		M1680	reso	22H00027	H	0
1631					SAI	1	TSH	+1.23	TSHTSH	0.0		M1680	reso	22H00027	H	0
1632			0.10	91	PID	4	TSH	+1.23	TSHTSH			L2157	rpri	22H00063	H99	
1633	37	131	0.15	97	SAI	2	TSH	+0.15	TSHTSH	0.2		S7752	reso	22H00028	H	0
1634					SAI	1	TSH	+0.15	TSHTSH	0		A9608	reso	22H00028	H	0
1635			0.15	80	PID	4	TSH	+0.15	TSHTSH			L2157	rpri	22H00063	H99	
1636	47	131	0.15	86	MAI	2	TSH	+0.11 TO+0.47	TSHTSH	0.3		M1680	reso	22H00027	H	0
1637			0.15	110	MAI	1	TSH	+0.11 TO+0.47	TSHTSH	0.2		M1680	reso	22H00027	H	0
[illegible]			0.13	119	PID	4	TSH	+0.11 TO+0.47	TSHTSH			L2157	rpri	22H00063	H99	
[illegible]	59	131	0.80	169	INR	P1	TSH	+0.85	TEHTEC			W4881	rsec	22C00023	C	0
1640			0.72	114	MBM	6	05C	+14.06	TEHTEC			R6452	reso	22C00023	C	0
1641	71	131	0.55	76	MBM	5	05H	+32.10	TEHTEC			T0042	reso	22C00034	C	0
1642	22	132	0.16	103	MAI	2	TSH	+0.39 TO+1.15	TSHTSH	0.5		A9608	reso	22H00028	H	0
1643			0.14	24	MAI	1	TSH	+0.39 TO+1.15	TSHTSH	0.4		A9608	reso	22H00028	H	0
1644			0.12	102	PID	4	TSH	+0.39 TO+1.15	TSHTSH			L2157	rpri	22H00063	H99	
1645	24	132	0.13	102	MAI	2	TSH	+0.87	TSHTSH	0.2		M1680	reso	22H00027	H	0
1646					MAI	1	TSH	+0.87	TSHTSH	0.0		M1680	reso	22H00027	H	0
1647			0.09	96	PID	4	TSH	+0.87	TSHTSH			L2157	rpri	22H00063	H99	
1648	36	132	0.19	59	MAI	1	TSH	+0.68	TSHTSH	0.2		M1680	reso	22H00027	H	0
1649			0.22	89	MAI	2	TSH	+0.68	TSHTSH	0.3		M1680	reso	22H00027	H	0
1650			0.18	91	PID	4	TSH	+0.68	TSHTSH			L2157	rpri	22H00063	H99	
1651			0.40	113	MBM	6	06C	+7.26	TEHTEC			R6452	reso	22C00023	C	0
1652	62	132	0.76	82	MBM	5	03H	+18.25	TEHTEC			R6452	reso	22C00035	C	0
1653	112	132	0.43	81	MBM	5	03H	+2.55	TEHTEC			T0042	reso	22C00034	C	0
1654	1	133			INF	9	TSH	+0.46	TSHTSH	HR		S7752	reso	22H00028	H	0
1655	5	133	0.98	88	MBM	6	TSC	+6.34	06HTEC			M1680	reso	22C00093	C	1
1656	37	133	0.36	129	NQI	P1	TSH	+0.64	TEHTEC			R6452	reso	22C00024	C	0
1657			0.13	98	MAI	2	TSH	+0.69	TSHTSH	0.2		S7752	reso	22H00028	H	0
1658					MAI	1	TSH	+0.69	TSHTSH	0		A9608	reso	22H00028	H	0
1659			0.11	120	PID	4	TSH	+0.69	TSHTSH			L2157	rpri	22H00063	H99	
1660	39	133	0.46	128	NQI	P1	TSH	+0.64	TEHTEC			W4881	rsec	22C00023	C	0
1661			0.20	99	MAI	2	TSH	+0.67	TSHTSH	0.7		M1680	reso	22H00027	H	0
1662			0.40	76	MAI	1	TSH	+0.67	TSHTSH	0.6		M1680	reso	22H00027	H	0
1663			0.19	105	PID	4	TSH	+0.67	TSHTSH			L2157	rpri	22H00063	H99	
	41	133	0.80	48	MBM	6	DH	+7.13	TEHTEC			R6452	reso	22C00024	C	0
1665			0.77	40	MBM	6	03C	+2.54	TEHTEC			R6452	reso	22C00024	C	0
1666			0.86	72	MBM	6	02C	+4.97	TEHTEC			R6452	reso	22C00024	C	0

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
1667			0.90	45	MBM	6	02C	+8.29	TEHTEC			R6452	reso	22C00024	C 0
1668			0.99	62	MBM	6	02C	+36.54	TEHTEC			R6452	reso	22C00024	C 0
1669	87	133	2.71	83	MBM	6	08C	+12.80	TEHTEC			T0042	reso	22C00034	C 0
1670	12	134	0.20	113	SAI	2	TSH	+0.73	TSHTSH	0.4		S7752	reso	22H00028	H 0
1671			0.23	90	SAI	1	TSH	+0.73	TSHTSH	0.3		S7752	reso	22H00028	H 0
1672			0.20	118	PID	4	TSH	+0.73	TSHTSH			L2157	rpri	22H00063	H99
1673			0.36	113	NQI	P1	TSH	+0.90	TEHTEC			P5436	rpri	22C00022	C 0
1674	18	134	0.12	105	SAI	2	TSH	+0.54	TSHTSH	0.3		M1680	reso	22H00027	H 0
1675					SAI	1	TSH	+0.54	TSHTSH	0.0		M1680	reso	22H00027	H 0
1676			0.08	108	PID	4	TSH	+0.54	TSHTSH			L2157	rpri	22H00063	H99
1677	24	134	0.40	66	NQI	P1	TSH	+1.06	TEHTEC			H2131	reso	22C00023	C 0
1678			0.12	89	MAI	2	TSH	+1.43	TSHTSH	0.2		M1680	reso	22H00027	H 0
1679					MAI	1	TSH	+1.43	TSHTSH	0.0		M1680	reso	22H00027	H 0
1680			0.10	110	PID	4	TSH	+1.43	TSHTSH			L2157	rpri	22H00063	H99
1681	34	134	1.01	72	MBM	6	02C	+16.46	TEHTEC			R6452	reso	22C00024	C 0
1682	38	134	0.13	124	SAI	2	TSH	+0.52	TSHTSH	0.4		S7752	reso	22H00028	H 0
1683			0.12	44	SAI	1	TSH	+0.52	TSHTSH	0.2		S7752	reso	22H00028	H 0
1684			0.14	121	PID	4	TSH	+0.52	TSHTSH			L2157	rpri	22H00063	H99
1685	42	134	0.32	83	SAI	2	TSH	+0.15	TSHTSH	0.3		S7752	reso	22H00028	H 0
1686			0.31	42	SAI	1	TSH	+0.15	TSHTSH	0.3		S7752	reso	22H00028	H 0
[illegible]			0.27	83	PID	4	TSH	+0.15	TSHTSH			L2157	rpri	22H00063	H99
1[illegible]	70	134	0.76	98	INR	6	TSH	+27.47	TEHTEC			M9082	rpri	22C00035	C 0
1689			1.71	95	INR	6	01H	+24.81	TEHTEC			M9082	rpri	22C00035	C 0
1690			1.46	85	MBM	5	04C	+23.56	TEHTEC			R6452	reso	22C00035	C 0
1691	76	134	0.65	66	MBM	6	VH	+27.51	TEHTEC			T0042	reso	22C00034	C 0
1692	94	134	0.12	120	WAR	P4	VC	+0.43	VC VC			A9608	reso	22C00087	C 5
1693			0.29	95	DSI	P1	VC	+0.44	TEHTEC			M9082	rpri	22C00035	C 0
1694	98	134	0.65	72	MBM	5	01C	+21.01	TEHTEC			R6452	reso	22C00035	C 0
1695	102	134	0.15	115	SCI	P1	TSH	+0.00	TSHTSH	0.2		C3340	reso	22H00026	H 0
1696			0.09	70	SCI	1	TSH	+0.00	TSHTSH	0.2		C3340	reso	22H00026	H 0
1697			0.16	111	PID	P1	TSH	+0.00	TSHTSH			L2157	rpri	22H00063	H99
1698	13	135			SAI	1	TSH	+1.24	TSHTSH	0		A9608	reso	22H00028	H 0
1699			0.11	111	SAI	2	TSH	+1.24	TSHTSH	0.1		S7752	reso	22H00028	H 0
1700			0.05	102	PID	4	TSH	+1.24	TSHTSH			L2157	rpri	22H00063	H99
1701	23	135	0.18	96	MAI	2	TSH	+0.90 TO+1.72	TSHTSH	0.3		M1680	reso	22H00027	H 0
1702					MAI	1	TSH	+0.90 TO+1.72	TSHTSH	0.0		M1680	reso	22H00027	H 0
1703			0.13	102	PID	4	TSH	+0.90 TO+1.72	TSHTSH			L2157	rpri	22H00063	H99
1704	31	135	0.20	116	SAI	2	TSH	+1.44	TSHTSH	0.2		K7060	reso	22H00054	H 0
1705					SAI	1	TSH	+1.44	TSHTSH	0.0		K7060	reso	22H00054	H 0
1706			0.21	112	PID	4	TSH	+1.44	TSHTSH			L2157	rpri	22H00063	H99
1707	39	135	0.20	108	SAI	2	TSH	+0.69	TSHTSH	0.4		S7752	reso	22H00028	H 0
1708			0.22	101	SAI	1	TSH	+0.69	TSHTSH	0.4		S7752	reso	22H00028	H 0
1709			0.18	117	PID	4	TSH	+0.69	TSHTSH			L2157	rpri	22H00063	H99
1710	45	135	0.19	97	MCI	P1	TSH	+0.18	TSHTSH	0.4		S7752	reso	22H00028	H 0
1711			0.64	58	MCI	1	TSH	+0.18	TSHTSH	0.4		S7752	reso	22H00028	H 0
1712			0.37	115	PID	P1	TSH	+0.18	TSHTSH			L2157	rpri	22H00063	H99
	49	135	1.22	9	INR	P1	TSH	+1.87	TEHTEC			M9082	rpri	22C00024	C 0
1714	91	135	0.32	86	MBM	5	01H	+4.55	TEHTEC			R6452	reso	22C00035	C 0
1715	6	136			OBS		06H	+10.60	05H06H			W4892	rpri	22H00080	H 2

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
1716	8	136			OBS	06C	+11.64		06C06C			S1848	rpri	22H00079	H 2
1717	24	136	0.35	55	MAI	1 TSH	+0.64	TO+1.45	TSHTSH	0.2		A9608	reso	22H00028	H 0
1718			0.24	110	MAI	2 TSH	+0.64	TO+1.45	TSHTSH	0.3		A9608	reso	22H00028	H 0
1719			0.13	83	PID	4 TSH	+0.64	TO+1.45	TSHTSH			G6391	rsec	22H00064	H99
1720			0.26	110	NQI	P1 TSH	+1.01		TEHTEC			S9098	rpri	22C00023	C 0
1721	28	136	0.29	108	MAI	2 TSH	+1.08		TSHTSH	0.7		S7752	reso	22H00028	H 0
1722			0.28	73	MAI	1 TSH	+1.08		TSHTSH	0.6		S7752	reso	22H00028	H 0
1723			0.27	102	PID	4 TSH	+1.08		TSHTSH			G6391	rsec	22H00064	H99
1724	40	136	0.08	136	SAI	2 TSH	+0.13		TSHTSH	0.2		K7060	reso	22H00054	H 0
1725					SAI	1 TSH	+0.13		TSHTSH	0.0		K7060	reso	22H00054	H 0
1726			0.19	97	MAI	2 TSH	+0.51		TSHTSH	0.3		K7060	reso	22H00054	H 0
1727					MAI	1 TSH	+0.51		TSHTSH	0.0		K7060	reso	22H00054	H 0
1728			0.16	93	PID	4 TSH	+0.51		TSHTSH			G6391	rsec	22H00064	H99
1729	56	136	0.12	98	SAI	2 TSH	+0.72		TSHTSH	0.2		M1680	reso	22H00027	H 0
1730					SAI	1 TSH	+0.72		TSHTSH	0.0		M1680	reso	22H00027	H 0
1731			0.09	111	PID	4 TSH	+0.72		TSHTSH			G6391	rsec	22H00064	H99
1732	62	136	1.43	73	MBM	6 05H	+16.56		TEHTEC			T0042	reso	22C00034	C 0
1733			1.02	83	MBM	5 07H	+4.82		TEHTEC			T0042	reso	22C00034	C 0
1734	102	136	0.54	81	MBM	5 08H	+14.05		TEHTEC			R6452	reso	22C00035	C 0
1735	7	137	0.45	65	MBM	5 02H	+26.27		TEHTEC			C3340	reso	22C00020	C 0
?					OBS	06H	+15.73		06H06H			A9608	reso	22H00106	H 2
1...					OBS	06C	+10.19		06C06C			W4892	rpri	22H00080	H 2
1738	21	137	0.15	73	SAI	2 TSH	+0.79		TSHTSH	0.4		S7752	reso	22H00028	H 0
1739			0.42	55	SAI	1 TSH	+0.79		TSHTSH	0.3		S7752	reso	22H00028	H 0
1740			0.11	77	PID	4 TSH	+0.79		TSHTSH			G6391	rsec	22H00064	H99
1741	27	137	0.28	108	MAI	2 TSH	+0.78		TSHTSH	0.5		S7752	reso	22H00028	H 0
1742			0.33	90	MAI	1 TSH	+0.78		TSHTSH	0.4		S7752	reso	22H00028	H 0
1743			0.24	105	PID	4 TSH	+0.78		TSHTSH			G6391	rsec	22H00064	H99
1744	31	137	0.36	127	NQI	P1 TSH	+0.81		TEHTEC			W4881	rsec	22C00023	C 0
1745			0.22	89	MAI	2 TSH	+0.92		TSHTSH	0.3		S7752	reso	22H00028	H 0
1746					MAI	1 TSH	+0.92		TSHTSH	0		A9608	reso	22H00028	H 0
1747			0.18	85	PID	4 TSH	+0.92		TSHTSH			G6391	rsec	22H00064	H99
1748	37	137	0.16	96	MAI	2 TSH	+0.45		TSHTSH	0.2		S7752	reso	22H00028	H 0
1749					MAI	1 TSH	+0.45		TSHTSH	0		A9608	reso	22H00028	H 0
1750			0.15	99	PID	4 TSH	+0.45		TSHTSH			G6391	rsec	22H00064	H99
1751	39	137	0.25	100	SAI	2 TSH	+0.44		TSHTSH	0.4		M1680	reso	22H00027	H 0
1752			0.25	75	SAI	1 TSH	+0.44		TSHTSH	0.4		M1680	reso	22H00027	H 0
1753			0.22	104	PID	4 TSH	+0.44		TSHTSH			G6391	rsec	22H00064	H99
1754	45	137	0.90	55	MBM	6 04H	+36.49		TEHTEC			R6452	reso	22C00024	C 0
1755	63	137	0.60	60	MBM	5 01H	+19.64		TEHTEC			H2131	reso	22C00056	C 0
1756	71	137	0.68	81	MBM	6 03H	+28.55		TEHTEC			T0042	reso	22C00034	C 0
1757			0.40	68	MBM	5 04H	+10.77		TEHTEC			T0042	reso	22C00034	C 0
1758			0.45	55	MBM	5 04H	+16.17		TEHTEC			T0042	reso	22C00034	C 0
1759			0.49	89	MBM	5 04H	+26.80		TEHTEC			T0042	reso	22C00034	C 0
1760			0.62	77	MBM	5 05H	-1.66		TEHTEC			T0042	reso	22C00034	C 0
1761	73	137	0.66	96	MBM	5 02C	+29.18		TEHTEC			R6452	reso	22C00035	C 0
	83	137	1.05	1	IDM	2 TSC	+6.20		TSCTSC			K7060	reso	22C00134	C 3
1763	16	138			SAI	1 TSH	+0.16		TSHTSH	0		H2131	reso	22H00011	H 0
1764			0.11	111	SAI	2 TSH	+0.16		TSHTSH	0.2		C3340	reso	22H00011	H 0

	ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION		EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
1765			0.10	51	SAI	1 TSH	+0.54		TSHTSH	0.2		C3340	reso	22H00011	H 0
1766			0.18	104	SAI	2 TSH	+0.54		TSHTSH	0.4		C3340	reso	22H00011	H 0
1767			0.14	92	PID	4 TSH	+0.54		TSHTSH			G6391	rsec	22H00064	H99
1768			0.18	105	SAI	2 TSH	+2.99		TSHTSH	0.3		C3340	reso	22H00011	H 0
1769			0.07	127	SAI	1 TSH	+2.99		TSHTSH	0.2		C3340	reso	22H00011	H 0
1770	28	138	0.17	91	MAI	2 TSH	+0.44	TO+1.33	TSHTSH	0.2		A9608	reso	22H00019	H 0
1771			0.05	92	MAI	1 TSH	+0.44	TO+1.33	TSHTSH	0.2		A9608	reso	22H00019	H 0
1772			0.23	102	PID	4 TSH	+0.44	TO+1.33	TSHTSH			G6391	rsec	22H00064	H99
1773	68	138	0.31	71	NQI	5 VM	+13.37		TEHTEC			S7752	reso	22C00011	C 0
1774					NDF	VM	+13.37		VM DC			A9608	reso	22C00087	C 5
1775	100	138	1.03	14	INR	P1 TSH	+1.59		TEHTEC			L7773	rpri	22C00011	C 0
1776	7	139			OBS	06H	+13.16		06H05H			M1680	reso	22H00071	H 2
1777					OBS	06H	+15.15		06H06H			A9608	reso	22H00106	H 2
1778	15	139	0.82	99	MBM	5 TSC	+0.55		TEHTEC			C3340	reso	22C00004	C 0
1779	19	139	0.22	85	SAI	1 TSH	+0.58		TSHTSH	0.2		C3340	reso	22H00011	H 0
1780			0.20	74	SAI	2 TSH	+0.58		TSHTSH	0.2		C3340	reso	22H00011	H 0
1781			0.19	66	PID	4 TSH	+0.58		TSHTSH			G6391	rsec	22H00064	H99
1782	27	139			SAI	1 TSH	+0.94		TSHTSH	0.0		H2131	reso	22H00019	H 0
1783			0.18	103	SAI	2 TSH	+0.94		TSHTSH	0.2		A9608	reso	22H00019	H 0
1784			0.15	111	PID	4 TSH	+0.94		TSHTSH			G6391	rsec	22H00064	H99
[illegible]	35	139			SAI	1 TSH	+0.35		TSHTSH	0.0		R6452	reso	22H00020	H 0
[illegible]			0.16	110	SAI	2 TSH	+0.35		TSHTSH	0.3		R6452	reso	22H00020	H 0
1787			0.15	96	PID	4 TSH	+0.35		TSHTSH			G6391	rsec	22H00064	H99
1788			0.12	115	SAI	2 TSH	+0.61		TSHTSH	0.2		R6452	reso	22H00020	H 0
1789					SAI	1 TSH	+0.61		TSHTSH	0.0		R6452	reso	22H00020	H 0
1790	43	139	1.06	81	NQI	5 01C	+11.89		TEHTEC			R6452	reso	22C00010	C 0
1791					NDF	2 01C	+11.89		02C01C			C3340	reso	22C00084	C 5
1792	47	139	0.75	141	21	P2 04C	+0.17		TEHTEC			R6452	reso	22C00010	C 0
1793			0.28	133	WAR	2 04C	+0.31		04C04C			C3340	reso	22C00084	C 5
1794	91	139	1.31	75	MBM	6 05H	+3.73		TEHTEC			R6452	reso	22C00010	C 0
1795			1.22	55	MBM	6 05H	+19.42		TEHTEC			R6452	reso	22C00010	C 0
1796	95	139	1.30	66	MBM	6 TSH	+35.19		TEHTEC			R6452	reso	22C00010	C 0
1797	60	140	0.76	66	MBM	6 05C	+8.85		TEHTEC			R6452	reso	22C00010	C 0
1798			0.94	61	MBM	6 05C	+24.30		TEHTEC			R6452	reso	22C00010	C 0
1799	15	141			SAI	1 TSH	+1.86		TSHTSH	0		H2131	reso	22H00011	H 0
1800			0.11	95	SAI	2 TSH	+1.86		TSHTSH	0.2		C3340	reso	22H00011	H 0
1801			0.12	97	PID	4 TSH	+1.86		TSHTSH			G6391	rsec	22H00064	H99
1802			0.64	74	MBM	6 05H	+23.67		TEHTEC			C3340	reso	22C00004	C 0
1803	91	141	0.83	65	MBM	6 04H	+31.68		TEHTEC			P4634	rsec	22C00012	C 0
1804	62	142	0.80	71	MBM	6 04H	+23.36		TEHTEC			P4634	rsec	22C00012	C 0
1805	84	142	2.30	87	MBM	6 04C	+2.64		TEHTEC			S7752	reso	22C00011	C 0
1806	75	143	0.56	67	MBM	6 TSH	+18.21		TEHTEC			S7752	reso	22C00012	C 0
1807	14	144	0.16	94	VOL	2 05H	+20.62		06C05H			C3340	reso	22H00070	H 2
1808	52	144	0.35	90	MBM	5 06C	+12.97		TEHTEC			A9608	reso	22C00007	C 0
1809			0.86	67	MBM	6 06C	+18.18		TEHTEC			S7752	reso	22C00007	C 0
1810			0.42	71	MBM	5 05C	+28.88		TEHTEC			A9608	reso	22C00007	C 0
	56	144	1.48	85	MBM	6 04H	+12.81		TEHTEC			S7752	reso	22C00007	C 0
1812	1	145			OBS	06C	+2.14		06CTEC			M9082	rpri	22C00093	C 1
1813	27	145	0.98	74	MBM	6 02C	+12.03		TEHTEC			S7752	reso	22C00007	C 0

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
1814	79	145	1.12	90	MBM	6 02C	+5.77	TEHTEC			A9608	reso	22C00027 C 0
1815	81	145	0.33	128	WAR	2 05H	+0.47	05H05H			C3340	reso	22H00065 H 4
1816			0.28	84	12	P2 05H	+0.54	TEHTEC			M7073	rsec	22C00013 C 0
1817	91	145			OBS	09C	+0.00	09C09C			A9608	reso	22C00088 C 2
1818	68	146	0.64	70	MBM	6 06H	+17.91	TEHTEC			R9311	rpri	22C00013 C 0
1819			0.47	87	MBM	6 06H	+21.32	TEHTEC			R9311	rpri	22C00013 C 0
1820	1	147			OBS	06C	+2.31	06CTEC			M1680	reso	22C00093 C 1
1821	9	147			SAI	1 VM	-2.94	06C05H	0		H2131	reso	22H00073 H 2
1822			0.16	116	SAI	2 VM	-2.94	06C05H	0.4		H2131	reso	22H00073 H 2
1823			0.32	147	PID	2 VM	-2.94	06HVM			O1057	rpri	22H00091 H99
1824	75	147	0.50	60	MBM	5 03H	+4.59	TEHTEC			K7060	reso	22C00013 C 0
1825	79	147	1.11	53	MBM	6 06C	+13.60	TEHTEC			R9311	rpri	22C00013 C 0
1826	52	148	0.94	57	MBM	6 02C	+10.20	TEHTEC			S7752	reso	22C00007 C 0
1827			0.75	74	MBM	6 02C	+13.83	TEHTEC			S7752	reso	22C00007 C 0
1828	1	149			OBS	06C	+0.74	06CTEC			M9082	rpri	22C00093 C 1
1829	1	151			OBS	06C	+3.95	06CTEC			M1680	reso	22C00093 C 1
1830	27	151	0.18	108	SVI	2 TSC	+0.03	TSCTSC	0.3		C3340	reso	22C00066 C 3
1831			0.23	93	SVI	1 TSC	+0.03	TSCTSC	0.3		C3340	reso	22C00066 C 3
1832			0.17	107	PID	4 TSC	+0.03	TSCTSC			M9082	rpri	22C00083 C99
1833	47	151	0.76	58	MBM	6 03C	+36.34	TEHTEC			R6452	reso	22C00005 C 0
[illegible]	26	152	0.31	102	SVI	2 TSC	+0.02	TSCTSC	0.3		B3720	reso	22C00127 C 3
1[illegible]			0.43	129	SVI	1 TSC	+0.02	TSCTSC	0.3		B3720	reso	22C00127 C 3
1836			0.22	101	PID	4 TSC	+0.02	TSCTSC			M0945	rsec	22C00140 C99
1837	72	152	1.25	77	MBM	5 TSH	+18.13	TEHTEC			M7073	rsec	22C00013 C 0
1838	1	153			OBS	06C	+2.75	06CTEC			M1680	reso	22C00093 C 1
1839	25	153	0.12	86	SVI	2 TSC	-0.04	TSCTSC	0.2		B3720	reso	22C00126 C 3
1840			0.07	47	SVI	1 TSC	-0.04	TSCTSC	0.2		B3720	reso	22C00126 C 3
1841			0.10	129	PID	4 TSC	-0.04	TSCTSC			M0945	rsec	22C00140 C99
1842	71	153	1.65	114	MBM	6 TSH	+20.75	TEHTEC			S7752	reso	22C00014 C 0
1843	73	153	1.54	64	MBM	6 04C	+33.25	TEHTEC			R9311	rpri	22C00013 C 0
1844	40	154	5.52	3	BLG	P1 TSH	+14.55	TEHTEC			W4892	rpri	22C00005 C 0
1845	1	155			OBS	06C	+1.49	06CTEC			M1680	reso	22C00093 C 1
1846	33	155	4.28	71	MBM	6 04C	+22.64	TEHTEC			S7752	reso	22C00006 C 0
1847	45	155	8.41	76	MBM	6 05C	+37.05	TEHTEC			S7752	reso	22C00006 C 0
1848	8	156			PRC			05H06H			H2131	reso	22H00091 H 2
1849			0.08	135	VOL	P1 05H	+3.67	06H05H			C3340	reso	22H00074 H 2
1850			0.07	103	VOL	P1 05H	+15.41	06H05H			C3340	reso	22H00074 H 2
1851	30	156	1.10	92	MBM	6 04H	+6.23	TEHTEC			S7752	reso	22C00006 C 0
1852	38	156	12.82	10	PVN	P1 02H	+7.49	TEHTEC			O1057	rpri	22C00006 C 0
1853	58	156	0.29	73	MBM	5 TSC	+29.53	TEHTEC			H3333	rsec	22C00006 C 0
1854	1	157			OBS	06C	+1.62	06CTEC			M1680	reso	22C00093 C 1
1855	8	158	1.43	83	INR	6 VM	+1.55 TO+2.50	TEHTEC			K7060	reso	22C00001 C 0
1856	22	158	0.32	118	INR	P1 02C	-0.95	TEHTEC			L2157	rpri	22C00004 C 0
1857	60	158	0.79	78	MBM	6 05C	+20.28	TEHTEC			R6452	reso	22C00005 C 0
1858			0.97	102	MBM	6 05C	+24.23	TEHTEC			R6452	reso	22C00005 C 0
1859	62	158	0.63	41	INR	P2 04H	-0.86	TEHTEC			K7060	reso	22C00013 C 0
	19	159	0.29	126	INR	P2 01H	-0.76	TEHTEC			N5877	rsec	22C00001 C 0
1861	41	159	0.85	80	MBM	6 TSC	+18.00	TEHTEC			S7752	reso	22C00004 C 0
1862	6	160			OBS	06H	+17.83	06H06H			A9608	reso	22H00106 H 2

ALL CALLS (EXCLUDING RETEST CODES & NDD)

UTILITY: Baltimore Gas & Electric

PLANT: CCNPP

UNIT: 2

SG: 22

DATABASE: CCNPP_UNIT2_SG22_0399_Final

May 17,1999 11:46

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL GROUP	LEG
1863	27	161	1.25	72	MBM 6	02C +27.78	TEHTEC			S7752	reso	22C00004	C 0
1864	12	162			OBS DH	+5.96	06HDH			A9608	reso	22H00106	H 2
1865	44	162	0.65	101	MBM 5	06H +9.11	TEHTEC			K7060	reso	22C00003	C 0
1866	1	163	0.34	81	PLP 9	TSH +0.58	TSHTSH			S4373	rpri	22H00010	H 0
1867					OBS 06C	+0.98	06CTEC			M1680	reso	22C00093	C 1
1868	11	163	0.17	29	SVI 1	TSC +0.03	TSCTSC	0.2		A9608	reso	22C00128	C 3
1869			0.12	116	SVI 2	TSC +0.03	TSCTSC	0.3		A9608	reso	22C00128	C 3
1870			0.18	70	PID 4	TSC +0.03	TSCTSC			M0945	rsec	22C00140	C99
1871	8	164	0.62	68	MBM 5	03H +18.84	TEHTEC			K7060	reso	22C00001	C 0
1872	14	164	0.89	81	MBM 6	02C +10.65	TEHTEC			C3340	reso	22C00002	C 0
1873	26	164	0.26	85	10 P2	VM +0.89	TEHTEC			L2157	rpri	22C00004	C 0
1874			0.17	88	WAR P4	VM +1.15	VM VM			A9608	reso	22C00087	C 5
1875	32	164	0.41	5	IDM 2	TSH -0.99	TSHTSH			K7060	reso	22H00054	H 0
1876	29	165	0.67	80	MBM 6	05C +14.82	TEHTEC			S7752	reso	22C00004	C 0
1877	15	167	0.44	90	19 P2	02C -0.98	TEHTEC			G5937	rsec	22C00001	C 0
1878			0.33	66	WAR 4	02C -0.93	02C02C			M0945	rsec	22C00095	C 5

ROW	LIN	VOLTS	DEG	PCT	CHN	LOCATION	EXTENT	UTIL1	UTIL2	NAME	TYPE	CAL	GROUP	LEG

QUERY REPORT SUMMARY:

QUERY PARAMETER		ENTRIES	TUBES
0 to 100 Percent		31	30
ADR	Indication Code	2	2
BLG	Indication Code	1	1
CUD	Indication Code	0	0
DEP	Indication Code	0	0
DNI	Indication Code	1	1
DRI	Indication Code	0	0
DSI	Indication Code	30	27
DTI	Indication Code	0	0
ETL	Indication Code	0	0
EXP	Indication Code	0	0
FSA	Indication Code	0	0
FSD	Indication Code	0	0
IDC	Indication Code	0	0
IDM	Indication Code	6	6
INF	Indication Code	17	14
INR	Indication Code	80	73
LDE	Indication Code	0	0
LPI	Indication Code	1	1
MAI	Indication Code	106	53
MBM	Indication Code	748	526
MCI	Indication Code	20	10
MMI	Indication Code	0	0
MSI	Indication Code	4	2
MVI	Indication Code	2	1
NDF	Indication Code	44	41
NQI	Indication Code	59	58
NRC	Indication Code	42	42
NRH	Indication Code	0	0
NSY	Indication Code	0	0
OBS	Indication Code	66	54
PBC	Indication Code	0	0
PID	Indication Code	203	203
PLP	Indication Code	49	44
PPS	Indication Code	1	1
PRC	Indication Code	2	2
PSP	Indication Code	1	1
PTS	Indication Code	0	0
PVN	Indication Code	5	5
SAI	Indication Code	242	110
SCI	Indication Code	42	21
SVI	Indication Code	18	9
UDE	Indication Code	0	0
VOL	Indication Code	14	13
WAR	Indication Code	41	37

TOTAL ENTRIES: 1878

TOTAL TUBES: 986

CCNPP-2 RFO12 Tube Plugging List										TUBE	STAB	LIST
S/G	ROW	COL	H/L	C/L	REASON FOR PLUGGING					QTY	QTY	REV
SG-22	29	49	ROLL	ROLL	SAI	@	TSH	+	0.41	1	0	00
SG-22	22	50	ROLL	ROLL	SAI	@	TSH	+	0.30	2	0	00
SG-22	86	50	ROLL	ROLL	SAI	@	TSH	+	0.15	3	0	00
SG-22	90	50	ROLL	ROLL	SAI	@	TSH	+	0.27	4	0	00
SG-22	25	51	ROLL/STAB	ROLL	SCI	@	TSH	+	0.04	5	1	00
SG-22	92	52	ROLL/STAB	ROLL	SCI	@	TSH	+	0.11	6	2	00
SG-22	29	53	ROLL/STAB	ROLL	SCI	@	TSH	+	0.02	7	3	00
SG-22	88	54	ROLL/STAB	ROLL	SCI	@	TSH	+	0.04	8	4	00
SG-22	49	57	ROLL	ROLL	MAI	@	01H	+	0.65	9	4	00
SG-22	24	60	ROLL/STAB	ROLL	SCI	@	TSH	-	0.44	10	5	00
SG-22	35	61	ROLL	ROLL	SAI	@	TSH	-	0.66	11	5	00
SG-22	34	68	ROLL	ROLL	MAI	@	TSH	+	1.60	12	5	00
SG-22	63	69	ROLL	ROLL	MAI	@	TSH	+	0.30	13	5	00
SG-22	41	71	ROLL	ROLL	MAI	@	TSH	+	1.80	14	5	00
SG-22	85	71	ROLL	ROLL	SAI	@	TSH	+	0.53	15	5	00
SG-22	84	72	ROLL	ROLL	SAI	@	TSH	+	0.79	16	5	00
SG-22	84	74	ROLL	ROLL	SAI	@	TSH	+	0.94	17	5	00
SG-22	43	75	ROLL	ROLL	SAI	@	TSH	+	2.57	18	5	00
SG-22	85	75	ROLL	ROLL	SAI	@	TSH	+	0.59	19	5	00
SG-22	41	77	ROLL	ROLL	MAI	@	TSH	+	1.37	20	5	00
SG-22	128	78	ROLL	ROLL	SAI	@	TSC	+	0.22	21	5	00
SG-22	78	80	ROLL	ROLL	SAI	@	TSH	+	1.49	22	5	00
SG-22	133	81	ROLL	ROLL	MVI	@	TSC	+	0.03	23	5	00
SG-22	135	81	ROLL	ROLL	SVI	@	TSC	+	0.20	24	5	00
SG-22	76	82	ROLL	ROLL	SAI	@	TSH	+	1.33	25	5	00
SG-22	78	82	ROLL	ROLL	SAI	@	TSH	+	1.93	26	5	00
SG-22	81	83	ROLL	ROLL	SAI	@	TSH	+	0.98	27	5	00
SG-22	70	84	ROLL	ROLL	SAI	@	TSH	+	1.86	28	5	00
					SAI	@	TSH	+	2.55			
SG-22	79	85	ROLL	ROLL	SAI	@	TSH	+	0.79	29	5	00
SG-22	42	86	ROLL	ROLL	SAI	@	TSH	+	0.95	30	5	00
SG-22	84	86	ROLL	ROLL	MAI	@	TSH	+	0.48	31	5	00
SG-22	90	86	ROLL	ROLL	SAI	@	TSH	+	0.65	32	5	00
SG-22	96	86	ROLL	ROLL	SAI	@	TSC	+	1.11	33	5	00
SG-22	69	87	ROLL	ROLL	SAI	@	TSH	+	2.25	34	5	00
SG-22	83	87	ROLL	ROLL	MAI	@	TSH	+	0.55	35	5	00
SG-22	87	87	ROLL	ROLL	SAI	@	TSH	+	0.94	36	5	00
SG-22	81	89	ROLL	ROLL	SAI	@	TSH	+	1.48	37	5	00
SG-22	80	90	ROLL	ROLL	SAI	@	TSH	+	1.36	38	5	00
SG-22	88	90	ROLL	ROLL	SAI	@	TSH	+	0.65	39	5	00
SG-22	42	92	ROLL	ROLL	SAI	@	TSH	-	1.29	40	5	00
SG-22	62	92	ROLL	ROLL	SAI	@	TSH	+	4.25	41	5	00
SG-22	80	92	ROLL	ROLL	MAI	@	TSH	+	0.77	42	5	00
SG-22	80	94	ROLL	ROLL	MSI	@	TSH	+	0.50	43	5	00
SG-22	78	96	ROLL	ROLL	SAI	@	TSH	+	1.06	44	5	00
SG-22	80	96	ROLL	ROLL	SAI	@	TSH	+	1.48	45	5	00
					SAI	@	TSH	+	1.04			00

CCNPP-2 RFO12 Tube Plugging List										TUBE	STAB	LIST
S/G	ROW	COL	H/L	C/L	REASON FOR PLUGGING					QTY	QTY	REV
SG-22	79	97	ROLL	ROLL	SAI	@	TSH	+	0.73	46	5	00
					SAI	@	TSH	+	1.16			00
SG-22	102	98	ROLL	ROLL	SAI	@	VH	+	2.74	47	5	00
SG-22	79	99	ROLL	ROLL	SAI	@	TSH	+	0.91	48	5	00
SG-22	65	107	ROLL	ROLL	SAI	@	TSH	+	0.78	49	5	00
SG-22	93	109	ROLL	ROLL	MAI	@	TSH	+	2.48	50	5	00
SG-22	9	113	ROLL	ROLL	MAI	@	02H	+	0.57	51	5	00
SG-22	86	116	ROLL	ROLL	SAI	@	TSH	+	0.24	52	5	00
SG-22	81	119	ROLL/STAB	ROLL	MCI	@	TSH	+	0.05	53	6	00
SG-22	85	119	ROLL	ROLL	SAI	@	TSH	+	0.25	54	6	00
SG-22	91	119	ROLL	ROLL	SAI	@	TSH	+	0.23	55	6	00
SG-22	14	120	ROLL	ROLL	MAI	@	TSH	+	1.70	56	6	00
SG-22	81	121	ROLL/STAB	ROLL	SCI	@	TSH	+	0.22	57	7	00
SG-22	87	121	ROLL/STAB	ROLL	SCI	@	TSH	+	0.17	58	8	00
SG-22	89	121	ROLL/STAB	ROLL	SCI	@	TSH	+	0.14	59	9	00
SG-22	77	123	ROLL/STAB	ROLL	SCI	@	TSH	+	0.10	60	10	00
SG-22	68	124	ROLL	ROLL	SAI	@	TSH	+	0.29	61	10	00
SG-22	76	124	ROLL/STAB	ROLL	SCI	@	TSH	+	0.10	62	11	00
SG-22	73	125	ROLL/STAB	ROLL	SCI	@	TSH	+	0.12	63	12	00
					MAI	@	TSH	+	0.57			
SG-22	78	126	ROLL	ROLL	SAI	@	TSH	+	0.33	64	12	00
SG-22	75	127	ROLL/STAB	ROLL	MCI	@	TSH	+	0.13	65	13	00
SG-22	76	128	ROLL/STAB	ROLL	SCI	@	TSH	+	0.06	66	14	00
SG-22	23	129	ROLL	ROLL	SAI	@	TSH	+	0.58	67	14	00
SG-22	65	129	ROLL/STAB	ROLL	MCI	@	TSH	+	0.06	68	15	00
SG-22	75	129	ROLL/STAB	ROLL	MCI	@	TSH	+	0.11	69	16	00
SG-22	10	130	ROLL	ROLL	SAI	@	VM	+	0.00	70	16	00
SG-22	25	131	ROLL	ROLL	SAI	@	TSH	+	5.47	71	16	00
					MAI	@	TSH	+	0.54			
					SAI	@	TSH	+	5.08			
SG-22	35	131	ROLL	ROLL	SAI	@	TSH	+	1.23	72	16	00
SG-22	37	131	ROLL	ROLL	SAI	@	TSH	+	0.15	73	16	00
SG-22	47	131	ROLL	ROLL	MAI	@	TSH	+	0.11	74	16	00
SG-22	22	132	ROLL	ROLL	MAI	@	TSH	+	0.39	75	16	00
SG-22	24	132	ROLL	ROLL	MAI	@	TSH	+	0.87	76	16	00
SG-22	36	132	ROLL	ROLL	MAI	@	TSH	+	0.68	77	16	00
SG-22	37	133	ROLL	ROLL	MAI	@	TSH	+	0.69	78	16	00
SG-22	39	133	ROLL	ROLL	MAI	@	TSH	+	0.67	79	16	00
SG-22	12	134	ROLL	ROLL	SAI	@	TSH	+	0.73	80	16	00
SG-22	18	134	ROLL	ROLL	SAI	@	TSH	+	0.54	81	16	00
SG-22	24	134	ROLL	ROLL	MAI	@	TSH	+	1.43	82	16	00
SG-22	38	134	ROLL	ROLL	SAI	@	TSH	+	0.52	83	16	00
SG-22	42	134	ROLL	ROLL	SAI	@	TSH	+	0.15	84	16	00
SG-22	102	134	ROLL/STAB	ROLL	SCI	@	TSH	+	0.00	85	17	00
SG-22	13	135	ROLL	ROLL	SAI	@	TSH	+	1.24	86	17	00
SG-22	23	135	ROLL	ROLL	MAI	@	TSH	+	0.90	87	17	00
SG-22	31	135	ROLL	ROLL	SAI	@	TSH	+	1.44	88	17	00
SG-22	39	135	ROLL	ROLL	SAI	@	TSH	+	0.69	89	17	00
SG-22	45	135	ROLL/STAB	ROLL	MCI	@	TSH	+	0.18	90	18	00

CCNPP-2 RFO12 Tube Plugging List										TUBE	STAB	LIST
S/G	ROW	COL	H/L	C/L	REASON FOR PLUGGING					QTY	QTY	REV
SG-22	24	136	ROLL	ROLL	MAI	@	TSH	+	0.64	91	18	00
SG-22	28	136	ROLL	ROLL	MAI	@	TSH	+	1.08	92	18	00
SG-22	40	136	ROLL	ROLL	SAI	@	TSH	+	0.13	93	18	00
					MAI	@	TSH	+	0.51			
SG-22	56	136	ROLL	ROLL	SAI	@	TSH	+	0.72	94	18	00
SG-22	21	137	ROLL	ROLL	SAI	@	TSH	+	0.79	95	18	00
SG-22	27	137	ROLL	ROLL	MAI	@	TSH	+	0.78	96	18	00
SG-22	31	137	ROLL	ROLL	MAI	@	TSH	+	0.92	97	18	00
SG-22	37	137	ROLL	ROLL	MAI	@	TSH	+	0.45	98	18	00
SG-22	39	137	ROLL	ROLL	SAI	@	TSH	+	0.44	99	18	00
SG-22	16	138	ROLL	ROLL	SAI	@	TSH	+	0.16	100	18	00
					SAI	@	TSH	+	0.54			
					SAI	@	TSH	+	2.99			
SG-22	28	138	ROLL	ROLL	MAI	@	TSH	+	0.44	101	18	00
SG-22	19	139	ROLL	ROLL	SAI	@	TSH	+	0.58	102	18	00
SG-22	27	139	ROLL	ROLL	SAI	@	TSH	+	0.94	103	18	00
SG-22	35	139	ROLL	ROLL	SAI	@	TSH	+	0.35	104	18	00
					SAI	@	TSH	+	0.61			
SG-22	15	141	ROLL	ROLL	SAI	@	TSH	+	1.86	105	18	00
SG-22	9	147	ROLL	ROLL	SAI	@	VM	-	2.94	106	18	00
SG-22	27	151	ROLL	ROLL	SVI	@	TSC	+	0.03	107	18	00
SG-22	26	152	ROLL	ROLL	SVI	@	TSC	+	0.02	108	18	00
SG-22	25	153	ROLL	ROLL	SVI	@	TSC	-	0.04	109	18	00
SG-22	11	163	ROLL	ROLL	SVI	@	TSC	+	0.03	110	18	00
SG-22	1	1	ROLL	ROLL	SVI	@	TSC	+	0.00	111	18	01
SG-22	22	22	ROLL/STAB	ROLL	SCI	@	TSH	+	0.17	112	19	01
SG-22	21	23	ROLL/STAB	ROLL	SCI	@	TSH	+	0.14	113	20	01
SG-22					SAI	@	TSH	+	0.55			
SG-22	18	24	ROLL/STAB	ROLL	SCI	@	TSH	+	0.10	114	21	00
SG-22	24	24	ROLL	ROLL	SAI	@	TSH	+	0.24	115	21	01
SG-22	19	25	ROLL/STAB	ROLL	SCI	@	TSH	+	0.07	116	22	01
SG-22	12	26	ROLL	ROLL	SAI	@	02H	+	0.29	117	22	01
SG-22	17	27	ROLL/STAB	ROLL	SCI	@	TSH	+	0.13	118	23	01
SG-22					SAI	@	TSH	+	0.31			
SG-22	31	27	ROLL	ROLL	MAI	@	TSH	+	0.73	119	23	00
SG-22	22	28	ROLL	ROLL	SAI	@	TSH	+	1.04	120	23	01
SG-22	24	28	ROLL	ROLL	MAI	@	TSH	+	0.85	121	23	01
SG-22	42	28	ROLL	ROLL	SAI	@	TSH	+	0.24	122	23	01
SG-22	89	29	ROLL	ROLL	SAI	@	TSC	+	4.22	123	23	01
SG-22	18	30	ROLL/STAB	ROLL	MCI	@	TSH	+	0.09	124	24	01
SG-22	42	30	ROLL	ROLL	SAI	@	TSH	+	0.14	125	24	01
SG-22	31	31	ROLL	ROLL	SAI	@	TSH	+	1.36	126	24	01
SG-22	2	32	ROLL	ROLL	PSP	@	TSC	+	0.00	127	24	01
SG-22	16	32	ROLL	ROLL	MAI	@	TSH	+	0.48	128	24	01
SG-22	49	33	ROLL	ROLL	SAI	@	TSH	+	0.23	129	24	01
SG-22	12	34	ROLL	ROLL	SAI	@	TSH	+	1.25	130	24	01
SG-22	20	34	ROLL	ROLL	SAI	@	TSH	+	0.69	131	24	01
SG-22	42	34	ROLL	ROLL	MAI	@	TSH	+	0.64	132	24	01
SG-22	46	34	ROLL	ROLL	SAI	@	TSH	+	0.67	133	24	01

CCNPP-2 RFO12 Tube Plugging List										TUBE	STAB	LIST
S/G	ROW	COL	H/L	C/L	REASON FOR PLUGGING					QTY	QTY	REV
SG-22	11	35	ROLL	ROLL	SAI	@	TSH	+	0.49	134	24	01
SG-22	19	35	ROLL	ROLL	SAI	@	TSH	+	0.64	135	24	01
SG-22	37	35	ROLL	ROLL	MAI	@	TSH	+	0.84	136	24	01
SG-22	53	35	ROLL/STAB	ROLL	MCI	@	TSH	+	0.10	137	25	01
SG-22	61	35	ROLL	ROLL	MAI	@	TSH	+	0.05	138	25	01
SG-22	16	36	ROLL	ROLL	SAI	@	TSH	+	2.06	139	25	01
SG-22	29	37	ROLL	ROLL	SAI	@	TSH	+	1.47	140	25	01
SG-22	39	37	ROLL	ROLL	SAI	@	TSH	+	0.60	141	25	01
SG-22	41	37	ROLL	ROLL	SAI	@	TSH	+	0.70	142	25	01
SG-22	11	39	ROLL	ROLL	SAI	@	TSH	+	0.56	143	25	01
SG-22	43	39	ROLL	ROLL	SAI	@	TSH	+	0.65	144	25	01
SG-22	49	39	ROLL	ROLL	MAI	@	TSH	+	0.53	145	25	01
SG-22	55	39	ROLL	ROLL	SAI	@	TSH	+	0.20	146	25	01
SG-22	59	39	ROLL	ROLL	SAI	@	TSH	+	0.50	147	25	01
SG-22	61	39	ROLL	ROLL	MAI	@	TSH	+	0.09	148	25	01
SG-22	48	40	ROLL	ROLL	SAI	@	TSH	+	0.69	149	25	01
SG-22	52	40	ROLL	ROLL	SAI	@	TSH	+	0.80	150	25	01
SG-22	19	41	ROLL	ROLL	SAI	@	TSH	+	2.88	151	25	01
SG-22	25	41	ROLL	ROLL	SAI	@	TSH	+	0.62	152	25	01
SG-22	49	41	ROLL	ROLL	SAI	@	TSH	+	0.85	153	25	01
SG-22	24	42	ROLL	ROLL	SAI	@	TSH	+	0.24	154	25	01
SG-22	28	42	ROLL	ROLL	MSI	@	TSH	+	0.12	155	25	01
SG-22	30	42	ROLL	ROLL	SAI	@	TSH	+	0.47	156	25	01
SG-22	15	43	ROLL	ROLL	SAI	@	TSH	+	2.33	157	25	01
SG-22	17	43	ROLL	ROLL	SAI	@	TSH	+	3.26	158	25	01
SG-22					SAI	@	TSH	+	2.15		25	01
SG-22	23	43	ROLL	ROLL	SAI	@	TSH	+	0.21	159	25	01
SG-22					SAI	@	TSH	+	3.06		25	01
SG-22					SAI	@	TSH	+	3.66		25	01
SG-22	31	43	ROLL	ROLL	SAI	@	TSH	+	0.77	160	25	01
SG-22	69	43	ROLL	ROLL	SAI	@	TSH	+	0.20	161	25	01
SG-22					SAI	@	TSH	+	2.18		25	01
SG-22	79	43	ROLL	ROLL	SAI	@	TSH	+	0.12	162	25	01
SG-22	62	44	ROLL	ROLL	MAI	@	TSH	+	0.15	163	25	01
SG-22	68	44	ROLL	ROLL	SAI	@	TSH	+	0.40	164	25	01
SG-22	29	45	ROLL	ROLL	MAI	@	TSH	+	0.48	165	25	01
SG-22	53	45	ROLL	ROLL	MAI	@	TSH	+	0.54	166	25	01
SG-22	67	45	ROLL	ROLL	SAI	@	TSH	+	0.42	167	25	01
SG-22	77	45	ROLL/STAB	ROLL	MCI	@	TSH	+	0.05	168	26	01
SG-22	90	46	ROLL/STAB	ROLL	SCI	@	TSH	+	0.12	169	27	01
SG-22	29	47	ROLL	ROLL	SAI	@	TSH	+	0.51	170	27	01
SG-22	87	47	ROLL/STAB	ROLL	MCI	@	TSH	+	0.06	171	28	01
SG-22	89	47	ROLL/STAB	ROLL	MCI	@	TSH	+	0.06	172	29	01
SG-22	95	47	ROLL/STAB	ROLL	SCI	@	TSH	+	0.04	173	30	01
SG-22	18	52	ROLL	ROLL	SAI	@	TSH	+	2.96	174	30	01
SG-22	9	53	ROLL	ROLL	SAI	@	TSH	+	2.34	175	30	01
SG-22	8	60	ROLL	ROLL	SAI	@	TSH	+	2.07	176	30	01
SG-22	137	67	ROLL	ROLL	SVI	@	TSC	+	0.07	177	30	01
SG-22	136	68	ROLL	ROLL	SVI	@	TSC	+	0.06	178	30	01

CCNPP-2 RFO12 Tube Plugging List										TUBE	STAB	LIST
S/G	ROW	COL	H/L	C/L	REASON FOR PLUGGING					QTY	QTY	REV
SG-22	138	68	ROLL	ROLL	SVI	@	TSC	+	0.10	179	30	01
SG-22	29	99	ROLL	ROLL/STAB	SCI	@	TSC	+	0.04	180	31	01
SG-22	29	101	ROLL	ROLL	SAI	@	TSC	+	0.15	181	31	01
SG-22	54	102	ROLL	ROLL	MAI	@	TSH	+	0.13	182	31	01
SG-22	56	102	ROLL	ROLL	MAI	@	TSH	+	0.36	183	31	01
SG-22	48	104	ROLL	ROLL	MAI	@	TSH	+	0.36	184	31	01
SG-22	54	104	ROLL	ROLL	MAI	@	TSH	+	0.07	185	31	01
SG-22	60	104	ROLL	ROLL	MAI	@	TSH	+	0.17	186	31	01
SG-22	36	106	ROLL	ROLL	SAI	@	TSH	-	2.64	187	31	01
SG-22	49	107	ROLL	ROLL	SAI	@	TSH	+	0.24	188	31	01
SG-22	50	108	ROLL	ROLL	SAI	@	TSH	+	0.66	189	31	01
SG-22	42	110	ROLL	ROLL	MAI	@	TSH	+	0.34	190	31	01
SG-22	46	110	ROLL	ROLL	SAI	@	TSH	+	0.60	191	31	01
SG-22	48	110	ROLL	ROLL	MAI	@	TSH	+	0.10	192	31	01
SG-22	29	111	ROLL	ROLL	MAI	@	TSH	+	0.10	193	31	01
SG-22	31	111	ROLL	ROLL	MAI	@	TSH	+	0.08	194	31	01
SG-22	39	111	ROLL	ROLL	MAI	@	TSH	+	0.30	195	31	01
SG-22	45	111	ROLL	ROLL	SAI	@	TSH	+	0.87	196	31	01
SG-22	42	112	ROLL	ROLL	MAI	@	TSH	+	0.27	197	31	01
SG-22	31	113	ROLL	ROLL	SAI	@	TSH	+	0.22	198	31	01
SG-22	35	113	ROLL	ROLL	MAI	@	TSH	+	0.09	199	31	01
SG-22	43	113	ROLL	ROLL	MAI	@	TSH	+	1.07	200	31	01
SG-22	36	114	ROLL	ROLL	MAI	@	TSH	+	0.45	201	31	01
SG-22	56	114	ROLL	ROLL	SAI	@	TSH	+	0.91	202	31	01
SG-22	2	124	ROLL	ROLL/STAB	LPI	@	TSC	+	0.15	203	32	01
							Totals			203	32	

Table 7-2: SG 21 Tubes Removed from Service due to Eggcrate Degradation
(Tube quantity count is continued from Section 6.0)

CCNPP-2 RFO12 Tube Plugging List - EC Degradation						TUBE	STAB	LIST
S/G	ROW	COL	H/L	C/L	REASON FOR PLUGGING	QTY	QTY	REV
SG-21	89	21	ROLL	ROLL	EC Degradation	251	20	2
SG-21	90	22	ROLL	ROLL	EC Degradation	252	20	2
SG-21	90	146	ROLL	ROLL	EC Degradation	253	20	2
SG-21	89	147	ROLL	ROLL	EC Degradation	254	20	2
					Totals	254	20	

Table 7-3: SG 22 Tubes Removed from Service due to Eggcrate Degradation
(Tube quantity count is continued from Section 6.0)

CCNPP-2 RFO12 Tube Plugging List - EC Degradation						TUBE	STAB	LIST
S/G	ROW	COL	H/L	C/L	REASON FOR PLUGGING	QTY	QTY	REV
SG-22	31	3	ROLL	ROLL	EC Degradation	204	32	4
SG-22	32	4	ROLL	ROLL	EC Degradation	205	32	4
SG-22	34	4	ROLL	ROLL	EC Degradation	206	32	4
SG-22	36	4	ROLL	ROLL	EC Degradation	207	32	4
SG-22	38	4	ROLL	ROLL	EC Degradation	208	32	4
SG-22	39	5	ROLL	ROLL	EC Degradation	209	32	4
SG-22	41	5	ROLL	ROLL	EC Degradation	210	32	4
SG-22	43	5	ROLL	ROLL	EC Degradation	211	32	3
SG-22	44	6	ROLL	ROLL	EC Degradation	212	32	3
SG-22	46	6	ROLL	ROLL	EC Degradation	213	32	3
SG-22	48	6	ROLL	ROLL	EC Degradation	214	32	3
SG-22	49	7	ROLL	ROLL	EC Degradation	215	32	3
SG-22	51	7	ROLL	ROLL	EC Degradation	216	32	3
SG-22	53	7	ROLL	ROLL	EC Degradation	217	32	3
SG-22	54	8	ROLL	ROLL	EC Degradation	218	32	3
SG-22	56	8	ROLL	ROLL	EC Degradation	219	32	3
SG-22	57	9	ROLL	ROLL	EC Degradation	220	32	3
SG-22	59	9	ROLL	ROLL	EC Degradation	221	32	3
SG-22	60	10	ROLL	ROLL	EC Degradation	222	32	3
SG-22	62	10	ROLL	ROLL	EC Degradation	223	32	3
SG-22	63	11	ROLL	ROLL	EC Degradation	224	32	3
SG-22	65	11	ROLL	ROLL	EC Degradation	225	32	3
SG-22	67	11	ROLL	ROLL	EC Degradation	226	32	3
SG-22	68	12	ROLL	ROLL	EC Degradation	227	32	3
SG-22	69	13	ROLL	ROLL	EC Degradation	228	32	3
SG-22	71	13	ROLL	ROLL	EC Degradation	229	32	3
SG-22	73	13	ROLL	ROLL	EC Degradation	230	32	3
SG-22	74	14	ROLL	ROLL	EC Degradation	231	32	3
SG-22	75	15	ROLL	ROLL	EC Degradation	232	32	3
SG-22	77	15	ROLL	ROLL	EC Degradation	233	32	3
SG-22	78	16	ROLL	ROLL	EC Degradation	234	32	3

CCNPP-2 RFO12 Tube Plugging List - EC Degradation						TUBE	STAB	LIST
S/G	ROW	COL	H/L	C/L	REASON FOR PLUGGING	QTY	QTY	REV
SG-22	80	16	ROLL	ROLL	EC Degradation	235	32	3
SG-22	81	17	ROLL	ROLL	EC Degradation	236	32	3
SG-22	83	17	ROLL	ROLL	EC Degradation	237	32	3
SG-22	84	18	ROLL	ROLL	EC Degradation	238	32	3
SG-22	85	19	ROLL	ROLL	EC Degradation	239	32	3
SG-22	87	19	ROLL	ROLL	EC Degradation	240	32	3
SG-22	88	20	ROLL	ROLL	EC Degradation	241	32	3
SG-22	89	21	ROLL	ROLL	EC Degradation	242	32	3
SG-22	91	21	ROLL	ROLL	EC Degradation	243	32	3
SG-22	90	22	ROLL	ROLL	EC Degradation	244	32	3
SG-22	92	22	ROLL	ROLL	EC Degradation	245	32	3
SG-22	93	23	ROLL	ROLL	EC Degradation	246	32	3
SG-22	95	23	ROLL	ROLL	EC Degradation	247	32	3
SG-22	96	24	ROLL	ROLL	EC Degradation	248	32	3
SG-22	97	25	ROLL	ROLL	EC Degradation	249	32	3
SG-22	99	25	ROLL	ROLL	EC Degradation	250	32	3
SG-22	100	26	ROLL	ROLL	EC Degradation	251	32	3
SG-22	101	27	ROLL	ROLL	EC Degradation	252	32	3
SG-22	101	141	ROLL	ROLL	EC Degradation	253	32	3
SG-22	98	142	ROLL	ROLL	EC Degradation	254	32	3
SG-22	100	142	ROLL	ROLL	EC Degradation	255	32	3
SG-22	97	143	ROLL	ROLL	EC Degradation	256	32	3
SG-22	96	144	ROLL	ROLL	EC Degradation	257	32	3
SG-22	93	145	ROLL	ROLL	EC Degradation	258	32	3
SG-22	95	145	ROLL	ROLL	EC Degradation	259	32	3
SG-22	90	146	ROLL	ROLL	EC Degradation	260	32	3
SG-22	92	146	ROLL	ROLL	EC Degradation	261	32	3
SG-22	89	147	ROLL	ROLL	EC Degradation	262	32	3
SG-22	91	147	ROLL	ROLL	EC Degradation	263	32	3
SG-22	88	148	ROLL	ROLL	EC Degradation	264	32	3
SG-22	85	149	ROLL	ROLL	EC Degradation	265	32	3
SG-22	87	149	ROLL	ROLL	EC Degradation	266	32	3
SG-22	84	150	ROLL	ROLL	EC Degradation	267	32	3
SG-22	81	151	ROLL	ROLL	EC Degradation	268	32	3
SG-22	83	151	ROLL	ROLL	EC Degradation	269	32	3
SG-22	78	152	ROLL	ROLL	EC Degradation	270	32	3
SG-22	80	152	ROLL	ROLL	EC Degradation	271	32	3
SG-22	75	153	ROLL	ROLL	EC Degradation	272	32	3
SG-22	77	153	ROLL	ROLL	EC Degradation	273	32	3
SG-22	74	154	ROLL	ROLL	EC Degradation	274	32	3
SG-22	69	155	ROLL	ROLL	EC Degradation	275	32	3
SG-22	71	155	ROLL	ROLL	EC Degradation	276	32	3
SG-22	73	155	ROLL	ROLL	EC Degradation	277	32	3
SG-22	68	156	ROLL	ROLL	EC Degradation	278	32	3
SG-22	63	157	ROLL	ROLL	EC Degradation	279	32	3
SG-22	65	157	ROLL	ROLL	EC Degradation	280	32	3

CCNPP-2 RFO12 Tube Plugging List - EC Degradation						TUBE	STAB	LIST
S/G	ROW	COL	H/L	C/L	REASON FOR PLUGGING	QTY	QTY	REV
SG-22	67	157	ROLL	ROLL	EC Degradation	281	32	3
SG-22	60	158	ROLL	ROLL	EC Degradation	282	32	3
SG-22	62	158	ROLL	ROLL	EC Degradation	283	32	3
SG-22	57	159	ROLL	ROLL	EC Degradation	284	32	3
SG-22	59	159	ROLL	ROLL	EC Degradation	285	32	3
SG-22	54	160	ROLL	ROLL	EC Degradation	286	32	3
SG-22	56	160	ROLL	ROLL	EC Degradation	287	32	3
SG-22	49	161	ROLL	ROLL	EC Degradation	288	32	3
SG-22	51	161	ROLL	ROLL	EC Degradation	289	32	3
SG-22	53	161	ROLL	ROLL	EC Degradation	290	32	3
SG-22	44	162	ROLL	ROLL	EC Degradation	291	32	3
SG-22	46	162	ROLL	ROLL	EC Degradation	292	32	3
SG-22	48	162	ROLL	ROLL	EC Degradation	293	32	3
SG-22	39	163	ROLL	ROLL	EC Degradation	294	32	4
SG-22	41	163	ROLL	ROLL	EC Degradation	295	32	4
SG-22	43	163	ROLL	ROLL	EC Degradation	296	32	3
SG-22	32	164	ROLL	ROLL	EC Degradation	297	32	4
SG-22	34	164	ROLL	ROLL	EC Degradation	298	32	4
SG-22	36	164	ROLL	ROLL	EC Degradation	299	32	4
SG-22	38	164	ROLL	ROLL	EC Degradation	300	32	4
SG-22	31	165	ROLL	ROLL	EC Degradation	301	32	4
					Totals	301	32	