

ATTACHMENT - E

FLORIDA POWER & LIGHT COMPANY

ST. LUCIE PLANT UNIT NOS. 1 & 2

LICENSE NUMBERS DPR-67 & NPF-16

CORRECTION TO THE
COMBINED ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT
FOR THE PERIOD
JANUARY 1, 1998 THROUGH DECEMBER 31, 1998

Affected Pages: Page 10 is the only affected page.

Two items were corrected for St. Lucie Unit 2 Liquid Effluents:

- 1) B. Tritium 1. Total Release Curies for Quarter # 4
- 2) B. Tritium 2. Average diluted Concentration
During Period for Quarter # 4

Remark: The typo induced error on page 10 did not affect any other previously reported liquid dose calculation. The error only impacted the reported Tritium Curies for St. Lucie Unit 2 Liquid in Quarter 4 of 1998.

FLORIDA POWER & LIGHT COMPANY
 ST. LUCIE UNIT # 2
 ANNUAL REPORT
 JANUARY 1, 1998 THROUGH DECEMBER 31, 1998

TABLE 3.3-2 LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES(Continued)

| | UNIT | QTR#3 | QTR#4 |
|--|--------|----------|-----------------------------|
| A. Fission and Activation Products | | | |
| 1. Total Release - (Not including Tritium, Gases, and Alpha) | Ci | 5.13E-03 | 2.50E-02 |
| 2. Average Diluted Concentration During Period | uCi/ml | 9.99E-12 | 1.28E-11 |
| B. Tritium | | | |
| 1. Total Release | Ci | 1.00E+02 | 1.67E+02 Corrected value |
| 2. Average Diluted Concentration During Period | uCi/ml | 1.95E-07 | 8.57E-08 Corrected value |
| C. Dissolved and Entrained Gases | | | |
| 1. Total Release | Ci | 1.37E-03 | 4.94E-02 |
| 2. Average Diluted Concentration During Period | uCi/ml | 2.67E-12 | 2.53E-11 |
| D. Gross Alpha Radioactivity | | | |
| 1. Total Release | Ci | 0.00E+00 | 0.00E+00 |
| E. Volume of Waste Released (Prior to Dilution) | | | |
| | Liters | 5.83E+05 | 1.13E+06 |
| F. Volume of Dilution Water Used During Period | | | |
| | Liters | 5.14E+11 | 1.95E+12 |