

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

February 22, 2000

United States Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555

Serial No. 00-090  
NAPS/JHL  
Docket Nos. 50-338  
50-339  
License Nos. NPF-4  
NPF-7

Gentlemen:

**VIRGINIA ELECTRIC AND POWER COMPANY**  
**NORTH ANNA POWER STATION UNIT NOS. 1 AND 2**  
**ANNUAL SPECIFIC ACTIVITY REPORT**

The results of specific activity analysis in which the primary coolant exceeded the limits of Technical Specification 3.4.8 are to be submitted on an annual basis pursuant to Technical Specification 6.9.1.5.c. There were no instances where the primary coolant exceeded 1.0  $\mu\text{Ci}/\text{gram}$  Dose Equivalent Iodine-131 or 100/E-bar  $\mu\text{Ci}/\text{gram}$  during 1999.

If you have any questions or require additional information, please contact us.

Very truly yours,



W. R. Matthews  
Site Vice President

cc: U. S. Nuclear Regulatory Commission  
Region II  
Atlanta Federal Center  
61 Forsyth Street, SW, Suite 23T85  
Atlanta, Georgia 30303

Mr. M. J. Morgan  
NRC Senior Resident Inspector  
North Anna Power Station

A001