



LEGEND

TEMPORARY PIPING ————

UR - MULTIVARIABLE RECORDER
 UI - MULTIVARIABLE INDICATOR
 PE - PRESSURE ELEMENT
 PIT - PRESSURE INDICATOR TRANSMITTER

NOTES

- EQUIPMENT SHOWN IS NOT TO BE PERMANENTLY INSTALLED.
- INDICATING LIGHTS FOR M.O.V.'S TO BE LOCATED ON RMS.
- ALL EQUIPMENT AND INSTRUMENT NUMBERS TO BE PREFIXED BY 2T23 UNLESS SHOWN OTHERWISE.
- ALL TUBING AND VALVES IN PORTABLE TEST PANEL TO BE 3/8" O.D. S.S.
- * REFER TO REFERENCE 3, APPENDIX F FOR POSITION OF THESE VALVES DURING ILRT.
- # REFER TO REFERENCE 3, APPENDIX B FOR POSITION OF THESE VALVES DURING ILRT.
- F - MOVE TO ACCESSIBLE LOCATION IN REACTOR BUILDING NEAR PENETRATION. MODIFY WIRING AS REQUIRED FOR REMOTE INSTALLATION
- TEMPORARY INSTRUMENTS WILL BE UTILIZED FOR THE ILRT IN PLACE OF THE ORIGINALLY PROVIDED EQUIPMENT. THE ORIGINALLY PROVIDED INSTRUMENTS ARE LEFT INSTALLED WITH THE EXCEPTION OF 2T23-N006 A,B,C,E,F,H AND 2T23-N007C WHICH WERE REMOVED.
- AIR COMPRESSORS, AFTERCOOLERS, MOISTURE SEPARATORS, AIR FILTER AND AIR DRYERS ARE RENTAL EQUIPMENT AND ACTUAL QUANTITIES AND CONFIGURATION OF EQUIPMENT MAY VARY FROM THAT SHOWN.

REFERENCES

	MPL NO.	S.S.I. NO.
1. N ₂ INERTING SYS P&ID	2T48-1010	H-26083
2. P.C. PURGE & INERTING SYS. P&ID	2T48-1020	H-26084
3. ILRT PROCEDURE	2T23-3510	-
4. AFTERCOOLER & MOISTURE SEPARATOR	T23-B001 T23-D002	SX-16518
5. COMPRESSED AIR FILTER	T23-D001	SX-16567
6. M.O. BUTTERFLY VALVES	T23-F010	SX-16563
7. DRYWELL TO TORUS DIFF PRESS SYS. P&ID	T248-1030	H-26079
8. ILRT ELEMENTARY	2T23	H-27755

BOUNDARY DIAGRAM NO.: 2T23-B01-13

FUNCTION(S) NO.: 2T23-01

PREPARED BY: FAROOK CHANDIWALA
 DATE: 10/20/98

REVIEWED BY: LARRY ORR
 DATE: 12/9/98

LICENSE RENEWAL DOCUMENT

MPL NO. 2T23-1010 ACAD14 HL26057

SOUTHERN COMPANY

LICENSE RENEWAL SCREENING FOR INFORMATION ONLY

EDWIN I. HATCH NUCLEAR PLANT UNIT No. 2
 PRIMARY CONTAINMENT INTEGRATED LEAK RATE TEST P&ID

Revision: A Date: 12-29-99
 APPROVED. ISSUED PER LICENSE RENEWAL BOUNDARY PACKAGES. DRAWING CREATED FROM H-26057, REV.10; BY TRM.

BY	CHKD	APPR	DATE	SCALE	LOCATION	DOCUMENT NUMBER	REVISION
TRM	RLM	ASK		None	10-502	HL-26057	A