



- SYMBOLS**
- DUCTWORK & DIRECTION OF FLOW.
  - AIR MOVEMENT WITHOUT DUCTS.
  - COOLING COIL.
  - HEATING COIL.
  - V.D. VOLUME DAMPER.
  - B.D. BACKWARD DRAFT DAMPER.
  - A.O. AIR OPERATED DAMPER.
  - M.D. MOTOR DAMPER.
  - F.D. FIRE DAMPER.
  - S.D. SPLITTER DAMPER.
  - ROLL FILTER.
  - A/C AIR CHANGE PER HOUR.
  - O.A. OUTSIDE AIR.
  - INLET CONTROL VANES.

- NOTES:**
- ALL INDICATING LAMPS ON VALVES TO BE ON VENTILATION PANEL BOARD IN MAIN CONTROL ROOM.
  - ALL ITEM NUMBERS TO BE PREFIXED BY 2T41 TO COMPLETE MPL LISTING UNLESS SHOWN OTHERWISE.
  - TWO UPSCALE TRIPS ON CHANNEL "A" OF REFUELING FLOOR AREA RADIATION EXHAUST MONITORS SHALL:
    - (1) SHUT DOWN THE REFUELING FLOOR SUPPLY AND EXHAUST FANS AND CLOSE REFUELING FLOOR SUPPLY AND EXHAUST ISOLATION VALVES
    - (2) INITIATE STANDBY GAS TREATMENT SYSTEM AND OPEN AO-F001A AND F003A (REF. 1) ANY ONE UPSCALE TRIP SHALL ALARM ANY ONE DOWNSCALE TRIP SHALL ALARM
  - TWO UPSCALE TRIPS ON CHANNEL "B" OF REFUELING FLOOR AREA RADIATION EXHAUST MONITORS SHALL:
    - (1) SHUT DOWN THE REFUELING FLOOR SUPPLY AND EXHAUST FANS AND CLOSE REFUELING FLOOR SUPPLY AND EXHAUST ISOLATION VALVES
    - (2) INITIATE STANDBY GAS TREATMENT SYSTEM AND OPEN AO-F001B AND F003B (REF. 1) ANY ONE UPSCALE TRIP SHALL ALARM ANY ONE DOWNSCALE TRIP SHALL ALARM
  - LOSS OF COOLANT ACCIDENT (LOCA) - DRYWELL HIGH PRESSURE OR RPV WATER LEVEL 2 SIGNALS SHALL:
    - (1) SHUT DOWN THE REFUELING FLOOR SUPPLY AND EXHAUST FANS AND CLOSE REFUELING FLOOR SUPPLY AND EXHAUST ISOLATION VALVES
    - (2) INITIATE STANDBY GAS TREATMENT SYSTEM AND OPEN AO-F001A & B AND F003A & B (REF. 1)
  - ALL SUPPLY AND EXHAUST DUCT ARE SEISMIC CLASS 1 AND SHALL MEET THE QUALITY ASSURANCE REQUIREMENTS.
  - \* INDICATES INSTRUMENT SUPPLIED WITH THE ASSOCIATED CONTRACTOR
  - # INDICATES INSTRUMENT SUPPLIED BY HVAC CONTRACTOR.
  - ALL DRAINS FROM FILTER TRAINS & COOLING COILS SHALL BE ROUTED TO THE NEAREST DRAIN.
  - FOR FIRE PROTECTION TO THE CARBON FILTER SEE REFERENCE 5.
  - HIGH RADIATION IN THE UNIT 1 OR UNIT 2 REACTOR BLDG. EXHAUST : SEE NOTE 1 AND 2 IN REF. 6.
  - SUPPLY AIR FAN (2T41-C002A OR B) LOW FLOW ALARM.

**REFERENCES:**

| REF | MPL NO.  | SSN                      |
|-----|--|--------------------------|
| 1.  | STANDBY GAS TREATMENT PROCESS FLOW & P&ID.                                     | 2746-1010 H-26078        |
| 2.  | PIPING AND INSTRUMENT SYMBOLS  | A42-1010 S-15051         |
| 3.  | NUCLEAR BOILER SYSTEM P&ID.  | 2B21-1010 H-26000, 1     |
| 4.  | PROCESS RADIATION MONITORING SYSTEM IED  | 2D11-1010 H-26011, 12,13 |
| 5.  | FIRE PROTECTION TO FILTER TRAINS IN REACTOR, RADWASTE & TURBINE BUILDINGS P&ID | H-21342                  |
| 6.  | REACTOR BUILDING VENTILATION SYSTEM P&ID                                       | 2T41-1010 H-26067        |
| 7.  | PLANT HEATING SYSTEM P&ID.   | 2P61-1020 H-26065        |
| 8.  | FIRE PROTECTION SYS. P&ID  | 2T43-1010 H-21017        |
| 9.  | DIGITAL INPUT SIGNALS TO THE ERF COMPUTER SYSTEM IED SHEET 8 OF 15.            | X75-1010 H-16410         |
| 10. | DIGITAL INPUT SIGNALS TO THE 2X75-1010 ERF COMPUTER SYSTEM IED SHEET 8 OF 15.  | H-26177                  |
| 11. | REFUELING FLOOR VENT P&ID (UNIT 1)   | 1T41 H-16014             |
| 12. | STANDBY GAS TREATMENT P&ID (UNIT 1)  | 1T46 H-16020 H-16174     |

**BOUNDARY DIAGRAM NO.: 2T41-B01-02**  
**FUNCTION(S) NO.: 2T41-01**  
**PREPARED BY: ED DAVIDSON**  
**DATE: 4/23/98**  
**REVIEWED BY: ALEX MORRISON**  
**DATE: 5/4/98**

**LICENSE RENEWAL DOCUMENT**

MPL NO. 2T41-1010 ACAD14 HL26072

**SOUTHERN COMPANY**

**LICENSE RENEWAL SCREENING FOR INFORMATION ONLY**

EDWIN I. HATCH NUCLEAR PLANT UNIT No. 2  
 REACTOR BUILDING REFUELING FLOOR VENTILATION SYSTEM P&ID.

|           |   |   |
|-----------|---|---|
| APPROVED: | ISSUED PER LICENSE RENEWAL BOUNDARY PACKAGES. | DRAWING CREATED FROM H-26072, REV.19; BY TRM. |
| DATE:     | 10-502  | HL-26072                                      |
| SCALE:    | None  | A   |

Revision: A Date: 1-7-2000

| BY  | CHKD | APPR | DATE |
|-----|------|------|------|
| TRM | ED   | ASK  |      |