

## TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
DESIGN CONTROL DOCUMENT INTRODUCTION		
1.0	Scope and Purpose of the Design Control Document . . . . .	Intro-1
1.1	Tier 1 Information . . . . .	Intro-1
1.2	Tier 2 Information . . . . .	Intro-2
1.3	Relationship of the Tier 1 Information to the Tier 2 Information . . .	Intro-2
1.4	Uses of the Design Control Document . . . . .	Intro-2
2.0	Effect of the Tier 1 Information . . . . .	Intro-3
2.1	Compliance with Tier 1 Information . . . . .	Intro-3
2.2	Design Descriptions . . . . .	Intro-3
2.3	Inspections, Tests, Analyses and Acceptance Criteria . . . . .	Intro-4
2.4	Tier 1 Site Parameters . . . . .	Intro-4
2.5	Tier 1 Information Interface Requirements . . . . .	Intro-5
3.0	Effect of the Tier 2 Information . . . . .	Intro-5
3.1	Compliance with the Tier 2 Information . . . . .	Intro-5
3.2	COL Information Items . . . . .	Intro-5
3.3	Tier 2 Information Interface Requirements . . . . .	Intro-5
3.4	Conceptual Designs . . . . .	Intro-6
3.5	Plant-Specific Changes to Designated Information in the Tier 2 Information . . . . .	Intro-6
3.6	Treatment of Probabilistic Risk Assessment Information . . . . .	Intro-6

**LIST OF TABLES**

<b><u>Table No.</u></b>	<b><u>Title</u></b>	<b><u>Page</u></b>
1-1	Index of AP600 Tier 2 Information requiring NRC approval for Change . . .	Intro-7

## DESIGN CONTROL DOCUMENT INTRODUCTION

### 1.0 SCOPE AND PURPOSE OF THE DESIGN CONTROL DOCUMENT

This Design Control Document (DCD) is a repository of information comprising the AP600<sup>TM(\*)</sup> Standard Plant Design. The design control document also provides that design-related information to be incorporated by reference into Appendix C to 10 CFR Part 52 (the AP600 design certification rule).

Applicants for a combined license pursuant to 10 CFR 52 must ensure that Appendix C to 10 CFR Part 52 and the associated Statements of Consideration are used when making licensing decisions relevant to the AP600 Standard Plant Design

Further sections of this introduction summarize the contents and use of the design control document. The design control document contains this introduction, the Tier 1 Information and the Tier 2 Information for the AP600 Standard Plant Design.

Detailed information on the application and use of the AP600 design control document may be found in Appendix C to 10 CFR Part 52.

If there is a conflict between this introduction and the AP600 design certification rule, the AP600 design certification rule controls.

### 1.1 Tier 1 Information

Tier 1 means the portion of the design-related information contained in the AP600 design control document that is approved and certified by the NRC. Tier 1 information includes:

- Definitions and general provisions;
- Design descriptions;
- Inspections, tests, analyses, and acceptance criteria (ITAAC);
- Significant site parameters; and
- Significant interface requirements between the AP600 Standard Plant Design and systems that are wholly or partially outside the scope of the AP600 Standard Plant Design

The Tier 1 Information includes a table of contents, a figure legend and an abbreviation list.

---

\* AP600 is a trademark of Westinghouse Electric Company LLC

## 1.2 Tier 2 Information

Tier 2 means the portion of the design-related information contained in the AP600 Design Control Document that is approved but not certified by the NRC. Tier 2 information includes:

- Information required by 10 CFR 52.47, with the exception of generic technical specifications and conceptual design information;
- Information required for a final safety analysis report under 10 CFR 50.34;
- Supporting information on the inspections, tests, and analyses that will be performed to demonstrate that the acceptance criteria in the ITAAC have been met; and
- Combined license (COL) information items which identify certain matters that shall be addressed in the site-specific portion of the final safety analysis report (FSAR) by an applicant who references the AP600 design certification rule

Each volume of the Tier 2 Information includes a master table of contents and each chapter contains a chapter specific table of contents.

## 1.3 Relationship of the Tier 1 Information to the Tier 2 Information

The design descriptions, interface requirements, and site parameters in Tier 1 are derived from Tier 2 information.

Compliance with Tier 2 is required, but generic changes to and plant-specific departures from Tier 2 are governed by the AP600 design certification rule. Compliance with Tier 2 provides a sufficient, but not the only acceptable, method for complying with Tier 1. Compliance methods differing from Tier 2 must satisfy the change process in Section VIII of the AP600 design certification rule.

## 1.4 Uses of the Design Control Document

An applicant for a license that wishes to reference the AP600 design certification rule shall, in addition to complying with the requirements of 10 CFR 52.77, 52.78, and 52.79, comply with the following requirements:

- Incorporate by reference, as part of its application, the AP600 design certification rule;

- Include, as part of its application:
  - A plant-specific design control document containing the same information and utilizing the same organization and numbering as the generic design control document for the AP600 Standard Plant Design, as modified and supplemented by the applicant's exemptions and departures;
  - The reports on departures from and updates to the plant-specific design control document required by Section X of the AP600 design certification rule;
  - Plant-specific technical specifications, consisting of the generic and site-specific technical specifications, that are required by 10 CFR 50.36 and 50.36a;
  - Information demonstrating compliance with the site parameters and interface requirements;
  - Information that addresses the COL information items; and
  - Information required by 10 CFR 52.47(a) that is not within the scope of the AP600 design certification rule.
  - Physically include, in the plant-specific design control document, the proprietary information referenced in the AP600 design control document.

The Commission reserves the right to determine in what manner the AP600 design certification rule may be referenced by an applicant for a construction permit or operating license under 10 CFR Part 50.

## 2.0 EFFECT OF THE TIER 1 INFORMATION

The following provisions describe the scope and effect of the Tier 1 Information.

### 2.1 Compliance with Tier 1 Information

All of the information in the Tier 1 Information is approved by the NRC and is applicable to a license application for a license that references the AP600 design certification rule, and is among the "matters resolved" under 10 CFR 52.63 (a)(4). The provisions and methods specified in the Tier 1 Information shall be complied with unless a plant specific exemption is granted by the NRC or a change is made to the Tier 1 Information in accordance with the change process specified in Section VIII of the AP600 design certification rule.

### 2.2 Design Descriptions

The Design Descriptions pertain only to the design of structures, systems and components of an AP600 Standard Plant Design and not to their operation, maintenance and administration.

In the event of an inconsistency between the Design Descriptions and the Tier 2 Information, the Design Descriptions shall govern.

### 2.3 Inspections, Tests, Analyses and Acceptance Criteria

An applicant or licensee who references the AP600 design certification rule shall perform and demonstrate conformance with the ITAAC before fuel load. With respect to activities subject to an ITAAC, an applicant for a license may proceed at its own risk with design and procurement activities, and a licensee may proceed at its own risk with design, procurement, construction, and preoperational activities, even though the NRC may not have found that any particular ITAAC has been satisfied.

In the event that an activity is subject to an ITAAC, and the applicant or licensee who references the AP600 design certification rule has not demonstrated that the ITAAC has been satisfied, the applicant or licensee may either take corrective actions to successfully complete that ITAAC, request an exemption from the ITAAC in accordance with Section VIII of the AP600 design certification rule and 10 CFR 52.97(b), or petition for rulemaking to amend the AP600 design certification rule by changing the requirements of the ITAAC, under 10 CFR 2.802 and 52.97(b).

In accordance with 10 CFR 52.99 and 52.103(g), the Commission shall find that the acceptance criteria in the ITAAC for the license are met before fuel load.

After the Commission has made the finding required by 10 CFR 52.103(g), the ITAAC do not, by virtue of their inclusion within the design control document, constitute regulatory requirements either for licensees or for renewal of the license; except for specific ITAAC, which are the subject of a Section 103(a) hearing, their expiration will occur upon final Commission action in such proceeding. However, subsequent modifications must comply with the Tier 1 and Tier 2 design descriptions in the plant-specific design control document unless the licensee has complied with the applicable requirements of 10 CFR 52.97 and Section VIII of the AP600 design certification rule.

### 2.4 Tier 1 Site Parameters

Site parameters are specified in the Tier 1 Information to establish the bounding parameters to be used in the selection of a suitable site for the facility referencing the AP600 certified design. Since the Tier 1 Information Site Parameters were used in the bounding evaluations of the certified design, they define the requirements for the design that must be met to ensure that a facility built on the site remains in conformance with the design certification. In the event that an inconsistency between the Tier 1 Information Site Parameters and the Tier 2 Information, the Tier 1 Information Site Parameters shall govern.

### 2.5 Tier 1 Interface Requirements

The Tier 1 Interface Requirements describe the significant design provisions for interfaces between the AP600 Standard Plant Design and structures, systems and components that are wholly or partially outside the scope of the AP600 Standard Plant Design. Tier 1 Interface

Requirements also define the significant attributes and performance characteristics that the out-of-scope portion of the plant must have in order to support the in-scope portion of the design. The FSAR shall contain provisions which implement the Interface Requirements in accordance with 10 CFR 52.79(b). Any plant-specific application for a COL shall contain additional ITAAC corresponding to these implementing provisions. In the event of an inconsistency between the Tier 1 Interface Requirements and the Tier 2 Information, the Tier 1 Interface Requirements shall govern.

### 3.0 EFFECT OF THE TIER 2 INFORMATION

The following provisions describe the scope and effect of the Tier 2 Information.

#### 3.1 Compliance with the Tier 2 Information

All of the information in the Tier 2 Information is approved by the NRC and, with the exceptions noted in Sections 3.2 and 3.4 below, is applicable to a license that references the AP600 design certification rule and is among the "matters resolved" under 10 CFR 52.63(a)(4). Compliance with the Tier 2 Information is a sufficient, but not necessarily the only, method of complying with the Tier 1 Information. The provisions and methods specified in the Tier 2 Information shall be followed unless a change is made in accordance with Section VIII of the AP600 design certification rule.

#### 3.2 COL information Items

Combined license (COL) information items, which identify certain matters that shall be addressed in the site-specific portion of the final safety analysis report (FSAR) by an applicant who references the AP600 design certification rule. These items constitute information requirements but are not the only acceptable set of information in the FSAR. An applicant may depart from or omit these items, provided that the departure or omission is identified and justified in the FSAR. After issuance of a construction permit or COL, these items are not requirements for the licensee unless such items are restated in the FSAR.

A summary of the AP600 COL Information Items is provided in Table 1.8-2 of the Tier 2 Information.

#### 3.3 Tier 2 Interface Requirements

The Tier 2 Interface Requirements describe the design provisions for interfaces between the AP600 Standard Plant Design and structures, systems and components that are wholly or partially outside the scope of the AP600 Standard Plant Design. Tier 2 Interface Requirements, summarized in Table 1.8-1 of the Tier 2 Information, also define the attributes and performance characteristics that the out-of-scope portion of the plant must have in order to support the in-scope portion of the design. The FSAR shall contain provisions which implement the Tier 2 Interface Requirements in accordance with 10 CFR 52.79(b). In the event of an inconsistency between the Tier 1 Interface Requirements and the Tier 2 Interface Requirements, the Tier 1 Interface Requirements shall govern.

### 3.4 Conceptual Designs

Conceptual designs for those portions of the plant that are outside the scope of the AP600 Standard Plant Design are described and designated as out-of-scope in various places in the Tier 2 Information. As provided by 10 CFR 52.47(a)(1)(ix), these conceptual designs are not a part of the design certification for the AP600 Standard Plant Design and do not impose requirements applicable to a COL, nor an application for a COL, that references the AP600 design certification rule. Those portions of the AP600 Standard Plant Design for which conceptual designs are included in the Tier 2 Information are identified by double brackets and listed in Section 1.8 of the Tier 2 Information.

### 3.5 Plant-Specific Changes to Designated Information in the Tier 2 Information

*Tier 2\** means the portion of the Tier 2 information, designated as such in the AP600 design control document, which is subject to the change process in Section VIII of the AP600 design certification rule. This designation expires for some Tier 2\* information under Section VIII of the AP600 design certification rule.

An applicant who references the AP600 design certification rule may not depart from Tier 2\* information, which is designated with italicized text or brackets and an asterisk in the AP600 design control document, without NRC approval. The departure will not be considered a resolved issue, within the meaning of Section VI of the AP600 design certification rule and 10 CFR 52.63(a)(4).

The AP600 Tier 2\* information, summarized in Table 1-1 of this introduction, is designated with italicized text in the Tier 2 Information. Certain figures that are indicated to be Tier 2\* may contain information beyond that that is considered to be Tier 2\*. A review of the text referencing the figure may be necessary to determine what information on the figure is considered to be Tier 2\*. The AP600 Tier 2\* information for which the Tier 2\* designation expires when the COL holder first achieves 100% power operation is indicated in Table 1-1 of this introduction.

### 3.6 Treatment of Probabilistic Risk Assessment Information

A design-specific Probabilistic Risk Assessment (PRA) for the AP600 Standard Plant Design was submitted as a part of the application for design certification as required by 10 CFR 52.47. One purpose of the PRA was to develop insights for the design and its features. Significant insights that resulted from the PRA are identified in Section 19.59 of the Tier 2 Information. However, the detailed methodology and quantitative portions of the design-specific PRA are not included in the Design Control Document because it is anticipated that this material will be subject to modifications and refinements as the detailed design is completed and the as-built plant parameters and new methodology become available.

Table 1-1  
Index of AP600 Tier 2 Information Requiring NRC approval for Change

Item	Expiration at First Full Power	Tier 2 Reference
Dimensions for Nuclear Island Structures	Yes	Fig. 3.7.1-16
Nuclear Island Key Structural Dimensions	Yes	Fig. 3.7.2-12
ASME Code, Section III Edition, Addenda	Yes	3.8.2.2 5.2.1.1
ASME Code Case N-284	Yes	3.8.2.5 App 3G
Design Summary of Critical Sections	Yes	3.8.3.5.8 3.8.4.5.4 3.8.5.4.5 App 3H
Use of ACI-318-95	Yes	3.8.4.4.1 3.8.5.5
Use of ACI 349-90	Yes	3.8.4.5.1 3.8.5.5
Use of ANS/AISC N690	Yes	3.8.4.5.2
Definition of critical locations and thicknesses for shield and auxiliary buildings	Yes	Table 3.8.4-7
Definition of critical locations and thicknesses for nuclear island basemat	Yes	Table 3.8.5-3
Seismic Qualification Standards	Yes	3.10.1.1
Methods and Procedures for Qualifying Electrical Equipment, Instrumentation and Mechanical Components	Yes	3.10.2
WCAP-12488-A, Fuel Criteria Evaluation Process"	No	Chapter 4 Table 1.6-1
Maximum Fuel Rod Average Burnup	No	4.1
Fuel Principal Design Requirements	No	4.1.1
Reactor Core Description (First Cycle)	Yes	Table 4.3-1
Nuclear Design Parameters (First Cycle)	Yes	Table 4.3-2

Table 1-1  
 Index of AP600 Tier 2 Information Requiring NRC approval for Change

Item	Expiration at First Full Power	Tier 2 Reference
Reactivity Requirements for Rod Cluster Control Assemblies	Yes	Table 4.3-3
MOV Design and Qualification	Yes	5.4.8.1.2
POV Design and Qualification	Yes	5.4.8.1.3
Motor Operated Valves	Yes	5.4.8.5.2
Power Operated Valves	Yes	5.4.8.5.3
WCAP-13383, "AP600 Instrumentation and Control Hardware & Software Design, Verification & Validation Process Report", Rev 1.	Yes	Chapter 7 Table 1.6-1
WCAP-14605, "Westinghouse Setpoint Methodology for Protection Systems, AP600", Rev 0	Yes	Chapter 7 Table 1.6-1
Verification and Validation	Yes	7.1.2.15
Conformance with Industry Standards	Yes	7.1.4.1.8
Nuclear Island Fire Areas	No	Figure 9A-1
Turbine Building Fire Areas	No	Figure 9A-2
Annex I & II Building Fire Areas	No	Figure 9A-3
Radwaste Building Fire Areas	No	Figure 9A-4
Diesel Generator Building Fire Areas	No	Figure 9A-5
Natural Circulation Test	First Plant Only	14.2.5
Description of "First Three Plant Tests"	Third Plant	14.2.5
Verification of proper operation of core makeup tanks in recirculation mode	Third Plant	14.2.9.1.3
Verification of automatic depressurization during hot functional testing	Third Plant	14.2.9.1.3
Verification of proper operation of core makeup tanks to transition to draindown mode	Third Plant	14.2.9.1.3

Table 1-1 (Cont.)  
Index of AP600 Tier 2 Information Requiring NRC approval for Change

Item	Expiration at First Full Power	Tier 2 Reference
Passive residual heat removal heat exchanger natural circulation test	First Plant Only	14.2.10.3.7
First-Plant-Only and Three-Plant-Only Tests	As Discussed	14.4.6
WCAP-14396, "Man-In-The-Loop Test Plan Description", Rev 2	No	Chapter 18 Table 1.6-1
WCAP-14401, "Programmatic Level Description of the AP600 Human Factors Verification and Validation Plan", Rev 3	No	Chapter 18 Table 1.6-1
WCAP-14651, "Integration of Human Reliability Analysis with Human Factors Engineering Design Implementation Plan", Rev 2	No	Chapter 18 Table 1.6-1
WCAP-14695, "Description of the Westinghouse Operator Decision Making Model and Function Based Task Analysis Methodology", Rev 0	No	Chapter 18 Table 1.6-1
WCAP-14701, "Methodology & Results of Defining Evaluation Issues for the AP600 Human System Interface Design Test Program", Rev 1	No	Chapter 18 Table 1.6-1
WCAP-14822, "AP600 Quality Assurance Procedures Supporting NRC review of AP600 SSAR Sections 18.2 and 18.8", Rev 0	No	Chapter 18 Table 1.6-1
Basis for Human Factors Engineering Program	No	18.1
Applicable Facilities	No	18.2.1.3
Applicable Human Systems Interfaces	No	18.2.1.4
Applicable Plant Personnel	No	18.2.1.5
Technical Basis	No	18.2.1.6
Regulatory Requirements for HFE	No	18.2.2
Responsibility	No	18.2.2.1
Composition of HFE Design Team	No	18.2.2.3

Table 1-1 (Cont.)  
 Index of AP600 Tier 2 Information Requiring NRC approval for Change

Item	Expiration at First Full Power	Tier 2 Reference
General Process and Procedures for Design Review of HFE Products	No	18.2.3.1
Human System Interface Design Team Process	No	Figure 18.2-1
HFE Technical Program and Milestones	No	18.2.5
AP600 Task Analysis Implementation Plan	No	18.5
Task Analysis Scope	No	18.5.1
Task Analysis Implementation Plan	No	18.5.2
Integration of Human Reliability Analysis with HFE	No	18.7
Safety Parameter Display System	No	18.8.2
Safety Parameter Display System HFE	No	18.8.2.5
Mail Control Area Mission and Major Tasks	No	18.8.3.2
Remote Shutdown Workstation Mission and Major Tasks	No	18.8.3.4
Technical Support Center Mission and Major Tasks	No	18.8.3.5
Human System Interface Design Test Program	No	18.11