

# **BWR Vessel and Internals Project Jet Pump Repair Design Criteria (BWRVIP-51NP)**

---

## **NON-PROPRIETARY INFORMATION**

NOTICE: This report contains the non-proprietary information that is included in the proprietary version of this report. The proprietary version of this report contains proprietary information that is the intellectual property of BWRVIP utility members and EPRI. Accordingly, the proprietary report is available only under license from EPRI and may not be reproduced or disclosed, wholly or in part, by any Licensee to any other person or organization.

# REPORT SUMMARY

---

The Boiling Water Reactor Vessel and Internals Project (BWRVIP), formed in June, 1994, is an association of utilities focused exclusively on BWR vessel and internals issues. This BWRVIP report documents criteria which can be used to design a repair for the jet pumps in a BWR.

## **Background**

In the event that significant degradation is observed in BWR jet pumps, repair to those components may be required. Utilities need criteria which can be used in the development of those repair designs.

## **Objectives**

To compile the appropriate design criteria for jet pump repairs into a document which can be used by utility personnel performing the design and which could be submitted to appropriate regulatory agencies for approval of the generic design process.

## **Approach**

The contractor assembled a draft document which discussed all elements which need to be considered in designing a jet pump repair. Items discussed include: design objectives; structural evaluation; system evaluation; materials, fabrication and installation considerations; and, required inspection and testing. The resulting draft was reviewed in depth by BWRVIP utility representatives as well as third party contractors. The final report incorporates comments received during those reviews.

## **Results**

The document provides general design acceptance criteria for the repair of jet pumps. Repairs designed to meet these criteria will maintain the structural integrity of the component under normal operation as well as under postulated transient and design basis accident conditions.

## **EPRI Perspective**

The criteria listed in the report define a standard set of considerations which are important in designing a jet pump repair. It is intended that these criteria will be submitted to the USNRC, and possibly non-US regulators, for their approval. Regulatory acceptance of these generic criteria will significantly reduce the utility effort required to obtain approval for plant-specific repairs.

**PROJECT**

WOB501

EPRI Project Manager: Warren Bilanin

Nuclear Power Group

Contractor: Sargent and Lundy

**For ordering information about this report, call the EPRI Program Manager at (650) 855-2340.**

**For membership information, call (650) 855-2514**

**TR-108718NP****Interest Categories**

Piping, reactor, vessel and internals

Licensing and safety assessment

**Key Words**

Boiling water reactor

Repair

Stress corrosion cracking

Jet pump

Vessel and internals

# **BWR Vessel and Internals Project**

## **Jet Pump Repair Design Criteria (BWRVIP-51NP)**

**TR-108718NP**  
**Research Project B501**  
Final Report, February 2000

Prepared by:

Sargent & Lundy LLC  
BWRVIP Repair Committee

Prepared for

**BOILING WATER REACTOR VESSEL & INTERNALS PROJECT and  
EPRI**

3412 Hillview Ave.  
Palo Alto, California 94304

## **DISCLAIMER OF WARRANTIES AND LIMITATION OF LIABILITIES**

This report was prepared by the organization(s) named below as an account of work sponsored or cosponsored by the BWR Vessel and Internals Project (BWRVIP) and the Electric Power Research Institute, Inc. (EPRI). Neither BWRVIP, EPRI, any member of EPRI, any cosponsor, the organization(s) named below, nor any person acting on behalf of any of them:

(a) makes any warranty or representation whatsoever, express or implied, (i) with respect to the use of any information, apparatus, method, process or similar item disclosed in this report, including merchantability and fitness for a particular purpose, or (ii) that such use does not infringe on or interfere with privately owned rights, including any party's intellectual property, or (iii) that this report is suitable to any particular user's circumstance, or

(b) assumes any responsibility for any damages or other liability whatsoever (including any consequential damages, even if BWRVIP, EPRI or any EPRI representative has been advised of the possibility of such damages) resulting from your selection or use of this report or any information, apparatus, method, process or similar item disclosed in this report.

Organization(s) that prepared this report:

**Sargent & Lundy LLC**

**BWRVIP Repair Committee**

## **ORDERING INFORMATION**

Requests for copies of this report should be directed to the BWRVIP Program Manager, 3412 Hillview Ave., Palo Alto, Ca. 94304, (650) 855-2340.

## ACKNOWLEDGMENTS

The members of the BWRVIP Jet Pump Repair Team, listed below, are gratefully acknowledged for their efforts which led to the successful completion of this document.

Priit Okas  
Kim Bezzant  
Paul Phelan  
Bob Geier  
Bruce McLeod  
Ken Wolfe

NYPA  
NSP  
Yankee Atomic  
ComEd  
Southern Nuclear  
EPRI

Sargent & Lundy LLC Principal Investigators:

Steve L. Lange  
Thomas J. Behringer

JET PUMP REPAIR DESIGN CRITERIA  
Table of Contents

		<u>Page</u>
EXECUTIVE SUMMARY .....		xi
1.0 INTRODUCTION .....		1
1.1 Background .....		1
1.2 Purpose .....		1
1.3 Scope .....		1
2.0 DEFINITIONS .....		3
3.0 JET PUMP ASSEMBLY CONFIGURATION AND SAFETY FUNCTION.....		5
3.1 Generic Physical Description .....		5
3.2 Safety Design Bases .....		5
3.3 Event Analyses .....		6
4.0 SCOPE OF REPAIRS.....		7
5.0 DESIGN OBJECTIVES .....		9
5.1 Design Life.. .....		9
5.2 Safety Design Bases .....		9
5.3 Safety Analysis Events.. .....		9
5.4 Structural Integrity .....		9
5.5 Retained Flaw(s).....		9
5.6 Loose Parts Considerations .....		10
5.7 Physical Interfaces with Other Reactor Internals.....		10
5.8 Installation .....		10
5.9 Leakage and Jet Pump Performance.....		11
5.10 Design Verification .....		11
6.0 GENERAL DESIGN CRITERIA .....		13
7.0 STRUCTURAL AND DESIGN EVALUATION.. .....		15
7.1 Load Definitions - Applied Loads .....		15
7.2 Service Level Conditions.. .....		19
7.3 Load Combinations .....		20
7.4 Allowable Stresses .....		24
7.5 Consideration of Shroud Repair or Cracking.....		24
7.6 Flow Induced Vibration.....		24
7.7 Impact on Existing Internal Components .....		25
7.8 Radiation Effects on Repair Design .....		25
7.9 Analysis Codes .....		25
7.10 Thermal Cycles .....		25

JET PUMP REPAIR DESIGN CRITERIA  
Table of Contents

		<u>Page</u>
7.11	Corrosion Allowance .....	26
7.12	Restrainer Bracket Adjusting Screw Gap Evaluation .....	26
8.0	SYSTEM EVALUATION .....	27
8.1	Leakage.. .....	27
8.2	Internal Jet Pump Pressure Drop.. .....	28
8.3	Impact to Flow Distribution.. .....	28
8.4	Emergency Operating Procedure (EOP) Calculations.. .....	28
8.5	Power Uprate .....	29
9.0	MATERIALS; FABRICATION AND INSTALLATION.....	31
9.1	Materials .....	31
9.2	Crevices .....	33
9.3	Welding and Fabrication .....	33
9.4	Pre-installation As-Built Inspection .....	34
9.5	Installation Cleanliness .....	34
9.6	ALARA .....	35
9.7	Qualification of Critical Design Parameters .....	35
10.0	INSPECTION AND TESTING .....	37
10.1	Inspection Access .....	37
10.2	Pre and Post Installation Inspection.. .....	37
10.3	Testing .....	38
11.0	QUALITY ASSURANCE .....	39
12.0	DESIGN BASIS DOCUMENTATION .....	41
13.0	REFERENCES .....	43

LIST OF FIGURES		<u>Page</u>
1	Typical Jet Pump Assembly .....	45
2A-2C	Typical Riser Braces .....	46-48
3A-3B	Beam-bolt Assemblies .....	49-50
4	Three Configurations for the Thermal Sleeve .....	51
5A-5C	Typical Riser Assemblies .....	52-54
6A-6B	Typical Transition Pieces .....	55-56
7A-7C	Typical Inlets .....	57-59
8A-8D	Typical Mixers .....	60-63
9A-9C	Typical Restrainer Brackets .....	64-66
10A-10C	Typical Wedge Assemblies.....	67-69
11A-11E	Typical Diffuser Assemblies .....	70-74
12A-12D	Typical Adapter Assemblies .....	75-78

#### LIST OF TABLES

Table 1	Plant Configurations Evaluated .....	2
Table 2	Summary of Recommended ASME Design Guidance .....	14
Table 3	Load Combinations for Mark I Plants .....	21
Table 4	Load Combinations for Mark II & III Plants .....	22
Table 5	Load Term Definitions for Tables 3 and 4 .....	23



## **Executive Summary**

The Boiling Water Reactor Vessel and Internals Project (BWRVIP) was formed in June 1994 as a utility-directed initiative to address BWR vessel and internals issues. This criteria document was developed by the Repair Technical Subcommittee of the BWRVIP.

This document provides the general design acceptance criteria for permanent or temporary repair of jet pump assemblies. It is provided to assist BWR owners in designing repairs which maintain the structural integrity and system functionality of the jet pump assemblies during normal operation and under postulated transient and design basis accident conditions for the remaining plant life or other service life as specified by the plant owner.

Issuance of this document is not intended to imply that repair of jet pump assemblies is the only viable method for resolving cracking or excessive gaps in components. Due to variations in the material, fabrication, environment and as-found condition of individual components, and depending upon which component is degraded, repair is only one of several options that are available. The action to be taken for individual plants will be determined by the plant licensee.

## 1.0 INTRODUCTION

### 1.1 Background

Recently, the BWR Vessel and Internals Project (BWRVIP) prepared a safety assessment of BWR internals [ 1 ]. The evaluation of the jet pump assembly included consideration of the consequence of failure of several jet pump sub-assemblies. It was determined that inspection and evaluation procedures have a role in assuring the long term integrity of the jet pump safety functions. Subsequently, an inspection and flaw evaluation guideline [16]. for the jet pump assembly was prepared by the BWRVIP to provide a prioritized inspection strategy and guidance for evaluation of flaws.

In conjunction with inspection and flaw evaluation guidelines, a repair design criteria is outlined here for cases in which repair of jet pump components is warranted.

### 1.2 Purpose

The purpose of this document is to provide general design guidance and acceptance criteria for permanent and temporary repair of jet pump assemblies. It is expected that individual licensees and vendors will adhere to these criteria in the application of plant-specific repairs.

The issuance of this document is not intended to imply that repair of jet pump assemblies is the only viable approach to resolution of the cracking/degradation issue.

### 1.3 Scope

This document is applicable to General Electric BWR/3-6 plants (BWRD plants do not contain jet pumps). Table 1 shows the plant configurations that were specifically evaluated in preparing this Guideline. Configuration and material information included in the guideline is based on the best information available. Plants are advised to confirm the accuracy of this information when designing repairs. Plants not listed in Table 1 should obtain their configuration and material information elsewhere, but are not excluded from the scope of this Guideline.

**Table 1: Plant Configurations Evaluated**

Plant Type	Plant Names
BWR/3	Millstone, Pilgrim, Monticello, Quad Cities 1,2, Dresden 2,3, Santa Maria de Garoña
BWR/4	Vermont Yankee <sup>(1)</sup> Fermi 2, Hope Creek 1, Limerick 1,2, Susquehanna 1, ,2, Browns Ferry 1,2,3, Peach Bottom 2,3, Brunswick 1,2, Hatch 1,2, Cooper, Fitzpatrick, Duane Arnold
BWR/5	LaSalle 1,2, Laguna Verde 1,2, Nine Mile Point 2, WNP2
BWR/6	Perry 1, Grand Gulf 1, River Bend, Clinton 1, Cofrentes

---

(1) Vermont Yankee is a hybrid BWR/3 and BWR/4 design.

## 2.0 DEFINITIONS

### Replacement

Replacement as used in the context of this document constitutes removal of components of the jet pump assembly that are subject to cracking and installation of new components in their place. The material and design shall be resistant to the cracking mechanisms that have been experienced in these components.

### Repair

Repair as used in the context of this document is a broad term that applies to actions taken to design, analyze, fabricate and install hardware that restores the structural and functional integrity of the jet pump assembly. Repairs differ from replacement primarily in that the flaws are left in place. Weld overlay, without removal of the defect, as well as removal of flaws by a qualified machining process are also considered repairs in the context of this document.

The repairs may be temporary, i.e. designed for a specified amount of time, e.g. months of operation, or permanent, i.e. designed for the remaining life of the plant.

### Jet Pump Assembly

Figure 1 shows a typical jet pump assembly. Each jet pump assembly is composed of two jet pumps and a common riser assembly. The riser assembly is a pipe, internal to the RPV, which connects the recirculation pump discharge line to the jet pump pair. A riser brace attaches the riser pipe to the vessel wall to provide lateral support.

### Safety Analysis Report

Safety Analysis Report (SAR) is used throughout this design criteria to refer to the current licensing document for the plant (e.g., FSAR, UFSAR, etc.).

### 3.0 JET PUMP ASSEMBLY CONFIGURATION AND SAFETY FUNCTION

#### 3.1 Generic Physical Description

The jet pumps are located in the annulus region between the core shroud and the vessel wall and provide core flow to control reactor power. Between 6 and 12 pairs of jet pumps are found in the BWR/3 through BWR/6 plants; depending on plant rating. BWR/2 plants do not contain jet pumps. During normal operation, each pair of jet pumps is driven by flow from a common riser pipe. The jet pump drive flow is pumped through the recirculation system through the riser and into each jet pump. Additional fluid from the annulus region is entrained into the jet pump flow which is then directed to the lower plenum region.

Figure 1 shows a typical jet pump assembly. Figures 2 to 12 show typical component details. Each jet pump assembly is composed of two jet pumps and a common riser assembly. The riser assembly is a pipe, internal to the RPV, which connects the recirculation pump discharge line to the jet pump pair. A riser brace attaches the riser pipe to the vessel wall to provide lateral support.

Each jet pump consists of an inlet-mixer assembly and a diffuser assembly. The inlet-mixer assembly consists of a 180° elbow, a nozzle section with suction inlets, and a mixing section. The inlet-mixer assembly is clamped to the riser transition piece by the beam-bolt assembly, and fits into a slip joint at the top of the diffuser assembly. A restrainer bracket attached to the riser provides lateral support for each mixer section to increase the stiffness of the assembly and reduce the effects of vibration. The diffuser assembly consists of a conical section terminating in a straight cylindrical section at the lower end which is welded to the shroud support plate. Instrumentation monitors jet pump flow through the diffuser to ascertain individual and collective jet pump flow rates under operating conditions.

#### 3.2 Safety Design Bases

**Content Deleted -  
EPRI Proprietary Information**

### 3.3 Event Analyses

As previously stated, the purpose of this document is to provide general design criteria for repairs of degraded jet pump assembly components. Accordingly, various events and operational conditions must be considered to ensure that the repair does not inhibit the ability of the jet pump assembly to perform the basic safety and operational functions. The following general load cases shall be considered in design of the proposed repair.

#### 3.3.1 Normal Operation

**Content Deleted -  
EPRI Proprietary Information**

#### 3.3.2 Anticipated Operational Occurrences (Upset Conditions)

**Content Deleted -  
EPRI Proprietary Information**

#### 3.3.3 Design Basis Accidents (EmerQency/Faulted Conditions)

**Content Deleted -  
EPRI Proprietary Information**

#### 3.3.4 Loading Combinations

**Content Deleted -  
EPRI Proprietary Information**

## **4.0 SCOPE OF REPAIRS**

- 4.1** This criteria applies to all of the jet pump assembly components except the flow sensing lines, the holddown beam and bolt assemblies, and the riser brace weld to the RPV. The holddown beam and bolt assemblies are readily replaceable and should be replaced rather than repaired if flaws are detected.
- 4.2** This criteria is not applicable to “like for like” replacement of components. Removal from the vessel to facilitate repairs of components would, however, be within the scope of this criteria.
- 4.3** The jet pump assembly repairs may address cracking in IGSCC susceptible components by a number of options. Local repairs such as weld overlays or mechanical devices which leave the flaws in place but structurally replace the flawed area may be used, or the flaw may be removed by a qualified machining process if it is not through-wall, with subsequent weld repair if required. Repairs include the hardware necessary to connect the new components to the existing assembly.
- 4.4** When either the vessel nozzle safe end or a weld attaching the nozzle thermal sleeve to the nozzle safe end is involved in the repair (the riser brace weld to the RPV is not in the scope of this criteria), ASME Class 1 requirements shall be invoked for the repair design within the ASME Section III and reactor pressure vessel jurisdiction.
- 4.5** Use of part circumferential weld overlays for repair of circumferential components shall follow the guidelines of Reference 17, previously developed for repair of RPV internal core spray piping. This repair procedure may be applied to any circumferential weld in the jet pump assembly except welds to the RFW or nozzle safe end. The weld overlays may be made to the ID or OD of the component in wet or dry conditions provided the guidelines of Reference 17 are followed.
- 4.6** Repairs to reduce gaps at the interface of the restrainer bracket and inlet mixer such as auxiliary restrainer bracket wedges are within the scope of this repair criteria. See Section 7.12 for further guidelines.
- 4.7** For repairs where the structural integrity of a flawed section is restored to its original level, the supporting structural evaluation can be limited to a comparison between the original and repaired structural parameters such as cross-sectional area, moment of inertia and section modulus, provided the root cause of the degradation is not the result of inadequacy in the original structural design. For this type of repair, e.g. a sleeve-type mechanical repair or a weld repair, a detailed evaluation of loads and stresses would not be required.



5.0 DESIGN OBJECTIVES

5.1 Desim Life

**Content Deleted -  
EPRI Proprietary Information**

5.2 Safetv Desim Bases

**Content Deleted -  
EPRI Proprietary Information**

5.3 Safetv Analysis Events

**Content Deleted -  
EPRI Proprietary Information**

5.4 Structural Integrity

**Content Deleted -  
EPRI Proprietary Information**

5.5 Retained Flaw(s)

**Content Deleted -  
EPRI Proprietary Information**

**Content Deleted -  
EPRI Proprietary Information**

5.6 Loose Parts Considerations

**Content Deleted -  
EPRI Proprietary Information**

5.7 Physical Interfaces with Other Reactor Internals

**Content Deleted -  
EPRI Proprietary Information**

5.8 Installation

**Content Deleted -  
EPRI Proprietary Information**

**Content Deleted -  
EPRI Proprietary Information**

5.9 Jet Pump Performance and Leakage

**Content Deleted -  
EPRI Proprietary Information**

5.10 Design Verification

**Content Deleted -  
EPRI Proprietary Information**



6.0 GENERAL DESIGN CRITERIA

**Content Deleted -  
EPRI Proprietary Information**

**Table 2: Summary of Recommended ASME Design Guidance**

**Content Deleted -  
EPRI Proprietary Information**

7.0 STRUCTURAL AND DESIGN EVALUATION

**Content Deleted -  
EPRI Proprietary Information**

7.1 Load Definitions - Applied Loads

**Content Deleted -  
EPRI Proprietary Information**

Applicability of Hydrodynamic Loads

**Content Deleted -  
EPRI Proprietary Information**

Deadweight (CDW)

**Content Deleted -  
EPRI Proprietary Information**

Hydraulic Loads (F)

**Content Deleted -  
EPRI Proprietary Information**

Differential Pressure (DP)

**Content Deleted -  
EPRI Proprietary Information**

Seismic Inertia

**Content Deleted -  
EPRI Proprietary Information**

Seismic Anchor Displacements

**Content Deleted -  
EPRI Proprietary Information**

**Content Deleted -  
EPRI Proprietary Information**

Safety Relief Valve Opening (SRV)

**Content Deleted -  
EPRI Proprietary Information**

Main Vent Clearing (MVC)

**Content Deleted -  
EPRI Proprietary Information**

Annulus Pressurization (AP)

**Content Deleted -  
EPRI Proprietary Information**

**Content Deleted -  
EPRI Proprietary Information**

Pool Swell, Condensation Oscillation and Chugging (PS, CO, CHG)

**Content Deleted -  
EPRI Proprietary Information**

Flow Induced Vibration (FIV)

**Content Deleted -  
EPRI Proprietary Information**

Thermal and Pressure Anchor Displacement

**Content Deleted -  
EPRI Proprietary Information**

**Content Deleted -  
EPRI Proprietary Information**

7.2 Service Level Conditions

**Content Deleted -  
EPRI Proprietary Information**

Service Level A (Normal Operating Conditions):

**Content Deleted -  
EPRI Proprietary Information**

Service Level B (Upset Conditions):

**Content Deleted -  
EPRI Proprietary Information**

Service Level C (Emergency Conditions):

**Content Deleted -  
EPRI Proprietary Information**

Service Level D (Faulted Conditions):

**Content Deleted -  
EPRI Proprietary Information**

7.3 Load Combinations

**Content Deleted -  
EPRI Proprietary Information**

7.3.1 Mark I Plants

**Content Deleted -  
EPRI Proprietary Information**

7.3.2 Mark II and III Plants

**Content Deleted -  
EPRI Proprietary Information**

**TABLE 3 LOAD COMBINATIONS FOR MARK I PLANTS**

**Content Deleted -  
EPRI Proprietary Information**

**TABLE 4 LOAD COMBINATIONS FOR MARK II & III PLANTS**

**Content Deleted -  
EPRI Proprietary Information**

**TABLE 5 LOAD TERM DEFINITIONS FOR TABLES 3 AND 4**

**Content Deleted -  
EPRI Proprietary Information**

7.4 Allowable Stresses

**Content Deleted -  
EPRI Proprietary Information**

7.5 Consideration of Shroud Repair or Cracking

**Content Deleted -  
EPRI Proprietary Information**

7.6 Flow Induced Vibration

**Content Deleted -  
EPRI Proprietary Information**

**Content Deleted -  
EPRI Proprietary Information**

7.7 Impact on Existing Internal Components

**Content Deleted -  
EPRI Proprietary Information**

7.8 Radiation Effects on Repair Design

**Content Deleted -  
EPRI Proprietary Information**

7.9 Analysis Codes

**Content Deleted -  
EPRI Proprietary Information**

7.10 Thermal Cycles

**Content Deleted -  
EPRI Proprietary Information**

7.11 Corrosion Allowance

**Content Deleted -  
EPRI Proprietary Information**

7.12 Restrainer Bracket Adjusting Screw Gap Evaluation

**Content Deleted -  
EPRI Proprietary Information**

8.0 SYSTEM EVALUATION

8.1 Leakage

**Content Deleted -  
EPRI Proprietary Information**

8.1 .1 Leakage Impact and Acceptance Criteria - Normal Operation

**Content Deleted -  
EPRI Proprietary Information**

8.1.2 Leakage Impact and Acceptance Criteria- Accident Conditions

**Content Deleted -  
EPRI Proprietary Information**

8.1.3 Leakage Evaluation Methodology - Accident Conditions

**Content Deleted -  
EPRI Proprietary Information**

8.2 Internal Jet Pump Pressure Drop

**Content Deleted -  
EPRI Proprietary Information**

8.3 Impact to Flow Distribution

**Content Deleted -  
EPRI Proprietary Information**

8.4 Emergency Operating Procedure (EOP) Calculations

**Content Deleted -  
EPRI Proprietary Information**

8.5 Power Uprate

**Content Deleted -  
EPRI Proprietary Information**



**9.0** MATERIALS. FABRICATION AND INSTALLATION

9.1 Materials

**Content Deleted -  
EPRI Proprietary Information**

**Content Deleted -  
EPRI Proprietary Information**

9.2 Crevices

**Content Deleted -  
EPRI Proprietary Information**

9.3 Welding and Fabrication

**Content Deleted -  
EPRI Proprietary Information**

**Content Deleted -  
EPRI Proprietary Information**

9.4 Pre-Installation As-Built Inspection

**Content Deleted -  
EPRI Proprietary Information**

9.5 Installation Cleanliness

**Content Deleted -  
EPRI Proprietary Information**

**Content Deleted -  
EPRI Proprietary Information**

9.6 ALARA

**Content Deleted -  
EPRI Proprietary Information**

9.7 Qualification of Critical Design Parameters and Process

**Content Deleted -  
EPRI Proprietary Information**



10. INSPECTION AND TESTING

10.1 Inspection Access

**Content Deleted -  
EPRI Proprietary Information**

10.2 Pre and Post Installation Inspection

**Content Deleted -  
EPRI Proprietary Information**

**Content Deleted -  
EPRI Proprietary Information**

10.3 Testing

**Content Deleted -  
EPRI Proprietary Information**

11.0 QUALITY ASSURANCE PROGRAM

**Content Deleted -  
EPRI Proprietary Information**



## 12.0 DESIGN BASIS DOCUMENTATION

The following documentation shall be prepared and forwarded to the plant owner and maintained as permanent records:

**Content Deleted -  
EPRI Proprietary Information**



### **13.0 REFERENCES**

1. BWR Vessel and Internals Project, Safety Assessment of BWR Reactor Internals (BWRVIP-06), EPRI Report TR-105707, October 1995.
2. ASME Boiler and Pressure Vessel Code Section II, 1989 Edition
3. ASME Boiler and Pressure Vessel Code Section III, 1989 Edition
4. ASME Boiler and Pressure Vessel Code Section V, 1989 Edition
5. ASME Boiler and Pressure Vessel Code Section XI, 1989 Edition
6. Regulatory Guide 1.85, Materials Code Case Acceptability - ASME Section III, Division I
7. 10 CFR 50.55a, Codes and Standards
8. Regulatory Guide 1.44, Control of the Use of Sensitized Stainless Steel
9. EPRI Document NP-7032, Material Specification for Alloy X-750 for Use in LWR Internal Components, Revision 1
10. ASTM A-262, Detecting Susceptibility to Intergranular Attack in Stainless Steel
11. Regulatory Guide 1.3 1, Control of Ferrite Content in Stainless Steel Weld Metal
12. EPRI Document 84-MG-18, Nuclear Grade Stainless Steel Procurement, Manufacturing and Fabrication Guidelines
13. ASME Code Case N-516, Underwater Welding, Section XI, Division 1, approved August 9, 1993
14. ASME Code Case N-516-1, Underwater Welding, Section XI, Division 1, approved December 3 1, 1996
15. 10 CFR 50, Appendix B
16. EPRI Document, "BWR Jet Pump Assembly Inspection and Flaw Evaluation Guidelines" BWRVIP-4 1, October 1997
17. EPRI Document TR-108 198, "Technical Basis for Part Circumference Weld Overlay Repair of Vessel Internal Core Spray Piping", BWRVIP-34, May 1997






Figure 1: Typical Jet Pump Assembly

**Content Deleted -  
EPRI Proprietary Information**

**Figure 2A: Typical Primary Single-Leaf Riser Brace**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 2B: Typical Primary Double-Leaf Riser Brace**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 2C: Typical Secondary Double-Leaf Riser Brace**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 3A: BWR/3 Beam-Bolt Assembly and Beam Top View**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 3B: BWR/4-6 Beam-Bolt Assembly and Beam Top View**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 4: Three Configurations for the Thermal Sleeve**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 5A: Typical BWR/3 Riser Assembly**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 5B: Typical BWR/4-6 Riser Assembly**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 5C: Riser Elbow and Thermal Sleeve**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 6A: Typical Transition Piece**

w  
ch

**Content Deleted -  
EPRI Proprietary Information**

**Figure 6B: Welded Transition Piece Detail**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 7A: Inlet with Single-Hole Nozzle**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 7B: Inlet with Five-Hole Hozzle**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 7C: Inlet-Mixer with Clamp Connection**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 8A: Typical BWR/3 Mixer without an Adapter**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 8B: Typical BWR/3 Mixer with an Adapter**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 8C: Typical BWR/4 Mixer**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 8D: Typical BWR/5-6 Mixer Section**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 9A: BWR/3 Swing Gate Restrainer Bracket Design**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 9B: BWR/3,4 Solid Ring Restrainer Bracket Design**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 9C: Solid Ring Restrainer Bracket Design Typical of Most BWR/4-6s**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 10A: BWR/3 Wedge Assembly-Welded to Restrainer Bracket**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 10B: BWR/3 Wedge Assembly-Welded to Mixer**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 10C: Typical BWR/4-6 Wedge Assembly**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 11A: Diffuser Assembly Typical of BWR/3 Plants with External Sensing Line Manifolds**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 11B: Diffuser Assembly Typical of BWR/3 Plants with Partial Internal Sensing Line Manifolds**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 11C: Typical BWR/4 Diffuser Assembly**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 11D: Typical BWR/5 Diffuser Assembly**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 11E: Typical BWR/6 Diffuser Assembly**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 12A: Straight Adapter Assembly**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 12B: Curved Adapter Assembly**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 12C: Straight Adapter Assembly with Overlap**

**Content Deleted -  
EPRI Proprietary Information**

**Figure 12D: Lower Ring Connection to Shroud Support Plate  
Typical of Most BWR/5s and 6s**

*Target:*  
Nuclear Power

### **About EPRI**

EPRI creates science and technology solutions for the global energy and energy services industry. U.S. electric utilities established the Electric Power Research Institute in 1973 as a nonprofit research consortium for the benefit of utility members, their customers, and society. Now known simply as EPRI, the company provides a wide range of innovative products and services to more than 1000 energy-related organizations in 40 countries. EPRI's multidisciplinary team of scientists and engineers draws on a worldwide network of technical and business expertise to help solve today's toughest energy and environmental problems.

EPRI. Powering Progress

© 2000 Electric Power Research Institute (EPRI), Inc. All rights reserved. Electric Power Research Institute and EPRI are registered service marks of the Electric Power Research Institute, Inc. EPRI. POWERING PROGRESS is a service mark of the Electric Power Research Institute, Inc.

♻️ Printed on recycled paper in the United States of America

TR-108718NP

EPRI • 3412 Hillview Avenue, Palo Alto, California 94304 • PO Box 10412, Palo Alto, California 94303 • USA  
800.313.3774 • 650.855.2121 • [askepri@epri.com](mailto:askepri@epri.com) • [www.epri.com](http://www.epri.com)