

March 21, 2000

Mr. J. P. O'Hanlon  
Senior Vice President - Nuclear  
Virginia Electric and Power Company  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

SUBJECT: NORTH ANNA POWER STATION UNITS 1 AND 2 - CLARIFICATION OF  
CONTROL ROD DROP TIME TEST CRITERIA, BASES CHANGE  
(TAC NOS. MA8232 AND MA8233)

Dear Mr. O'Hanlon:

By letter dated October 28, 1999, you submitted for our information your proposed Technical Specifications (TS) Bases change for "Clarification of Control Rod Drop Time Test Criteria." You stated TS Bases Section 3/4.1.3 was revised to explain that the control rod drop time surveillance criteria were adjusted downward from the TS Limiting Condition for Operation value to conservatively account for the effects of a concurrent seismic event on post-accident trip reactivity insertion.

Title 10 of the *Code of Federal Regulations*, Part 50 (10 CFR 50), Section 59, permits licensees to make changes in the facility as described in the safety analysis report, without prior Commission approval, unless the proposed change involves a change in the TS incorporated in the license or an unreviewed safety question. Your letter stated that it has been determined that these proposed changes do not involve an unreviewed safety question, as defined in 10 CFR 50.59. Accordingly, the regulations authorize you to make the proposed TS Bases change without our review. Your changes to the Bases may be subject to our future inspections or audits.

This completes our effort under TAC Nos. MA8232 and MA8233, and the TACs are closed.

If you have any questions, please call me at (301) 415-1448.

Sincerely,

*/RA/*

Gordon E. Edison, Senior Project Manager, Section 1  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-338 and 50-339

cc: See next page

March 21, 2000

Mr. J. P. O'Hanlon  
Senior Vice President - Nuclear  
Virginia Electric and Power Company  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

SUBJECT: NORTH ANNA POWER STATION UNITS 1 AND 2 - CLARIFICATION OF  
CONTROL ROD DROP TIME TEST CRITERIA, BASES CHANGE  
(TAC NOS. MA8232 AND MA8233)

Dear Mr. O'Hanlon:

By letter dated October 28, 1999, you submitted for our information your proposed Technical Specifications (TS) Bases change for "Clarification of Control Rod Drop Time Test Criteria." You stated TS Bases Section 3/4.1.3 was revised to explain that the control rod drop time surveillance criteria were adjusted downward from the TS Limiting Condition for Operation value to conservatively account for the effects of a concurrent seismic event on post-accident trip reactivity insertion.

Title 10 of the *Code of Federal Regulations*, Part 50 (10 CFR 50), Section 59, permits licensees to make changes in the facility as described in the safety analysis report, without prior Commission approval, unless the proposed change involves a change in the TS incorporated in the license or an unreviewed safety question. Your letter stated that it has been determined that these proposed changes do not involve an unreviewed safety question, as defined in 10 CFR 50.59. Accordingly, the regulations authorize you to make the proposed TS Bases change without our review. Your changes to the Bases may be subject to our future inspections or audits.

This completes our effort under TAC Nos. MA8232 and MA8233, and the TACs are closed.

If you have any questions, please call me at (301) 415-1448.

Sincerely,  
**/RA/**

Gordon E. Edison, Senior Project Manager, Section 1  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-338 and 50-339

cc: See next page

Distribution:

File Center	OGC	ACRS
PUBLIC	WBeckner	RHaag, RII
PDII-1 RF	HBerkow	GHill (4)

DOCUMENT NAME: C:\MA8232-3.BSS.wpd

OFFICE	PM:PDII-1	PM:PDII-1	LA:PDII-2	SC:PDII-1
NAME	SMonarque:cn	GEEdison	EDunnington	REmch
DATE	3/13/00	3/13/00	3/10/00	3/20/00
COPY	YES / NO	YES / NO	YES / NO	YES / NO

OFFICIAL RECORD COPY

Mr. J. P. O'Hanlon  
Virginia Electric and Power Company

North Anna Power Station  
Units 1 and 2

cc:

Mr. J. Jeffrey Lunsford  
County Administrator  
Louisa County  
P.O. Box 160  
Louisa, Virginia 23093

Mr. W. R. Matthews  
Site Vice President  
North Anna Power Station  
P.O. Box 402  
Mineral, Virginia 23117

Mr. Donald P. Irwin, Esquire  
Hunton and Williams  
Riverfront Plaza, East Tower  
951 E. Byrd Street  
Richmond, Virginia 23219

Mr. E. S. Grecheck  
Site Vice President  
Surry Power Station  
Virginia Electric and Power Company  
5570 Hog Island Road  
Surry, Virginia 23883

Dr. W. T. Lough  
Virginia State Corporation  
Commission  
Division of Energy Regulation  
P.O. Box 1197  
Richmond, Virginia 23209

Robert B. Strobe, M.D., M.P.H.  
State Health Commissioner  
Office of the Commissioner  
Virginia Department of Health  
P. O. Box 2448  
Richmond, Virginia 23218

Old Dominion Electric Cooperative  
4201 Dominion Blvd.  
Glen Allen, Virginia 23060

Mr. J. H. McCarthy, Manager  
Nuclear Licensing & Operations Support  
Virginia Electric and Power Company  
Innsbrook Technical Center  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060

Office of the Attorney General  
Commonwealth of Virginia  
900 East Main Street  
Richmond, Virginia 23219

Senior Resident Inspector  
North Anna Power Station  
U.S. Nuclear Regulatory Commission  
1024 Haley Drive  
Mineral, Virginia 23117