

March 21, 2000

Mr. J. P. O'Hanlon
Senior Vice President - Nuclear
Virginia Electric and Power Company
5000 Dominion Blvd.
Glen Allen, Virginia 23060

SUBJECT: NORTH ANNA POWER STATION UNITS 1 AND 2 - CORRECTION TO MAIN
STEAM SAFETY VALVE CODE EDITION, BASES CHANGE (TAC NOS. MA8239
AND MA8240)

Dear Mr. O'Hanlon:

By letter dated October 28, 1999, you submitted for our information your proposed Technical Specifications (TS) Bases change for "Correction to Main Steam Safety Valve Code Edition." You stated that TS Bases Section 3/4.7.1.1 has been revised to reflect that the design capacity of the Main Steam Safety Valves is based upon the 1968 Edition of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code with Addenda through Winter 1970. The Bases previously referred to the 1971 Edition of the ASME Code.

Title 10 of the *Code of Federal Regulations*, Part 50 (10 CFR 50), Section 59, permits licensees to make changes in the facility as described in the safety analysis report, without prior Commission approval, unless the proposed change involves a change in the TS incorporated in the license or an unreviewed safety question. Your letter stated that it has been determined that these proposed changes do not involve an unreviewed safety question, as defined in 10 CFR 50.59. Accordingly, the regulations authorize you to make the proposed TS Bases change without our review. Your changes to the Bases may be subject to our future inspections or audits.

This completes our effort under TAC Nos. MA8239 and MA8240, and the TACs are closed.

If you have any questions, please call me at (301) 415-1448.

Sincerely,

/RA/

Gordon E. Edison, Senior Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-338 and 50-339

cc: See next page

March 21, 2000

Mr. J. P. O'Hanlon
Senior Vice President - Nuclear
Virginia Electric and Power Company
5000 Dominion Blvd.
Glen Allen, Virginia 23060

SUBJECT: NORTH ANNA POWER STATION UNITS 1 AND 2 - CORRECTION TO MAIN
STEAM SAFETY VALVE CODE EDITION, BASES CHANGE (TAC NOS. MA8239
AND MA8240)

Dear Mr. O'Hanlon:

By letter dated October 28, 1999, you submitted for our information your proposed Technical Specifications (TS) Bases change for "Correction to Main Steam Safety Valve Code Edition." You stated that TS Bases Section 3/4.7.1.1 has been revised to reflect that the design capacity of the Main Steam Safety Valves is based upon the 1968 Edition of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code with Addenda through Winter 1970. The Bases previously referred to the 1971 Edition of the ASME Code.

Title 10 of the *Code of Federal Regulations*, Part 50 (10 CFR 50), Section 59, permits licensees to make changes in the facility as described in the safety analysis report, without prior Commission approval, unless the proposed change involves a change in the TS incorporated in the license or an unreviewed safety question. Your letter stated that it has been determined that these proposed changes do not involve an unreviewed safety question, as defined in 10 CFR 50.59. Accordingly, the regulations authorize you to make the proposed TS Bases change without our review. Your changes to the Bases may be subject to our future inspections or audits.

This completes our effort under TAC Nos. MA8239 and MA8240, and the TACs are closed.

If you have any questions, please call me at (301) 415-1448.

Sincerely,

/RA/

Gordon E. Edison, Senior Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-338 and 50-339

cc: See next page

Distribution:

File Center GHill (4) ACRS
PUBLIC HBerkow OGC
PDII-1 RF WBeckner RHaug, RII

DOCUMENT NAME: C:\MA8239-40.BSS.wpd

OFFICE	PM:PDII-1	PM:PDII-1	LA:PDII-2	SC:PDII-1
NAME	SMonarque:cn	GEdison	EDunnington	REmch
DATE	3/14/00	3/14/00	3/13/00	3/20/00
COPY	YES / NO	YES / NO	YES / NO	YES / NO

OFFICIAL RECORD COPY

Mr. J. P. O'Hanlon
Virginia Electric and Power Company

North Anna Power Station
Units 1 and 2

cc:

Mr. J. Jeffrey Lunsford
County Administrator
Louisa County
P.O. Box 160
Louisa, Virginia 23093

Mr. W. R. Matthews
Site Vice President
North Anna Power Station
P.O. Box 402
Mineral, Virginia 23117

Mr. Donald P. Irwin, Esquire
Hunton and Williams
Riverfront Plaza, East Tower
951 E. Byrd Street
Richmond, Virginia 23219

Mr. E. S. Grecheck
Site Vice President
Surry Power Station
Virginia Electric and Power Company
5570 Hog Island Road
Surry, Virginia 23883

Dr. W. T. Lough
Virginia State Corporation
Commission
Division of Energy Regulation
P.O. Box 1197
Richmond, Virginia 23209

Robert B. Strobe, M.D., M.P.H.
State Health Commissioner
Office of the Commissioner
Virginia Department of Health
P. O. Box 2448
Richmond, Virginia 23218

Old Dominion Electric Cooperative
4201 Dominion Blvd.
Glen Allen, Virginia 23060

Mr. J. H. McCarthy, Manager
Nuclear Licensing & Operations Support
Virginia Electric and Power Company
Innsbrook Technical Center
5000 Dominion Blvd.
Glen Allen, Virginia 23060

Office of the Attorney General
Commonwealth of Virginia
900 East Main Street
Richmond, Virginia 23219

Senior Resident Inspector
North Anna Power Station
U.S. Nuclear Regulatory Commission
1024 Haley Drive
Mineral, Virginia 23117