

AmerGen Energy Company, LLC Three Mile Island Unit 1

Route 441 South, P.O. Box 480 Middletown, PA 17057 Phone: 717-944-7621

March 12, 2000 5928-00-20061

U. S. Nuclear Regulatory Commission Washington, DC 20555-0001

Attn: Document Control Desk

Dear Sir or Madam:

SUBJECT: THREE MILE ISLAND, UNIT 1 (TMI UNIT 1)

OPERATING LICENSE NO. DPR-50

DOCKET NO. 50-289

ADDITIONAL INFORMATION - NRC CONFIRMATORY ORDER DATED

AUGUST 11, 1999 - THERMO-LAG

This letter provides notification that TMI Unit 1 has completed the implementation of the Thermo-Lag 330-1 fire barrier corrective actions in accordance with the scope and schedule specified in the above captioned order. These corrective actions were required to be completed by June 30, 2000. A summary of the scope of these completed corrective actions is listed below:

- Upgrade of Thermo-Lag fire barriers to a one-hour rating in compliance with Appendix R, Section III.G.2.c in fire zones AB-FZ-3, AB-FZ-5, AB-FZ-7, and FH-FZ-2 for the one-hour fire barriers included in the TMI Unit 1 exemption request dated December 31, 1996.
- 2) Installation of the wet pipe sprinkler system in fire zone FH-FZ-6 and installation of the combustible gas detector in fire zone CB-FA-1.

The corrective actions for fire zones AB-FZ-3, FH-FZ-6, and CB-FA-1, listed above, were completed previously as identified in AmerGen letter to the NRC, dated December 30, 1999 (1920-99-20641).

AmerGen believes that completion of these corrective actions has satisfied the requirements of the "Confirmatory Order Modifying License No. DPR-50, Three Mile Island Nuclear Station, Unit 1", dated August 11, 1999.

If any additional information is needed, please contact David J. Distel at (610) 640-6672.

Very truly yours,

John B. Cotton

Vice President, TMI Unit 1

JBC/djd

cc: H. J. Miller, Administrator, USNRC Region I

T. G. Colburn, Senior Project Manager, TMI Unit 1

W. L. Schmidt, Senior Resident Inspector, TMI Unit 1

File No. 94032