

March 6, 2000
NMP2L 1944

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

RE: Nine Mile Point Unit 2
Docket No. 50-410
NPF-69

Subject: Monthly Operating Report for February 2000

Dear Sir:

Submitted herewith is the Operating Data Report, the Unit Shutdowns, and Summary of Operating Experience for February 2000.

Very truly yours,



M. F. Peckham
Plant Manager - Unit 2

/db

Attachments

xc: H.J. Miller, Regional Administrator, Region I
G.K. Hunegs, Senior Resident Inspector
Records Management

IE24

NIAGARA MOHAWK POWER CORPORATION
NINE MILE POINT NUCLEAR STATION UNIT #2
SUMMARY OF OPERATING EXPERIENCE

Nine Mile Point Unit Two operated with a capacity factor (MDC) of 102.5% and an availability factor of 100.00% for the month of **February 2000**.

There were no challenges to the safety relief valves during this period.

OPERATING DATA REPORT

DOCKET NO.: 50-410

DATE: 000301

PREPARED BY: C. Caroccio

TELEPHONE: (315) 349-4615

OPERATING STATUS

Unit Name: **Nine Mile Point Unit #2**
Reporting Period: **1143.3**
2. Maximum Dependable Capacity (Net MWe): **1123.4**

	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>
3. Number of Hours Reactor was Critical	696.0	1,440.0	81,192.8
4. Hours Generator On-Line	696.0	1,440.0	78,649.2
5. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
6. Net Electrical Energy Gen. (MWH)	801,451.8	1,654,342.2	80,852,306.8

UNIT SHUTDOWNS

DOCKET NO: 50-410

UNIT NAME: NMP#2

DATE: 000301

PREPARED BY: C. Caroccio

TELEPHONE: (315) 349-4615

APPENDIX B
REPORTING PERIOD - FEBRUARY 2000

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reasons ¹	Method of Shutting Down ²	Cause & Corrective Actions Comments
--NONE--						

¹

Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training & License Exam
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

²

Method:

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)