



**Florida  
Power**

CORPORATION  
Crystal River Unit 3  
Docket No. 50-302  
Operating License No. DPR-72

March 14, 2000  
3F0300-02

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555-0001

Subject: Monthly Operating Report

Dear Sir:

Florida Power Corporation hereby submits the Crystal River Unit 3 (CR-3) February 2000 Monthly Operating Report. This report is being submitted in accordance with the CR-3 Improved Technical Specification 5.7.1.2 as Attachment A.

During Spring 1996, CR-3 replaced the low pressure turbine rotors. Beginning in September 1997 until February 1998, CR-3 was shutdown due to an extended design outage. Partial performance runs of the replaced low pressure turbine rotors were completed prior to entering the design outage. The balance of the performance runs were completed during the remainder of 1998 and 1999 after CR-3 emerged from the outage. Beginning in January 2000, as a result of this modification and the completion of performance runs, the Maximum Dependable Capacity (MWe-Net) value measuring plant output was increased from 818 to 843. A revised Appendix A - Operating Data Report for the January 2000 Monthly Operating Report is being provided as Attachment B in order to update the MWe-Net value, accordingly.

If you have any questions regarding this submittal, please contact Mr. Sid Powell, Manager, Nuclear Licensing at (352) 563-4883.

Sincerely,

D. L. Roderick  
Director, Nuclear Plant Operations

DLR/ff

xc: Regional Administrator, Region II  
Senior Resident Inspector  
NRR Project Manager

Attachments:

- A. Monthly Operating Report - February 2000
- B. Monthly Operating Report - January 2000  
Revised Appendix A - Operating Data Report

IE24