



H. B. Barron  
Vice President

**Duke Energy Corporation**

McGuire Nuclear Station  
12700 Hagers Ferry Road  
Huntersville, NC 28078-9340  
(704) 875-4800 OFFICE  
(704) 875-4809 FAX

March 23, 2000

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Subject: Retraction of Relief Request 99-002  
McGuire Nuclear Station Unit 1 Docket Number 50-369  
McGuire Nuclear Station Unit 2 Docket Number 50-370

Re: Letter Duke Energy Corporation to U.S. Nuclear Regulatory Commission  
Relief Request 99-002  
January 5, 2000 from H.B. Barron

Duke Energy requested relief from certain requirements of 10 CFR 50.55 (a) in a letter dated January 5, 2000. Duke based this requested relief on ASME Code Case N-323-1 "Alternative Examination for Welded Attachments to Pressure Vessels Section XI, Division 1." Duke was relying on the NRC Staff's future endorsement of the case in an upcoming revision of Regulatory Guide 1.147 "Inservice Inspection Code Case Acceptability, ASME Section XI, Division 1".

Duke had a teleconference on February 9, 2000 with Office of Nuclear Regulation (ONRR) staff to discuss this relief request. During that call the staff advised Duke that the staff would not likely endorse Code Case N-323-1. As such, Duke does not have the regulatory foundation for Relief Request 99-002 and hereby retracts that request.

Please contact Mike Cash (704 875-4117, mtcash@duke-energy.com) if you have questions on this matter.

H. B. Barron, Vice President  
McGuire Nuclear Station  
Duke Energy Corporation

AC47

Cc:

L.A. Reyes  
Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

F. Rinaldi  
Project Manager  
U.S. Nuclear Regulatory Commission  
One White Flint North, Mail Stop 9H3  
Washington, DC 20555

S.M. Shaeffer  
Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
McGuire Nuclear Station

Bcc:

J.O Barbour  
R. Branch  
R.K. Rhyne  
G.D. Scarboro  
ELL File / NRIA  
N.T. Simms