

March 14, 2000

Mr. S. E. Scace - Director  
Nuclear Oversight and Regulatory Affairs  
c/o Mr. David A. Smith  
Northeast Nuclear Energy Company  
P. O. Box 128  
Waterford, CT 06385-0128

SUBJECT: MILLSTONE NUCLEAR POWER STATION, UNIT NO. 2, REQUEST FOR  
ADDITIONAL INFORMATION (RAI) RE: FUEL HANDLING AND CASK DROP  
ACCIDENTS (TAC NO. MA7712)

Dear Mr. Scace:

By letter dated December 14, 1999, you proposed changes to the Technical Specifications and the Final Safety Analysis Report related to fuel handling and cask drop accidents at the Millstone Nuclear Power Station, Unit No. 2. The staff has reviewed this request and determined that additional information is needed to complete the review. Enclosed is the staff's RAI. We request that you respond by March 30, 2000, as discussed with and agreed upon by Paul Russell of your staff.

Questions regarding this request should be sent to my attention at the above address or you can contact me at 301-415-1445.

Sincerely,

*/RA/*

Alan B. Wang, Project Manager, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-336

Enclosure: Request for Additional Information

cc w/encl: See next page

March 14, 2000

Mr. S. E. Scace - Director  
Nuclear Oversight and Regulatory Affairs  
c/o Mr. David A. Smith  
Northeast Nuclear Energy Company  
P. O. Box 128  
Waterford, CT 06385-0128

SUBJECT: MILLSTONE NUCLEAR POWER STATION, UNIT NOS. 2, REQUEST FOR  
ADDITIONAL INFORMATION (RAI) RE: FUEL HANDLING AND CASK DROP  
ACCIDENTS (TAC NO. MA7712)

Dear Mr. Scace:

By letter dated December 14, 1999, you proposed changes to the Technical Specifications and the Final Safety Analysis Report related to fuel handling and cask drop accidents at the Millstone Nuclear Power Station, Unit No. 2. The staff has reviewed this request and determined that additional information is needed to complete the review. Enclosed is the staff's RAI. We request that you respond by March 30, 2000, as discussed with and agreed upon by Paul Russell of your staff.

Questions regarding this request should be sent to my attention at the above address or you can contact me at 301-415-1445.

Sincerely,

*/RA/*

Alan B. Wang, Project Manager, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-336

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION

File Center            TClark                    LBerry  
PUBLIC                OGC                        CAndersen, RGN-I  
PDI-2 Reading        ACRS                       EAdensam (e-mail)  
JClifford              JZimmerman              SBlack  
AWang

DOCUMENT NAME: C:\ma7712rai.wpd

To receive a copy of this document, indicate "C" in the box					
OFFICE	PDI-2/PM	C	PDI-2/LA	C	PDI-2/SC
NAME	AWang:am		TClark		JClifford
DATE	3/14/00		3/14/00		3/14/00

OFFICIAL RECORD COPY

**MILLSTONE NUCLEAR POWER STATION UNIT NO. 2 (MILLSTONE 2)**

**FUEL HANDLING AND CASK DROP ACCIDENT**

**REQUEST FOR ADDITIONAL INFORMATION**

By letter dated December 14, 1999, Northeast Nuclear Energy Company (NNECO) proposed changes to the Millstone 2 Technical Specifications (TSs) and Final Safety Analysis Report. The proposed changes will result in a slight increase in the consequences of a fuel handling accident in the spent fuel pool area. As part of the staff's review to ensure that new analysis is within the 10 CFR Part 100 limits we have the following questions:

1. TS 3.9.4 Bases specifies a "designated" individual to close the containment air lock doors within 10 minutes as opposed to a "dedicated" individual who would have no other duties. Specify what other duties the designated individual will have and where they will be stationed relative to the air lock doors. For example, will this person be responsible for an inventory of people inside containment in addition to the other duties?
2. TS 3.9.4: What types of hoses and cables will be allowed to pass through the open air lock doors? What provisions will be made for the designated individual to separate these in order to close the air lock door while minimizing hazards from these hoses and cables?
3. The spent fuel pool handling analysis assumes a bypass flow associated with the Auxiliary Building elevator of 2%. Describe the testing and analysis used to derive this value. What factors might change this value over time, if any?
4. TS 3.9.17: Does removing the requirement that the boron concentration in the spent fuel pool will be uniform change any plant procedures to ensure boron concentration uniformity or measurements taken of boron concentration?
5. TS 3.9.14/3.9.15: The requirement that the auxiliary building doors must be closed has been replaced by a requirement that spent fuel pool area integrity shall be maintained. Are these two requirements equivalent? If not, specify the differences.

Millstone Nuclear Power Station  
Unit 2

cc:

Ms. L. M. Cuoco  
Senior Nuclear Counsel  
Northeast Utilities Service Company  
P. O. Box 270  
Hartford, CT 06141-0270

Edward L. Wilds, Jr., Ph.D.  
Director, Division of Radiation  
Department of Environmental Protection  
79 Elm Street  
Hartford, CT 06106-5127

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

First Selectmen  
Town of Waterford  
15 Rope Ferry Road  
Waterford, CT 06385

Charles Brinkman, Manager  
Washington Nuclear Operations  
ABB Combustion Engineering  
12300 Twinbrook Pkwy, Suite 330  
Rockville, MD 20852

Senior Resident Inspector  
Millstone Nuclear Power Station  
c/o U.S. Nuclear Regulatory Commission  
P.O. Box 513  
Niantic, CT 06357

Mr. F. C. Rothen  
Vice President - Nuclear Work Services  
Northeast Utilities Service Company  
P. O. Box 128  
Waterford, CT 06385

Ernest C. Hadley, Esquire  
1040 B Main Street  
P.O. Box 549  
West Wareham, MA 02576

Mr. R. P. Necci  
Vice President - Nuclear Technical Services  
Northeast Nuclear Energy Company  
P. O. Box 128  
Waterford, CT 06385

Mr. J. T. Carlin  
Vice President - Human Services - Nuclear  
Northeast Utilities Service Company  
P. O. Box 128  
Waterford, CT 06385

Mr. Allan Johanson, Assistant Director  
Office of Policy and Management  
Policy Development and Planning  
Division  
450 Capitol Avenue - MS# 52ERN  
P. O. Box 341441  
Hartford, CT 06134-1441

Mr. M. H. Brothers  
Vice President - Millstone Operations  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385

Mr. C. J. Schwarz  
Station Director  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385

Mr. L. Olivier  
Senior Vice President and Chief  
Nuclear Officer - Millstone  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385

Millstone Nuclear Power Station  
Unit 2

cc:

Citizens Regulatory Commission  
ATTN: Ms. Geri Winslow  
P. O. Box 199  
Waterford, CT 06385

Deborah Katz, President  
Citizens Awareness Network  
P. O. Box 83  
Shelburne Falls, MA 03170

Ms. Terry Concannon  
Co-Chair  
Nuclear Energy Advisory Council  
41 South Buckboard Lane  
Marlborough, CT 06447

Mr. Evan W. Woollacott  
Co-Chair  
Nuclear Energy Advisory Council  
128 Terry's Plain Road  
Simsbury, CT 06070

Attorney Nicholas J. Scobbo, Jr.  
Ferriter, Scobbo, Caruso, Rodophele, PC  
75 State Street, 7th Floor  
Boston, MA 02108-1807

Mr. D. B. Amerine  
Vice President - Engineering Services  
Northeast Nuclear Energy Company  
P. O. Box 128  
Waterford, CT 06385

Mr. D. A. Smith  
Manager - Regulatory Affairs  
Northeast Nuclear Energy Company  
P. O. Box 128  
Waterford, CT 06385

Ms. Nancy Burton  
147 Cross Highway  
Redding Ridge, CT 00870

Mr. G. D. Hicks  
Director - Nuclear Training Services  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385

Mr. S. E. Scace  
Director - Nuclear Oversight  
and Regulatory Affairs  
Northeast Nuclear Energy Company  
P. O. Box 128  
Waterford, CT 06385