ALT.	DATE	REVISION	BY	CKD.
A	8/9/70	INCREASED LENGTH OF PC. NOS. D1B & DXII B IN SECTIONS I & XII.	gbc	[illegible]
B	5/1/70	ADDED TOTAL WEIGHT AND WEIGHT PER SECTION. ADDED NOTES WITH INFORMATION ABOUT ADDITIONAL CONNECTIONS "CE", "CF", "CG", "CH" AND "CI".	gbc	[illegible]

EXPIRES ON
STOP MAR 27 2000 STOP
NON - CONTROLLED PRINT



PLAN VIEW



DETAIL "AV"
SCALE: 3"=1'-0"
SHELL 1A ONLY



SECTION "V-V"
SCALE: 3"=1'-0"



DETAIL "AT"
SCALE: 3"=1'-0"
SHELL 1A ONLY



DETAIL "AF"
SCALE: 6"=1'-0"





DETAIL "F"
SCALE: ¾"=1'-0"
(5) PLACES ONLY



DETAIL "M"
SCALE: 1½"=1'-0"



SECTION "J-J"
SCALE: 1"=1'-0"
TYPICAL VIEW OF SHEAR PLATES



DETAIL "H"
SCALE: ¾"=1'-0"
(3) PLACES ONLY



NOTE:
FOR LOCATION OF ADDED CONNECTIONS "CE", "CF", AND "CH", TO BE SHIPPED LOOSE AND INSTALLED IN FIELD, SEE DWG. EC93877GA (SHT. 2 OF 4) CONDENSER 1A AND FOR DETAILS SEE DWG. DC93877SC-1, DETAIL "A" AND BILL OF MATERIAL SHT. 110.

CONDENSER 1A
SCALE: ½"=1'-0"
SIDE VIEW OF CONNECTIONS



DETAIL OF ALIGNMENT BRACKETS TO BE SHOP INSTALLED AT TOP, BOTTOM AND END OF SECTIONS
DETAIL "U"
SCALE: 3"=1'-0"
(NOT REQUIRED ON OUTLET END)

NOTE:
FOR DETAILS OF SECTION XII SEE DET. "N".
DWG. DC93877S2 SHT. 2 OF 2



SECTION "A-A"

NOTE:
FOR DETAILS OF SECTION I SEE DET. "N".
DWG. DC93877S2 SHT. 2 OF 2
SEE DET. "C"



SECTION "B-B"

NOTE:
ALL BAFFLES, PLENUMS, AND TRAYS TO BE SHIPPED LOOSE AND FIELD WELDED IN SECTIONS IV AND IX.



DETAIL "D"
SCALE: 1½"=1'-0"



NOTE:
FOR LOCATION OF ADDED CONNECTION "CI", TO BE SHIPPED LOOSE AND INSTALLED IN FIELD, SEE DWG. EC93877GA (SHT. 1 OF 4) CONDENSER 1B AND FOR DETAILS SEE DWG. DC93877SC-1, DETAIL OF START-UP RECIRCULATION CONNECTION AND BILL OF MATERIAL SHT. 110.





DETAIL "C"
SCALE: 1½"=1'-0"

FILMED SEP 26 1974

RECEIVED SEP 11 1974 68004 1075

RECEIVED FEB 5 1974 BURNS and ROE HEAVASTER

REV.	DATE	REV.
8/9/70		A

RELEASE FOR MFR.

INDUSTRIAL PRODUCTS DIVISION
MARYLAND SHIPBUILDING & DRYDOCK CO.
BALTIMORE, MD.

MIDDLE SHELL ASSEMBLY
CONDENSER 1B
FOR CONSUMERS PUBLIC POWER DISTRICT

DESIGNED		CHECKED M.N.R. 5-19-69	
DRAWN J.C. 5-1-69		APPROVED	
CONT. NO. 93877	SCALE ½"=1'-0"	DRWG. EC93877S2	SHT. 1 OF 2

TOTAL WEIGHT 78,000 LBS.

D-3