

Commonwealth Edison Company
Quad Cities Generating Station
22710 206th Avenue North
Cordova, IL 61242-9740
Tel 309-654-2241



March 23, 2000

SVP-00-056

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Quad Cities Nuclear Power Station, Units 1 and 2
Facility Operating License Nos. DPR-29 and DPR-30
NRC Docket Nos. 50-254 and 50-265

Subject: Commitments Completed During Unit 2 Refueling Outage

- Reference:
- (1) Letter from J. Hosmer (ComEd) to USNRC, "Dresden Nuclear Power Station Units 2 and 3, Quad Cities Nuclear Power Station Units 1 and 2, Reactor Water Clean Up (RWCU) System High Energy Line Break (HELB) Outside the Drywell," dated December 10, 1996.
 - (2) Letter from D.A. Sager (ComEd) to USNRC, "Identification of Appendix R Discrepancies," dated April 20, 1998.
 - (3) Letter from J.C. Brons (ComEd) to NRC Dresden, Quad Cities, and LaSalle Station response to NRC Generic Letter 94-02, "Long-Term Solutions and Upgrade of Interim Operating Recommendations for Thermal-Hydraulic Instabilities in Boiling Water Reactors," dated September 8, 1994.

On February 12, 2000, Commonwealth Edison (ComEd) returned Quad Cities Nuclear Power Station Unit 2 to service following the Unit's fifteenth Refueling Outage. In the course of this outage, ComEd completed actions related to NRC commitments described in the references listed above. This letter provides a summary of those NRC commitments that were completed.


- 1) Installation of the Reactor Water Clean-Up (RWCU) High Temperature Isolation Modification for Unit 2, Reference 1. Since this modification was completed on Unit 1 during Q1R15, this completes the actions of Reference 1.
- 2) Installation of the Automatic Depressurization System inhibit switch, and installation of manual trip switches for the Reactor recirculation pumps on Unit 2. These actions address two of the identified Fire Protection Appendix R deficiencies, discussed in Reference 2.

March 23, 2000
U.S. Nuclear Regulatory Commission
Page 2

- 3) Installation of the Oscillation Power Range Monitor (OPRM) on Unit 2, described in Reference 3. The modification installed functional annunciators on the eight OPRM channels. This phase of installation did not add the oscillation trip to the Reactor Protection System.

Should you have any questions concerning this letter, please contact Mr. C.C. Peterson at (309) 654-2241, extension 3609.

Respectfully,



Joel P. Dimmette, Jr.
Site Vice President
Quad Cities Nuclear Power Station

cc: Regional Administrator – NRC Region III
NRC Senior Resident Inspector – Quad Cities Nuclear Power Station