



South Texas Project Electric Generating Station P.O. Box 289 Wadsworth, Texas 77483

March 27, 2000  
NOC-AE-00000784  
File No.: T1.01, T3.02  
10CFR50.55a

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555-0001

South Texas Project  
Units 1 and 2  
Docket Nos. STN 50-498 and STN 50-499  
Supplement 3 to Inservice Inspection Plan for First Inspection Interval

Attached are four copies of Supplement 3 to the South Texas Project Inservice Inspection (ISI) Plans for the current inspection interval. These supplements incorporate into the ISI plans additional ASME Section XI Code Cases which were either determined to be acceptable for use by the USNRC in Regulatory Guide 1.147, "Inservice Inspection Code Case Acceptability - ASME Section XI, Division 1", or approved by the Nuclear Regulatory Commission for use at the South Texas Project pursuant to our request.

If there are any questions, please contact either Mr. M. S. Lashley at (361) 972-7523 or me at (361) 972-7902.

A handwritten signature in black ink, appearing to read "T. J. Jordan".

T. J. Jordan  
Manager,  
Nuclear Engineering

PLW

Attachments: Inservice Inspection Plan for the First Inspection Interval of the South Texas Project Electric Generating Station - Unit 1; Revision 0, Supplement 3

Inservice Inspection Plan for the First Inspection Interval of the South Texas Project Electric Generating Station - Unit 2; Revision 0, Supplement 3

A047

cc:

Ellis W. Merschoff  
Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, Texas 76011-8064

John A. Nakoski  
Project Manager, Mail Code 0-4D3  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Cornelius F. O'Keefe  
c/o U. S. Nuclear Regulatory Commission  
P. O. Box 910  
Bay City, TX 77404-0910

A. H. Gutterman  
Morgan, Lewis & Bockius  
1800 M. Street, N.W.  
Washington, DC 20036-5869

M. T. Hardt/W. C. Gunst  
City Public Service  
P. O. Box 1771  
San Antonio, TX 78296

A. Ramirez/C. M. Canady  
City of Austin  
Electric Utility Department  
721 Barton Springs Road  
Austin, TX 78704

Jon C. Wood  
Matthews & Branscomb  
One Alamo Center  
106 S. St. Mary's Street, Suite 700  
San Antonio, TX 78205-3692

Institute of Nuclear Power  
Operations - Records Center  
700 Galleria Parkway  
Atlanta, GA 30339-5957


Richard A. Ratliff  
Bureau of Radiation Control  
Texas Department of Health  
1100 West 49th Street  
Austin, TX 78756-3189

D. G. Tees/R. L. Balcom  
Houston Lighting & Power Co.  
P. O. Box 1700  
Houston, TX 77251

Central Power and Light Company  
ATTN: G. E. Vaughn/C. A. Johnson  
P. O. Box 289, Mail Code: N5012  
Wadsworth, TX 77483

U. S. Nuclear Regulatory Commission\*  
Attention: Document Control Desk  
Washington, D.C. 20555-0001

\*The Document Control Desk receives four copies.



**INSERVICE INSPECTION PLAN  
FOR THE  
FIRST INSPECTION INTERVAL**

**of the**

**SOUTH TEXAS PROJECT  
ELECTRIC GENERATING STATION - UNIT 1  
REVISION 0, SUPPLEMENT 3**

Operator: STP Nuclear Operating Company

Address: P.O. Box 289  
Wadsworth, Texas 77483

Commercial  
Operation: August 25, 1988

Issue Date: January 5, 2000

**INSERVICE INSPECTION PLAN  
FOR THE  
FIRST INSPECTION INTERVAL**


**of the**


**SOUTH TEXAS PROJECT  
ELECTRIC GENERATING STATION - UNIT 1  
REVISION 0, SUPPLEMENT 3**

**USNRC DOCKET NO.: 50-498**

**OPERATING LICENSE NO.: NPF-76**

**COMMERCIAL OPERATION DATE: AUGUST 25, 1988**


Prepared by:  28 DEC 1999  
J. C. Younger  
ISI Engineer  
Date

Approved by:  1/4/00  
C. A. Murry  
Supervisor - Section XI Section  
Date

South Texas Project Electric Generating Station  
Unit 1  
Docket No. STN 50-498  
“Revision 0, Supplement 3, to ISI Plan for First Inspection Interval”

Supplement 3 to the ISI Plan for the First Inspection Interval adds the following Section XI Code Cases to Section 2.1.5 of the Plan:

- N-460           “Alternative Examination Coverage for Class 1 and Class 2 Welds, Section XI, Division 1”
  
- N-491-1       “Alternate Rules for Examination of Class 1, 2, 3, and MC Component Supports of Light-Water Cooled Power Plants, Section XI, Division 1”
  
- N-498           “Alternative Rules for 10-Year Hydrostatic Pressure Testing for Class 1 and 2 Systems, Section XI, Division 1”
  
- N-498-1       “Alternative Rules for 10-Year System Hydrostatic Testing for Class 1, 2, and 3 Systems, Section XI, Division 1”
  
- N-504           “Alternative Rules for Repair of Class 1, 2, and 3 Austenitic Stainless Steel Piping, Section XI, Division 1”
  
- N-522           “Pressure Testing of Containment Penetration Piping, Section XI, Division 1”



**INSERVICE INSPECTION PLAN  
FOR THE  
FIRST INSPECTION INTERVAL**

**of the**

**SOUTH TEXAS PROJECT  
ELECTRIC GENERATING STATION - UNIT 2  
REVISION 0, SUPPLEMENT 3**

Operator: STP Nuclear Operating Company

Address: P.O. Box 289  
Wadsworth, Texas 77483

Commercial  
Operation: June 19, 1989

Issue Date: January 5, 2000

**INSERVICE INSPECTION PLAN  
FOR THE  
FIRST INSPECTION INTERVAL**

of the


**SOUTH TEXAS PROJECT  
ELECTRIC GENERATING STATION - UNIT 2  
REVISION 0, SUPPLEMENT 3**

**USNRC DOCKET NO.: 50-499**

**OPERATING LICENSE NO.: NPF-80**

**COMMERCIAL OPERATION DATE: JUNE 19, 1989**

Prepared by:  28 DEC 1999  
J. C. Younger Date  
ISI Engineer

Approved by:  1/4/00  
C. A. Murry Date  
Supervisor - Section XI Section

South Texas Project Electric Generating Station  
Unit 2  
Docket No. STN 50-499  
“Revision 0, Supplement 3, to ISI Plan for First Inspection Interval”

Supplement 3 to the ISI Plan for the First Inspection Interval adds the following Section XI Code Cases to Section 2.1.5 of the Plan:

- N-460            “Alternative Examination Coverage for Class 1 and Class 2 Welds, Section XI, Division 1”
  
- N-491-1        “Alternate Rules for Examination of Class 1, 2, 3, and MC Component Supports of Light-Water Cooled Power Plants, Section XI, Division 1”
  
- N-498            “Alternative Rules for 10-Year Hydrostatic Pressure Testing for Class 1 and 2 Systems, Section XI, Division 1”
  
- N-498-1        “Alternative Rules for 10-Year System Hydrostatic Testing for Class 1, 2, and 3 Systems, Section XI, Division 1”
  
- N-504            “Alternative Rules for Repair of Class 1, 2, and 3 Austenitic Stainless Steel Piping, Section XI, Division 1”
  
- N-522            “Pressure Testing of Containment Penetration Piping, Section XI, Division 1”