



March 24, 2000

C0300-19  
10 CFR 50.4

Docket Nos: 50-315  
50-316

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Stop O-P1-17  
Washington, D.C. 20555

Donald C. Cook Nuclear Plant Units 1 and 2  
NOTIFICATION OF STORM WATER PERMIT NONCOMPLIANCE

Indiana Michigan Power Company is the holder of general Storm Water Permit MIS529000 for Donald C. Cook Nuclear Plant. Section 5.4.2 to Part II of Appendix B (Environmental Technical Specifications) to Facility Operating Licenses DPR-58 and DPR-74 requires reports of non-routine events that are reportable to state agencies to be submitted to the Nuclear Regulatory Commission (NRC).

In a letter dated March 24, 2000, the Michigan Department of Environmental Quality (MDEQ) was notified of an illicit connection to the plant's storm drain system. The notification of this noncompliance was provided to MDEQ per Part II, Section C.1 of the storm water permit. In accordance with the Environmental Technical Specifications, a copy of the report is hereby provided to the NRC.

Should you have any questions or concerns regarding this notification, please contact John P. Carlson, Environmental Superintendent, at (616) 465-5901, extension 1153.

Sincerely,

A handwritten signature in black ink, appearing to read 'R. C. Godley', followed by the text 'for R.C.G.'.

Robert C. Godley  
Regulatory Affairs Director

\dms

Attachment

C001

c: J. E. Dyer  
MDEQ - DW & RPD  
NRC Resident Inspector  
R. Whale

**ATTACHMENT TO C0300-19**

**Notification of Storm Water Permit Noncompliance  
to Michigan Department of Environmental Quality**

Indiana Michigan  
Power Company  
Cook Nuclear Plant  
One Cook Plant  
Bridgman, MI 49106  
616 465 5901



Ms. Jenny Molloy, Storm Water Section  
Surface Water Quality Division  
Michigan Department of Environmental Quality  
1342 SR89 West Suite B  
Plainwell, MI 49080

March 24, 2000

Dear Ms. Molloy:

Subject: Donald C. Cook Nuclear Plant  
Storm Water Permit MIS520011.

As required in our general Stormwater permit MIS529000 Part II, Section C.1, we are providing you with a notification of noncompliance. During a routine inspection of the stormwater system, we uncovered an illicit connection to the plant's North Stormwater Outfall (#001S). During a renovation at the plant's office complex, a coffee station and sink were installed. The drain from the sink was routed to a floor drain that drained directly to the storm drain system.

This sink was used mainly for coffee preparation and associated coffeepot washing operations. The use of the sink has been halted. The drain will either be rerouted to the sanitary system or disconnected permanently.

Plant modifications such as this must now go through a Design Change or Plant Modification process and an environmental review will be required to prevent similar occurrences like this in the future.

If you have any questions, please contact me at (616) 465-5901, ext. 1153.

Sincerely,

A handwritten signature in dark ink, appearing to read 'J. Carlson'.

John Carlson  
Environmental Superintendent

C: U.S. Nuclear Regulatory Commission per App. B T.S.

Control #2000-7

March 24, 2000  
Storm Water Permit MIS520011  
Ms. Jenny Molloy

I certify under penalty of law that I have personally examined and am familiar with the information submitted on this and all attached documents, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

A handwritten signature in dark ink, appearing to read 'A.C. Bakken III', followed by a circular stamp or mark.

A.C. Bakken III  
Site Vice President

Bc: A. C. Bakken III  
J. P. Carlson  
R. C. Godley  
C. E. Hawk  
T. J. O'Leary  
J. E. Pollock  
W. H. Schalk/T. Kratt  
S. C. Sterk  
B. K. Zordell  
MDEQ File  
NDM (Control #2000-7), Mail Zone 1