

General Information or Other (PAR)

Event # 36861

<b>Rep Org:</b> PPG ARCHITECTURAL FINISHES <b>Supplier:</b> PPG ARCHITECTURAL FINISHES	<b>Notification Date / Time:</b> 04/03/2000 13:20 (EDT) <b>Event Date / Time:</b> 04/03/2000 (EDT) <b>Last Modification:</b> 04/03/2000
<b>Region:</b> 1 <b>City:</b> PITTSBURG <b>County:</b> <b>State:</b> PA	<b>Docket #:</b> <b>Agreement State:</b> No <b>License #:</b>
<b>NRC Notified by:</b> JOSEPH KARAS <b>HQ Ops Officer:</b> FANGIE JONES <b>Emergency Class:</b> NON EMERGENCY <b>10 CFR Section:</b> 21.21                    UNSPECIFIED PARAGRAPH	<b>Notifications:</b> VERN HODGE (FAX)                    NRR

10 CFR PART 21 REPORT

"This notification is being made by PPG Architectural Finishes (PPG) concerning relatively small quantities of a silicon stainless steel enamel coating used inside primary containment supplied to a single utility which is a NRC nuclear power plant licensee. The coating was not appropriately controlled such that its formulation changed from that which was originally supplied. The utility has been informed and is working with PPG. Further investigation is being conducted which may result in the withdrawal or modification of this notification. Written notification in accordance with 10 C.F.R. § 21.2 1(d)(3)(ii) will follow."

\*\*\*\*\*

IE20



PPG Industries, Inc.  
One PPG Place  
Pittsburgh, PA 15272

April 3, 2000

---

To: Nuclear Regulatory Commission  
Company:  
Phone: 301/816-5100  
Fax: 301/816-5151

From: Joseph M. Karas  
Phone: 412-434-2415  
Fax: 412-434-4291

Total number of pages,  
including cover:

Message: See the attached initial notification being filed today for PPG Architectural Finishes, Inc.

If you experience difficulties in receiving this transmission,  
contact Mindy Shick at 412-434-2869.

*This transmittal is confidential and is intended only for the addressee. If you are not the addressee, any disclosure or use of this information by you is strictly prohibited. If you have received this facsimile in error, please notify us by telephone immediately.*



**PPG Industries, Inc.**  
One PPG Place Pittsburgh, Pennsylvania 15272 USA

Law Department  
Telecopy No.: (412) 434-4291  
Writer's Direct Dial No.: 412-434-2415

## PPG ARCHITECTURAL FINISHES

### **Initial Notification of a Possible Defect in Accordance with 10 C.F.R. § 21.21(d)(3)(i)**

This notification is being made by PPG Architectural Finishes ("PPG") concerning relatively small quantities of a silicon stainless steel enamel coating used inside primary containment supplied to a single utility which is a NRC nuclear power plant licensee. The coating was not appropriately controlled such that its formulation changed from that which was originally supplied. The utility has been informed and is working with PPG. Further investigation is being conducted which may result in the withdrawal or modification of this notification. Written notification in accordance with 10 C.F.R. § 21.21(d)(3)(ii) will follow.

Submitted by,

  
Name Joseph M. Karas  
Title Assistant Counsel  
Address One PPG Place  
Pittsburgh, PA 15272  
Telephone 412-434-2415  
E-mail [jkaras@ppg.com](mailto:jkaras@ppg.com)  
Date: April 3, 2000