

Entergy Operations, Inc. Waterloo Road P.O. Box 756 Port Gibson, MS 39150 Tel 601 437 6470

Jerry C. Roberts Director Nuclear Safety Assurance

March 30, 2000

U.S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, D.C. 20555

Subject: Grand Gulf Nuclear Station Unit 1 Docket No. 50-416 License No. NPF-29

GGNS Motor Operated Valve (MOV) Risk-Ranking Methodology

GNRO-2000/00022

Gentlemen:

On March 9, 2000, there was a conference call between Grand Gulf and NRC Staff to discuss the February 29, 2000, letter transmitted to the NRC regarding GGNS Motor Operated Valve Risk Ranking Methodology (GNRO-2000/00014). A request was made for GGNS to provide more information on Table 1, 'Comparison of GGNS to BWR E for BWROG Composite List of "High Risk" Ranked Valves'. Specifically, the request was to provide justification for the RCIC valve and RHR valve ranking differences noted between GGNS and the BWR E plant. The requested information is provided in revised Table 1 attached.

This letter contains no new commitments. If you have any questions, please contact Rita R. Jackson at (601) 437-2149.

Yours truly,

JCR/RRJ attachment:

CC:

Table 1. Comparison of GGNS to BWR E for BWROG Composite List of "High Risk" Ranked Valves (See Next Page) March 30, 2000 GNRO-2000/00022 Page 2 of 2

CC:

Ms. J. L. Dixon-Herrity, GGNS Senior Resident (w/a) Mr. D. E. Levanway (Wise Carter) Mr. L. J. Smith (Wise Carter) (w/a) Mr. N. S. Reynolds (w/a) Mr. H. L. Thomas (w/o)

Mr. E. W. Merschoff (w/a) Regional Administrator U.S. Nuclear Regulatory Commission Region IV 611 Ryan Plaza Drive, Suite 400 Arlington, TX 76011

Mr. S. P. Sekerak, NRR/DLPM/PD IV-I (W/2) U.S. Nuclear Regulatory Commission One White Flint North, Mail Stop 04-D3 11555 Rockville Pike Rockville, MD 20852-2378

BWROG Composite	Valve	GGNS	BWRE	COMMENTS
List of High Valves		Rank	Rank	
HPCI (HPCS) Injection	E22F004	Н	М	
Valve				
HPCI Steam Inlet Valve	N/A	N/A	N/A	1
HPCI (HPCS) Torus	E22F015	M	М	
(Suppression Pool) Suction		l		
HPCI Steam Line Isolation	N/A	N/A	N/A	
RCIC Injection	E51F013	M	М	
RCIC Steam Inlet	E51F045	M	М	
RCIC Torus (Suppression	E51F031	L	М	See Note 1 below.
Pool) Suction				
RCIC Lube Oil Cooling	E51F046	M	M	
RCIC Steam Line Isolation	E51F063,	L	L	
	E51F064			
RHR Suppression Pool	E12F004A/B	L	L	
Suction				
RHR Containment Spray	E12F028A/B	L	N/A	BWR E does not have
Valve				Containment Spray
RHR Suppression Pool	E12F024A/B	L	Н	Containment heat removal is
Cooling Return Valve				more important at BWR E
				because containment failure can
				lead to loss of injection. This
				failure mode is not as important
DUD C Test Return	E12E021	 т	 _	
DUD Uest Evchanger	DAIE014A/B			Sama commont og volvog
Service Water Supply	F41FVI4A/D	141	n	E12E02/A/B
RHR Shutdown Cooling	F12F006A/B		T T	E121024A/D
Suction from Vessel	LIZI WORD			
Containment Isolation -	P45F096.097			
Equipment Drains	P45F273.274			
LPCS Injection	E21F005	L	+ _{Τ.}	
LPCI (RHR) Injection	E12F042A/B/C		I.	
Service Water Pump	P41F001A/B		н Н	
Discharge			1.	
Service Water Train	P41F005A/B	Н		Corresponding valves could not
Discharge (Return to	P41F011			be identified.
Tower)				
Service Water Non-	P41F154,155A/B	L	L	
essential Load Isolation				
(SSW to IA Compressor)				
Service Water - DG Jacket	P41F018A/B	M		Corresponding valves could not
Cooler				be identified.
RBCCW Drywell	P42F114	L	L	
Supply/Return Isolation	P42F116			
	P42F117			

Table 1. Comparison of GGNS to BWR E for BWROG Composite List of "High Risk" Ranked Valves

Note 1. The RCIC SP suction has a lower importance than other RCIC motor operated valves because it is demanded after RCIC has operated for a period of time (approximately six to eight hours) with the condensate storage tank as its suction source. This time period allows for credit of recovery actions (i.e., recovery of offsite power or alignment of firewater as an injection source) which lowers the importance of this valve.