Template- NRR-106

Mr. W. R. McCollum, Jr. Vice President, Oconee Site Duke Energy Corporation 7800 Rochester Highway Seneca, SC 29672

## SUBJECT: OCONEE NUCLEAR STATION, UNITS 1, 2 AND 3 RE: FINAL ACCIDENT SEQUENCE PRECURSOR ANALYSIS OF OPERATIONAL CONDITION

Dear Mr. McCollum:

By letter dated March 10, 2000, the NRC staff supplied you a copy of the final Accident

Sequence Precursor analysis of the operational condition at the Oconee Nuclear Station,

Units 1, 2, and 3, that was reported in Licensee Event Report No. 269/98-004. This was

Enclosure 1 to the letter. Enclosure 2 contained our responses to your specific comments.

It has recently been determined that page 26 of Enclosure 1 and page 3 of Enclosure 2 were

inadvertently omitted from the letter. These pages are enclosed with this letter.

Sincerely,

/RA/

David E. LaBarge, Senior Project Manager, Section 1 Project Directorate II Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270, and 50-287

Enclosure: As stated

cc w/encl: See next page

Distribution: PUBLIC PD II-1 R/F (paper copy) RidsNrrDlpmLpdii-1 (REmch) RidsNrrLACHawes RidsNrrPMDLaBarge RidsOgcRp

RidsAcrsAcnwMailCenter RidsRegioniiMailCenter SMays PO'Reilly

DOCUMENT NAME: G:\PDII-1\OCONEE\ASP Rev.wpd

To receive a copy of this document, indicate in the box C=Copy w/o attachment/enclosure E=Copy with attachment/enclosure N = No copy

OFFICE	PDII-1/PM	PDII-1/LA	PDII-1/SC
NAME	DLaBarge:cn	CHawes	REmch
DATE	417100	417 100	417100

OFFICIAL RECORD COPY



## UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

April 11, 2000

Mr. W. R. McCollum, Jr. Vice President, Oconee Site Duke Energy Corporation 7800 Rochester Highway Seneca, SC 29672

## SUBJECT: OCONEE NUCLEAR STATION, UNITS 1, 2 AND 3 RE: FINAL ACCIDENT SEQUENCE PRECURSOR ANALYSIS OF OPERATIONAL CONDITION

Dear Mr. McCollum:

By letter dated March 10, 2000, the NRC staff supplied you a copy of the final Accident

Sequence Precursor analysis of the operational condition at the Oconee Nuclear Station,

Units 1, 2, and 3, that was reported in Licensee Event Report No. 269/98-004. This was

Enclosure 1 to the letter. Enclosure 2 contained our responses to your specific comments.

It has recently been determined that page 26 of Enclosure 1 and page 3 of Enclosure 2 were

inadvertently omitted from the letter. These pages are enclosed with this letter.

Sincerely,

David E. LaBarge, Senior Project Manager, Section 1 Project Directorate II Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270, and 50-287

Enclosure: As stated

cc w/encl: See next page

## **Oconee Nuclear Station**

cc:

Ms. Lisa F. Vaughn Legal Department (PBO5E) Duke Energy Corporation 422 South Church Street Charlotte, North Carolina 28201-1006

Anne W. Cottingham, Esquire Winston and Strawn 1400 L Street, NW Washington, DC 20005

Mr. Rick N. Edwards Framatome Technologies Suite 525 1700 Rockville Pike Rockville, Maryland 20852-1631

Manager, LIS NUS Corporation 2650 McCormick Drive, 3rd Floor Clearwater, Florida 34619-1035

Senior Resident Inspector U. S. Nuclear Regulatory Commission 7812B Rochester Highway Seneca, South Carolina 29672

Virgil R. Autry, Director Division of Radioactive Waste Management Bureau of Land and Waste Management Department of Health and Environmental Control 2600 Bull Street Columbia, South Carolina 29201-1708 Mr. L. E. Nicholson Compliance Manager Duke Energy Corporation Oconee Nuclear Site 7800 Rochester Highway Seneca, South Carolina 29672

Ms. Karen E. Long Assistant Attorney General North Carolina Department of Justice P. O. Box 629 Raleigh, North Carolina 27602

Mr. C. Jeffrey Thomas Manager - Nuclear Regulatory Licensing Duke Energy Corporation 526 South Church Street Charlotte, North Carolina 28201-1006

Mr. Richard M. Fry, Director Division of Radiation Protection North Carolina Department of Environment, Health, and Natural Resources 3825 Barrett Drive Raleigh, North Carolina 27609-7721

Mr. Steven P. Shaver Senior Sales Engineer Westinghouse Electric Company 5929 Carnegie Blvd. Suite 500 Charlotte, North Carolina 28209

Event tree name	Sequence number	Logic
MLOCA + RECIRC	2-4	/RT, /HPI, /RBES-OK, CLBREAK, NO-DELAY, /DEPRESS, LPR-REC
MLOCA + RECIRC	2-5	/RT, /HPI, /RBES-OK, CLBREAK, NO-DELAY, DEPRESS
MLOCA + RECIRC	2-9	/RT, /HPI, RBES-OK, /CLBREAK, RBES-MIN, OPS-MIN, /DEPRESS, LPR-REC
MLOCA + RECIRC	2-10	/RT, /HPI, RBES-OK, /CLBREAK, RBES-MIN, OPS-MIN, DEPRESS
MLOCA + RECIRC	2-14	/RT, /HPI, RBES-OK, CLBREAK, RBES-MIN, OPS-MIN, /DEPRESS, LPR-REC
MLOCA + RECIRC 2-15		/RT, /HPI, RBES-OK, CLBREAK, RBES-MIN, OPS-MIN, DEPRESS

Table 11. Sequence Logic for MLOCA Sequences for LER No. 361/98-003

- 1. For the medium-break LOCAs, ~90 min is required to deplete the BWST inventory. The time to significant core heatup following the loss of injection should be longer than for the large LOCA case discussed previously. The time available for evaluation is sufficient to establish a reasonable understanding of the nature of the events.
- 2. The TSC is expected to be available prior the loss of injection. Because the TSC will be in place during the important stages of the event, their evaluation is more likely to be rapid and correct. The availability of the TSC is expected to aid the control room in determining the appropriate action.
- 3. Considerations of break size and location that are not the most limiting would also contribute to a higher likelihood of success.

The availability of the TSC to monitor the accident and assist in the diagnosis and decision making is expected to provide reasonable reliability in arriving at an appropriate course of action. Success under these conditions is likely, and a nonrecovery probability of 0.1 is judged to be a more appropriate value. The medium-break LOCA situation is judged to be similar to the small-break LOCA situation because of the TSC availability.

**Response 1b:** The availability of the TSC by the time that sump switchover is required following a mediumbreak LOCA is acknowledged, at least for day-time working hours. This availability would impact branch OPS-MIN as well as LPR-REC. Since LPR-REC is only demanded if the operators fail to effect transfer to the sump before the ECCS pumps fail, the TSC, if available, will have also failed to understand the event before pump failure. Considering the limited time available to recover recirculation (15 min based on the Oconee PRA description of LLP0P3CREC), the burden imposed by the unusual nature of the failure, and the expected difficulty in analyzing the nature of the failure,<sup>a</sup> a nonrecovery probability of 0.5 for LPR-REC (conditional on the failure of OPS-MIN) is considered appropriate and has been retained in the analysis. The intent was not to use 0.5 because there was complete uncertainty as to the recovery potential in a Bayesian sense, but to instead use the value because it was a reasonable estimate of the conditional probability that LPR would not be recovered, given that OPS-MIN had already failed.

The medium-break LOCA CCDPs, accounting for the unavailability of the TSC, are  $9.8 \times 10^{-7}$  for Units 1 and 2 and  $8.5 \times 10^{-7}$  for Unit 3; the overall CCDP for the event is  $1.7 \times 10^{-6}$ 

<sup>&</sup>lt;sup>a</sup>See, for example, the analysis of LER No. 287/97-003 in the 1997 annual precursor report (*Precursors to Potential Severe Core Damage Accidents: 1997, A Status Report*, NUREG/CR-4674, Vol. 26, November 1998). In this event, two Oconee 3 HPI pumps were damaged during a reactor shutdown as a result of a low water level in the letdown storage tank. Over a 15-min time period following observation of low HPI pump discharge pressure, the operators started and stopped the two pumps and operated associated valves in an attempt to recover HPI pump discharge pressure before recognizing the potential cause of the problem and securing the pumps.