

James A. FitzPatrick
Nuclear Power Plant
268 Lake Road
P.O. Box 41
Lycoming, New York 13093
315-342-3840



Michael J. Colomb
Site Executive Officer

April 7, 2000
JAFP-00-0085

U. S. Nuclear Regulatory Commission
Mail Station P1-137
Washington, D. C. 20555

ATTENTION: Document Control Desk

SUBJECT: OPERATING STATUS REPORT

Reference: Docket No. 50-333

Dear Sir:

Enclosed is the Operating Status Report for the James A. FitzPatrick Nuclear Power Plant for the month of March, 2000.

If there are any questions concerning this report, please contact Saleh Alafifi, Reactor Engineer, at (315)349-6309.

A handwritten signature in black ink, appearing to read 'Michael J. Colomb', with a long horizontal stroke extending to the right.

MICHAEL J. COLOMB

MJC:GC:SA:mac
Enclosure

cc: JAF Department Heads
New York Office
White Plains Office
JTS JAFP File
RMS (JAF)
RMS (WPO)

JE24

**NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
OPERATING DATA REPORT**

REPORT MONTH: MARCH 2000

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	April 4, 2000
Completed By:	Saleh Alafifi
Telephone:	(315)349-6309

OPERATING STATUS

1. Unit name: FitzPatrick
2. Reporting period: 03/01/2000 – 03/31/2000
3. Licensed thermal power (MWT): 2536
4. Nameplate rating (gross MWE): 883.0
5. Design electrical rating (net MWE): 816
6. Maximum dependable capacity (gross MWE): 839
7. Maximum dependable capacity (net MWE): 813
8. If changes occur in capacity ratings (Items 3-7) since last report, give reasons:
9. Power level to which restricted, if any (net MWE):
10. Reasons for restrictions, if any:

NO.	DATA REQUESTED	THIS MONTH	YR-TO-DATE	CUMULATIVE
11	Hours in reporting period:	744.00	2184.00	216337.00
12	Number of hours reactor was critical:	744.00	2184.00	158911.40
13	Reactor reserve shutdown hours:	0.00	0.00	0.00
14	Hours generator on-line:	744.00	2184.00	153951.13
15	Unit reserve shutdown hours:	0.00	0.00	0.00
16	Gross thermal energy generated (MWH):	1884922.80	5373666.72	347189395.52
17	Gross electrical energy generated (MWH):	646200.00	1839840.00	117359990.00
18	Net electrical energy generated (MWH):	625115.00	1778370.00	113007865.00
19	Unit service factor:	100.00	100.00	71.16
20	Unit availability factor:	100.00	100.00	71.16
21	Unit capacity factor (using MDC net):	103.35	100.16	72.76
22	Unit capacity factor (using DER net)	102.97	99.79	64.02
23	Unit forced outage rate:	0.00	0.00	11.35

24. Shutdowns scheduled over next 6 months (type, date, and duration of each): _____
25. If shutdown at end of report period, estimated date of startup: _____
26. Units in test status (prior to commercial operation):

<u>FORECAST</u>	<u>ACHIEVED</u>
Initial Criticality:	
Initial Electricity:	
Commercial Operation:	

**NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
OPERATING DATA REPORT**

REPORT MONTH: MARCH, 2000

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	April 4, 2000
Completed By:	Saleh Alafifi
Telephone:	(315)349-6309

DAY	NET AVERAGE DAILY POWER LEVEL	DAY	NET AVERAGE DAILY POWER LEVEL
1	840	17	841
2	841	18	841
3	840	19	833
4	841	20	840
5	841	21	841
6	840	22	841
7	841	23	839
8	840	24	841
9	841	25	840
10	840	26	840
11	840	27	840
12	841	28	840
13	841	29	840
14	841	30	840
15	841	31	840
16	841		

REPORT MONTH: MARCH 2000

Docket No.: 50-333 Unit Name: FitzPatrick Date: April 4, 2000 Completed By: Saleh Alafifi Telephone: (315)349-6309
--

NO.	DATE	TYPE	DURATION HOURS	REASON	METHOD OF SHUTTING DOWN THE REACTOR	LICENSEE EVENT REPORT NO.	SYSTEM CODE	COMPONENT CODE	CAUSE and CORRECTIVE ACTION TO PREVENT RECURRENCE

F: FORCED
S: SCHEDULED

REASON:

- A. Equipment failure (explain)
- B. Maintenance or Test
- C. Refueling
- D. Regulatory Restriction
- E. Operator training and license examination
- F. Administrative
- G. Operational error (explain)
- H. Other (explain)

METHOD:

- 1. Manual
- 2. Manual Scram
- 3. Automatic Scram
- 4. Continued
- 5. Reduced load
- 9. Other

EXHIBIT G: Instructions for preparation of data entry sheets for Licensee Event Report (LER) file (NUREG-0161)

REPORT MONTH: MARCH 2000

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	April 4, 2000
Completed By:	Saleh Alafifi
Telephone:	(315)349-6309

The FitzPatrick Plant operated at or near rated power for the entire month.