### Attachment 2

## PRAIRIE ISLAND NUCLEAR GENERATING PLANT

### WCAP-14637 Revision 3

## Prairie Island Unit 2 Heatup and Cooldown Limit Curves Normal Operation

WCAP-14637, Revision 3

# PRAIRIE **ISLAND UNIT** 2 **HEATUP AND COOLDOWN** LIMIT **CURVES**  FOR NORMAL OPERATION

T. **J.** Laubham

December 1999

Prepared by Westinghouse Electric Company for Northern States Power Company

Approved:

C. H. Boyd, Manager Engineering & Materials Technology

Approved:

**D.** M. Trombola, Manager Mechanical Systems Integration

WESTINGHOUSE ELECTRIC COMPANY LLC Nuclear Service Division P.O. Box 355 Pittsburgh, Pennsylvania 15230-0355

© 1999 Westinghouse Electric Company All Rights Reserved

### PREFACE

ì

The following revisions have been made to this report:

#### Revision 3:

This revision was completed to change the initial RT<sub>NDT</sub> of the Intermediate Shell Forging and Lower Shell Forging to *14oF* and -4oF respectively. This change is a result of a customer request. Only Page 13 is affected by this updated information.

Revision 2:

- Added Executive Summary.
- Revised Table 1 and added new Table 2 to include upper shell Cu and Ni content data.
- Renumbered Tables 2 through 9 to be 3 through 10.
- Revised Tables 3, 4, 5, 7 and 8 to include upper shell and update other material data and fluences, and revise calculations.
- **-** Revised margin discussion in Section 4 to include provisions for surveillance capsule data which is not credible.
- **-** Revised Figure 1 and 2 and Tables 9 and 10 to include new heatup and cooldown curves and data listing.

Revision 1:

- Revised Tables 4, 6 and 7 per updated fluences given in reference 5.
- Added Table 9.
- Deleted Executive Summary.

Verified By: Ed Territi

E. Terek

# **EXECUTIVE** SUMMARY

The pressure-temperature limit curves for the Prairie Island Unit 2 plant heatup and cooldown were calculated using the adjusted  $RT_{NOT}$  (reference nil-ductility transition temperature) corresponding to the limiting beitline region material in the core region of the reactor vessel. The upper shell forging and the upper to intermediate shell weld seam were considered beltline materials along with the intermediate and lower shell forgings and the intermediate to lower shell weld seam because the upper shell extends below the top of the core.

The RT<sub>NDT</sub> values for the materials were adjusted for the effects of exposure to fastneutron radiation in accordance with NRC Regulatory Guide 1.99, Revision 2. The results of the Prairie Island Unit 2 Surveillance Capsule P analysis were included in the calculation of the Adjusted Reference Temperature (ART) values (initial  $RT_{NOT} + RT_{NDT}$ shift due to neutron exposure) at the 1/4T and 3/4T locations. The most limiting ART values were used in the generation of heatup and cooldown pressure-temperature limit curves at 35 EFPY (EOL). The upper to intermediate shell weld seam was found to be the limiting beltline material. See Figures 1 and 2 of this report for the curves which were generated.

Prairie Island Unit 2 Heatup and Cooldown Limit Curves for Normal Operation

# TABLE OF CONTENTS

ă.



# **LIST** OF **TABLES**

 $\frac{1}{2}$ 

 $\bar{\bar{z}}$ 



iv

# **LIST** OF **FIGURES**

J



Figure 2 Prairie Island Unit 2 Reactor Coolant System Cooldown Limitations (Cooldown Rates up to 100°F/hr) Applicable for the First 35 EFPY (Without Margins for Instrumentation Errors)\* **.....................................** 17

Includes Vessel flange requirements of 98 °F and 621 psig per 10CFR50, Appendix G.

**V**

1

#### 1 **INTRODUCTION**

Heatup and cooldown limit curves are calculated using the adjusted  $RT_{NDT}$  (reference nil-ductility temperature) corresponding to the limiting beltline region material of the reactor vessel. The adjusted RT<sub>NDT</sub> of the limiting material in the core region of the reactor vessel is determined by using the unirradiated reactor vessel material fracture toughness properties, estimating the radiation-induced  $\Delta RT_{NOT}$ , and adding a margin. The unirradiated  $RT_{NOT}$  is designated as the higher of either the drop weight nil-ductility transition temperature (NDTT) or the temperature at which the material exhibits at least 50 ft-lb of impact energy and 35-mil lateral expansion (normal to the major working direction) minus 60°F.

RT<sub>NDT</sub> increases as the material is exposed to fast-neutron radiation. Therefore, to find the most limiting  $RT_{NOT}$  at any time period in the reactor's life,  $\triangle RT_{NOT}$  due to the radiation exposure associated with that time period must be added to the unirradiated RT<sub>NDT</sub> (IRT<sub>NDT</sub>) The extent of the shift in RT<sub>NDT</sub> is enhanced by certain chemical elements (such as copper and nickel) present in reactor vessel steels. The Nuclear Regulatory Commission (NRC) has published a method for predicting radiation embrittlement in Regulatory Guide 1.99, Revision 2, "Radiation Embrittlement of Reactor Vessel Materials"<sup>(1]</sup>. Regulatory Guide 1.99, Revision 2, is used for the calculation of Adjusted Reference Temperature (ART) values (IRT<sub>NDT</sub> +  $\Delta RT_{NOT}$  + margins for uncertainties) at the 1/4T and 3/4T locations, where T is the thickness of the vessel at the beltline region measured from the clad/base metal interface. The most limiting ART values are used in the generation of the heatup and cooldown pressure-temperature limit curves.

# 2 FRACTURE **TOUGHNESS** PROPERTIES

The fracture-toughness properties of the ferritic material in the reactor coolant pressure boundary are determined in accordance with the NRC Standard Review Plan<sup>[2]</sup>. The beltline material copper and nickel content values for the Prairie Island Unit 2 reactor vessel presented in Tables 1 and 2 are from References 3 through 7 and 12 through 17.

The average Cu and Ni values were used to calculate chemistry factor (CF) values per Tables 1 and 2 of Regulatory Guide 1.99, Revision 2. (See Table 3.) Additionally, surveillance capsule data is available for four capsules (Capsules V, T, R, and P) already removed from the Prairie Island Unit 2 reactor vessel. This surveillance capsule data was used to calculate chemistry factor (CF) values (Table 4) in addition to those calculated per Tables 1 and 2 of Regulatory Guide 1.99, Revision 2.



#### **NOTES:**

(a) Surveillance program base metal material.

**(b)** The upper shell forging is being included here since it is **6.833** inches below the top of the active fuel stack.



NOTES:

- (a) The Surveillance Program weld metal is identical to the intermediate to lower shell girth weld seam W3 and was fabricated with Weld Wire Type UM40, Heat No. 2721, Flux Type UM89, Lot No. 1263.
- (b) Weld seam W2 is being included here, since it is 6.833 inches below the top of the active fuel stack. Weld seam W2 was fabricated with Weld Wire Type UM40, Heat No. 1752, FluxType UM89, Lot No. 1263.
- (c) These values are the average of all data points from the Prairie Island Unit 2 surveillance weld which was fabricated with the same heat of weld wire.
- (d) These values are the average of all data points from Reference 18 for the Prairie Island Unit 1 surveillance weld which was fabricated with the same heat of weld wire.



 $\bar{\phantom{a}}$ 

Prairie Island Unit 2 Heatup and Cooldown Limit Curves for Normal Operation



### NOTES:

- $\overline{(a)}$  f = fluence  $(10^{19} \text{ n/cm}^2, E > 1.0 \text{ MeV})$ . All updated fluence values were taken from the Capsule P analysis. WCAP-14613<sup>[5]</sup>.
- (b)  $FF =$  fluence factor = f  $^{(0.28 0.17) \text{og }0}$
- (c) The  $\Delta RT_{NOT}$  values are measured values obtained from the Capsule P analysis<sup>[5]</sup>
- (d) The measured  $\Delta RT_{NDT}$  values obtained from the Capsule P analysis<sup>(5)</sup> were multiplied by a ratio factor of 1.15.  $(CF_{Vessel} \div CF_{SCWeld} = 51.6 \div 44.8 = 1.15)$ .

# **3** CRITERIA FOR ALLOWABLE PRESSURE-TEMPERATURE **RELATIONSHIPS**

Appendix G to 10 CFR Part 50, "Fracture Toughness Requirements"<sup>[8]</sup> specifies fracture toughness requirements for ferritic materials of pressure-retaining components of the reactor coolant pressure boundary of light water nuclear power reactors to provide adequate margins of safety during any condition of normal operation, including anticipated operational occurrences and system hydrostatic tests, to which the pressure boundary may be subjected over its service lifetime. The ASME Boiler and Pressure Vessel Code forms the basis for these requirements. Section Xl, Division 1, "Rules for Inservice Inspection of Nuclear Power Plant Components"<sup>[9]</sup>. Vessels, contains the conservative methods of analysis.

The ASME approach for calculating the allowable limit curves for various heatup and cooldown rates specifies that the total stress intensity factor,  $K<sub>1</sub>$ , for the combined thermal and pressure stresses at any time during heatup or cooldown cannot be greater than the reference stress intensity factor,  $K_{la}$ , for the metal temperature at that time.  $K_{la}$  is obtained from the reference fracture toughness curve, defined in Appendix G of the ASME Code, Section XI. The K<sub>la</sub> curve is given by the following equation:

$$
K_{Ia} = 26.78 + 1.223 * e^{(0.0145(T - RT_{NOT} + 160))}
$$
 (1)

where,

 $K<sub>1a</sub>$  = reference stress intensity factor as a function of the metal temperature T and the metal reference nil-ductility temperature  $RT<sub>NOT</sub>$ 

Therefore, the governing equation for the heatup-cooldown analysis is defined in Appendix G of the ASME Code as follows:

$$
C*K_{\text{im}}+K_{lt} < K_{l\sigma} \tag{2}
$$

where,



At any time during the heatup or cooldown transient, K<sub>a</sub> is determined by the metal temperature at the tip of a postulated flaw at the 1/4T and 3/4T location, the appropriate value for  $RT_{NOT}$ , and the reference fracture toughness curve. The thermal stresses resulting from the temperature gradients through the vessel wall are calculated and then the corresponding (thermal) stress intensity factors,  $K_{tt}$ , for the reference flaw are computed. From Equation 2, the pressure stress intensity factors are obtained and, from these, the allowable pressures are calculated.

For the calculation of the allowable pressure versus coolant temperature during cooldown, the reference flaw of Appendix G to the ASME Code is assumed to exist at the inside of the vessel wall. During cooldown, the controlling location of the flaw is always at the inside of the wall because the thermal gradients produce tensile stresses at the inside, which increase with increasing cooldown rates. Allowable pressure-temperature relations are generated for both steady-state and finite cooldown rate situations. From these relations, composite limit curves are constructed for each cooldown rate of interest.

The use of the composite curve in the cooldown analysis is necessary because control of the cooldown procedure is based on the measurement of reactor coolant temperature, whereas the limiting pressure is actually dependent on the material temperature at the tip of the assumed flaw. During cooldown, the 1/4T vessel location is at a higher temperature than the fluid adjacent to the vessel inner diameter. This condition, of course, is not true for the steady-state situation. It follows that, at any given reactor coolant temperature, the  $\Delta T$  (temperature) developed during cooldown results in a higher value of  $K_{\rm Ia}$  at the 1/4T location for finite cooldown rates than for steady-state operation. Furthermore, if conditions exist so that the increase in  $K_{la}$  exceeds  $K_{ht}$ , the calculated allowable pressure during cooldown will be greater than the steady-state value.

The above procedures are needed because there is no direct control on temperature at the 114T location and, therefore, allowable pressures may unknowingly be violated if the rate of cooling is decreased at various intervals along a cooldown ramp. The use of the composite curve eliminates this problem and ensures conservative operation of the system for the entire cooldown period.

Three separate calculations are required to determine the limit curves for finite heatup rates. As is done in the cooldown analysis, allowable pressure-temperature relationships are developed for steady-state conditions as well as finite heatup rate conditions assuming the presence of a 1/4T defect at the inside of the wall. The heatup results in compressive stresses at the inside surface that alleviate the tensile stresses produced by internal pressure. The metal temperature at the crack tip lags the coolant temperature; therefore, the  $K_{\text{la}}$  for the 1/4T crack during heatup is lower than the  $K_{la}$  for the 1/4T crack during steady-state conditions at the same coolant temperature. During heatup, especially at the end of the transient, conditions may exist so that

the effects of compressive thermal stresses and lower K<sub>ia</sub> values do not offset each other, and the pressure-temperature curve based on steady-state conditions no longer represents a lower bound of all similar curves for finite heatup rates when the 1/4T flaw is considered. Therefore, both cases have to be analyzed in order to ensure that at any coolant temperature the lower value of the allowable pressure calculated for steady-state and finite heatup rates is obtained.

The second portion of the heatup analysis concerns the calculation of the pressure- temperature limitations for the case in which a 114T flaw located at the 1/4T location from the outside surface is assumed. Unlike the situation at the vessel inside surface, the thermal gradients established at the outside surface during heatup produce stresses which are tensile in nature and therefore tend to reinforce any pressure stresses present. These thermal stresses are dependent on both the rate of heatup and the time (or coolant temperature) along the heatup ramp. Since the thermal stresses at the outside are tensile and increase with increasing heatup rates, each heatup rate must be analyzed on an individual basis.

Following the generation of pressure-temperature curves for both the steady state and finite heatup rate situations, the final limit curves are produced by constructing a composite curve based on a point-by-point comparison of the steady-state and finite heatup rate data. At any given temperature, the allowable pressure is taken to be the lesser of the three values taken from the curves under consideration. The use of the composite curve is necessary to set conservative heatup limitations because it is possible for conditions to exist wherein, over the course of the heatup ramp, the controlling condition switches from the inside to the outside, and the pressure limit must at all times be based on analysis of the most critical criterion.

10 CFR Part 50, Appendix G addresses the metal temperature of the closure head flange and vessel flange regions. This rule states that the metal temperature of the closure flange regions must exceed the material unirradiated  $RT_{NOT}$  by at least 120°F for normal operation when the pressure exceeds 20 percent of the preservice hydrostatic test pressure (3106 psig), which is 621 psig for Prairie Island Unit 2.

The limiting unirradiated RT<sub>NDT</sub> of -22°F occurs in the vessel flange of the Prairie Island Unit 2 reactor vessel, so the minimum allowable temperature of this region is 98°F at pressures greater than 621 psig. This limit (where the horizontal line indicates that the pressure shall not exceed 621 psig for temperatures less than 98°F) is shown as a notch in the curves, presented wherever applicable in Figures 1 and 2.

### 4 **CALCULATION OF ADJUSTED** REFERENCE TEMPERATURE

From Regulatory Guide **1.99,** Revision 2, the adjusted reference temperature (ART) for each material in the beltline region is given by the following expression:

$$
ART = Initial RTNOT + \Delta RTNDT + Margin
$$
\n(3)

Initial RT<sub>NDT</sub> is the reference temperature for the unirradiated material as defined in paragraph NB-2331 of Section III of the ASME Boiler and Pressure Vessel Code<sup>rol</sup>. If measured values of initial RT<sub>NDT</sub> for the material in question are not available, generic mean values for that class of material may be used if there are sufficient test results to establish a mean and standard deviation for the class.

 $\Delta RT_{NOT}$  is the mean value of the adjustment in reference temperature caused by irradiation and should be calculated as follows:

$$
\Delta RT_{NDT} = CF * f^{(0.28-0.10 \log \beta)} \tag{4}
$$

To calculate  $\Delta RT_{NOT}$  at any depth (e.g., at 1/4T or 3/4T), the following formula must first be used to attenuate the fluence at the specific depth.

$$
f_{\text{(depthx)}} = f_{\text{surface}} * e^{(-0.24x)} \tag{5}
$$

where x inches (vessel beltline thickness is 6.692 inches) is the depth into the vessel wall measured from the vessel clad/base metal interface. The resultant fluence is then placed in Equation 4 to calculate the  $\Delta RT_{NOT}$  at the specific depth. The fluence (E > 1.0 MeV) values on the pressure vessel clad/base metal interface for the Prairie Island Unit 2 reactor vessel are presented in Table 5.



The chemistry factor values obtained from Tables 1 and 2 of Regulatory Guide 1.99, Revision 2, were determined in Table 3 using the copper and nickel content values reported in Tables 1 and 2 of this report. Chemistry factors were also calculated using surveillance capsule data as shown in Table 4.

Margin is calculated as, M =  $2\sqrt{\sigma_i^2 + {\sigma_A}^2}$ . The standard deviation for the initial RT<sub>NDT</sub> margin term,  $\sigma_{i_1}$  is 0°F when the initial RT<sub>NDT</sub> is a measured value, and 17°F when a generic value is available. The standard deviation for the  $\Delta RT_{NDT}$  margin term,  $\sigma_{\Delta}$ , is 17°F for plates or forgings, and 8.5°F for plates or forgings (half the value) when credible surveillance data is used. For welds,  $\sigma_{\Delta}$  is equal to 28°F when surveillance capsule data is not used, and is 14°F (half the value) when credible surveillance capsule data is used.  $\sigma_{\Delta}$  need not exceed one-half the mean value of  $\Delta RT_{NDT}$ . See Table 6. In the case of Prairie Island Unit No. 2, the surveillance capsule forging material data is deemed to be not credible in accordance with the Regulatory Guide 1.99, Revision 2<sup>[5]</sup> credibility criteria. Since data points for all of the calculated  $\triangle RT_{NDT}$  values do not fall within the prescribed margins for the surveillance capsule data, NSP has chosen to use the full  $\sigma_{\Delta}$  margin of 17°F for forgings. In the case of the Prairie Island Unit No. 1 surveillance capsule weld material, which is used to evaluate Unit No. 2 upper to intermediate shell weld seam W2, the data is also deemed not credible in accordance with the Regulatory Guide 1.99, Revision 2 credibility criteria<sup>[18]</sup>, and the full  $\sigma_{\Delta}$  margin of 28°F for welds is used. The Prairie Island Unit 2 surveillance weld data is credible<sup>[5]</sup>. Hence, for the intermediate to lower shell weld seam W3, a  $\sigma_{\Delta}$  margin of 14°F was used.



#### NOTES:

**-Amookow-**

(a) The Prairie Island Unit No. 2 surveillance capsule forging data is not credible. Therefore, a full  $\sigma_\Delta$  of 17°F for forgings in used in the margin term providing a total margin of 34°F.

(b) The Prairie Island Unit No. 1 surveillance capsule weld data is not credible. Therefore, a full  $\sigma_{\Delta}$  of 28°F for welds is used in the margin term for upper to intermediate shell weld seam W2 providing a total margin of 56°F. The Prairie Island Unit No. 2 surveillance capsule weld data is credible. Therefore, a  $\frac{1}{2}$  o<sub> $\Delta$ </sub> is used for weld seam W3.

All materials in the beltline region of the Prairie Island Unit 2 reactor vessel were considered in determining the limiting material. Sample calculations to determine the ART values for weld seam W2 are shown in Table 7. The resulting ART values for all beltline materials at the 114T and 3/4T locations are summarized in Table 8. From Table 8, it can be seen that the limiting material is Upper to Intermediate Shell Weld Seam W2. Therefore, the 1/4T and 3/4T ART values for Weld Seam W2 will be used in the generation of the heatup and cooldown curves.



#### <u>NOTES:</u>

(a) Fluence, f, is based upon  $f_{\text{surf}}$  (10<sup>19</sup> n/cm<sup>2</sup>, E>1.0 MeV) = 2.379 at 35 EFPY.

(b) The Prairie Island Unit 2 reactor vessel wall thickness is 6.692 inches at the beltline region.



NOTE:

(a) Fluence values are x 10<sup>19</sup> n/cm<sup>2</sup> (E > 1.0 MeV). In addition, the values used are the Best-Estimate values since thay are higher than the calculated values.

(b) This calculation is using the chemistry factor based on the surveillance capsule data from the Prairie Island Unit 1 surveillance program. Per WCAP-14779 Rev. 1, the surveillance weld data is not credible, therefore, a full  $\sigma_{\Delta}$  of 28°F was used in the margin term.

(c) When two or more credible surveillance data sets become available, the data sets may be used to determine ART values as described in Reg. Guide 1.99, Rev. 2, Pos.2.1. If the ART values based on surveillance capsule data are larger than those calculated per Reg. Guide 1.99, Rev. 2, Pos. 1.1, the surveillance data must be used. If the surveillance capsule data gives lower values, either may be used. In the case of Prairie Island Unit 2, where the surveillance data for the forging material is not credible, and the Unit 1 surveillance weld data used to evaluate the upper to intermediate shell weld seam is not credible, the ART values based on the surveillance capsule data with the full margins included are larger. Therefore, the ART values based on the surveillance capsule data were used.)

13

Prairie Island Unit 2 Heatup and Cooldown Limit Curves for Normal Operation

# **5 HEATUP AND COOLDOWN** PRESSURE-TEMPERATURE LIMIT **CURVES**

Pressure-temperature limit curves for normal heatup and cooldown of the primary reactor coolant system have been calculated for the pressure and temperature in the reactor vessel beitline region using the methods<sup>[11]</sup> discussed in Section 3 and 4 of this report. Since indication of reactor vessel beltline pressure is not available directly to the operator, the pressure difference between the wide-range pressure transmitter and the limiting beltline region must be accounted for when using the pressure-temperature limits presented in Figures **1** and 2.

Figure 1 presents the heatup curves without margins for possible instrumentation errors using heatup rates up to 100°F/hr applicable for the first 35 EFPY. Figure 2 presents the cooldown curves without margins for possible instrumentation errors using cooldown rates up to 100°F/hr applicable for 35 EFPY. Allowable combinations of temperature and pressure for specific temperature change rates are below and to the right of the limit lines shown in Figures 1 and 2. This is in addition to other criteria which must be met before the reactor is made critical, as discussed below in the following paragraphs.

The reactor must not be made critical until pressure-temperature combinations are to the right of the criticality limit line shown in Figure 1. The straight-line portion of the criticality limit is at the minimum permissible temperature for the 2485 psig inservice hydrostatic test as required by Appendix G to 10 CFR Part 50. The governing equation for the hydrostatic test is defined in Appendix G to Section XI of the ASME Code as follows:

$$
1.5 K_{lm} < K_{la} \tag{6}
$$

where,

 $K_{lm}$  is the stress intensity factor covered by membrane (pressure) stress, *a=* 26.78 **+** 1.223 e [0.0145 (T-RTNDT+ **160)l** 

T is the minimum permissible metal temperature, and

RT<sub>NDT</sub> is the metal reference nil-ductility temperature.

The criticality limit curve specifies pressure-temperature limits for core operation to provide additional margin during actual power production as specified in Reference 10. The pressure-temperature limits for core operation (except for low power physics tests) are that the reactor vessel must be at a temperature equal to or higher than the minimum temperature required for the inservice hydrostatic test, and at least 40°F higher than the minimum permissible temperature in the corresponding pressure-temperature curve for heatup and cooldown calculated as described in Section 3 of this report. The minimum temperatures for the inservice hydrostatic leak tests for the Prairie Island Unit 1 reactor vessel at 35 EFPY is 246°F. The vertical line drawn from these points on the pressure-temperature curve, intersecting a curve 40°F higher than the pressure-temperature limit curve, constitutes the limit for core operation for the reactor vessel.

Figures 1 and 2 define all of the above limits for ensuring prevention of nonductile failure for the Prairie Island Unit 2 reactor vessel.

The data points used for the heatup and cooldown pressure-temperature limit curves shown in Figures 1 and 2 are presented in Tables 9 and 10.

#### MATERIAL PROPERTY BASIS

**LIMITING** MATERIAL: UPPER TO INTERMEDIATE **SHELL** WELD **SEAM** W2 **LIMITING** ART **VALUES AT 35** EFPY: 1/4T, 134°F

314T, **116°F** 



Prairie Island Unit 2 Reactor Coolant System Heatup Limitations (Heatup Rates up to 100°F/hr) Applicable for the First 35 EFPY (Without Margins for Instrumentation Errors) FIGURE 1

Includes Vessel flange requirements of **98°F** and 621 psig per 1OCFR50, Appendix **G.**

#### MATERIAL PROPERTY BASIS

LIMITING MATERIAL: UPPER TO INTERMEDIATE SHELL WELD SEAM W2 LIMITING ART VALUES AT 35 EFPY: 1/4T, 134°F

3/4T, **1160F**



Prairie Island Unit 2 Reactor Coolant System Cooldown Limitations (Cooldown Rates up to **1** O0°F/hr) Applicable for the First 35 EFPY (Without Margins for Instrumentation Errors) FIGURE 2

Includes Vessel flange requirements of **98°F** and 621 psig per 10CFRS0, Appendix **G.**

Prairie Island Unit 2 Heatup and Cooldown Limit Curves for Normal Operation

## TABLE 9 35 EFPY Heatup Curve Data Points (Without Instrumentation Error Margins)

 $\mathbf{r}$ 



TABLE 10 35 EFPY Cooldown Curve Data Points (Without Instrumentation Error Margins)



 $\ddot{\phantom{a}}$ 

## **6 REFERENCES**

- 1. Regulatory Guide 1.99, Revision 2, "Radiation Embrittlement of Reactor Vessel Materials", U.S. Nuclear Regulatory Commission, May, 1988.
- 2. "Fracture Toughness Requirements", Branch Technical Position MTEB 5-2, Chapter 5.3.2 in Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants, LWR Edition, NUREG-0800, 1981.
- 3. WCAP-8193, "Northern States Power Co. Prairie Island Unit No. 2 Reactor Vessel Radiation Surveillance Program", S.E. Yanichko et. al., September 1973.
- 4. WCAP-1 1343, "Analysis of Capsule R from the Northern States Power Company Prairie Island Unit 2 Reactor Vessel Radiation Surveillance Program", S.E. Yanichko, et. al., December 1986.
- 5. WCAP-14613 Rev. 2, "Analysis of Capsule P from the Northern States Power Company Prairie Island Unit 2 Reactor Vessel Radiation Surveillance Program", S.L. Abbott, et. al., February 1998.
- 6. Societe Des Forges Et Ateliers Du Creusot Usines Schneider, Report No. 3.5.7, Rev. 1, Item C, Heat No. 22829, Order No. 700 814/54, Dated September 8, 1970.
- 7. Societe Des Forges Et Ateliers Du Creusot Usines Schneider, Report No. 4.5.7, Rev. 1, Item D, Heat No. 22642, Order No. 700 814/54, Dated June 24, 1970.
- 8. 10 CFR Part 50, Appendix G, "Fracture Toughness Requirements", Federal Register, Volume 60, No. 243, dated December 19, 1995.
- 9. 1992 Section XI, Division 1, of the ASME Boiler and Pressure Vessel Code, Appendix G, "Vessels".
- 10. 1989 Section III, Division 1 of the ASME Boiler and Pressure Vessel Code, Paragraph NB-2331, "Material for Vessels".
- 11. WCAP-7924-A, "Basis for Heatup and Cooldown Limit Curves", W. S. Hazelton, et al., April 1975.
- 12. Societe Des Forges et Ateliers Du Creusot Usines Schneider, Report No. 2.5.7, Rev. 1, Item B, Heat No. 22231/39088, Order No. 700 814/45, Dated February 27, 1970.
- 13. Proces Verbal De Recette De Produits De Soudure, SFAC, Code No. 119 957 TN 54 119 937 TN 54, Designation UM 40 (fill) Lot No. 2721, UM 89 (flux), Lot No. 1263, Specification PS 308/R, Dated 7/31/70.

- 14. Proces Verbal De Recette De Produits De Soudure, S.A.F., Code No. 118 716 A 54 119 937 TN 54, Designation UM 40 (fill) Lot No. 1752-69, UM 89 (flux), Lot No. 1263, Specification PS 308/R, Dated 3/26/70.
- 15. Proces Verbal De Recette De Produits De Soudure, S.A.F., Code No. 118 716 A 54, Designation UM 40 (fill) Lot No. 1752-69, UM 89 (flux), Lot No. 1230, Specification PS 308/R, Dated 3/31170.
- 16. Proces Verbal De Recette De Produits De Soudure, S.A.F., Code No. 118 716 A 54, Designation UM 40 (fill) Lot No. 1752-69, UM 89 (flux), Lot No. 1180, Specification PS 308/R, Dated 10/13/68.
- 17. WCAP-14781, Revision 3, "Evaluation of Pressurized Thermal Shock for Prairie Island Unit 1," S.L. Abbott, February 1998.
- 18. WCAP-14779 Rev. 2, "Analysis of Capsule S from the Northern States Power Company Prairie Island Unit **1** Reactor Vessel Radiation Surveillance Program", S.L. Abbott, et. al., February 1998.

![](_page_27_Picture_5.jpeg)

**W**