



COMBUSTION ENGINEERING OWNERS GROUP

ABB Inc.

Baltimore Gas & Electric
Calvert Cliffs 1, 2

Entergy Operations, Inc.
ANO 2 WSES Unit 3YGN 3, 4

Korea Electric Power Corp.
Uchin 3, 4

Omaha Public Power District
Ft. Calhoun

Arizona Public Service Co.
Palo Verde 1, 2, 3

Consumers Energy Co.
Palisades

Florida Power & Light Co.
St. Lucie 1, 2

Northeast Utilities Service Co.
Millstone 2

Southern California Edison
SONGS 2, 3

NRC CEOG Project Number 692

April 11, 2000
CEOG-00-098

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Subject: Submittal of Approved Topical Report CE NPSD-1045-A

Reference: S. A. Richards (NRC) to R. L. Phelps (CEOG), "Acceptance for Referencing of CE NPSD-1045, 'Joint Applications Report, Modifications to the Containment Spray System, and the Low Pressure Safety Injection System Technical Specifications' (TAC No. MA1956)" dated December 21, 1999.

The Combustion Engineering Owners Group submitted Topical Report CE NPSD-1045 for staff review on April 6, 1998. Review of this report was completed and the proposed changes to the allowed outage time of seven days for one containment spray system train approved by the above reference. Requested modifications to the allowed outage time for the low pressure safety injection system and the containment spray system technical specification end states were deferred until the industry submits its generic request for changes to tech spec end states.

Forwarded herewith in accordance with procedures established in NUREG-0390, "Topical Report Review Status," are 11 copies of the subject report. The referenced acceptance letter and attached safety evaluation have been incorporated as requested into the approved report.

This report is non-proprietary and may be openly distributed. If you have any questions, please contact me.

Very truly yours,

Ralph Phelps, Chairman
CE Owners Group

cc: J. S. Cushing, w/1 copy (NRC)
CEOG Members

1/11
DD47