



TXU Electric
Comanche Peak
Steam Electric Station
P.O. Box 1002
Glen Rose, TX 76043
Tel: 254 897 8920
Fax: 254 897 6652
lterry1@txu.com

C. Lance Terry
Senior Vice President & Principal Nuclear Officer

Log # TXX-00073
File # 10010
236
Ref. # 10CFR50.36
10CFR50.90
10CFR50.91

April 13, 2000

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
REQUEST FOR ADDITIONAL INFORMATION - LICENSE
AMENDMENT REQUEST 99-07, REVISION TO VENTILATION
FILTER TESTING PROGRAM (TAC # MA7188 AND MA7189)

REF: TXU Electric Letter, logged TXX-99231, from C. L. Terry to the NRC
dated November 8, 1999

Gentlemen:

Per the referenced letter, TXU Electric submitted a request to amend the CPSES Unit 1 Operating License (NPF-87) and CPSES Unit 2 Operating License (NPF-89) by incorporating changes that would incorporate the guidance of NRC Generic Letter 99-02, specifically, the laboratory testing of ESF Ventillation System charcoal for CPSES Units 1 and 2.

The following information is provided in response to a question asked by the NRC:

Based on the manufacturer's design documentation, it was concluded that the system face velocity at the charcoal adsorber section will not exceed 44 FPM at the maximum system flow rates specified in the Technical Specifications.

A081

TXX-00073

Page 2 of 2

Attachment 1 is the affidavit for the request for additional information to License Amendment Request 99-07.

In accordance with 10CFR50.91(b), TXU Electric is providing the State of Texas with a copy of this additional information.

If you have any questions regarding this information, please contact Mr. Manu C. Patel at (254) 897-0139.


This communication contains no new licensing basis commitments regarding CPSES Units 1 and 2.

Sincerely,



C. L. Terry

By:



Roger D. Walker
Regulatory Affairs Manager

MCP/mcp
Attachment

c - E. W. Merschoff, Region IV
J. I. Tapia, Region IV
D. H. Jaffe, NRR
Resident Inspectors, CPSES

Mr. Arthur C. Tate
Bureau of Radiation Control
Texas Department of Public Health
1100 West 49th Street
Austin, Texas 78704

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

In the Matter of

TXU Electric

(Comanche Peak Steam Electric
Station, Units 1 & 2)

)
)
)
)
)
)

Docket Nos. 50-445
50-446
License Nos. NPF-87
NPF-89

AFFIDAVIT

Roger D. Walker being duly sworn, hereby deposes and says that he is the Regulatory Affairs Manager of TXU Electric, the licensee herein; that he is duly authorized to sign and file with the Nuclear Regulatory Commission this additional information regarding License Amendment Request 99-07; that he is familiar with the content thereof; and that the matters set forth therein are true and correct to the best of his knowledge, information and belief.

Roger D. Walker


Roger D. Walker
Regulatory Affairs Manager

STATE OF TEXAS

COUNTY OF Somervell

)
)
)

Subscribed and sworn to before me, on this 13th day of April, 2000



Gayle R. Peck Jespersen
Notary Public