

No. 94-144  
Tel. 301/415-8200

FOR IMMEDIATE RELEASE  
(Monday, September 19, 1994)

NOTE TO EDITORS:

The Nuclear Regulatory Commission has received two reports (attached) from its independent Advisory Committee on Reactor Safeguards. The reports, in the form of letters, comment on a proposed Generic Letter, "Voltage-Based Repair Criteria for Westinghouse Steam Generator Tubes" and revised regulatory analysis guidelines.

In addition, the NRC's Executive Director for Operations received a report (also attached) on a proposed Generic Letter on the use of an industry report on "Guideline on Licensing Digital Upgrades".

Attachments:  
As stated

September 12, 1994

The Honorable Ivan Selin  
Chairman  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555-0001

Dear Chairman Selin:

SUBJECT: PROPOSED GENERIC LETTER 94-XX, "VOLTAGE-BASED REPAIR CRITERIA FOR WESTINGHOUSE STEAM GENERATOR TUBES"

During the 412th meeting of the Advisory Committee on Reactor Safeguards, August 4-5, 1994, we reviewed the subject generic letter (GL), an associated differing professional opinion (DPO), and a draft of an Advance Notice of Proposed Rulemaking on Steam Generator Tube Integrity. During the 413th meeting, September

8-10, 1994, we discussed the NRC staff's revised calculations for radiological consequences of a main steamline break associated with a degraded steam generator. During our review, we had the benefit of discussions with representatives of the NRC staff and the Nuclear Energy Institute (NEI), as well as the author of the DPO. We also had the benefit of the documents referenced. In part, this report is in response to a request made by the Executive Director for Operations in a July 15, 1994, memorandum to the Executive Director of the Advisory Committee on Reactor Safeguards.

Although existing mechanics-based design criteria and evaluation methods have served to ensure adequate steam generator tube integrity, they appear to be overly conservative for some types of degradation, and result in unnecessary tube plugging or repair. The proposed GL provides an alternate approach applicable solely to axially oriented outside diameter stress corrosion cracking (ODSCC) of tubes at the tube-support-plate intersections in Westinghouse steam generators with drilled-hole support plates.

We support the issuance of the proposed GL for public comment. We have reviewed the DPO and do not believe that it identifies any fundamental shortcomings in the approach proposed in the GL.

The DPO cites a high core damage frequency (CDF) of  $3.4 \times 10^{-4}$ /RY. This value was based on a preliminary scoping analysis performed by the Office of Nuclear Regulatory Research (RES). Subsequent analyses performed by RES in support of the application of the interim plugging criteria for the Trojan Nuclear Plant and for NUREG-1477 give CDFs of less than  $2 \times 10^{-6}$ /RY. These values are based on conservative estimates of leakage from degraded tubes. Except perhaps for steamline breaks, the structural restraint provided by the tube-support plate provides a high degree of assurance against tube bursts.

The criticism in the DPO of the approach used in the proposed GL and in the Standard Review Plan to compute radiological releases during a main steamline break appears to warrant further consideration. The basis for the definition of the iodine spike during a rapid depressurization transient as 500 times the equilibrium release rate is not clear. However, an alternate calculation of the release based on the gap inventory of iodine in leaking fuel elements appears to give comparable releases. In both approaches there appears to be margin in meeting the 10 CFR Part 100 limits. The staff should review the spiking data or consider other approaches to estimate the iodine release to provide a more satisfactory basis for the radiological dose estimates. In particular, we encourage the staff to quantify the level of conservatism in its analyses.

While the proposed GL appears to provide a useful interim approach for assessing steam generator tube integrity, the database for the present empirical correlations for burst pressure and leakage with

the bobbin coil voltage, appears to be only marginally adequate, and more data need to be developed.

The use of such empirical correlations as the basis for assuring the integrity of steam generator tubing would also seem to require an ongoing tube-pull program with associated burst and leak testing and metallurgical examinations as outlined in the proposed GL to ensure that the correlations remain valid as degradation continues. In the longer term, it would be worthwhile to reconsider a fracture-mechanics-based approach utilizing improved non-destructive examination techniques that provide more accurate detection and characterization of degradation. Ongoing efforts in RES and in industry to develop and implement such an approach should be continued and encouraged.

We agree with the staff position that rulemaking is the preferred regulatory approach to the problem of steam generator tube degradation, although we are skeptical that a new rule can be developed as expeditiously as the proposed schedule suggests. The overall objective and attributes of the new rule, as described by the staff, pay proper obeisance to performance-based regulation. We would like to be kept informed of the progress by the staff in the implementation of a performance-based approach.

Sincerely,

T. S. Kress  
Chairman

References:

1. Memorandum dated July 8, 1994, from F. J. Miraglia, Deputy Director, Office of Nuclear Reactor Regulation, for E. L. Jordan, Chairman, Committee to Review Generic Requirements, Subject: CRGR Review of Generic Letter 94-XX, "Voltage-Based Repair Criteria for Westinghouse Steam Generator Tubes"
  2. Memorandum dated July 15, 1994, from J. M. Taylor, NRC Executive Director for Operations, for J. T. Larkins, ACRS Executive Director, Subject: ACRS Review of Proposed Generic Letter 94-XX, Voltage-Based Repair Criteria for Westinghouse Steam Generator Tubes
  3. U.S. Nuclear Regulatory Commission, 10 CFR Part 50, RIN 3150-, Steam Generator Tube Integrity (7590-01), Draft Advance Notice of Proposed Rulemaking, received July 20, 1994
  4. Memorandum dated August 17, 1994, from J. A. Calvo, NRC Office of Nuclear Reactor Regulation, for J. T. Larkins, ACRS Executive Director, Subject: Revisions to Slides Used by Staff During August 3, 1994, Subcommittee Briefing on Steam Generator Alternate Repair Criteria
  5. U.S. Nuclear Regulatory Commission, NUREG-1477, "Voltage-Based Interim Plugging Criteria for Steam Generator Tubes," Draft Report for Comment, June 1993
  6. Memorandum dated January 15, 1993, from E. S. Beckjord, Director, Office of Nuclear Regulatory Research, to T. E. Murley, Director, Office of Nuclear Reactor Regulation, Subject: Interim Plugging Criteria for Trojan Nuclear Plant
- 

September 14, 1994

The Honorable Ivan Selin  
Chairman  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555-0001

Dear Chairman Selin:

SUBJECT: REVISED REGULATORY ANALYSIS GUIDELINES

During the 413th meeting of the Advisory Committee on Reactor Safeguards, September 8-10, 1994, we discussed the proposed final

"Regulatory Analysis Guidelines of the U.S. Nuclear Regulatory Commission." During this meeting, we had the benefit of discussions with representatives of the NRC staff. We note that the industry did not have the opportunity to review the staff response to public comments. We had provided comments on a preliminary version of these Guidelines to the Executive Director for Operations in a letter dated November 12, 1992. We also had the benefit of the documents referenced.

In our November 12, 1992 letter, we made a number of substantive comments on areas in which we disagreed with the staff proposals. In the revised version, the staff has satisfactorily addressed most of our earlier concerns. In addition, we believe the staff response to the public comments has been balanced and appropriate.

We believe these Guidelines will be valuable to the NRC staff in its various decision-making functions. At this time, we still have concerns in two areas:

1. Until new guidance has been developed on the appropriate monetary values to apply to adverse health and land contamination effects, the staff proposes the continued use of an undiscounted \$1000/man-rem. as a surrogate for the actual discounted values.

We do not support this proposal. The correct treatment requires separate, realistic values for each effect and these should be discounted for present-worth evaluation. The Guidelines should not be issued until a technically correct approach with the appropriate values is developed.

2. The revised Guidelines now propose a definition for containment failure that is "... consistent with the performance goal used in the review of evolutionary ALWRs and documented in SECY-93-087." This is a change from the definition used in a prior version of the Guidelines which was taken from NUREG-1150.

The definition in NUREG-1150, which addresses the risk dominant sequences, is the appropriate one for use in these Guidelines.

The issuance of the new Regulatory Analysis Guidelines should be delayed until these issues are reconsidered.

Sincerely,

T. S. Kress  
Chairman

References:

1. Letter dated June 29, 1994, from C. J. Heltemes, Jr., NRC Office of Nuclear Regulatory Research, to T. S. Kress, ACRS Chairman, transmitting draft SECY Paper: Regulatory Analysis Guidelines of the U.S. NRC (Draft Predecisional)
  2. Letter dated November 12, 1992, from Paul Shewmon, ACRS Chairman, to James M. Taylor, NRC Executive Director for Operations, Subject: Revised Regulatory Analysis Guidelines
- 

September 14, 1994

Mr. James M. Taylor  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555-0001

Dear Mr. Taylor:

SUBJECT: PROPOSED GENERIC LETTER ON THE USE OF NUMARC/EPRI REPORT TR-102348, "GUIDELINE ON LICENSING DIGITAL UPGRADES"

During the 413th meeting of the Advisory Committee on Reactor Safeguards, September 8-10, 1994, we reviewed the subject proposed generic letter. During our review, we had the benefit of discussions with representatives of the NRC staff and the Nuclear Energy Institute. We also had the benefit of the documents referenced.

The proposed generic letter endorses, with two clarifications, Nuclear Management and Resources Council/Electric Power Research Institute (NUMARC/EPRI) Report TR-102348 as useful guidance for effectively implementing digital upgrades and for determining when these can be performed without prior NRC staff approval under the requirements of 10 CFR 50.59.

We basically concur with the proposed generic letter and have no objection to issuing it for public comment. However, we believe that additional clarification should be provided regarding

equipment environmental compatibility. Specifically, it should be made clear in the generic letter that the environmental requirements as defined in Subsection 5.3, "Compatibility With the Environment," of the NUMARC/EPRI report include all environmental conditions resulting from internal and external events to which the equipment may be subjected. This subsection currently focuses on the need to address electromagnetic interference. We believe that any guideline which purports to cover environmental compatibility issues for replacement equipment must require that other environmental stressors such as temperature, humidity, radiation, vibration/seismic, and smoke be addressed. We note that the need to prioritize these and to verify the appropriateness of current research programs was identified in our letter of November 12, 1992, and that you agreed. We anticipate a briefing on the results of this effort.

Sincerely,

T. S. Kress  
Chairman

References:

1. Memorandum dated August 30, 1994, from E. Doolittle, NRC Office of Nuclear Reactor Regulation, to J. Larkins, ACRS Executive Director, forwarding Proposed NRC Generic Letter on the Use of NUMARC/EPRI Report TR-102348, "Guideline on Licensing Digital Upgrades"
2. Letter dated December 22, 1993, from W. Rasin, NUMARC, to W. Russell, NRC Office of Nuclear Reactor Regulation, forwarding EPRI Report TR-102348
3. ACRS letter dated November 12, 1992, from Paul Shewmon, ACRS Chairman, to Ivan Selin, NRC Chairman, Subject: Environmental Qualification for Digital Instrumentation and Control Systems
4. Letter dated December 10, 1992, from James M. Taylor, NRC Executive Director for Operations, to Paul Shewmon, ACRS Chairman, Subject: Environmental Qualification for Digital Instrumentation and Control Systems