



Duke Power
Catawba Nuclear Station
4800 Concord Road
York, SC 29745
(803) 831-3000

April 12, 2000

RE: Catawba Nuclear Station
Selected Licensee Commitments Manual
Revision Date 03/28/00

Attached are revisions to the Catawba Nuclear Station Selected Licensee Commitments Manual.
Please remove and replace the following pages:

REMOVE

INSERT

LIST OF EFFECTIVE PAGES

Page 2 of 8

Page 2 of 8

TAB 16.7

Chapter 16.7-11, page 1 of 1
dated 01/16/99

Chapter 16.7-11, page 1 of 1
dated 03/28/00

If you have any questions concerning the contents of this package update, contact Toni Pasour at (803) 831-3566.

Gary D. Gilbert
Regulatory Compliance Manager

Handwritten: 5/21/01
A045

**CATAWBA NUCLEAR STATION
SELECTED LICENSEE COMMITMENTS MANUAL**

List of Effective Pages

Tab 16.6

16.6-1 Page 1 of 1	01/16/99
16.6-2 Page 1 of 2	01/16/99
16.6-2 Page 2 of 2	01/16/99
16.6-3 Page 1 of 2	01/16/99
16.6-3 Page 2 of 2	01/16/99
16.6-4 Page 1 of 2	01/16/99
16.6-4 Page 2 of 2	01/16/99

Tab 16.7

16.7-1 Page 1 of 2	05/04/98
16.7-1 Page 2 of 2	05/04/98
16.7-2 Page 1 of 4	01/16/99
16.7-2 Page 2 of 4	01/16/99
16.7-2 Page 3 of 4	01/16/99
16.7-2 Page 4 of 4	01/16/99
16.7-3 Page 1 of 4	01/17/00
16.7-3 Page 2 of 4	01/17/00
16.7-3 Page 3 of 4	01/17/00
16.7-3 Page 4 of 4	01/17/00
16.7-4 Page 1 of 2	09/20/99
16.7-4 Page 2 of 2	09/20/99
16.7-5 Page 1 of 2	06/10/99
16.7-5 Page 2 of 2	05/04/98
16.7-6 Page 1 of 2	01/16/99
16.7-6 Page 2 of 2	01/16/99
16.7-7 Page 1 of 2	05/05/99
16.7-7 Page 2 of 2	01/16/99
16.7-8 Page 1 of 2	01/16/99
16.7-8 Page 2 of 2	05/05/99
16.7-9 Page 1 of 4	09/20/99
16.7-9 Page 2 of 4	09/20/99
16.7-9 Page 3 of 4	09/20/99
16.7-9 Page 4 of 4	09/20/99
16.7-10 Page 1 of 6	01/17/00
16.7-10 Page 2 of 6	01/17/00
16.7-10 Page 3 of 6	01/17/00
16.7-10 Page 4 of 6	01/17/00
16.7-10 Page 5 of 6	01/17/00
16.7-10 Page 6 of 6	01/17/00
16.7-11 Page 1 of 1	03/28/00
16.7-12 Page 1 of 2	01/16/99
16.7-12 Page 2 of 2	01/16/99

16.7 **INSTRUMENTATION**

16.7-11 **POSITION INDICATION SYSTEM – SHUTDOWN**

COMMITMENT:

One digital rod position indicator (excluding demand position indication) shall be OPERABLE and capable of determining the control rod position within ± 12 steps for each shutdown or control rod not fully inserted.

APPLICABILITY:

MODES 3*, 4*, and 5*.

REMEDIAL ACTION:

With less than the above required position indicator(s) OPERABLE, immediately open the Reactor Trip system breakers.**

TESTING REQUIREMENTS:

Testing Requirements are specified in Technical Specification Surveillance Requirement 3.1.7.1.

REFERENCES:

1. Letter from NRC to Gary R. Peterson, Duke, Issuance of Improved Technical Specifications Amendments for Catawba, September 30, 1998.

BASES:

OPERABILITY of the Digital Rod Position Indicators is required to determine control rod positions and thereby ensure compliance with the control rod alignment and insertion limits of the Technical Specifications.

As long as all shutdown and control rods are fully inserted, digital rod position indication is not required to be OPERABLE.

* With the Reactor Trip System breakers in the closed position.

** Once the reactor trip breakers have been opened, alternate methods may be used to ensure there is no possibility of rod motion. These methods are pulling fuses or sliding links in the rod control cabinets, tagging open the MG set feeder breakers from LXC and LXD, or tagging open the MG set output breakers. After one of these alternate methods is used, the reactor trip breakers may be reclosed if desired.