

NIAGARA MOHAWK POWER CORPORATION



NIAGARA MOHAWK POWER CORPORATION
NINE MILE POINT NUCLEAR STATION
P.O. BOX 63, LYCOMING, NY 13093

April 8, 1999
(NMP95121)

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

RE: Nine Mile Point Unit 2
Docket No. 50-410
NPF-69

Subject: Monthly Operating Report for March 2000

Dear Sir:

Submitted herewith is the Operating Data Report, the Unit Shutdowns, and Summary of Operating Experience for March 2000.

Very truly yours,

A handwritten signature in cursive script, appearing to read "M. F. Peckham".

M. F. Peckham
Plant Manager - Unit 2

/db

Attachments

xc: H.J. Miller, Regional Administrator, Region I
G.K. Hunegs, Senior Resident Inspector
Records Management

Handwritten initials and date:
HJM
1/24

OPERATING DATA REPORT

DOCKET NO.: 50-410

DATE: 000403

PREPARED BY: C. Caroccio

TELEPHONE: (315) 349-4615

OPERATING STATUS

Unit Name:	Nine Mile Point Unit #2
Reporting Period:	March 2000
1. Design Electrical Rating (MWe)	1143.3
2. Maximum Dependable Capacity (Net MWe):	1123.4

	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>
3. Number of Hours Reactor was Critical	62.3	1,502.3	81,255.1
4. Hours Generator On-Line	62.3	1,502.3	78,711.5
5. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
6. Net Electrical Energy Gen. (MWH)	65,405.1	1,719,747.3	80,917,711.9

UNIT SHUTDOWNS

DOCKET NO: 50-410

APPENDIX B

UNIT NAME: NMP#2

REPORTING PERIOD - MARCH 2000

DATE: 000403

PREPARED BY: C. Caroccio

TELEPHONE: (315) 349-4615

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reasons ¹	Method of Shutting Down ²	Cause & Corrective Actions Comments
00-01	000303	S	681.7	C	2	Shutdown for refueling and maintenance activities

¹

- Reason:**
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Exam
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

²

- Method:**
1-Manual
2-Manual Trip/Scram
3-Automatic Trip/Scram
4-Continuation
5-Other (Explain)