

**PETER E. KATZ**  
Plant General Manager  
Calvert Cliffs Nuclear Power Plant

Baltimore Gas and Electric Company  
Calvert Cliffs Nuclear Power Plant  
1650 Calvert Cliffs Parkway  
Lusby, Maryland 20657  
410 495-4101



April 20, 2000

U. S. Nuclear Regulatory Commission  
Washington, DC 20555

**ATTENTION:** Document Control Desk

**SUBJECT:** Calvert Cliffs Nuclear Power Plant  
Unit No. 1; Docket No. 50-317  
Report of Steam Generator Tube Plugging

---

**REFERENCE:** (a) Calvert Cliffs Unit 1 Technical Specifications 5.6.9.a

As required by Reference (a), this letter reports the number of tubes plugged or repaired in the Calvert Cliffs Unit 1 steam generators during the recently completed Inservice Inspection:

- ◆ In the No. 11 Steam Generator a total of 80 tubes were plugged and 26 tubes were repaired this outage. Prior to this outage, 604 tubes had been plugged and no tubes had been repaired in the No. 11 Steam Generator. To date, a total of 684 tubes are plugged and 26 tubes are repaired in the No. 11 Steam Generator.
- ◆ In the No. 12 Steam Generator a total of 100 tubes were plugged and 41 tubes were repaired this outage. Prior to this outage, 776 tubes had been plugged and no tubes had been repaired in the No. 12 Steam Generator. To date, a total of 876 tubes are plugged and 41 tubes are repaired in the No. 12 Steam Generator.

Should you have questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

A handwritten signature in black ink that reads 'Peter Katz'.

PEK/GT/bjd

cc: R. S. Fleishman, Esquire  
J. E. Silberg, Esquire  
Director, Project Directorate I-1, NRC  
A. W. Dromerick, NRC

H. J. Miller, NRC  
Resident Inspector, NRC  
R. I. McLean, DNR  
J. H. Walter, PSC

ADD 1/0