60-209-E

MATCH LINE - SEE DWG M-20 B.G.E.E. Nº 60-212-E

U.H. NO.15 | U.H. NO.16 | U.H. NO.17

DRINKING FOUNTAIN

REMOVABLE GRATING

REMOVABLE GRATING FOR CONDENSATE PUMPS (TYP 3 PLACES)

REMOVABLE GRATING (TYP 6 PLACES)

11A1 11A2 (CIV4) | 12A1 12A2 (CIV5) | 13A1 13A2 (CIV4)

U.H. NO.14

ALTERNATOR | GENERATOR | H₂ COOLER EL 53'-6" | H₂ COOLER EL 53'-6"

TURBINE GENERATION

L.P. TURBINE | L.P. TURBINE | L.P. TURBINE

REMOVABLE CHECKERED PLATE

11B1 11B2 (CIV1) | 12B1 12B2 (CIV2) | 13B1 13B2 (CIV 3)

MATCH LINE SEE DWG M-22 B.G.E. Nº 60-214-E

25°

RADIUS = 115 feet

U.H. NO.13

OPEN HATCH

OPENINGS FOR HEATER DRAIN PUMPS-REMOVABLE GRATING

OPENING FOR FEED PUMP TURBINE - REMOVABLE CHECKERED PLATE

U.H. NO.11 | U.H. NO.10

REMOVABLE GRATING

ISOLATED PHASE BUS DUCTS | UNIT HEATER NO.12

ISOLATED PHASE BUS DUCT EL 63'-6" (TYP 3 PLACES)

ISOLATED PHASE BUS DUCT COOLING UNIT BASE EL 45'-4"

HEATER U.H. NO.21

F.D. FAN Nº11

FLUE GAS DISCH. STACK (TO ATMOS.)

FEEDWATER INLET & OUTLET

L.P. FEEDWATER HEATER Nº 15A EL 49'-6"

L.P. FEEDWATER HEATER Nº 15B EL 47'-6"

PLAT EL 51'-10½" | PLAT EL 55'-6"

SHELL PULL | SHELL PULL

DEAERATING FEEDWATER HTR.

F.D. FAN Nº12

UNIT HEATER NO.20

MOTORS

MCC 125

U.H. NO.19

DRINKING FOUNTAIN

U.H. NO.22

ROLLING DOOR

REMOVABLE GRATING FOR REACTOR COOLANT PUMP BREAKER

MATCH LINE SEE DWG M-6 | B.G.E. 60-204-E

AUXIL. BOILER ROOM IRON EL 45'-0"

COMPRESSION TANK & EL. 63'-9"

CHEMICAL ADDITION TANK & PUMP

KEY PLAN

M-20 | M-21 | M-31 | UNIT 2 | UNIT 1

NOTICE
USERS MUST REFER TO THE DCN CATALOGS OR THE COMPUTERIZED DCN INDEX FOR APPLICABLE DCN'S
M-2

WORK THIS DWG WITH M-11 B.G.E. Nº 60-207-E; M-12 B.G.E. Nº 60-208-E; M-26 B.G.E. Nº 60-216-E; M-32 B.G.E. Nº 60-221-E

REV. NO.	DATE	DESCRIPTION	DES.	CHK.	SUP. ENG.	PROJ. ENG.
6	3-5-74	AS BUILT PER DCN 2007-2010, DCR M-335 (PCR E1-1044)	VP	—	—	
5	1-31-73	AS BUILT PER DCN 2003-2010, DCR M-335 (PCR E1-1044)	JW	KR		
4	10-4-72	GENERAL REVISION	AGW	THC	AB	
3	4-24-72	ADDED UNIT HEATERS TAGGED PER DCN M-484	WB	GK	WHG	
2	2-25-72	GENERAL REVISION	JBS	RBM		
1	11-24-71	REVISED STAIRWAY & RELOCATED DOOR AT H-5	GJF	RBM		
0	7-7-71	ISSUED FOR CONSTRUCTION	GJF	WHS		

EQUIPMENT LOCATION
TURBINE BLDG. UNIT Nº1
PLAN-FLOOR EL. 45'-0"

ELECTRIC PRODUCTION PLANT

CALVERT CLIFFS UNIT Nº1 & 2

BALTIMORE GAS AND ELECTRIC CO.
ELECTRIC ENGINEERING DEPARTMENT

BECHTEL ASSOCIATES
FSAR FIG. NO. 1-19

DESIGNED	DRAWN	CHECKED	APPROVALS	BECHTEL JOB	DRAWING NO.	SCALE	REV.
				6750	M-13	1"=10'	6

CHIEF ENGR. _____ DATE _____
PROJ. ENGR. _____ DATE _____

60-209-E

60-209

D2