



OFFICE OF THE
SECRETARY

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

June 28, 1995

Jimmy/Ralph/Ted
FYE.
Dave

MEMORANDUM TO: James M. Taylor
Executive Director for Operations

FROM: *John C. Hoyle*
John C. Hoyle, Secretary

SUBJECT: SECY-95-132 - POLICY AND TECHNICAL ISSUES
ASSOCIATED WITH THE REGULATORY TREATMENT OF
NON-SAFETY SYSTEMS (RTNSS) IN PASSIVE PLANT
DESIGNS (SECY-94-084)

The Commission (with all Commissioners agreeing) has approved the recommendations contained in the subject paper.

The staff should clarify Recommendation No. 4 under Item H. "Inservice Testing of Pumps and Valves," in Attachment 2 to be consistent with Attachment 1 of the paper, and clearly differentiate the types of testing that are to be performed to ensure design-basis capability of safety-related power-operated valves prior to installation, prior to initial startup, and during the operational phase (i.e., qualification test, preoperational test).

cc: The Chairman
Commissioner Rogers
Commissioner de Planque
Commissioner Jackson
OGC
OCA
OIG
Office Directors, Regions, ACRS, ACNW, ASLBP (via E-Mail)

SECY NOTE: THIS SRM, SECY-95-132, AND THE VOTE SHEETS OF ALL COMMISSIONERS WILL BE MADE PUBLICLY AVAILABLE 5 WORKING DAYS FROM THE DATE OF THIS SRM.