



OFFICE OF THE  
SECRETARY

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

June 28, 1995

*Jimmy/Ralph/Ted*

*FYE.*

*Dave*

MEMORANDUM TO: James M. Taylor  
Executive Director for Operations

FROM: *John C. Hoyle*  
John C. Hoyle, Secretary

SUBJECT: SECY-95-132 - POLICY AND TECHNICAL ISSUES  
ASSOCIATED WITH THE REGULATORY TREATMENT OF  
NON-SAFETY SYSTEMS (RTNSS) IN PASSIVE PLANT  
DESIGNS (SECY-94-084)

The Commission (with all Commissioners agreeing) has approved the recommendations contained in the subject paper.

The staff should clarify Recommendation No. 4 under Item H. "Inservice Testing of Pumps and Valves," in Attachment 2 to be consistent with Attachment 1 of the paper, and clearly differentiate the types of testing that are to be performed to ensure design-basis capability of safety-related power-operated valves prior to installation, prior to initial startup, and during the operational phase (i.e., qualification test, preoperational test).

cc: The Chairman  
Commissioner Rogers  
Commissioner de Planque  
Commissioner Jackson  
OGC  
OCA  
OIG  
Office Directors, Regions, ACRS, ACNW, ASLBP (via E-Mail)

SECY NOTE: THIS SRM, SECY-95-132, AND THE VOTE SHEETS OF ALL COMMISSIONERS WILL BE MADE PUBLICLY AVAILABLE 5 WORKING DAYS FROM THE DATE OF THIS SRM.