



RULEMAKING ISSUE **(Affirmation)**

April 15, 1996

SECY-96-077

FOR: The Commissioners

FROM: James M. Taylor
Executive Director for Operations

SUBJECT: CERTIFICATION OF TWO EVOLUTIONARY DESIGNS

PURPOSE: To request the Commission's approval to publish two final rules in the *Federal Register* that amend 10 CFR Part 52 to certify the U.S. Advanced Boiling Water Reactor (ABWR) and System 80+ designs by rulemaking.

BACKGROUND: On April 7, 1995 (60 FR 17902 and 60 FR 17924), NRC published two proposed rules for certification of the U.S. ABWR and the System 80+ designs and the environmental assessments for each design. NRC invited public comment on the proposed rules and environmental assessments and provided an opportunity to request an informal hearing before an Atomic Safety and Licensing Board. In addition, NRC conducted public meetings on May 11 and December 4, 1995, for the purpose of clarifying the provisions of the rules and affording commenters the opportunity to further explain their written comments. The official comment period ended on August 7, 1995. NRC did not receive any requests for an informal hearing or comments on the environmental assessments. However, written comments on the proposed rules were received from the Nuclear Energy Institute (NEI), vendors, utilities, the Department of Energy (DOE), and a public interest group. The NRC staff has addressed these comments in the attached *Federal Register* notices (Attachments 1 and 5). The NRC staff requested Commission guidance on two issues that were contested by NEI (SECY-96-028, "Two Issues for Design Certification Rules," dated February 6, 1996). This paper supersedes SECY-96-028, in accordance with the staff requirements memorandum (SRM) dated March 27, 1996, and provides a supplemental paper on the history of applicable regulations (Attachment 9).

NOTE: TO BE MADE PUBLICLY AVAILABLE IN
3 WORKING DAYS FROM THE DATE OF THIS PAPER

CONTACTS:
H. S. Tovmassian, NRR
415-6231

J. N. Wilson, NRR
415-3145

DISCUSSION: The process whereby the NRC may grant design certifications for evolutionary or advanced light-water reactor designs is set forth in 10 CFR Part 52. GE Nuclear Energy (GE), an operating component of General Electric Company's power systems business, applied for certification of the U.S. ABWR design. Likewise, Asea Brown Boveri-Combustion Engineering, Inc. (ABB-CE) submitted an application for certification for the System 80+ design. The NRC staff has reviewed both designs and issued its final safety evaluation reports (FSERs) as NUREG-1503 and NUREG-1462, respectively.

In parallel with the review of the U.S. ABWR and System 80+ designs, the staff developed the form and content of design certification rules. The staff solicited public participation in this process. The staff originally proposed a conceptual design certification rule for evolutionary designs in SECY-92-287, "Form and Content for a Design Certification Rule," and subsequently briefed the Commission on September 8, 1992. On March 26, 1993, the staff responded, in SECY-92-287A, to issues put forth by the Commission in its SRM on SECY-92-287 and to specific questions raised by Commissioner Curtiss in a memorandum dated September 9, 1992. The draft rule in SECY-92-287 was then modified to incorporate the Commission's guidance and industry comments and was published in the *Federal Register* for comment, as an advance notice of proposed rulemaking (ANPR) on November 3, 1993 (58 FR 58665). On November 23, 1993, the staff solicited further comment on this rulemaking when it conducted a public meeting entitled "Topics Related to Certification of Evolutionary Light-Water Reactor Designs." All holders of operating licenses or construction permits were informed of the issuance of the ANPR and the public meeting through NRC Administrative Letter 93-05, dated October 29, 1993. Separate announcements of the meeting were also sent, on October 18, 1993, to the Union of Concerned Scientists, the Nuclear Information and Resource Service, the Natural Resources Defense Council, the Public Citizen Litigation Group, the Ohio Citizens for Responsible Energy, Inc., and the State of Illinois Department of Nuclear Safety.

NRC addressed the public comments on the ANPR and published two proposed rules that would, if promulgated, provide certification of the two evolutionary designs. Each rule adds an appendix to Part 52 and incorporates by reference Tier 1 and Tier 2 of the design control document (DCD). The staff has reviewed and approved the DCD for each design. In accordance with the rulemaking procedures approved by the Commission, in its memorandum of April 30, 1993 to the General Counsel, a public comment period of 120 days was specified and the public was also provided a concurrent time frame in which it could request an informal hearing. The comment period expired on August 7, 1995 and no requests for an informal hearing were received. The staff has addressed the public comments and revised the proposed rules accordingly. Because of the revisions to the proposed rules, the "Introductions" to the DCDs must be revised to conform with the final rules. The revised DCDs must also conform with any changes to the final rules made by the Commission. Because there were no comments on the environmental assessments (EAs), only minor editorial changes were made to the final EAs in Attachments 2 and 6.

The staff is planning to issue supplements to the FSERs for the U.S. ABWR and System 80+ designs. These supplements will document the staff's evaluation of certain changes that GE and ABB-CE made to the design documentation in their DCDs, provide errata to the FSERs, and address any changes directed by the Commission, such as changes to applicable regulations. The staff informed the Commission of the changes to the U.S. ABWR documentation in a memorandum dated February 5, 1995, and to the System 80+ documentation in a memorandum dated March 14, 1995. The staff intends to provide these FSER supplements to the Commission prior to publication of the final rules in the *Federal Register*. In addition, the ABWR supplement will document the resolution of confirmatory items relating to the preparation of the DCD for design certification rulemaking and relating to the closeout of detailed design records showing that ongoing design work internationally and in first-of-a-kind-engineering did not affect the U.S. ABWR design. Also, the supplement will provide additional staff evaluations of certain documentation changes that were not evaluated in the FSER. For the System 80+ design, there were no confirmatory issues and the changes that were made to the design documentation, after issuance of the FSER, did not impact the findings in the FSER.

On March 8, 1996, the Commission conducted a public meeting in which industry representatives and NRC staff presented their views on SECY-96-028. During this meeting, NEI and the staff both indicated agreement on the ITAAC verification issue. Subsequently, the NRC staff met with representatives of ABB-CE, GE, and NEI on March 25, 1996 and proposed various means to reduce or otherwise resolve the need for new applicable regulations. The industry, represented by NEI, neither provided a proposal for resolution of applicable regulations (other than to eliminate them altogether) nor indicated any support for the staff's proposals. As a result, the NRC staff has provided revised resolutions of applicable regulations and ITAAC determinations that supersede the proposals in SECY-96-028. In addition, the final rules include various requirements that apply to combined license holders after fuel loading (e.g. outage planning and control for shutdown risk). These are generally included as requirements on applicants and licensees in Section 4 of the final rules. However, the technical specifications in the generic DCD are not requirements but are only recommendations. Most importantly, a provision has been included in Section 4 to provide that the final rules do not resolve any issues regarding conditions needed for safe operation (as opposed to safe design). The result is that, although Section 4 specifies various necessary operational requirements, they are not resolved as sufficient and the entire issue of technical specifications and other post-fuel loading operational limitations will be subject to review, possible litigation, and resolution in the combined license proceeding. This is not inconsistent with Part 52's focus on design finality and it preserves NRC's flexibility to backfit future rules on operational matters such as steam generator tube plugging criteria even though such rules may affect the design incidentally. This provision does raise a policy question because it emphasizes that the rulemaking still leaves important safety issues unresolved and subject to future litigation and backfitting. Therefore, although the staff believes that the final rules provide satisfactory resolution of the industry's comments, there may be areas

where the industry disagrees with these resolutions.

The staff is preparing a letter to the Director, Office of the Federal Register (OFR), requesting preliminary approval of the ABWR and System 80+ DCDs for incorporation by reference. The letter will address OFR's criteria for approval of documents for incorporation by reference. Final approval of the DCDs and Federal Register notices will be requested after the DCDs are revised to conform with the final rules.

COORDINATION: The Offices of Nuclear Reactor Regulation, Nuclear Regulatory Research, Administration, Enforcement, and the General Counsel have concurred in the issuance of these amendments to 10 CFR Part 52. Copies of this paper are provided to the Advisory Committee on Reactor Safeguards for its review.

RECOMMENDATIONS: That the Commission:

1. Approve the Federal Register Notices in Attachments 1 and 5.
2. Approve the final environmental assessments in Attachments 2 and 6.
3. Authorize the staff to direct the revision of the ABWR and System 80+ DCDs to conform with the final rules.
4. Certify that these rules, if promulgated, will not have a negative economic impact on a substantial number of small entities in order to satisfy requirements of the Regulatory Flexibility Act, 5 U.S.C. 605(b). Refer to Section VII of Attachments 1 and 5.
5. Note:
 - a. This paper will be placed in the NRC's public document room three days after it is forwarded to the Commission. A *Federal Register* notice will be issued that declares availability of this paper, provides for a 30 day comment period, and notices a public meeting to answer questions on the final rules.
 - b. The Chief Counsel for Advocacy of the Small Business Administration will be informed of these final rules regarding the economic impact on small entities and the reasons for it as required by the Regulatory Flexibility Act;
 - c. These final rules contain a new information collection requirement subject to the Paperwork Reduction Act of 1995 (44 U.S.C. 3150-0151). Refer to Section V of Attachments 1 and 5.
 - d. Public announcements will be issued (Attachments 3 and 7).
 - e. The appropriate congressional committees will be informed (Attachments 4 and 8).

- f. The staff will request the Director, Office of the Federal Register, to approve the revised DCDs for incorporation by reference.
- g. The staff does not believe that the final rules fall within the Office of Management and Budget's (OMB) definition of a "major" rule and, therefore, they may become effective without a 60 day Congressional review period. However, OMB will be consulted on this matter during the comment period.


James M. Taylor
Executive Director
for Operations

Attachments:

1. Federal Register Notice - U.S. ABWR
2. Final Environmental Assessment
3. Public Announcement - U.S. ABWR
4. Congressional letters - U.S. ABWR
5. Federal Register Notice - System 80+
6. Final Environmental Assessment
7. Public Announcement - System 80+
8. Congressional letters - System 80+
9. History of Applicable Regulations

Commissioners' comments or consent should be provided directly to the Office of the Secretary by COB June 14, 1996.

Commission Staff Office comments, if any, should be submitted to the Commissioners NLT May 24, 1996, with an information copy to the Office of the Secretary. If the paper is of such a nature that it requires additional review and comment, the Commissioners and the Secretariat should be apprised of when comments may be expected.

This paper is tentatively scheduled for Discussion at an Open Meeting during the week of May 28, 1996. Please refer to the appropriate Weekly Commission Schedule, when published, for a specific date and time.

DISTRIBUTION:

Commissioners
OGC
OCAA
OIG
OPA
OIP
OCA
ACRS
ASLBP
EDO
SECY

NUCLEAR REGULATORY COMMISSION
10 CFR PART 52
RIN 3150 - AE87

**Standard Design Certification for the
U.S. Advanced Boiling Water Reactor Design**

AGENCY: Nuclear Regulatory Commission.

ACTION: Final rule.

SUMMARY: The Nuclear Regulatory Commission (NRC or Commission) is amending its regulations to certify the U.S. Advanced Boiling Water Reactor (ABWR) design. The NRC is adding a new provision to its regulations that approves the U.S. ABWR design by rulemaking. This action is necessary so that applicants for a combined license that intend to construct and operate the U.S. ABWR design may do so by appropriately referencing this regulation. The applicant for certification of the U.S. ABWR design was GE Nuclear Energy.

EFFECTIVE DATE: The effective date of this rule is [insert the date 30 days after the publication date]. The incorporation by reference of certain publications listed in the regulations is approved by the Director of the Federal Register as of [insert the date 30 days after the publication date].

FOR FURTHER INFORMATION CONTACT: Jerry N. Wilson, Office of Nuclear Reactor Regulation, telephone (301) 415-3145, Harry S. Tovmassian, Office of Nuclear Regulatory Research, telephone (301) 415-6231, or Geary S. Mizuno, Office of the General Counsel, telephone (301) 415-1639, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

SUPPLEMENTARY INFORMATION:

Table of Contents

- I. Background.
- II. Public comment summary and resolution.
 - A. Principal Issues.
 - 1. Issue Resolution (Issue Finality).
 - 2. Tier 2 Change Process.
 - 3. Need for Applicable Regulations.
 - 4. Analysis of New Applicable Regulations.
 - B. Responses to specific requests for comment from proposed rule.
 - C. Other Issues.
 - 1. NRC Verification of ITAAC Determinations.
 - 2. DCD Introduction.
 - 3. Duplicate documentation in design certification rule.
 - 4-7. OCRE comments
- III. Section-by-section discussion of this design certification rule.
 - A. Introduction (Section 1).

- B. Definitions (Section 2).
- C. Scope and contents of this design certification (Section 3).
- D. Applications and licenses referencing this design certification: additional requirements and restrictions (Section 4).
- E. Applicable regulations (Section 5).
- F. Issue resolution for this design certification (Section 6).
- G. Duration of this design certification (Section 7).
- H. Processes for changes and departures (Section 8).
- I. Inspections, tests, analyses, and acceptance criteria (Section 9).
- J. Records and Reporting (Section 10).
- IV. Finding of no significant environmental impact: availability.
- V. Paperwork Reduction Act statement.
- VI. Regulatory analysis.
- VII. Regulatory Flexibility Act certification.
- VIII. Backfit analysis.

I. Background

On September 29, 1987, General Electric Company applied for certification of the U.S. ABWR standard design with the NRC. The application was made in accordance with the procedures specified in 10 CFR Part 50, Appendix O, and the Policy Statement on Nuclear Power Plant Standardization, dated September 15, 1987. The application was docketed on February 22, 1988 (Docket No. STN 50-605).

On May 18, 1989 (54 FR 15372), the NRC added 10 CFR Part 52 to its regulations to provide for the issuance of early site permits, standard design certifications, and combined licenses for nuclear power reactors. Subpart B of 10 CFR Part 52 established the process for obtaining design certifications. A major purpose of this rule was to achieve early resolution of licensing issues and to enhance the safety and reliability of nuclear power plants.

On December 20, 1991, GE Nuclear Energy (GE), an operating component of General Electric Company's power systems business, requested that its application, originally submitted pursuant to 10 CFR Part 50, Appendix O, be considered as an application for design approval and subsequent design certification pursuant to Subpart B of 10 CFR Part 52. Notice of receipt of this request was published in the Federal Register on March 20, 1992 (57 FR 9749), and a new docket number (52-001) was assigned.

The NRC staff issued a final safety evaluation report (FSER) related to the certification of the U.S. ABWR design in July 1994 (NUREG-1503). The FSER documents the results of the NRC staff's safety review of the U.S. ABWR design against the requirements of 10 CFR Part 52, Subpart B, and delineates the scope of the technical details considered in evaluating the proposed design. A final design approval for the U.S. ABWR design was issued on July 13, 1994, and published in the Federal Register on July 20, 1994 (59 FR 37058).

The NRC staff originally proposed a conceptual design certification rule for evolutionary standard plant designs in SECY-92-287, "Form and Content for a Design Certification Rule." Subsequently, the NRC staff modified the draft rule language proposed in SECY-92-287 to incorporate Commission guidance and published a draft-proposed design certification rule in the Federal Register on November 3, 1993 (58 FR 58665), as an Advanced Notice of Proposed Rulemaking (ANPR) for public comment. In accordance with the Administrative Procedure Act (APA), Part 52 provides the opportunity for the public to submit

written comments on proposed design certification rules. However, Part 52 went beyond the requirements of the APA by providing the public with an opportunity to request a hearing before an Atomic Safety and Licensing Board in a design certification rulemaking. Therefore, on April 7, 1995 (60 FR 17902), the NRC published a proposed rule in the Federal Register which invited public comment and provided the public with the opportunity to request an informal hearing before an Atomic Safety and Licensing Board. The NRC staff conducted public meetings on the development of this design certification rule on November 23, 1993, May 11, 1995, and December 4, 1995, in order to enhance public participation. The period within which an informal hearing could be requested expired on August 7, 1995. The NRC did not receive any requests for an informal hearing during this period.

The Commission has considered the comments received and made appropriate modifications to this design certification rule, as discussed in Sections II and III. With these modifications, the Commission adopts as final this design certification rule, 10 CFR Part 52, Appendix A, for the U.S. ABWR design.

II. Public Comment Summary and Resolution

The public comment period for the proposed design certification rule, the design control document, and the environmental assessment for the U.S. ABWR design expired on August 7, 1995. The NRC received twenty letters containing public comments on the proposed rule. The most extensive comments were provided by the Nuclear Energy Institute (NEI), which provided comments on behalf of the industry. In general, NEI commended the NRC for its efforts to provide standard design certifications but expressed serious concerns about aspects of the proposed rule that would, in NEI's view, undermine the goals of design certification. These concerns are addressed in the following responses to the public comments. Fourteen utilities and three vendors also provided comments. All of these comment letters endorsed the NEI comments and some provided additional comments. The Department of Energy and the Ohio Citizens for Responsible Energy, Inc. (OCRE) also submitted comment letters. OCRE provided two sets of comments, the first addressed the NRC's specific requests for comment and the second addressed OCRE's concerns about certain aspects of the U.S. ABWR design.

The NRC received other letters that were entered into the docket file and are part of the record of the rulemaking proceeding. An August 4, 1995 letter from NEI to the Chairman of the NRC, which submitted a copy of the Executive Summary of their public comment letter, and a May 11, 1995 letter, which provided suggestions on finality, secondary references, and other explanatory material. Also, the NRC received a second letter from the General Electric Company, which commented on the comments provided by OCRE, and a second letter from Combustion Engineering, Inc. (ABB-CE), which provided proposed Statements of Consideration (SOC) that conformed with its comments.

On February 6, 1996, the NRC staff issued SECY-96-028, "Two Issues for Design Certification Rules," which requested the Commission's approval of the staff's position on two major issues raised by NEI in its comments on the proposed design certification rules. The staff issued this paper because of fundamental disagreements with industry on the need for applicable regulations and the matters to be considered in verifying inspections, tests, analyses, and acceptance criteria (ITAAC). Both NEI and DOE commented on SECY-96-028 in letters dated March 5 and 13, 1996, respectively.

On March 8, 1996, the Commission conducted a public meeting in which industry representatives and NRC staff presented their views on SECY-96-028. During this meeting, NEI and the staff both indicated agreement on the ITAAC verification issue. Subsequently, in a staff requirements memorandum (SRM) dated March 21, 1996, the Commission requested the staff to meet again with industry to try to resolve the issue of applicable regulations. The staff met with representatives of ABB-CE, GE Nuclear Energy, and NEI in a public meeting on March 25, 1996 and proposed various means to reduce or otherwise resolve the need for new applicable regulations. The industry, represented by NEI, neither provided a proposal for resolution of applicable regulations (other than to eliminate them altogether) nor indicated any support for the staff's proposals. As a result, the staff has provided revised resolutions of applicable regulations and ITAAC determinations in the following discussion (sections II.A.3, II.A.4, and II.C.1) that supersede the proposals in SECY-96-028. In addition to the formally scheduled meetings noted above, there have also been numerous less formal interactions between NRC and industry representatives.

The following discussion is separated into three groups: (1) resolution of the principle issues raised by the commenters, (2) resolution of the NRC's specific requests for comment from the proposed rule, and (3) resolution of other issues raised by the commenters.

A. Principal Issues.

1. Issue Resolution (Issue Finality).

Comment Summary. The applicant and NEI criticized Section 6 of the proposed appendix, which describes the scope of issues that were proposed to be resolved by this design certification rulemaking. In brief, both commenters argued that:

- The scope of issues accorded finality is too narrow;
- Changes made in accordance with the change process are not accorded finality; and
- The rule does not provide finality in all subsequent proceedings.

These comments are found in NEI Comment, Attachment B, pp. 1-23 and GE Comment, Attachment A, pp. 2-4. The applicant and NEI provided specific language for a redrafted Section 6 which addresses their criticisms. With the exception of the industry position regarding the exclusion of Tier 2 departures from an opportunity for a hearing, the Commission generally agrees with the applicant and NEI.

Response: Scope of issues accorded finality.

The applicant and NEI took issue with the proposed rule's language limiting the scope of nuclear safety issues resolved to those issues "associated with" the information in the FSER or Design Control Document (DCD). Each argued that there were many other documents which included and/or addressed issues whose status should be regarded as "resolved in connection with" this design certification rulemaking. These additional documents include "secondary references" (*i.e.*, DCD references to documents and information which are not contained in the DCD, including secondary references

containing proprietary and safeguards information), docketed material, and the entire rulemaking record (refer to GE Comments, Attachment A, pp. 2-3; NEI Comments, Attachment B, pp. 6-9).

The Commission has reconsidered its position and decided that the ambit of issues resolved by this rulemaking should be the information that is reviewed and approved in the design certification rulemaking, which includes the rulemaking record for the standard design. This position reflects the Commission's SRM on SECY-90-377, dated February 15, 1991. Also, the Commission concludes that the set of issues resolved should be those that were addressed (or could have been addressed if they were considered significant) as part of the design certification rulemaking process. However, the Commission does not agree that all matters submitted on the docket for design certification should be accorded finality under 10 CFR 52.63(a)(4). Some of this information was neither reviewed nor approved and some was not directly related to the scope of issues resolved by this rulemaking. Therefore, the final rule provides finality for all nuclear safety issues associated with the information in the FSER and any supplements to it, the generic DCD including referenced information that is intended as requirements, and the rulemaking record.

In adopting this final design certification rulemaking, the Commission also finds that the design certification does not require any additional or alternative design criteria, design features, structures, systems, components, testing, analyses, acceptance criteria, or additional justifications in support of these matters. Inherent in the concept of design certification by rulemaking is that all these issues which were addressed, or could have been addressed, in this rulemaking are resolved and therefore, may not be raised in a subsequent NRC proceeding. If this were not the case and one could always argue in a subsequent proceeding that an additional, alternative, or modified system, structure or component of a previously-certified design was needed, or additional justification was necessary, or a modification to the testing and acceptance criteria is necessary, there would be little regulatory certainty and stability associated with a design certification. The underlying benefits of certification of individual designs by rulemaking, e.g., early Commission consideration and resolution of design issues and early Commission consideration and agreement on the methods and criteria for demonstrating completion of detailed design and construction in compliance with the certified design, would be virtually negated. Thus, in accord with the views of the applicant and NEI, the Commission clarifies and makes explicit its previously implicit determination that the scope of issues resolved in connection with the design certification rulemaking includes the lack of need for alternative, additional or modified design criteria, design features, structures, systems, components, or inspections, tests, analyses, acceptance criteria or justifications, and such matters may not be raised in subsequent NRC proceedings.

In the SOC for the proposed rule, the Commission proposed that issues associated with "requirements" in secondary references, not specifically approved for incorporation by reference by the Office of the Federal Register (OFR) because they contained proprietary or safeguards information, would not be considered resolved in the design certification rulemaking within the meaning of 10 CFR 52.63(a)(4) (See 60 FR 17902, 17911). Both GE and NEI took exception to this position, arguing that issues arising from secondary references should be included in the set of issues resolved (See GE Comments,

Attachment A, pp. 2-3; NEI Comments, Attachment B, pp. 6-9). The Commission has determined that the set of issues resolved by this rulemaking embraces those issues arising from secondary references that are requirements for the certified design, including those containing proprietary and safeguards information. This is consistent with the intent of 10 CFR Part 52 that issues related to the design certification should be considered and resolved in the design certification rulemaking. However, since OFR does not approve of "incorporation by reference" of proprietary and safeguards information, even though it was available to potential commenters on this proposed design certification rule (see 60 FR 17902 at 17920-21; April 7, 1995), the Commission has included in Section 6(d) of this appendix, a process for obtaining proprietary and safeguards information at the time that notice of a hearing in connection with issuance of a combined license is published in the Federal Register. Such persons will have actual notice of the requirements contained in the proprietary and safeguards information and, therefore, will be subject to the issue finality provisions of Section 6 of this appendix.

Changes made in accordance with the change process.

The proposed design certification rule included a change process similar to that provided in 10 CFR 50.59. Specifically, Section 8(b)(5) provided "that such changes open the possibility for challenge in a hearing" for Tier 2 changes in accordance with the Commission's guidance in its SRM on SECY-90-377, dated February 15, 1991. The NRC also believed that providing an opportunity for a hearing would serve to discourage changes that could erode the benefits of standardization. The applicant and NEI argued that Tier 2 departures under the "§ 50.59-like" process should not be subject to any opportunity for hearing but may only be challenged via a 10 CFR 2.206 petition; and, therefore should be subject to the backfit restrictions of 10 CFR 52.63(a).

The Commission has reconsidered and changed its position on issue resolution in connection with Tier 2 departures under the "§ 50.59-like" process. Section 50.59 was originally adopted by the Commission to afford a Part 50 operating license holder greater flexibility in changing the facility as described in the FSAR while still assuring that safety-significant changes of the facility would be subject to prior NRC review and approval [refer to 27 FR 5491, 5492 (first column); June 9, 1962]. The "unreviewed safety question" definition was intended by the Commission to exclude from prior regulatory consideration those licensee-initiated changes from the previously NRC-approved FSAR that could not be viewed as having safety significance sufficient to warrant prior NRC licensing review and approval. To put it another way, any change properly implemented pursuant to § 50.59 should continue to be regarded as within the envelope of the original safety finding by the NRC. Moreover, the departure process for Tier 2 information, as specified in Section 8(b), includes additional restrictions derived from 10 CFR 52.63(b)(2), viz., the Tier 2 change must not involve a change to Tier 1 information. Thus, the departure process of Section 8(b)(5), *if properly implemented by an applicant or licensee*, must logically result in departures which are both "within the envelope" of the Commission's safety finding for the design certification rule and for which the Commission has no safety concern. Therefore, it follows that *properly implemented* departures from Tier

2 should continue to be accorded the same extent of issue resolution as that of the original Tier 2 information from which it was "derived." Section 8(b)(5) has been amended to reflect the Commission's determination on issue resolution for Tier 2 changes made in accordance with the departure process and Section 6 has been amended to provide backfit protection for changes made in accordance with the processes of Section 8 of this appendix.

However, the converse of this reasoning leads the Commission to reject the applicant's and NEI's contention that *no* part of the applicant's or licensee's implementation of the Section 8(b)(5) departure process should be open to challenge in a subsequent licensing proceeding, but instead should be raised as a petition for enforcement action under 10 CFR 2.206. Because §2.206 applies to holders of licenses and is considered a request for enforcement action (thereby presenting some potential difficulties when attempting to apply this in the context of a combined license applicant), it is unclear why an applicant or licensee who departs from the design certification rule in noncompliance with the Section 8(b)(5) process should nonetheless reap the benefits of issue resolution stemming from the design certification rule. An incorrect departure from the requirements of this appendix essentially places the departure outside of the scope of the Commission's safety finding in the design certification rulemaking. It follows that properly-founded contentions alleging such incorrectly-implemented departures cannot be considered "resolved" by this rulemaking. The industry also appears to oppose an opportunity for a hearing on the basis that there is no "remedy" available to the Commission in a licensing proceeding that would not also constitute a violation of the Tier 2 [Section 8(b)] backfitting restrictions applicable to the Commission and that in a comparable situation with an operating plant the proper remedy is enforcement action. However, for purposes of issue finality the focus should be on the initial licensing proceeding where the result of an improper change evaluation would simply be that the change is not considered resolved and no enforcement action is needed. Neither the applicant nor NEI provided compelling reasons why contentions alleging that applicants or licensees have not properly implemented the Section 8(b)(5) departure process should be entirely precluded from consideration in an appropriate licensing proceeding where they are relevant to the subject of the proceeding.

Although the Commission disagrees with the applicant and NEI over the admissibility of contentions alleging incorrect implementation of the departure process, the Commission acknowledges that they have a valid concern regarding whether the scope of the contentions will incorrectly focus on the substance of correctly-performed departures and the possible lengthened time necessary to litigate such matters in a hearing (See, e.g., Transcript of December 4, 1995 Public Meeting, p. 47). Therefore, the Commission has included in Section 8(b)(5)(vi) an expedited review process, similar to that provided in 10 CFR 2.758, for considering the admissibility of such contentions. Persons who seek a hearing on whether an applicant has departed from Tier 2 information in noncompliance with the applicable requirements must submit a petition, together with information required by 10 CFR 2.714(b)(2), to the presiding officer. If the presiding officer concludes that a *prima facie* case has been presented, he or she shall certify the petition and the responses to the Commission for final determination as to admissibility.

Finality in all subsequent proceedings.

GE and NEI proposed that Section 6 of the proposed rule be expanded to include a more detailed statement regarding the findings, issues resolved, and restrictions on the Commission's ability to "backfit" this appendix. The Commission agrees that the industry's proposal has some merit, and has revised Section 6 of this appendix, beginning with the general subjects embodied in NEI's proposed redraft of Section 6, but restructured the NEI proposal into three sections to reflect the scope of issues resolved, change process, and rulemaking findings, thereby conforming the language to reflect the conventions of the appendix (e.g., generic *changes* versus plant-specific *departures*), and making minor editorial changes for clarity and consistency. However, one area in which the Commission declines to adopt the industry's proposal is the inclusion of a statement in Section 6 which extends issue finality to *all* subsequent proceedings.

Section 52.63(a)(4) explicitly states that issues resolved in a design certification rulemaking have finality in combined license proceedings, proceedings under § 52.103, and operating license proceedings. There are other NRC proceedings not mentioned in § 52.63(a)(4), e.g., combined license amendment proceedings and enforcement proceedings, in which the design certification should logically be afforded issue resolution and, therefore, will be included in Section 6. However, NEI listed NRC proceedings such as design certification renewal proceedings, for which issue finality would not be appropriate. Moreover, it should be understood that to say that this design certification rule is accorded "issue finality" does not eliminate changes properly made under the change restrictions in Section 8. Therefore, the Commission declines to adopt in its entirety the industry proposal that issue finality should extend to all subsequent NRC proceedings.

2. Tier 2 Change Process.

Comment Summary. NEI provided many comments in its Attachment B on the following aspects of the Tier 2 change process:

- Scope of the Section 8(b)(5) change process;
- Post-design certification rulemaking changes to Tier 2 information;
- Restrictions on Tier 2* information;
- Technical Specifications; and
- Additional aspects of the change process.

Response. The proposed design certification rule provided a change process for Tier 2 information that has the same elements as the Tier 1 change process in order to implement the two-tiered rule structure that was requested by industry. Specifically, the Tier 2 change process in Section 8(b) provides for generic changes, plant-specific changes, and exemptions similar to the provisions in 10 CFR 52.63, except that some of the standards for plant-specific orders and exemptions are different. Section 8(b) also has a provision similar to 10 CFR 50.59 that allows for departures from Tier 2 information by an applicant or licensee, without prior NRC approval, subject to certain restrictions, in accordance with the Commission's SRM on SECY-90-377, dated February 15, 1991.

Scope of the Section 8(b)(5) change process.

In its comments in Attachment B, pp. 67-82, NEI raised a concern regarding application of the § 50.59-like change process to severe accident information, and stated:

Instead of applying the § 50.59-like process to all of Chapter 19, we propose (1) that the process be applied only to those sections that identify features that contribute significantly to the mitigation or prevention of severe accidents (i.e., Section 19.8 for the ABWR and Section 19.15 for the System 80+), and (2) that changes in these sections should constitute unreviewed safety questions only if they would result in a substantial increase in the probability or consequences of a severe accident.

The Commission agrees that departures from Tier 2 information that describe the resolution of severe accident issues should use a criteria that is different from the criteria in 10 CFR 50.59 for determining if a departure constitutes an unreviewed safety question (USQ). Because of the increased uncertainty in severe accident issue resolutions, the NRC has included a "substantial increase" criteria in Section 8(b)(5)(iii) of this Appendix for Tier 2 information that is associated with the resolution of severe accident issues. The (§ 50.59-like) criteria in Section 8(b)(5)(ii), for determining if a departure constitutes a USQ, will apply to the remaining Tier 2 information. If the proposed departure from Tier 2 information involves the resolution of other safety issues in addition to the severe accident issues, then the USQ determination must use the criteria in Section 8(b)(5)(ii) of this appendix.

However, NEI has misidentified the sections of the DCD that describe the resolutions of the severe accident issues. Section 19.8 for the U.S. ABWR and Section 19.15 for the System 80+ design identify important features that were derived from various analyses of the design, such as seismic analyses, fire analyses, and the probabilistic risk assessment. This information was used in preparation of the Tier 1 information and, as stated in the proposed rule, it should be used to ensure that departures from Tier 2 information do not impact Tier 1 information. For these reasons, the Commission rejects the contention that the severe accident resolutions are contained in Chapter 19.8 of the generic DCD.

Post-design certification rulemaking changes to Tier 2 information.

In its comments in Attachment B, pp. 83-89, NEI requested that the NRC add a § 50.59-like provision to the change process that would allow design certification applicants to make generic changes to Tier 2 information prior to the first license application. These applicant-initiated, post-certification Tier 2 changes would be binding upon all referencing applicants and licensees (i.e., referencing applicants and licensees must comply with all such changes) and would continue to enjoy "issue preclusion" (i.e., issues with respect to the adequacy of the change could not be raised in a subsequent proceeding as a matter of right). However, the changes would not be subject to public notice and comment. Instead NEI proposed that the changes would be considered resolved and final (not subject to further NRC review) six months

after submission, unless the NRC staff informs the design certification applicant that it disagrees with the determination that no unreviewed safety question exists.

The Commission declines to adopt the NEI proposal. The applicant-initiated Tier 2 changes proposed by NEI have the essential attributes of a "rule," and the process of NRC review and "approval" (negative consent) would appear to be "rulemaking," as these terms are defined in Section 551 of the APA. Section 553(b) of the APA requires public notice in the Federal Register and an opportunity for public comment for all rulemakings, except in certain situations delineated in Section 553(b)(A) and (B) which do not appear to be applicable here. The NEI proposal appears to be in conflict with the rulemaking requirements of the APA. If the NEI proposal is based upon a desire to permit the applicant to disseminate worthwhile Tier 2 changes, there are three alternatives already afforded by Part 52 and this rule. The applicant (as any member of the public) may submit a petition for rulemaking pursuant to 10 CFR Part 2, Subpart H, to modify this design certification rule to incorporate the proposed changes to Tier 2. If the Commission grants the petition and adopts a final rule, the change is binding on all referencing applicants and licensees in accordance with Section 8(b)(2) of this rule. Also, the applicant could develop acceptable documentation to support a Tier 2 (including Tier 2*) departure in accordance with Section 8(b)(5) [or 8(b)(6)]. This documentation could be submitted for NRC staff review and approval, similar to the manner in which the NRC staff reviews topical reports¹. And finally, the applicant could provide its proposed changes to a COL applicant who could seek approval as part of its COL application review. The Commission regards these regulatory approaches to be preferable to the NEI proposal, which is fraught with the difficulties identified above. However, if NEI is requesting that the Commission change its preliminary determination, as set forth in its February 15, 1991 SRM on SECY 90-377, that generic Tier 2 rulemaking changes be subject to the same restrictive standard as generic Tier 1 changes, the Commission declines to do so. The Commission believes that maintaining a high standard for generic changes to both Tier 1 and Tier 2 will ensure that the benefits of standardization are appropriately achieved.

Restrictions on Tier 2* information.

In its comments in Attachment B, pp. 119-123, NEI requested that the restriction on departures from all Tier 2* information expire at first full power and, in any event, the expiration of the restrictions should be consistent for both the U.S. ABWR and System 80+ designs. As stated in the

¹Topical reports, which are usually submitted by vendors such as GE, Westinghouse, and Combustion Engineering, request NRC staff review and approval of generic information and approaches for addressing one or more of the Commission's requirements. If the topical report is approved by the NRC staff, it issues a safety evaluation setting forth the bases for the staff's approval together with any limitations on referencing by individual applicants and licensees. Applicants and licensees may incorporate by reference topical reports in their applications, in order to facilitate timely review and approval of their applications or responses to requests for information. However, limitations in NRC resources may affect review schedules for these topical reports.

proposed design certification rule, the restriction on changing Tier 2* information resulted from the development of the Tier 1 information in the generic DCD. During the development of the Tier 1 information, the applicant for design certification requested that the amount of information in Tier 1 be minimized to provide additional flexibility for an applicant or licensee who references this design certification. Also, many codes, standards, and design processes, which were not specified in Tier 1, that are acceptable for meeting ITAAC were specified in Tier 2. The result of these actions is that certain significant information only exists in Tier 2 and the NRC does not want this significant information to be changed without prior NRC approval. This Tier 2* information is identified in the generic DCD with italicized text and brackets and the change restriction has compensated for industry's desire to minimize the amount of information in Tier 1.

Although the Tier 2* designation was originally intended to last for the lifetime of the facility, like Tier 1 information, the NRC staff reevaluated the duration of the change restriction for Tier 2* information during the preparation of the proposed rule. The NRC staff determined that some of the Tier 2* information could expire when the plant first achieves full (100%) power, after the finding required by 10 CFR 52.103(g), while other Tier 2* information must remain in effect throughout the life of the plant that references this rule. The determining factors were the Tier 1 information that would govern these areas after first full power and the NRC staff's judgement on whether prior approval was required before implementation of the change due to the significance of the information.

As a result of NEI's comment, the NRC has again reevaluated the durations of the Tier 2* change restrictions. The NRC agrees with NEI that expiration of Tier 2* information for the two evolutionary designs should be consistent, unless there is a design-specific reason for a different treatment. One area of Tier 2* information that had different expiration dates was equipment seismic qualification methods. The NRC has determined that, due to its significance, changes to the qualification methodology must be approved before implementation. Therefore, the Tier 2* designation for this information will not expire for either design.

For reactor core acceptance criteria, the licensing criteria for fuel and control rods is designated as Tier 2* in the U.S. ABWR DCD in order to clarify the acceptance criteria for reviewing changes to the current fuel and control rod design. As discussed in Section 4.2 of the U.S. ABWR FSER (NUREG-1503), the criteria were based on previous work with GE Nuclear Energy to define the licensing acceptance criteria for core reload calculations. The NRC believed that by endorsing the licensing acceptance criteria contained in a GE topical report, this would reduce the amount of information to be submitted by GE. Thus, changes to the GE fuels could be made by analyzing the effects of the change against this licensing criteria, without further review by the NRC.

Recent industry proposals for currently operating core fuel designs have indicated a desire to modify the fuel burnup limit design parameter. However, operational experience with fuel with extended fuel burnup has indicated that cores should not be allowed to operate beyond the burnup limits specified in the generic DCDs without NRC approval. This experience is summarized in a Commission memorandum from James M. Taylor, "Reactivity Transients and High Burnup Fuel," dated September 13, 1994, including Information Notice (IN) 94-64, "Reactivity Insertion Transient and Accident Limits for High Burnup Fuel,"

dated August 31, 1994. Experimental data on the performance of high burnup fuel under reactivity insertion conditions became available in mid-1993. The NRC issued IN 94-64 and IN 94-64, Supplement 1, on April 6, 1995, to inform industry of the data. The unexpectedly low energy deposition to initiation of fuel failure in the first test rod (at 62 GWd/MTU) led to a re-evaluation of the licensing basis assumptions in the NRC's standard review plan (SRP). The NRC performed a preliminary safety assessment and concluded that there was no immediate safety issue for currently operating cores because of the low to medium burnup status of the fuel (refer to Commission Memorandum from James M. Taylor, "Reactivity Transients and Fuel Damage Criteria for High Burnup Fuel," dated November 9, 1994, including an NRR safety assessment and the joint NRR/RES action plan). Therefore, the NRC has determined that additional actions by industry are not needed to justify current burnup limits for operating reactor fuel designs.

However, the NRC is working with industry and fuel vendors to assess fuel performance for high burnup fuel and reevaluate current SRP licensing acceptance criteria. Because the fuel failure threshold may decline with increasing burnup, the NRC is assessing licensing-basis design acceptance criteria as a function of burnup or a performance-based design criteria. Therefore, the NRC has determined that it needs to carefully consider any proposed changes to the fuel burnup parameter in the generic DCDs for these fuel designs until further experience is gained with extended fuel burnup characteristics. Requests for extension of these burnup limits will be evaluated based on supporting experimental data and analyses, as appropriate, for current and advanced fuel designs. Therefore, the NRC has determined that the Tier 2* designation for the fuel burnup parameters should not expire for the lifetime of a referencing facility.

Technical Specifications.

In its comments in Attachment B, pp. 124-129, NEI requested that the NRC establish a single set of integrated technical specifications governing the operation of each plant that references this design certification and that the technical specifications be controlled by a single change process. The NRC included the technical specifications for the standard designs in the generic DCD in order to maximize the standardization of the technical specifications for plants that reference this design certification. As a result, a plant that references this design certification would have two sets of technical specifications associated with its license: (1) technical specifications from Chapter 16 of Tier 2 of the generic DCD and applicable to the standardized portion of the plant, and (2) those technical specifications applicable to the site-specific portion for the plant. While each portion of the technical specifications would be subject to a different change process, the substantive aspects of the change processes would be essentially the same.

Although a potential loss in standardization may result, the Commission has decided not to require COL applicants to conform with the technical specifications in Chapter 16 of the generic DCD. These technical specifications will not be part of Tier 2 and will be treated like conceptual design information. Applicants who reference this appendix will be able to develop new technical specifications for their plant as part of their COL application and the NRC will consider future operating experience when it reviews the new technical specifications. However, the NRC expects that COL

applicants will develop their new technical specifications based on the technical specifications in Chapter 16 that were prepared for this standard design. The change process for the new technical specifications will be similar to the current process in § 50.90 and § 50.92, provided that the changes do not affect the information in the DCD. A consequence of this decision is that there will not be any issue resolution for the technical specifications developed during this design certification review.

Additional aspects of the change process.

In its comments in Attachment B, pp. 109-118, NEI raised some additional concerns with the Tier 2 change process. The first concern was with the process for determining if a departure from Tier 2 information constituted an unreviewed safety question. Specifically, NEI identified the following statement in section III.H of the proposed rule. ". . . if the change involves an issue that the NRC staff has not previously approved, then NRC approval is required." A clarification of this statement was provided in the May 11, 1995 public meeting on design certification (pp. 12-14 of meeting transcript), when the NRC staff stated that the NRC was not creating a new criterion for determining unreviewed safety questions but was explaining existing criteria. A further discussion of this statement took place between the staff and counsel to GE Nuclear Energy at the December 4, 1995 public meeting on design certification (pp. 53-56 of meeting transcript), in which counsel for GE Nuclear Energy agreed that a departure which creates an issue that was not previously reviewed by the NRC would be evaluated against the existing criteria for determining whether there was an unreviewed safety question. With this clarification at the public meeting, the Commission does not believe there is a need for a change to the language of this appendix.

NEI also requested that Section 8(b) of this appendix be revised to state that exemptions are not required for changes to the technical specifications or Tier 2* information that do not involve an unreviewed safety question. The Commission has determined that this is consistent with the Commission's intent that permitted departures from Tier 2* under Section 8(b) of this appendix should not also require an exemption, unless otherwise required by, or implied by extension from 10 CFR Part 52, Subpart B and, accordingly, has revised Section 8(b) of this appendix. As discussed above, the technical specifications in Chapter 16 of the generic DCD are not requirements of this appendix and, therefore, the issue of exemptions to these technical specifications is moot. NEI also raised a concern with the requirement for quarterly reporting of design changes during the construction period. This issue is discussed in section III.J.

Finally, NEI raised a concern with the status of 10 CFR 52.63(b)(2) in the two-tiered rule structure that has been implemented in this appendix and claimed that 10 CFR 52.63(b) clearly embodies a two-tier structure. NEI's claim is not correct. The Commission adopted a two-tiered design certification rule structure (Commission SRM on SECY-90-377, dated February 15, 1991) and created a change process for Tier 2 information that has the same elements as the Tier 1 change process. In addition, the Tier 2 change process includes a provision that is similar to 10 CFR 50.59, namely Section 8(b)(5). Therefore, as stated in section II (Topic 6) of the proposed rule, there is no need for 10 CFR 52.63(b)(2) in the two-tiered change process that has been implemented for this Appendix.

3. Need for Applicable Regulations.

Comment Summary. NEI and the other industry commenters criticized Section 5(c) of the proposed design certification rule, which designated additional applicable regulations for the purposes of 10 CFR 52.48, 52.54, 52.59, and 52.63 (refer to NEI Comment, Attachment B, pp. 24-56).

Response. In its first group of comments, NEI stated that there is no requirement in 10 CFR Part 52 that compels the Commission to adopt these new applicable regulations, that the new applicable regulations are not necessary for adequate protection or to improve the safety of the standard designs, and that the applicable regulations are inconsistent with the Commission's SRM, dated September 14, 1993. Although the Commission was not compelled to adopt new applicable regulations, it has been developing them in accordance with the goals of 10 CFR Part 52 and to achieve the purposes of 10 CFR 52.48, 52.54, 52.59, and 52.63 (refer to SECY-96-028, dated February 6, 1996). The Commission chose design-specific rulemaking rather than generic rulemaking for the new technical and severe accident issues. The Commission adopted this approach early in the design certification review process because it was concerned that generic rulemakings would cause significant delay in the design certification reviews and it was thought that the new requirements would be design-specific. In its SRM on SECY-91-262, dated January 28, 1992, the Commission approved the NRC staff's recommendation to proceed with design-specific rulemakings through individual design certifications to resolve these technical and severe accident issues for the U.S. ABWR and System 80+ designs and continued to support this approach, as stated in its SRM on SECY-93-226, dated September 14, 1993. However, the Commission delayed its decision on the need for generic rulemaking for advanced LWRs. It is this later guidance that NEI appears to have misunderstood.

In its second group of comments, NEI stated that the applicable regulations are unnecessary because the NRC staff has applied these technical positions in reviewing and approving the standard designs. In addition, each of these positions has corresponding staff-approved provisions in the respective design control documents (DCD) and these provisions already serve the purpose of applicable regulations for all of the situations identified by the NRC staff. NEI's statement that information in the DCD will constitute an applicable regulation confuses the difference between design descriptions approved by rulemaking and the regulations (safety standards) that are used as the basis to approve the design. During a meeting on April 25, 1994, and in a letter from Mr. Dennis Crutchfield (NRC) to Mr. William Rasin (NEI), dated July 25, 1994, the NRC staff stated that design information cannot function as a surrogate for the new (design-specific) applicable regulations because this information describes only one method for meeting the regulation and would not provide a basis for evaluating proposed changes to the previously approved design descriptions. The NRC needs the applicable regulations to evaluate proposed changes (§ 52.63) and requests for renewals (§ 52.59). Also, the technical positions that form the basis for the new applicable regulations were used during the reviews because the design-specific rulemaking for the new applicable regulations has been established in parallel with the design certification rulemaking, in accordance with Commission guidance.

In its third group of comments, NEI is concerned that "broadly stated" applicable regulations could be used in the future by the NRC staff to impose backfits on applicants and licensees that could not otherwise be justified on

the basis of adequate protection of public health and safety. However, NEI acknowledged in its comments that the NRC staff did not intend to reinterpret the applicable regulations to impose compliance backfits and because implementation of the applicable regulations was approved in the DCD, the NRC staff could not impose a backfit on the approved implementation without meeting the standards in the change process. In response to NEI's comments, the final design certification rules state that the standard designs meet the applicable regulations and by approving the design information that describes how these regulations were met, the potential for differing interpretations of the new applicable regulations has been minimized. Despite these assurances, the Commission has decided to include a special provision in Section 8(c) of this appendix for compliance backfits to the additional applicable regulations identified in Section 5(c) of this appendix.

Finally, in response to the comment that portions of some of the additional applicable regulations are requirements on an applicant or licensee who references this appendix, the Commission has removed those requirements from the new applicable regulations in Section 5(c) of this appendix and moved them to Section 4 of this appendix. Section 4 sets forth additional requirements applicable to applicants and licensees who reference this appendix.

4. Analysis of New Applicable Regulations.

In response to question 4 in the proposed design certification rules, NEI provided additional comments on the specific wording of each new applicable regulation. The following discussion responds to NEI's comments in the order that the new applicable regulations are listed in Section 5(c) of this appendix. Statements, in the following discussion, that indicate Commission approval of staff positions in SECY papers constitute "tentative" approval subject to the Commission's final decision in this design certification rulemaking.

Intersystem LOCA

Section 5(c)(1) imposes a requirement on the designer to reduce the possibility of a loss of coolant accident (LOCA) outside containment by designing as much of the systems and subsystems connected to the reactor coolant system (RCS) as possible to an ultimate rupture strength at least equal to the normal RCS operating pressure.

The requirements for resolving GSI 105, "Interfacing System LOCA at LWRs," were established in SECY-90-016, "Evolutionary Light Water Reactor (LWR) Certification Issues and Their Relationship to Current Regulatory Requirements," dated January 12, 1990, and the Staff Requirements Memorandum (SRM) dated June 26, 1990. The Commission position regarding ISLOCA protection is that future ALWR designs should reduce the possibility of a LOCA outside containment by designing, to the extent practicable, all systems and subsystems connected to the RCS to a pressure that would ensure reasonable protection against burst failure should the low-pressure system be subjected to full RCS pressure.

The Commission has determined that using a design pressure equal to 40 percent of the normal operating RCS pressure resolves this issue for the design because that value will provide sufficient design margin such that (1) the likelihood or rupture of the pressure boundary is low, (2) the likelihood

of intolerable leakage of flange joints or valve bonnets is reasonably low, and (3) an acceptably small number of piping components might undergo gross yielding. The Commission also notes that the degree of isolation or number of barriers (e.g., three isolation valves) is not sufficient justification for using low-pressure components that are practical to design to a higher pressure. For example, piping runs should always be designed to meet the higher pressure, as should all associated flanges, connectors, and packings, including valve stem seals, pump seals, heat exchanger tubes, valve bonnets, and RCS drain and vent lines. The design should attempt to reduce the level of pressure challenge to all systems and subsystems connected to the RCS should an ISLOCA occur. The Commission does recognize, however, that all systems must eventually interface with atmospheric pressure and that it would be difficult or prohibitively expensive to design certain large tanks and heat exchangers to a higher pressure.

GE provided acceptable justification for each interfacing system and component not designed to the higher pressure by demonstrating that it is not practicable to reduce the pressure challenge any further. GE also demonstrated a compensating isolation capability for each such interface. In NUREG-1503, Vol. 1, "Final Safety Evaluation Report [FSER] Related to the Certification of the Advanced Boiling Water Reactor Design - Main Report," the Commission concluded that the ABWR design meets the criteria of SECY-90-016 regarding ISLOCA prevention and mitigation. Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(1) of this appendix.

Comment Summary. NEI raised the following objections to the proposed wording of the regulations and GE raised similar objections:

- The phrases "the effects . . . shall be minimized" and "to the extent practical" are vague and subject to numerous interpretations. The state-of-the-art may change over time, and what is infeasible today may be practical in the future. If so, NRC's proposed language could be used to require a backfit to the standard design even though such a backfit would not be needed for adequate protection. This result would be destabilizing and contrary to the intent of design certification.

- Additionally, the phrase "the effects . . . shall be minimized" is inconsistent with "to the extent practical." It also deviates from the staff position in SECY-90-16 that the Commission approved in a Staff Requirements Memorandum (SRM) dated June 26, 1990, which does not require the effects of intersystem LOCAs to "be minimized."

- Finally, "withstand" has no standard definition, and could be subject to future reinterpretation. This is potentially exacerbated by the ABWR Final Safety Evaluation Report (FSER), p. 3-71, which states that the ABWR piping "nearly achieves" the staff's goal of 90% survival probability under ISLOCA conditions, and p. 3-72, which states the likelihood of rupture is "low." Given the language in the FSER, the staff in the future may attempt to use the proposed "applicable regulation" to impose backfits, which would be inconsistent with Part 52's purpose.

Response. In response to the comments from NEI and GE, the Commission has removed the phrases "the effects...shall be minimized," and "withstand" and has reworded the regulation to make it clearer and consistent with SECY-90-016. Finally, the term "to the extent practical" was modified to reflect

that the Commission intends to define practicality as the capabilities and means available at the time of design certification.

Inservice Testing of Pumps and Valves

Section 5(c)(2) imposes a requirement on the designer to allow for proper testing of pumps and valves. This requirement is necessary to ensure that adequate testing to verify operability can be conducted. For check valves in particular, the important issue is the ability to adequately monitor or assess the condition of the valve.

In the FSER, the staff states that a licensee will periodically test the performance and measure performance parameters of safety-related pumps and valves in accordance with ASME Code Section XI, as required by 10 CFR 50.55a(f). Periodic measurements of various parameters will be compared to baseline measurements to detect long-term degradation of the pump or valve performance. The tests, measurements, and comparisons will ensure the operational readiness of these pumps and valves. However, as discussed in SECY-90-016, the staff determined that ASME Code Section XI requirements do not assure the necessary level of component operability that is desired for evolutionary LWR designs. Accordingly, in SECY-90-016, as supplemented by the staff's April 27, 1990, response to comments by the ACRS, the staff recommended criteria to the Commission to be used to supplement Section XI of the ASME Code. In its SRM of June 26, 1990, on SECY-90-016, the Commission approved the staff's recommendations. Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(2) of this appendix.

Comment Summary. NEI raised the following objections to the proposed wording:

- With respect to paragraph (i), it is not always possible to test check valves at maximum design flow. Some check valves can only be tested at full system flow. Thus, paragraph (i) is not possible to implement fully.
- Paragraph (ii) relates to the inservice testing program, not to the design. Inservice testing programs are the responsibility of the applicant/licensee, and are not appropriate as an "applicable regulation" for the standard design. If the NRC believes that the requirements in this paragraph should be imposed on applicants and licensees, it should initiate rulemaking to amend Part 50 to do so.
- Additionally, the term "advanced non-intrusive techniques" is vague and its application will change as the state-of-the-art changes. Therefore, this provision is particularly susceptible to changing interpretations and potential backfits over time. This result would be destabilizing and contrary to the intent of design certification.

Response. The staff agrees with NEI's first comment. Paragraph (i) of the rule was rewritten to allow for less than maximum design flow. The staff believes that it is acceptable to exercise check valves with sufficient flow to fully-open the valve, provided the valve's full-open position can be positively confirmed, or with the maximum required accident flowrate.

With regard to NEI's second comment regarding the appropriateness of addressing applicant/licensee issues in the design certification rulemaking, the Commission has reconsidered its position and moved these issues to Section

4 of this appendix which sets forth requirements for applicants and licensees referencing this design certification rule. While it would be possible to amend 10 CFR 50.55a to reflect these IST requirements, the Commission believes it is better to consolidate the design certification-specific technical requirements which are applicable to plants referencing this design certification rule in the design certification rule itself.

Digital Instrumentation and Control Systems

Section 5(c)(3) imposes a requirement on the designer to consider the unique concerns related to the use of digital instrumentation and control (I&C) systems. The I&C systems of this design are microprocessor-based systems that share processing functions (software) and process equipment (hardware). Therefore, a hardware design error, a software design error, or a software programming error may cause redundant equipment to fail. The Commission is concerned that the use of digital computer technology could result in safety-significant common-mode failures (CMFs). CMFs could both defeat the redundancy achieved by the hardware architectural structure and result in the loss of more than one echelon of defense-in-depth provided by the I&C system. The two principal factors for defense against CMFs are quality and diversity. The Commission position on defense-in-depth and diversity for ALWRs, as discussed in the dated July 21, 1993, SRM in response to SECY-93-087, is as follows:

(1) The vendor or applicant shall assess the defense-in-depth and diversity of the proposed instrumentation and control system to demonstrate that vulnerabilities to CMFs have been adequately addressed.

(2) In performing the assessment, the vendor or applicant shall analyze each postulated event that is in the accident analysis section of the SAR using best-estimate methods. The vendor or applicant shall demonstrate adequate diversity within the design for each of these events.

(3) If a postulated CMF could disable a safety function, then a diverse means, with a documented bases that the diverse means is unlikely to be subject to the same CMF, shall be required to perform either the same function or a different function. The diverse or different function may be performed by a non-safety system if the system is of sufficient quality to perform the necessary function under the associated event conditions.

(4) A set of displays and controls located in the main control room (MCR) shall be provided for system-level actuation and control of critical safety functions. The displays and controls shall be independent and diverse from the safety computer system identified in items 1 and 3. Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(3) of this appendix.

Comment Summary. NEI commented that the terms "adequate defense" and "critical safety functions" are vague and subject to numerous interpretations.

Response. The Commission does not agree with NEI's comment. The terms are widely used in industry standards and the Commission has clearly found the design acceptable as it is.

Alternate Offsite Power Source to Non-Safety Equipment

Section 5(c)(4) imposes a requirement on the designer to include a second offsite power source and to ensure that it has sufficient capacity and capability to provide power to non-safety equipment sufficient to provide the operator with the capability to bring the plant to a safe shutdown, following a loss of the normal power supply and plant trip. The second offsite power source will significantly reduce the number of plant trips that involve a loss of power to the non-safety loads and require that the plant be shut down under natural circulation. Such an additional source of power would improve plant safety, because these events continue to be identified as more severe than the turbine-trip-only event in standard plant safety analysis reports.

The requirement for alternate sources of power for non-safety-related loads arose from an NRC policy issue. In SECY-91-078, the staff recommended that the Commission approve the staff's position that an evolutionary plant design should include an alternate power source to the non-safety-related loads, unless it can be demonstrated that the design margins are so great that transients resulting from a loss of non-safety power event are no more severe than those associated with the turbine-trip-only event in current existing plant designs. In its August 15, 1991 SRM, the Commission approved the staff's position. The staff, in its safety evaluation report (SER) for the EPRI Evolutionary Utility Requirements Document (URD) clarified the intent of this position by stating that: "...an alternate power source be provided to a sufficient string of non-safety loads so that forced circulation could be maintained, and the operator would have available to him the complement of non-safety equipment that would most facilitate his ability to bring the plant to a stable shutdown condition, following a loss of the normal power supply and plant trip." The staff believes that this issue provides defense-in-depth. Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(4) of this appendix.

Comment Summary. NEI commented that the terms "most facilitate" and "necessary complement of non-safety equipment" are vague and subject to numerous interpretations.

Response. The Commission has decided to modify the words to more specifically define the non-safety equipment required.

Offsite Power Source to Safety Divisions

Section 5(c)(5) imposes a requirement on the designer to ensure that faults from non-safety loads will not effect safety buses. Powering safety buses directly from an offsite power source is an NRC policy issue. The issue was raised by the staff because feeding safety buses from the offsite power sources through non-safety buses is not the most reliable configuration. In this configuration, the safety loads are subjected to transients caused by the non-Class 1E loads and add additional failure points between the offsite power sources and safety loads. To overcome these shortcomings, the staff recommended energizing the safety buses directly from the offsite power source's transformers.

In its August 15, 1991, SRM, on SECY-91-078, the Commission approved the position that an evolutionary plant design should include at least one offsite circuit to each redundant safety division supplied directly from one of the offsite power sources with no intervening non-safety buses in such a manner that the offsite source can power the safety buses upon a failure of any

non-safety bus. Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(5) of this appendix.

Comment Summary. NEI commented that although the staff found the designs acceptable, it is possible that in the future members of the NRC staff could determine that the designs do not satisfy the literal language of the NRC's proposed applicable regulation. In addition, GE commented that, as a result of further detailed design work, it did not believe that the ABWR design would meet the regulation.

Response The Commission has decided to modify the words to clarify design requirements for the offsite circuit to more clearly reflect the original intent. The ABWR design can now meet the intent of the proposed regulation.

Post-Fire Safe Shutdown

Section 5(c)(6) imposes a requirement on the designer to ensure that, among other things, the plant can be shutdown safely after a fire that renders all equipment in any one fire area inoperable.

As background information, the NRC established fire protection requirements for nuclear power plants in GDC 3, 10 CFR 50.48, and Appendix R to 10 CFR Part 50. The Commission considered Sections III.G, III.J, and III.O, and Appendix R to be of particular importance. In July 1981, NRC revised BTP APCS 9.5-1 (SRP Section 9.5.1) to include these provisions from Appendix R.

The Commission has also issued supplemental guidance on fire protection in documents such as Generic Letter (GL) 81-12 (45 FR 76602, November 19, 1981), dated February 20, 1981, and GL 86-10, dated April 24, 1986. GL 81-12 presents information on safe-shutdown methodology and GL 86-10 presents technical information on conformance with National Fire Protection Association codes and standards.

The Commission has concluded that fire protection issues raised through operating experience and through the External Events Program must be resolved for evolutionary ALWRs. To minimize fire as a significant contributor to the likelihood of severe accidents for advanced plants, the Commission concluded that current NRC guidance must be enhanced. The enhanced guidelines are discussed in SECY-90-016, "Evolutionary Light Water Reactor (LWR) Certification Issues and Their Relationship to Current Regulatory Requirements," dated January 12, 1990 and in SECY-93-087, "Policy, Technical, and Licensing Issues Pertaining to Evolutionary and Advanced Light Water Reactor (ALWR) Designs".

The Commission expects any new reactor design to propose fire protection systems based on the best technology available, not on the methods allowed for plants already operating or in the advanced stages of design and construction. Specifically, the Commission expects that the new designs will have improved separation of fire areas and that physical separation within an area will not generally be relied on. Therefore, the Commission evaluated the fire protection system of the standard designs against the new criteria of SRP Section 9.5.1 (BTP CMEB 9.5-1 Rev. 2), which meets the requirements of GDC 3.

Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(6) of this appendix.

Comment Summary NEI raised the following objections to the proposed wording and GE also raised similar objections:

- The reference in paragraph (i) to 10 CFR 50.48 is unnecessary. Section 50.48 is already applicable to plants that reference the ABWR or System 80+ through Section 52.83. Therefore, this reference is redundant and confusing.

- The reference to structures, systems and components "important to safety" in paragraphs (i) and (ii) is inappropriate and incorrect. Part 50, Appendix R, Section III.G.1.a, applies to structures, systems, and components "important to safe shutdown." Furthermore, this applicable regulation does not reflect the language in SECY-90-016, as approved by the Commission in the SRM dated June 26, 1990, which refers to "safe shutdown", not "important to safety" or "safety-related".

- The proposed "applicable regulation" contained in the ABWR FSER, p. 9-57, and in the System 80+ FSER, p. 9-57, recognized that because of "unique design layout", areas other than the containment and control room might be accepted on an individual basis. This provision was deleted in the proposed rule. As discussed on pages 9-59 to 9-61 of the ABWR FSER, the ABWR has certain exceptions to the general provision on separation (*e.g.*, in the main steam tunnel), and the NRC has found this to be acceptable. Without the allowance for "unique design layout," the currently-approved ABWR design might be found to be inconsistent with the "applicable regulation" on fire protection.

- Furthermore, because the allowance for "unique design layout" was in SECY-90-016, as approved by the Commission in the SRM dated June 26, 1990, the "applicable regulation" is inconsistent with the Commission's previous directions.

- The term "to the extent practical" is vague and subject to numerous interpretations. Additionally, as the state-of-the-art evolves, what is "practical" will evolve, resulting in the potential for destabilizing backfits to the standard design.

Response The Commission has decided to modify the wording. Paragraph (i) of the regulation has been deleted in response to the first comment. The references to SSCs that are "important to safety" have been changed to "important to safe shutdown" in response to the second comment. The exception for the main steam tunnel was added to address the third and fifth comments. Finally, the term "to the extent practical" was modified to reflect that the Commission intends to define practicality as the capabilities and means available at the time of design certification.

Analysis of External Events

Section 5(c)(7) imposes a requirement on the designer to include both internal and external events in the design-specific probabilistic risk assessment. In its July 21, 1993 SRM on SECY-93-087, the Commission approved several positions related to this topic including: (1) the requirement that the analyses submitted in accordance with 10 CFR 52.47 include an assessment of internal events; (2) the use of 1.67 times the design basis safe shutdown earthquake for a margin-type assessment of seismic events; and (3) the requirement that the ALWR vendors should perform bounding analyses of site-

specific external events likely to be a challenge to the plant. In Generic Letter 88-20, "Individual Plant Examinations for Severe Accident Vulnerabilities - 10 CFR 50.54(f)" and its supplements, the NRC staff stated that construction permit holders and power reactor licensees should consider the safety implications of both internal and external events. Such consideration should involve performing separate individual plant examinations (IPEs) and individual plant examinations for external events. PRAs and IPEs that have evaluated both internal and external events generally estimate the risks from external events to be the same order of magnitude as internal events. Therefore, the Commission concluded that the design-specific PRAs required in 10 CFR 52.47 should include an assessment of both internal and external events.

Lessons from past risk-based studies indicate that fire, internal floods, and seismic events can be important potential contributors to core damage. However, the estimates of the core damage frequencies for fire and seismic events continue to include considerable uncertainty. Consequently, the Commission concluded that fire and seismic event can be evaluated using simplified probabilistic methods and margin methods similar to those developed for existing plants, supported by insights from internal event PRAs, including ALWR design-specific PRAs. The designer should use traditional probabilistic techniques to study internal floods. These techniques include the development of event trees and fault trees analysis; the definition of accident sequences, an analysis of plant systems and their operation, the development of data base for initiating events, component failures, and human errors; and an assessment of accident-sequence frequencies.

The Commission determined that the plant designer can best determine the seismic capability of the plant through a combined approach that takes advantage of the strengths of both PRA and margins methods. This approach (based on an internal events PRA, its existing event and fault trees, and its random failures and human errors) allows for a comprehensive and integrated treatment of the plant's response to an earthquake. This approach should yield meaningful measures of a proposed design's seismic capability.

The major difference between a seismic PRA and the proposed PRA-based margins approach is that the latter does not combine fragility curves with hazard curves. Rather, the PRA-based margins approach measures the robustness of the plant to withstand earthquakes of a given ground acceleration level. This method eliminates the need to deal with uncertainty in the seismic hazard curve for the site and identifies potential design-specific seismic vulnerabilities. Understanding these vulnerabilities may be useful in developing the reliability assurance programs, identifying operator training requirements, and focus on accident management capabilities.

The Commission believes that it is important to fully understand potentially significant seismic vulnerabilities and other seismic insights. The Commission concluded that this information would be captured by a PRA-based seismic margins analysis that considers sequence-level high confidence in low probability of failure (HCLPF) values and fragilities for all sequences leading to core damage or containment failures up to approximately one and two-thirds of the SSE.

Based on the FSER, the Commission concludes that the design-specific PRA submitted by GE satisfies Section 5(c)(7) of this appendix.

Comment Summary. There were no technical comments on this applicable regulation.

Alternate AC Power Source

Section 5(c)(8) imposes a requirement on the designer to include an on-site alternate AC power source in the design to deal with station blackout conditions. As background information, the staff developed a policy issue in SECY-90-016, dated January 12, 1990, that was approved by the Commission on June 26, 1990, which requires that the evolutionary ALWRs meet the requirements of the station blackout (SBO) rule by including an alternate AC power source (e.g., CTG) of diverse design capable of powering at least one complete set of normal shutdown loads and to back up the EDGs. The Commission's policy is that a coping analysis or a less capable alternate AC source would not be acceptable because the CTG provides the operator with power to more equipment to cope with the event, and does not require complicated operator actions to shed loads. Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(8) of this appendix.

Comment Summary. NEI commented that the NRC staff's language does not reflect the specifics of each of the standard designs. Moreover NEI stated that, as written, the "applicable regulation" appears to conflict with the regulation that already governs use of an alternate AC power source, § 50.63.

Response. The Commission did not necessarily intend that the language for each regulation be different for each design. The staff clearly stated the requirement that the designs were evaluated against. This requirement is meant to be more restrictive than 50.63 in that an alternate AC source that is fully capable of powering at least one complete set of equipment necessary to achieve and maintain safe-shutdown is the required approach.

Core Debris Cooling

Section 5(c)(9) imposes requirements on the designer to include features to enhance core debris cooling in the design. As background information, core debris coolability and quenchability have been the subject of extensive research over the past decade; however, much uncertainty still exists relative to this phenomenon which will most likely not be resolved in the near future. Because of this uncertainty, the Commission decided that the question is not whether coolability or quenchability has been achieved or can be achieved; but rather, what is the impact on the containment design if they are not achieved.

Corium-concrete interaction (CCI) is a severe-accident phenomenon that involves the melting and decomposition of concrete in contact with molten core debris. This phenomenon may occur following accident sequences which result in molten core debris breaching the reactor vessel and spreading onto the floor of the reactor cavity. The thickness of the layer of core debris within the reactor cavity depends upon the amount of core debris, its spreadability, and the area of the reactor cavity floor. Once on the reactor cavity floor, the molten core debris may react with the concrete and any available water producing non-condensable gases, water vapor, and heat from exothermic reactions.

CCI can challenge the containment by various mechanisms including: pressurization from non-condensable gas and steam generated, destruction of structural support members, and melt-through of the containment liner. Non-condensable gases, primarily carbon dioxide, carbon monoxide, and hydrogen, are released from the concrete as it decomposes and are formed from reactions between water and metals within the molten core debris. The core debris and concrete are heated from the combined effects of decay heat and exothermic chemical reactions.

In its July 21, 1993, SRM on SECY-93-087, the Commission approved the position that both the evolutionary and passive LWR designs meet the following criteria: (1) provide reactor cavity floor space to enhance debris spreading; (2) provide a means to flood the reactor cavity to assist in the cooling process; (3) protect the containment liner and other structural members with concrete if necessary; and (4) ensure that the best-estimate environmental conditions (pressure and temperature) resulting from core-concrete interactions do not exceed ASME Code Service Level C limits for steel containments or factored load category for concrete containments, for approximately 24 hours. In addition, ensure that the containment capability has margin to accommodate uncertainties in the environmental conditions from CCIs.

Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(9) of this appendix.

Comment Summary. NEI raised the following objections to the proposed wording and GE also raised similar objections:

- The terms "reduce the potential for," "enhance," "assist in the cooling process," and "most significant" are vague and subject to numerous interpretations.

- The term "structural members" lacks specificity.

- The term "best-estimate" is open-ended, and could lead to needless recalculations of "estimates" as the state-of-the-art evolves.

- Finally, the ABWR standard design currently only provides a capability to withstand environmental conditions of some severe accident scenarios for 8 to 20 hours, and the FSER has found that acceptable. (FSER, pp. 19-54 and 55) In this regard, the FSER, pp. 19-53, states that the 24-hour period was intended as a "guideline," which is inconsistent with incorporating it in an "applicable regulation."

Response The Commission has decided to modify the wording. The specific severe accident sequences have been identified instead of using the term "most significant." The size of the reactor cavity floor space and the actual structural members of concern have also been identified. To address the comment on the term "best estimate," the section of the DCD that defines the environmental conditions is now cited. Finally, to address the concern over the term "approximately 24 hours," a sufficiency standard has been added.

High Pressure Core Melt Ejection

Section 5(c)(10) imposes a requirement on the designer to include a means to depressurize the reactor coolant system and cavity design features to mitigate the effects of a high pressure core melt ejection accident. As background information, in its June 26, 1990, SRM on SECY-90-016, the Commission approved the position that evolutionary LWR designs should have a

depressurization system and cavity design features to contain ejected core debris. In addition, the Commission stated that the cavity design, as a mitigating feature, should not unduly interfere with such operations as refueling, maintenance, or surveillance.

In its July 21, 1993, SRM on SECY-93-087, the Commission modified its position slightly and approved the general criteria that the evolutionary LWR designs should have a reliable depressurization system and cavity design features to decrease the amount of ejected core debris that reaches the upper containment.

On the basis of engineering judgment, the Commission believes that examples of cavity design features that will decrease the amount of ejected core debris reaching the upper containment are ledges or walls that would deflect core debris and a tortuous path from the reactor cavity to the upper containment.

Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(10) of this appendix.

Comment Summary. NEI commented that the terms "reliable means" and "reduce the amount" are vague and subject to numerous interpretations. NEI also stated that what is considered "reliable" may change as the state-of-the-art changes, leading to the potential for destabilizing backfits to the standard designs.

Response. The Commission has decided to modify the wording to allow for a safety-related depressurization system for this application. The Commission did not remove the phrase "reduce the amount" because it believes that it is the most appropriate wording based on the engineering judgement involved in the review.

Equipment Survivability

Section 5(c)(11) imposes a requirement on the designer to perform analyses to demonstrate that certain equipment and instrumentation can function under severe accident environmental conditions. As background information, in its SRM of July 21, 1983, on SECY-93-087, the Commission approved the position that for the review of the credible severe-accident scenarios for ALWRs, the Commission will evaluate the design certification applicant's identification of the equipment needed to perform mitigative functions as well as the conditions under which the mitigative systems must operate.

Beyond design basis events can generally be categorized into in-vessel and ex-vessel severe accidents. The environmental conditions resulting from these events are generally more limiting than those from design bases events. The Commission established a criterion to provide a reasonable level of confidence that the necessary equipment will function in the severe accident environment for the time span for which it is needed. This criterion is commonly referred to as "equipment survivability" and is fundamentally different from equipment qualification.

The applicable criteria for mechanical and electrical equipment and instrumentation required for recovery from in-vessel severe accidents are provided in 10 CFR 50.34(f):

- Part 50.34(f)(2)(ix)(c) states that equipment necessary for achieving and maintaining safe shutdown of the plant and maintaining containment

integrity will perform its safety function during and after being exposed to the environmental conditions attendant with the release of hydrogen generated by the equivalent of a 100 percent fuel-clad metal-water reaction including the environmental conditions created by activation of the hydrogen control system.

- Part 50.34(f)(3)(v) states that systems necessary to ensure containment integrity shall be demonstrated to perform their function under conditions associated with an accident that releases hydrogen generated from 100 percent fuel-clad metal-water reaction.

- Part 50.34(f)(2)(xvii) requires instrumentation to measure containment pressure, containment water level, containment hydrogen concentration, containment radiation intensity, and noble gas effluents at all potential accident release points.

- Part 50.34(f)(2)(xix) requires instrumentation adequate for monitoring plant conditions following an accident that includes core damage.

The applicable criteria for mechanical and electrical equipment required to mitigate the consequences of ex-vessel severe accidents are discussed in the Equipment Survivability section of SECY-90-016. In its SRM of June 26, 1990, relating to SECY-90-016, the Commission approved the position that features provided only for severe-accident protection, prevention and mitigation (i.e. not required for design basis accidents) need not be subject to the 10 CFR 50.49 environmental qualification requirements; 10 CFR Part 50, Appendix B quality assurance requirements; and 10 CFR Part 50, Appendix A redundancy/diversity requirements. The reason for this judgement is that the Commission believes that severe core damage accidents should not be treated as design basis accidents (DBAs).

However, mitigation features must be designed to provide reasonable assurance that they will operate in the severe-accident environment for which they are intended and over the time span for which they are needed. In cases where safety-related equipment (equipment provided for DBAs) is relied upon to cope with severe accident situations, there should be reasonable assurance that this equipment will survive accident conditions for the period that is needed to perform its intended function.

Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(11) of this appendix.

Comment Summary. NEI raised the following objections to the proposed wording:

- The term "needed" is inappropriate because severe accident features are not "needed" to satisfy NRC regulations or assure the adequate protection of public health and safety.

- Further, the term "best available" and "best-estimate" are open-ended, and could lead to needless re-evaluations and the potential for backfits as the state-of-the-art evolves. Such a result is very likely to occur, because research regarding the effects of severe accidents is still in its infancy, and knowledge of severe accident phenomena is rapidly increasing.

Additionally, requirements for use of the "best-available" method and "best-estimates" deviate from the provision in SECY-90-16 that was approved by the Commission in the SRM dated June 26, 1990, which only required "reasonable assurance" of equipment survivability.

Response. The Commission has decided to modify the words in response to these comments. The analytical techniques available at the time of the design certification were deemed to be acceptable and the specific environmental conditions were referenced.

Containment Performance

Section 5(c)(12) imposes a requirement on the designer to include features intended to limit the conditional containment failure probability. As background information, the Commission's approach for ensuring containment survivability from severe accident challenges consists of requiring inclusion of accident prevention and consequence mitigation features and the containment performance goal (CPG). The CPG ensures that the containment would perform its function in the face of most severe-accident challenges and that the design (including its mitigation features) would be adequate if called upon to mitigate a severe accident.

Two alternative CPGs were identified in SECY-90-016: a conditional containment failure probability (CCFP) of 0.1 or a deterministic CPG that offers comparable protection. In its June 26, 1990, SRM, the Commission approved the use of the 0.1 CCFP as a basis for establishing regulatory guidance for evolutionary ALWRs. In assessing the probability of containment failure, two definitions of containment failure were considered. These include a CCFP based on structural integrity and on a dose definition. The Commission also directed that the use of a 0.1 CCFP should not be imposed as a requirement, and that the use of the CCFP should not discourage accident prevention.

The FSER contains the staff's analysis of the design features that contribute to limiting the CCFP and their evaluation of the severe accident phenomena that are mitigated by these design features. Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(12) of this appendix.

Comment Summary. NEI commented that the terms "limit" and "more likely" are vague and subject to numerous interpretations.

Response. The Commission has decided to modify the wording. The new regulation defines the CCFP limit as 0.1 and identifies the DCD section which lists the severe accident sequences that are subject to this requirement.

Shutdown Risk

Section 5(c)(13) imposes a requirement on the designer to perform specific assessments of the design with regard to shutdown risk. As background information, various incidents occurring at nuclear power plants during low power and shutdown operation modes over the past several years have raised Commission concerns regarding plant vulnerability during these operating modes. The Commission conducted a comprehensive review of low-power and shutdown operations including hot shutdown, cold shutdown, and refueling at all nuclear plants and other shutdown-related issues identified by foreign regulatory organizations and the NRC. The findings of the review were published in NUREG-1449, "Shutdown and Low Power Operation at Commercial Nuclear Power Plants in the United States."

In SECY-90-016, the Commission identified reduced inventory operation as a significant safety issue. In SECY-93-190, "Regulatory Approach to Shutdown and Low-Power Operations," the Commission discussed the advantages and disadvantages of a proposed rulemaking to establish new regulatory requirements for shutdown and low-power operations in the following areas: outage planning and control, technical specifications, fire protection, and instrumentation.

Based on the above, the Commission required that the designer perform a systematic examination of shutdown risk, including evaluation of specific design features that minimize shutdown risk, quantification of the reliability of the decay heat removal systems, identification of any vulnerabilities introduced by new design features and consideration of fires and floods with the plant in modes other than full power.

The Commission reviewed the applicant's submittals and found that the PRA shutdown risk evaluation was acceptable. Further, the Commission concluded that the designer adequately addressed the shutdown risk concerns in NUREG-1449 and has demonstrated that the design will not introduce significant risk during shutdown operations. Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(13) of this appendix.

Comment Summary. NEI raised the following objections to the proposed wording:

- The terms "systematic," "minimize," "new design features," and "modes other than full power" are vague and subject to numerous interpretations.

- Paragraph (ii) relates to the COL applicant, not the standard design. It is not appropriate as an "applicable regulation" for the standard design. If the NRC believes that the requirements in this paragraph should be imposed on applicants and licensees, it should initiate a rulemaking to amend Part 50 to do so.

- In this regard, NRC has already initiated a rulemaking proceeding to amend Part 50 to include requirements related to shutdown conditions. (See 59 Fed. Reg. 52707 (October 19, 1994).) The NRC should not pre-empt or prejudge the results of that rulemaking by imposing an "applicable regulation" on shutdown conditions.

Response. The Commission has decided to modify the wording. In response to the first comment, the wording has been made more specific where possible. In response to the second and third comments regarding the appropriateness of addressing applicant/licensee issues in the design certification rulemaking, the Commission has reconsidered its position and moved these issues to Section 4 of this appendix which sets forth requirements for applicants and licensees referencing this design certification rule. While the Commission has initiated a rulemaking proceeding to amend Part 50 to include requirements related to shutdown conditions, the Commission believes it is better to consolidate the design certification-specific technical requirements which are applicable to plants referencing this design certification rule in the design certification rule itself.

B. Responses to specific requests for comment.

Only two commenters addressed the specific requests for comments that were set forth in section IV of the proposed rule. These commenters were NEI

and the Ohio Citizens for Responsible Energy, Inc. (OCRE). The following discussion provides a summary of the comments and the Commission's response to each of the specific requests.

1. Should the requirements of 10 CFR 52.63(c) be added to a new 10 CFR 52.79(e)?

Comment Summary. OCRE agreed that the requirements of 10 CFR 52.63(c) should be added to a new 10 CFR 52.79(e) and NEI had no objection, as long as the substantive requirements in § 52.63(c) were not changed.

Response. Because there is no objection to adding the requirements of 10 CFR 52.63(c) to Subpart C of Part 52, as 10 CFR 52.79(e), the Commission will consider this amendment as part of a future review of Part 52. This future review will also consider lessons learned from this rulemaking and will determine if 10 CFR 52.63(c) should be deleted from Subpart B of Part 52.

2. Are there other words or phrases that should be defined in Section 2 of the proposed rule?

Comment Summary. Neither NEI nor OCRE suggested other words or phrases that need to be added to the definition section. However, NEI recommended expanded definitions for specific terms in Section 2 of the proposed rule.

Response. The Commission has revised Section 2 of this appendix as a result of comments from NEI and DOE. A discussion of these changes is provided in section II.C.2 and II.C.3.

3. What change process should apply to design-related information developed by a combined license (COL) applicant or holder that references this design certification rule?

Comment Summary. OCRE recommended the change process in Section 8(b)(5)(i) of the proposed rule and stated that it is essential that any design-related COL information including the plant-specific PRA (and changes thereto) developed by the COL applicant or holder not have issue preclusion and be subject to litigation in any COL hearing. NEI recommended that the COL information be controlled by 10 CFR 50.54 and 50.59 but recognized that the COL applicant or holder must also consider impacts on Tier 1 and Tier 2 information.

Response. The Commission will develop a change process for the plant-specific information submitted in a COL application that references this design certification as part of a future review of Part 52. The Commission expects that the change process for the plant-specific portion of the COL application will be similar to Section 8(b)(5). This approach is generally consistent with the recommendations of OCRE and NEI.

The Commission agrees with OCRE that the plant-specific portion of the COL application will not have issue preclusion in the COL proceeding. A discussion of the information that will have issue preclusion is provided in section II.A.1.

4. Are each of the applicable regulations set forth in Section 5(c) of the proposed rule justified?

Comment Summary. OCRE found each of the applicable regulations to be justified and stated that these requirements are responsive to issues arising from operating experience and will greatly reduce the risk of severe accidents

for plants using these standard designs. NEI believes that none of the applicable regulations are justified and stated that they are legally and technically unnecessary, could give rise to unwarranted backfits, are destabilizing and, therefore, contrary to the purpose of 10 CFR Part 52.

Response. The Commission has determined that applicable regulations are necessary, as described in section II.A.3. The justification for the specific wording of each applicable regulation is described in section II.A.4.

5. Section 8(b)(5)(i) authorizes an applicant or licensee who references the design certification to depart from Tier 2 information without prior NRC approval if the applicant or licensee makes a determination that the change does not involve a change to Tier 1 or Tier 2* information, as identified in the DCD; the technical specifications; or an unreviewed safety question, as defined in Sections 8(b)(5)(ii) and (iii). Where Section 8(b)(5)(i) states that a change made pursuant to that paragraph will no longer be considered as a matter resolved in connection with the issuance or renewal of a design certification within the meaning of 10 CFR 52.63(a)(4), should this mean that the determination may be challenged as not demonstrating that the change may be made without prior NRC approval or that the change itself may be challenged as not complying with the Commission's requirements?

Comment Summary. OCRE believes that the process for making plant-specific departures from Tier 2, as well as the substantive aspect of the change itself, should be open to challenge, although OCRE believes that the second aspect is the more important. By contrast, NEI argued that neither the departure process nor the change should be subject to litigation in any licensing hearing. Rather, NEI argued that any person who wished to challenge the change should raise the matter in a petition for an enforcement action under 10 CFR 2.206.

Response. The Commission has determined that an interested person should be provided the opportunity to challenge, in an appropriate licensing proceeding, whether the licensee properly complied with the Tier 2 departure process. Therefore, Section 8(b)(5) of this Appendix has been modified. The scope of finality for plant-specific departures is discussed in greater detail in section II.A.1 above.

6. How should the determinations made by an applicant or licensee that changes may be made under Section 8(b)(5)(i) without prior NRC approval be made available to the public in order for those determinations to be challenged or for the changes themselves to be challenged?

Comment Summary. OCRE recommends that the determinations and descriptions of the changes be set forth in the COL application and that they should be submitted to the NRC after COL issuance. Any person wishing to challenge the determinations or changes should file a petition pursuant to 10 CFR 2.206. NEI recommends submitting periodic reports that summarize departures made under Section 8(b)(5) to the NRC pursuant to Section 9(b) of the proposed design certification rules, consistent with the existing process for NRC notifications by licensees under 10 CFR 50.59. These reports will be available in the NRC's Public Document Room.

Response. The Tier 2 departure process in Section 8(b)(5) and the respective reporting requirements in Section 9(b) of the proposed design certification rule [Section 10(b) of this appendix] were based on 10 CFR

50.59. It therefore seems reasonable that the information collection and reporting requirements that should be used to control Tier 2 departures made in accordance with Section 8(b)(5) should generally follow the regulatory scheme in 10 CFR 50.59 (except that the requirements should also be applied to COL applicants), absent countervailing considerations unique to the design certification and combined license regulatory scheme in Part 52. OCRE's proposal raises policy considerations which are not unique to this design certification, but are equally applicable to the Part 50 licensing scheme. In fact, OCRE has submitted a petition (see 59 FR 30308; June 13, 1994) which raises the generic matter of public access to licensee-held information. In view of the generic nature of OCRE's concern and the pendency of OCRE's petition, which independently raises this matter, the Commission concludes that this rulemaking should not address and resolve this matter.

7. What is the preferred regulatory process (including opportunities for public participation) for NRC review of proposed changes to Tier 2* information and the commenter's basis for recommending a particular process?

Comment Summary. OCRE recommends either an amendment to the license application or an amendment to the license, with the requisite hearing rights. NEI recommends NRC approval by letter with an opportunity for public hearing only for those Tier 2* changes that also involve either a change in Tier 1 or technical specifications, or an unreviewed safety question.

Response. The Commission has developed a change process for Tier 2* information, as described in sections II.A.2 and III.H, which essentially treats the proposed departure as a request for a license amendment with an opportunity for hearing. Since Tier 2* departures require NRC review and approval, and involve a licensee departing from the requirements of this appendix, the Commission regards such requests for departures as analogous to license amendments. Accordingly, Section 8(b)(6) specifies that such requests will be treated as requests for license amendments, and that the proposed Tier 2* departure shall not be considered to be matters resolved by this rulemaking.

8. Should determinations of whether proposed changes to severe accident issues constitute an unreviewed safety question use different criteria than for other safety issues resolved in the design certification review and, if so, what should those criteria be?

Comment Summary. OCRE supports the concept behind the criteria in the proposed rule for determining if a proposed change to severe accident issues constitutes an unreviewed safety question, but proposes changes to the criteria. NEI agrees with the criteria in the proposed rule but recommends an expansion of the scope of information that would come under the special criteria for determining an unreviewed safety question.

Response. The Commission disagrees with the recommendations of both NEI and OCRE. The Commission has decided to retain the special change process in Section 8(b)(5) of the proposed rule for severe accident information, as described in section II.A.2.

9. (a)(1) Should construction permit applicants under 10 CFR Part 50 be allowed to reference design certification rules to satisfy the relevant requirements of 10 CFR Part 50?

(2) What, if any, issue preclusion exists in a subsequent operating license stage and NRC enforcement, after the Commission authorizes a construction permit applicant to reference a design certification rule?

(3) Should construction permit applicants referencing a design certification rule be either permitted or required to reference the ITAAC? If so, what are the legal consequences, in terms of the scope of NRC review and approval and the scope of admissible contentions, at the subsequent operating license proceeding?

(4) What would distinguish the "old" 10 CFR Part 50 2-step process from the 10 CFR Part 52 combined license process if a construction permit applicant is permitted to reference a design certification rule and the final design and ITAAC are given full issue preclusion in the operating license proceeding? To the extent this circumstance approximates a combined license, without being one, is it inconsistent with Section 189(b) of the Atomic Energy Act (added by the Energy Policy Act of 1992) providing specifically for combined licenses?

(b)(1) Should operating license applicants under 10 CFR Part 50 be allowed to reference design certification rules to satisfy the relevant requirements of 10 CFR Part 50?

(2) What should be the legal consequences, from the standpoints of issue resolution in the operating license proceeding, NRC enforcement, and licensee operation if a design certification rule is referenced by an applicant for an operating license under 10 CFR Part 50?

(c) Is it necessary to resolve these issues as part of this design certification, or may resolution of these issues be deferred without adverse consequence (e.g., without foreclosing alternatives for future resolution).

Comment Summary. OCRE argued that a construction permit applicant should be allowed to reference design certifications and that the applicant be required to reference ITAAC because they are Tier 1. OCRE indicated that in a construction permit hearing, those issues representing a challenge to the design certification rule would be prohibited pursuant to 10 CFR 2.758. At the operating license stage, only an applicant whose construction permit referenced a design certification rule should be allowed to reference the design certification. In the operating license hearing, issues would be limited to whether the ITAAC have been met. Requiring a construction permit applicant to reference the ITAAC would not be the same as a combined license under Part 52, in OCRE's view, apparently because the specific hearing provisions of 10 CFR 52.103 would not be employed. Finally, OCRE argued that resolution of these issues could be safely deferred because the circumstances with which these issues attend are not likely to be faced.

NEI also argued that a construction permit applicant should be allowed to reference design certifications. However, NEI believed that the applicant should be permitted, but not required, to reference the ITAAC. If the applicant did not reference the ITAAC, then "construction-related issues" would be subject to both NRC review and an opportunity for hearing at the operating license stage in the same manner as construction-related issues in current Part 50 operating license proceedings. NEI reiterated its view that design certification issues should be considered resolved in all subsequent NRC proceedings. With respect to deferring a Commission decision on the matter, NEI suggested that these issues be resolved now because the industry wishes to "reinforce" the permissibility of using a design certification in a Part 50 proceeding. Further, NEI argues that deletion of all mention of

construction permits and operating licenses in the design certification rule could be construed as indicating the Commission's desire to preclude a construction permit or operating license applicant from referencing a design certification.

Response. Although Part 52 provides for referencing of design certification rules in Part 50 applications and licenses, the Commission wishes to reserve for future consideration whether a Part 50 applicant should be permitted to reference this design certification and, if so, should be permitted or required to reference the ITAAC. This decision is due to the manner in which ITAAC were developed for this appendix and recognition of the lack of experience with design certifications in combined licenses, in particular the implementation of ITAAC. Therefore, the Commission has decided to defer a decision on this matter. Section 4 of this Appendix contains an explicit reservation of this matter in order to avoid any uncertainty with respect to the Commission's intent.

C. Other Issues

1. NRC Verification of ITAAC Determinations.

Comment Summary. In Attachment B of its comments (pp. 58-66), NEI raised an industry concern regarding the matters to be considered by the NRC in verifying inspections, tests, analyses, and acceptance criteria (ITAAC) determinations pursuant to 10 CFR 52.99, specifically citing quality assurance and quality control (QA/QC) deficiencies. Although this issue was not specifically addressed in the proposed design certification rule, the following response is provided because of its importance relative to future considerations of the successful performance of ITAAC for a nuclear power facility.

Response. The NRC disagrees with any assertion that QA/QC deficiencies have no relevance to the NRC determination of whether ITAAC have been successfully completed. Simply confirming that an ITAAC had been performed in some manner and a result obtained apparently showing that the acceptance criteria had been met would not be sufficient to support a determination that the ITAAC had been successfully completed. The manner in which an ITAAC is performed can be relevant and material to the results of the ITAAC. For example, in conducting an ITAAC to verify a pump's flow rate, it is logical, even if not explicitly specified in the ITAAC, that the gauge used to verify the pump flow rate must be calibrated in accordance with relevant QA/QC requirements and that the test configuration is representative of the final as-built plant conditions (i.e. valve or system line-ups, gauge locations, system pressures or temperatures). Otherwise, the acceptance criteria for pump flow rate in the ITAAC could apparently be met while the actual flow rate in the system could be much less than that required by the approved design.

The NRC has determined that a QA/QC deficiency may be considered in determining whether an ITAAC has been successfully completed if: (1) the QA/QC deficiency is directly and materially related to one or more aspects of the relevant ITAAC (or supporting Tier 2 information); and (2) the deficiency (considered by itself, with other deficiencies, or with other information known to the NRC) leads the NRC to question whether there is a reasonable basis for concluding that the relevant aspect of the ITAAC has been successfully completed. This approach is consistent with the NRC's current methods

for verifying initial test programs. The NRC recognizes that there may be programmatic QA/QC deficiencies that are not relevant to one or more aspects of a given ITAAC under review and, therefore, should not be relevant to or considered in the NRC's determination as to whether an ITAAC has been successfully completed. Similarly, individual QA/QC deficiencies unrelated to an aspect of the ITAAC in question would not form the basis for an NRC determination that an ITAAC has not been met. Using the ITAAC for pump flow rate example, a specific QA deficiency in the calibration of pump gauges would not preclude an NRC determination of successful ITAAC completion if the licensee could demonstrate that the original deficiency was properly corrected (e.g., analysis, scope of effect, root cause determination, and corrective actions as appropriate), or that the deficiency could not have materially affected the test in question.

Furthermore, although the Tier 1 information was developed to focus on the performance of the structures, systems, and components of the design, the information contains implicit quality standards. For example, the design descriptions for reactor and fluid systems describe which systems are "safety-related;" important piping systems are classified as "Seismic Category I" and identify the ASME Code Class; and important electrical and instrumentation and control systems are classified as "Class 1E." The use of these terms by the evolutionary plant designers was meant to ensure that the systems would be built and maintained to the appropriate standards. Quality assurance deficiencies for these systems would be assessed for their impact on the performance of the ITAAC, based on their safety significance to the system. The QA requirements of 10 CFR Part 50, Appendix B, apply to safety-related activities. Therefore, the Commission anticipates that, because of the special significance of ITAAC related to verification of the facility, the licensee will implement similar QA processes for ITAAC activities that are not safety-related.

During the ITAAC development, the design certification applicants determined that it was impossible (or extremely burdensome) to provide all details relevant to verifying all aspects of ITAAC (e.g., QA/QC) in Tier 1 or Tier 2. Therefore, the NRC staff accepted the applicants' proposal that top-level design information be stated in the ITAAC to ensure that it was verified, with an emphasis on verification of the design and construction details in the "as-built" facility. To argue that consideration of underlying information which is relevant and material to determining whether ITAAC have been successfully completed ignores the history of ITAAC development. In summary, the Commission concludes that information such as QA/QC deficiencies which are relevant and material to ITAAC may be considered by the NRC in determining whether the ITAAC have been successfully completed. Despite this conclusion, the Commission has decided to add a provision to Section 9(b) of this appendix, which was requested by NEI. This provision requires the NRC's findings that the prescribed acceptance criteria have been met to be based solely on the inspections, tests, and analyses. The Commission has added this provision, which is fully consistent with 10 CFR Part 52, with the understanding that it does not affect the manner in which the NRC intends to implement 10 CFR 52.99 and 52.103(g), as described above.

Licensee Documentation of ITAAC Verification

A related concern was raised by Mr. R. P. McDonald of the Advanced Reactor Corporation at the public meeting on December 4, 1995, regarding the type and quantity of information that must be submitted by a licensee to certify that an ITAAC has been successfully completed. While this issue also was not addressed in the proposed rule, this response is provided because of its importance to the industry regarding the performance of ITAAC. This response represents current NRC thinking on this subject and is not part of the Commission's binding determination in this rulemaking.

The documentation requirements for a facility that is licensed under 10 CFR Part 52 are similar to the documentation requirements under Part 50. The difference is that under Part 52 the documentation should be formatted to demonstrate the bases for completion of ITAAC. In general, sufficient information must be submitted to the NRC to adequately document the bases for the conclusion that the ITAAC have been successfully performed and the acceptance criteria have been met. However, this information is expected to be summarized because the NRC does not intend that all the details of the inspections, tests, and analyses related to a specific ITAAC must be submitted.

The licensee should certify to the NRC that an ITAAC has been successfully completed and that the acceptance criteria have been met. The certification letter should identify the specific ITAAC(s) that have been completed; it should identify, in summary form, the bases for the conclusion that the ITAAC have been met; and it should identify the location of any supporting documentation that is available for audit. The supporting documentation may include items such as test reports, engineering analyses, calculations, drawings, vendor component tests, inspections, quality assurance records, and other facility records. NEI provided a preliminary conceptual example of this type of letter in a meeting with the NRC staff on March 15, 1995, as documented in a meeting summary dated April 7, 1995. However, the specific bases for satisfaction of any particular ITAAC must be established by each licensee.

The design descriptions and functional system drawings available for review during the design certification and COL application stages were sufficient to perform licensing reviews and make final safety determinations but are not adequate for actual construction or construction inspection activities. Therefore, before construction begins on any given portion of the facility, the licensee must ensure that the certified design plus site-specific design information in the COL application, including that required by the design acceptance criteria (DAC), has been translated into detailed, plant-specific, design and construction drawings. The level of detail in the certified design and the use of DAC allow for some variation in implementing the certified design. The applicant or licensee also has some flexibility in completing the final design for Tier 2 design information, by means of the Tier 2 change process. The ITAAC will verify that the as-built facility will operate in accordance with the approved design and applicable regulations. Therefore, the licensee should ensure that the drawings and other documentation reflect the final as-built configuration of the facility so that they can be used as part of the bases, where appropriate, for completion of the ITAAC.

NRC Inspection

The licensee bears the responsibility for performing ITAAC. The NRC must verify through its inspection program that the ITAAC have been performed by the licensee in an acceptable manner, thereby ensuring there is reasonable assurance that the facility has been built and will operate in accordance with the license and applicable regulations. SECY-94-294, "Construction Inspection and ITAAC Verification," discussed the development of a construction inspection program to accommodate the requirements of future reactors licensed under Part 52 and to incorporate lessons learned from experience with the current construction inspection program. One of the objectives of this inspection program will be to inspect the licensee's process for performing ITAAC and to inspect the licensee's program for ensuring ITAAC requirements are met. This could include the results of the pre-operational test program, quality assurance program, and various facility construction programs. The NRC expects that there will be increased interaction between the licensee and the NRC throughout the facility construction stage.

Facility ITAAC Verification

The NRC must find that all acceptance criteria specified in the license are met before facility operation. Because ITAAC are the sole source of acceptance criteria, the COL for a facility must include, all those implementation issues sufficiently important to require satisfactory resolution before fuel loading. Thus, the COL ITAAC include the ITAAC in the DCD for a referenced design plus plant-specific ITAAC derived from the COL proceeding. Plant-specific ITAAC comprise ITAAC associated with site-specific design information and other significant issues submitted by the COL applicant, as approved by the NRC staff.

2. DCD Introduction.

Comment Summary. The proposed rule incorporated Tier 1 and Tier 2 information into the DCD but did not include the introduction to the DCD. The SOC for the proposed rule (60 FR 17902 and 17909) indicated that this was a deliberate decision, stating:

The introduction to the DCD is neither Tier 1 nor Tier 2 information, and is not part of the information in the DCD that is incorporated by reference into this design certification rule. Rather, the DCD introduction constitutes an explanation of requirements and other provisions of this design certification rule. If there is a conflict between the explanations in the DCD introduction and the explanations of this design certification rule in these statements of consideration (SOC), then this SOC is controlling.

Both the applicant and NEI took strong exception to this statement. They both argued that the language of the DCD introduction was the subject of careful discussion and negotiation between the NRC staff, NRC's Office of the General Counsel, and representatives of the applicant and NEI. They, therefore, suggested that the definition of the DCD in Section 2(a) of the proposed rule be amended to explicitly include the DCD Introduction and that Section 4(a) of the proposed rule be amended to generally require that applicants or licensees

comply with the entire DCD. However, in the event that the Commission rejected their suggestion, NEI alternatively argued that the substantive provisions of the DCD Introduction be directly incorporated into the design certification rule's language (refer to NEI Comments, Attachment B, pp. 90-108; GE Comments, Attachment A, pp. 10-11).

Response. The DCD Introduction was created to be a convenient explanation of some provisions of the design certification rule and was not intended to become rule language itself. Therefore, the Commission has adopted NEI's alternative suggestion of incorporating substantive procedural and administrative requirements into the design certification rule. It is the Commission's view that the substantive procedural and administrative provisions described in the DCD Introduction should be included in, and be an integrated part of, the design certification rule which is published in the Federal Register and codified in the Code of Federal Regulations. The portion of the rule that is published in the Federal Register contains the bulk of the rule's procedural and administrative requirements. It would be better from the standpoint of form and convenience to include the appropriate provisions into a single part of the rule. As a result, Sections 2, 4, 6, 8, and 10 have been revised and Section 9 of this Appendix was created to adopt appropriate provisions from the DCD Introduction. In some cases, the wording of these provisions has been modified to conform with the final design certification rule. Therefore, the applicant for this design certification must revise its DCD Introduction to conform with the final rule.

3. Duplicate documentation in design certification rule.

Comment Summary. On page 4 of its comments, dated August 7, 1995, the Department of Energy (DOE) recommended that the process for preparing the design certification rule be simplified by eliminating the DCD, which DOE claims is essentially a repetition of the Standard Safety Analysis Report (SSAR). DOE's concern, which was further clarified during a public meeting on December 4, 1995, is that the NRC will require separate copies of the DCD and SSAR to be maintained. During the public meeting, DOE also expressed a concern that § 52.79(b) could be confusing to an applicant for a combined license because it currently states ... "The final safety analysis report and other required information may incorporate by reference the final safety analysis report for a certified standard design." ...

Response. The NRC does not require duplicate documentation for this design certification rule. The DCD is the document that is incorporated by reference into this appendix in order to meet the requirements of Subpart B of Part 52. The SSAR supports the final design approval that was issued under Appendix O to 10 CFR Part 52. The DCD was developed to meet the requirements for incorporation by reference and to conform with requests from the industry such as deletion of the quantitative portions of the design-specific probabilistic risk assessment. Because the DCD terminology was not envisioned at the time that Part 52 was developed, the Commission will consider modifying § 52.79(b), as part of its future review of Part 52, in order to clarify the use of the term "final safety analysis report." In the records and reporting requirements in Section 10 of this rule, additional terms were used to distinguish between the documents to be maintained by the applicant for this design certification rule and the document to be maintained by an applicant or licensee who references this appendix. These new terms are defined in Section

2 of this appendix and further described in the section-by-section discussion on records and reporting requirements in section III.J.

4. In its comments, dated August 12, 1995, OCRE stated:

Although the ABWR will use the same type of Main Steam Isolation Valves as are used in operating BWRs, it will not have a MSIV Leakage Control System. Instead, GE is taking credit for fission product retention in the main steam lines and main condenser. However, in a main steam line break outside of containment, a design basis event, such fission product retention will not occur. Given the excessive leakage experience of MSIVs in operating BWRs, it would be prudent to incorporate a MSIVLCS into the ABWR design. OCRE would recommend a positive pressure MSIVLCS, which would pressurize the main steam lines between the inboard and outboard MSIVs after MSIV closure to a pressure above that in the reactor pressure vessel. Thus, any leakage through the inboard MSIV will be into the reactor.

Response. The NRC had concerns with the effectiveness of the main steam isolation valve leakage collection system (MSIVLCS) to perform its intended function under conditions of high MSIV leakage. NRC classified this concern as a generic issue (C-8). An NRC study of Generic Issue C-8 showed that neither the installation or removal of the MSIVLCS could be justified. Operating experience with these systems has shown that the MSIVLCS has required substantial maintenance and resulted in substantial worker radiation exposure. The BWR Owners Group subsequently proposed a resolution that would eliminate the safety-related MSIVLCS and take recognition of the fact that plate-out and holdup of fission products leaking past the main steam isolation valves will occur in the main steam lines and condenser. For the purpose of giving credit to iodine holdup and plate-out in the main steam lines and condensers, the NRC requires that the main steam piping (including its associated piping to the condenser) and the condenser remain structurally intact following a safe shutdown earthquake (Refer to NRC Commission paper, SECY-93-087, "Policy, Technical, and Licensing Issues Pertaining to Evolutionary and Advanced Light-Water Reactor (ALWR) Designs," dated April 2, 1993). The BWR Owners Group submitted a topical report that proposed to eliminate the MSIVLCS and increase the allowable MSIV leakage rates by taking credit for the holdup and plate-out of fission products. The NRC has already approved plant specific technical specification changes to eliminate the MSIVLCS for the Hatch, Duane Arnold, and Limerick plants.

The U.S. ABWR design was evaluated against a number of design basis accidents and was approved without a MSIVLCS. For the U.S. ABWR, fission product holdup and plate-out in components of the main steam system was justified and, therefore, was assumed in NRC's design basis analyses. However, for the main steam line break, the NRC assumed that one of the four main steam lines ruptured between the outer isolation valve and turbine control valves, and did not take credit for retention of iodine and noble gases in the coolant released through the break. Any leakage through the MSIV after isolation was also assumed to be released directly to the atmosphere. The contribution of this leakage is insignificant when compared to the amount of reactor coolant lost through the break prior to automatic isolation of the

MSIV. In summary, the U.S. ABWR represents an improved boiling water reactor design that reduces worker radiation exposure, and meets the requirements of 10 CFR Part 100 without the need for a MSIVLCS. Inclusion of an MSIVLCS would result in substantial occupational exposures with little safety benefit. Therefore, the Commission declines to adopt OCRE's recommendation that a positive-pressure MSIVLCS be incorporated into the U.S. ABWR design.

5. In its comments, dated August 12, 1995, OCRE stated:

The ABWR Standby Liquid Control System requires simultaneous parallel, two-pump operation to achieve 100 gpm flow rate, necessary to comply with 10 CFR 50.62(c)(4). However, a single failure rendering one train inoperable would only yield a flow of 50 gpm, which does not comply with the ATWS rule. OCRE recommends increasing the capacity of each SLCS train to 100 gpm, so that the SLCS can perform its ATWS mitigation function even with a single failure.

Response. The ATWS rule (10 CFR 50.62) requires the following with regard to the SLCS for a boiling water reactor (BWR): "Each boiling water reactor must have a standby liquid control system (SLCS) with the capability of injecting into the reactor pressure vessel a borated water solution at such a flow rate, level of boron concentration and boron-10 isotope enrichment, and accounting for reactor pressure vessel volume, that the resulting reactivity control is at least equivalent to that resulting from injection of 86 gallons per minute of 13 weight percent sodium pentaborate decahydrate solution at the natural boron-10 isotope abundance into a 251-inch inside diameter reactor pressure vessel for a given core design." For the U.S. ABWR design with a 278 inch inside diameter vessel, the ATWS rule is satisfied with injection of 100 gpm of 13.4 weight percent of natural boron solution.

The Commission has previously concluded, as part of the ATWS rulemaking, that a single-failure need not be assumed in the evaluation of the SLCS. The statements of consideration for the ATWS rule 10 CFR 50.62 (49 FR 26036; June 26, 1984), under the heading "Considerations Regarding System and Equipment Criteria," states: "In view of the redundancy provided in existing reactor trip systems, the equipment required by this amendment does not have to be redundant within itself." OCRE presented no information which would lead the Commission to reconsider and change its previous determination with respect to a single-failure and the Commission declines to adopt OCRE's proposal.

6. In its comments, dated August 12, 1995, OCRE stated:

In the ABWR, the drywell to wetwell vacuum breakers consist of a single vacuum breaker valve in each line. In operating BWRs, there are two vacuum breaker valves in series in each line. The ABWR design thus is vulnerable to a single failure, a stuck-open vacuum breaker, which would result in suppression pool bypass, which can overpressurize the containment in both design basis and severe accidents. Having the containment function vulnerable to a single failure is unacceptable. OCRE recommends the addition of a second vacuum breaker valve in series with the one proposed in the design

Response. The wetwell to drywell vacuum breaker system of operating BWRs varies. Some operating BWRs have a single check valve per line (typically Mark I's), others have two check valves in series (typically Mark II's), and still others have a check valve in series with a motor operated valve (typically Mark III's). The main concern with the number of valves per vacuum breaker line focusses on the suppression pool bypass capability of the containment design. In the evaluation of the suppression pool bypass capability, a number of factors other than the number of valves in each line must be considered to determine the acceptability of the design. These factors are specified in the Standard Review Plan Section 6.2.1.1.C, Appendix A (NUREG-0800) and include the capability of containment sprays, periodic bypass leakage testing and surveillance, and vacuum relief valve position indication. A complete discussion of all these factors is included in the NRC's NUREG-1503, Volume 1, "Final Safety Evaluation Report Related to the Certification of the Advanced Boiling Water Reactor Design," Sections 6.2.1.5, 6.2.1.8, 19.1.3.5.3, 19.2.3.3.5, and 20.5.1.

The U.S. ABWR wetwell to drywell vacuum breaker system consists of eight lines, with a single check valve per line. For design basis accidents, a single failure of the vacuum breaker in the stuck-open position is not required to be considered for the U.S. ABWR. The U.S. ABWR vacuum breakers are biased closed due to gravity and have redundant position indication and alarm in the control room. Operating plants have experienced stuck-open vacuum breakers as a result of monthly stroke testing of the vacuum breakers. Most of these failures have been related to the motor-operators installed for the purpose of surveillance testing. The U.S. ABWR vacuum breakers do not have motor operators and are subject to functional testing every 18 months. Therefore, they are not subject to the motor operator failure mode and due to the reduced frequency of surveillance testing and position indication, these check valves are less likely to be stuck open when needed during an accident.

A single failure of the vacuum breaker in the stuck-open position is, however, considered in the evaluation of severe accident mitigation capability. The analysis performed by GE indicates that the various containment spray systems are capable of mitigating the consequences of this scenario. In addition to the normal containment spray system, the containment spray header can be supplied with water from the AC independent water addition system (fire system) to mitigate bypass for severe accidents.

GE performed an evaluation of many potential enhancements, including adding a second vacuum breaker valve in series (Appendix 19P of the U.S. ABWR SSAR). This evaluation concludes that the potential safety enhancement of a second vacuum breaker valve in series is minimal due to the existing design features. The NRC evaluated Appendix 19P and concurs with GE's conclusion. Although OCRE's suggested design change (the addition of a second vacuum breaker valve in series) could minimally enhance safety, the costs of such a change are not justified in view of the marginal increase in safety. Accordingly, the Commission declines to adopt OCRE's proposal.

7. In its comments, dated August 12, 1995, OCRE referred to additional remarks made in a letter from the Advisory Committee on Reactor Safeguards (ACRS), dated July 18, 1989, on proposed NRC staff actions regarding the fire risk scoping study (NUREG/CR-5088). OCRE believes that the recommendation, from two ACRS members, that the staff require the use of armored electrical cable

in advanced light-water reactors is sound advice. OCRE recommended that the NRC require the use of armored cable in the U.S. ABWR and in all future nuclear power plants.

Response. In reviewing the U.S. ABWR design, the NRC staff used the enhanced guidance described in SECY-90-016, "Evolutionary Light Water Reactor (LWR) Certification Issues and Their Relationships to Current Regulatory Requirements," dated January 12, 1990. The Commission approved the NRC staff's position in SECY-90-016. This guidance was used to resolve fire protection issues to minimize fire as a significant contributor to the likelihood of a severe accident. The NRC staff required that the U.S. ABWR design must be able to ensure that safe shutdown can be achieved assuming that all equipment in any one fire area will be rendered inoperable by fire and that reentry into the fire area for repairs and operator actions is not possible. Because of its physical configuration, the control room is excluded from this approach and the U.S. ABWR is provided with an independent alternative shutdown capability that is physically and electrically independent of the control room. In the reactor containment building, the safety divisions are widely separated around containment so that a single fire will not cause the failure of any combination of active components that could prevent safe shutdown. Additionally, the U.S. ABWR containment is inerted with nitrogen during power operation which will prevent propagation of any potential fire inside containment.

Evaluation of fire protection using this guidance assures an acceptable level of safety for the U.S. ABWR. Instead of trying to protect equipment in the fire area, the enhanced guidance requires that equipment needed for safe shutdown be located in separate areas of the plant so that one fire will not damage enough equipment to jeopardize safe shutdown. While the use of armored electrical cable may provide some protection to the electrical cables in the fire area, it does not ensure that the cables will not be affected by the heat generated by the fire. In addition, following a fire or other event that could affect the cables, it would be impossible to inspect the cables to determine if they were damaged by the event. Therefore, the NRC staff does not agree that advanced light-water reactors should be required to use armored electrical cables.

III. Section-by-section discussion of the design certification rule.

A. Introduction.

The purpose of Section 1 of this appendix is to identify the standard plant design that is approved by this design certification rule and the applicant for certification of the standard design. The implementation of 10 CFR 52.63(c) depends on whether an applicant for a COL contracts with the design certification applicant to provide the generic DCD and supporting design information. If the COL applicant does not use the design certification applicant to provide this information, then the COL applicant will have to meet the requirements in 10 CFR 52.63(c). Also, Section 10(a)(1) of this appendix imposes a requirement on the design certification applicant to maintain the generic DCD throughout the time period in which this appendix may be referenced. Therefore, identification of the design certification applicant is necessary to implement this appendix.

B. Definitions (Section 2).

The terms Tier 1, Tier 2, Tier 2*, and COL action items (license information) are defined in Section 2 of this appendix because these concepts were not envisioned when 10 CFR Part 52 was developed. The design certification applicants and the NRC staff used these terms in implementing the two-tiered rule structure that was proposed by industry after the issuance of 10 CFR Part 52. In addition, during consideration of the comments received on the proposed rule, the Commission determined that it would be useful to distinguish between the "plant-specific DCD," in order to clarify the obligations of applicants and licenses that reference this appendix, and the "generic DCD," which is incorporated by reference into this appendix and remains unaffected by plant-specific departures. Therefore, appropriate definitions for these two additional terms are included in the final rule.

The Tier 1 portion of the design-related information contained in the DCD is *certified* and required by this appendix. This information consists of an introduction to Tier 1, the design descriptions and corresponding inspections, tests, analyses, and acceptance criteria (ITAAC) for systems and structures of the design, design material applicable to multiple systems of the design, significant interface requirements, and significant site parameters for the design. The design descriptions, interface requirements, and site parameters in Tier 1 were derived entirely from Tier 2, but may be more general than the Tier 2 information. The NRC staff's evaluation of the Tier 1 information, including a description of how this information was developed is provided in Section 14.3 of the FSER. Changes to or departures from the Tier 1 information must comply with Section 8(a) of this Appendix.

The Tier 1 design descriptions serve as design commitments for the lifetime of a facility referencing the design certification. The ITAAC verify that the as-built facility conforms with the approved design and applicable regulations. In accordance with 10 CFR 52.103(g), the Commission must find that the acceptance criteria in the ITAAC are met before operation. After the Commission has made the finding required by 10 CFR 52.103(g), the ITAAC do not constitute regulatory requirements for subsequent modifications. However, subsequent modifications to the facility must comply with the Tier 1 design descriptions unless changes are made in accordance with the change process in Section 8 of this appendix. The Tier 1 interface requirements are the most significant of the interface requirements for systems that are wholly or partially outside the scope of the standard design, which were submitted in response to 10 CFR 52.47(a)(1)(vii) and must be met by the site-specific portions of a facility that references the design certification. The Tier 1 site parameters are the most significant site parameters, which were submitted in response to 10 CFR 52.47(a)(1)(iii), that must be addressed as part of the application for a combined license.

Tier 2 is the portion of the design-related information contained in the DCD that is *approved* and required by this appendix but is not certified. Tier 2 includes the information required by 10 CFR 52.47, with the exception of technical specifications and conceptual design information, and supporting information on the inspections, tests, and analyses that will be performed to demonstrate that the acceptance criteria in the ITAAC have been met. All of the information in Tier 2 is approved by the NRC, is required (except for the COL action items and conceptual design information) for those COL applicants

and licensees whose applications reference this appendix, and is among the "matters resolved" under 10 CFR 52.63(a)(4). The definition of Tier 2 makes clear that Tier 2 information has been determined by the Commission, by virtue of its inclusion in this appendix and its designation as Tier 2 information, to be an approved ("sufficient") method for meeting Tier 1 requirements. However, there may be other acceptable ways of complying with Tier 1. The appropriate criteria for departing from Tier 2 information are set forth in Section 8 of this appendix.

Certain Tier 2 information has been designated in the generic DCD with brackets and italicized text as "Tier 2*" information. As discussed in greater detail in the section-by-section explanation for Section 8, a plant-specific departure from Tier 2* information requires prior NRC approval under Section 8(b)(6) of this appendix. However, the Tier 2* designation expires for some of this information when the facility first achieves full power after the finding required by 10 CFR 52.103(g). The process for changing Tier 2* information and the time at which its status as Tier 2* expires is set forth in Section 8(b)(6) of this appendix.

A definition of "combined license (COL) action items" (COL license information) has been added to clarify that COL applicants are required to address these matters in their license application, but the COL action items do not include substantive criteria for judging the sufficiency of the information submitted. Thus, an applicant for a combined license may be able to address particular COL action items by justifying, in appropriate circumstances, why no further action is necessary.

In developing the proposed design certification rule, the Commission contemplated that there would be both "master" DCDs (termed generic DCDs) maintained by the NRC and the design certification applicant, as well as individual plant-specific DCDs, maintained by each applicant and licensee who references this design certification rule. The master DCDs (identical to each other) would reflect generic changes to the version of the DCD approved in this design certification rulemaking. The generic changes would occur as the result of generic rulemaking by the Commission (subject to the change criteria in Section 8 of this Appendix). In addition, the Commission understood that each applicant and licensee referencing this Appendix would be required to submit and maintain a plant-specific DCD. This plant-specific DCD would contain (not just incorporate by reference) the information in the generic or master DCD. The plant-specific DCD would be updated as necessary to reflect the generic changes to the DCD that the Commission may adopt through rulemaking, any plant-specific departures from the generic DCD that the Commission imposed on the licensee by order, and any plant-specific departures which the licensee chose to make in accordance with the relevant processes in Section 8 of this Appendix. However, the proposed rule defined only the concept of the "master" DCD. The Commission continues to believe that there should be both a "master" DCD and plant-specific DCDs. To clarify this matter, the proposed rule's definition of DCD has been redesignated as the "generic DCD," a new definition of "plant-specific DCD" has been added, and conforming changes have been made to the remainder of the rule. Further information on exemptions or departures from information in the DCD is provided in section III.H below. The Final Safety Analysis Report (FSAR) that is required by § 52.79(b) will consist of the plant-specific DCD, the site-specific portion of the FSAR, and the technical specifications.

C. Scope and contents of this design certification.

The purpose of Section 3 of this appendix is to describe and define the scope and contents of the standard design certification and to set forth how documentation discrepancies or inconsistencies are to be resolved. Paragraph (a) is the required statement of the Office of the Federal Register (OFR) for approval of the incorporation by reference of Tier 1 and Tier 2 into this appendix and paragraph (b) requires COL applicants and licensees to comply with the requirements of this appendix, including Tier 1 and Tier 2. The legal effect of incorporation by reference is that the material is treated as if it were published in the Federal Register. This material, like any other properly-issued regulation, has the force and effect of law. Tier 1 and Tier 2 information have been combined into a single document, called the design control document (DCD), in order to effectively control this information and facilitate its incorporation by reference into the rule. The DCD was prepared to meet the requirements of the OFR for incorporation by reference (1 CFR Part 51). The generic DCD for this design certification will be archived at NRC's central file with a matching copy at OFR. Copies of the up-to-date DCD will also be available at the NRC's Public Document Room. Questions concerning the accuracy of information in an application that references this Appendix will be resolved by checking the generic DCD in NRC's central file. If a generic change (rulemaking) is made to the DCD pursuant to the change process in Section 8 of this appendix, then at the completion of the rulemaking the NRC will request approval of the Director, OFR for the changed incorporation by reference and change its copies of the generic DCD and notify the OFR and the design certification applicant to change their copies. The Commission is requiring that the design certification applicant maintain an up-to-date copy under Section 10(a)(1) of this appendix because it is likely that most applicants intending to reference the standard design will likely obtain the generic DCD from the design certification applicant. Plant-specific changes to and departures from the DCD will be maintained by the applicant or licensee that references this design certification under Section 10(a)(2) of this appendix.

In order to meet the requirements of OFR for incorporation by reference, the design certification applicant must make the DCD available upon request after the final design certification rule is issued. Therefore, this Section states that copies of the DCD can be obtained from [the applicant or an organization designated by the applicant. If the applicant selects an organization, such as the National Technical Information Service, to distribute the generic DCD, then the applicant must provide that organization with an up-to-date copy.]

Paragraphs (c) and (d) set forth the manner in which potential conflicts are to be resolved. Paragraph (c) establishes the Tier 1 description in the DCD as controlling in the event of an inconsistency between the Tier 1 and Tier 2 information in the DCD. Paragraph (d) establishes the generic DCD as the controlling document in the event of an inconsistency between the DCD and either the application for certification of the standard design, or the final safety evaluation report (FSER) for the standard design.

Paragraph (e) clarifies that the conceptual design information and the technical specifications in the generic DCD are not considered to be part of this appendix. The conceptual design information is for those portions of the plant that are outside the scope of the standard design and are intermingled

throughout Tier 2. As provided by 10 CFR 52.47(a)(1)(ix), these conceptual designs are not part of this appendix and, therefore, are not applicable to an application for a combined license that references this appendix. The technical specifications, which are provided in Chapter 16 of the generic DCD, are not part of this appendix but may be used to develop the technical specifications for a nuclear facility that references this appendix.

D. Applications and licenses referencing this design certification: additional requirements and restrictions.

Section 4 of this appendix is a new section which sets forth additional requirements and restrictions imposed upon the applicant or licensee who references this Appendix. Section 4(a) sets forth the additional information required of combined license applicants who reference this Appendix. This Appendix distinguishes between information and/or documents which must actually be *included* in the application or the DCD, versus those which may be *incorporated by reference* (i.e., referenced in the application as if the information or documents were actually included in the application), thereby reducing the bulk of the application. Any incorporation by reference in the application should be clear and should specify the title, date, edition, or version of a document, and the page number(s) and table(s) containing the relevant information to be incorporated by reference.

Paragraph (a)(1) requires an applicant to incorporate by reference this appendix. This appendix is legally-binding on any applicant or licensee who references this appendix. Paragraph (a)(2)(i) is intended to make clear that the initial application must include a plant-specific DCD. This assures, among other things, that the applicant commits to complying with both Tier 1 and Tier 2 of the DCD. This paragraph also requires the plant-specific DCD to use the same format as the generic DCD and to reflect the applicant's proposed departures and exemptions from the generic DCD as of the time of submission of the application. The Commission expects that the plant-specific DCD will become the basis for the plant's final safety analysis report (FSAR), by including within its pages, at the appropriate points, information such as site-specific information for the portions of the plant outside the scope of the referenced design, including related ITAAC, and other matters required to be included in an FSAR by 10 CFR 50.34. Integration of the plant-specific DCD and remaining information, as the plant's FSAR, will be easier to use and should minimize "duplicate documentation" and the attendant possibility for confusion. Paragraph (a)(2)(i) is also intended to make clear that the initial application must include the reports on departures and exemptions as of the time of submission of the application. Paragraph (a)(2)(ii) requires that the application include the reports required by Section 10(b) of this design certification rule for exemptions and departures proposed by the applicant as of the date of submission of its application. Paragraph (a)(2)(iii) requires submission of technical specifications for the plant in accordance with the requirements in effect at the time of the COL review. Paragraph (a)(2)(iv) makes clear that the applicant must provide information demonstrating that the proposed site falls within this rule's site parameters and that the plant-specific design complies with the interface requirements, as required by 10 CFR 52.79(b). Paragraph (a)(2)(v) requires submission of information addressing COL Action Items, which are identified in the generic

DCD as COL License Information, in the COL application. The COL Action Items (COL License Information) identify matters that need to be addressed by an applicant or licensee that references this appendix, as required by 10 CFR 52.77 and 52.79. The COL applicant does not need to conform with the conceptual design information in the generic DCD that was provided by the design certification applicant in response to 10 CFR 52.47(a)(1)(ix). The conceptual design information, which are examples of site-specific design features, was required to facilitate the design certification review. Conceptual design information is neither Tier 1 nor 2. The introduction to the DCD identifies the location of the conceptual design information and explains that this information is not applicable to a COL application. Paragraph (a)(2)(vi) requires that the application include the information required by 10 CFR 52.47(a) that is not within the scope of this rule, such as generic issues that must be addressed by an applicant that references this rule. The detailed methodology and quantitative portions of the design-specific probabilistic risk assessment (PRA), as required by 10 CFR 52.47(a)(1)(v), was not included in the DCD. The NRC agreed with the design certification applicant's request to delete this information because conformance with the deleted portions of the PRA is not required. The NRC's position is also predicated in part upon NEI's acceptance, in conceptual form, of a future generic rulemaking that will require a COL applicant or licensee to have a plant-specific PRA that updates and supersedes the design-specific PRA and maintain it throughout the operational life of the plant.

Paragraph (a)(2)(vii) requires a COL applicant to include descriptions of in-service testing (IST) and in-service inspection (ISI) programs that include the features described in sub-paragraphs (A), and (B) in their application. This requirement was moved from Section 5(c) of this appendix in response to NEI comments that, since the programs are the responsibility of the applicant and licensee, it was not appropriate as a new applicable regulation. The Commission's views on ISI and IST have been evolving. The purpose of this requirement is to ensure that a licensee will use the best available methods and incorporate the techniques specified in this requirement.

Paragraph (a)(2)(viii) requires a COL applicant to include a description of their outage planning and control program that includes consideration of shutdown risk concerns. This requirement was moved from Section 5(c) of this appendix in response to NEI comments that, since the program is the responsibility of the applicant and licensee, it was not appropriate as a new applicable regulation. The purpose of the requirement is to ensure that, in light of the Commission's findings in NUREG-1449, the applicant's program for outage planning and control adequately addresses shutdown risk concerns.

Paragraph (a)(2)(ix) requires a COL applicant to include a description of a design reliability assurance program (DRAP) in their application. As background information, in SECY-89-013, "Design Requirements Related to the Evolutionary Advanced Light Water Reactors," dated January 19, 1989, the staff identified several issues for next-generation light water reactors that may go beyond present acceptance criteria defined in the SRP. The reliability assurance program (RAP), as one of these issues, was defined as a program to ensure that the design reliability of safety significant structures, systems, and components (SSCs) is maintained over the life of a plant. In SECY-93-087, the staff gave the Commission its interim position that a high-level commitment to a RAP should be required as a generic Tier 1 requirement with no

associated inspections, tests, analyses, and acceptance criteria. DRAP involves a top-level program at the design stage that defines the scope, conceptual framework, and essential elements of an effective RAP. DRAP also implements those aspects of the program that are applicable to the design process. In addition, DRAP identifies the relevant aspects of plant operation, maintenance, and performance monitoring for the risk-significant SSCs for the operator's consideration.

The conceptual framework, program structure, and essential elements of the DRAP are discussed in section 17.3 of the DCD. The DRAP should (1) identify and prioritize a list of risk-significant SSCs based on the design certification PRA and other sources, (2) ensure that the vendor's design organization determines that significant design assumptions, such as equipment that satisfies the design reliability and unavailability, are realistic and achievable, (3) provide input to the procurement process for obtaining equipment that satisfies the design reliability assumptions, and (4) provide these design assumptions as input to the COL applicant for consideration. A COL applicant would augment the design certification D-RAP with site-specific design information and would implement the balance of the D-RAP, including input to the procurement process.

The staff's final position on RAP was presented in the Commission Paper on the Regulatory Treatment of Non-Safety Systems (RTNSS), SECY-94-084, dated March 28, 1994. The Commission approved this position in an SRM dated June 30, 1994. Note that in paragraph (a)(4)(iii)(B), the staff expects that the "other analytical methods" would include sound engineering judgement.

Paragraph (a)(3) requires the applicant to physically include, not simply reference, the proprietary and safeguards information referenced in the U.S. ABWR DCD, to assure that the applicant has actual notice of these requirements.

Paragraph (a)(4) requires an applicant to establish and implement a design reliability assurance program that includes the features specified in Section 4(a)(2)(ix) because additional design work will be performed by the COL applicant and DRAP must be implemented during this period before the COL application is approved by the Commission.

Paragraphs (b)(1), (b)(2) and (b)(3) require a holder of a COL to implement the programs described above. The NRC intends that the requirement of paragraph (b)(2) to implement the D-RAP program will apply from the date of COL issuance until the date of fuel load. The ISI, IST and outage planning and control programs are required to be implemented throughout the service life of the plant.

Section 4(c) reserves the right of the Commission to impose limited plant-specific requirements for post-fuel load operational safety, including verification activities, as license conditions for portions of the plant within the scope of this design certification, e.g. start-up and power ascension testing. The requirement to perform these testing programs is contained in Tier 1 information. However, ITAAC cannot be specified for these subjects because the matters to be addressed in these license conditions cannot be verified prior to fuel load and operation, when the combined license ITAAC are satisfied. As provided in Section 9(b)(3), ITAAC do not constitute regulatory requirements after the finding required by 10 CFR 52.103(g). Therefore, another regulatory vehicle is necessary to assure that holders of combined licenses comply with the matters contained in the license conditions. License conditions for these areas cannot be developed now because this

requires the type of detailed design information that will be developed after design certification. In the absence of detailed design information to evaluate the need for and develop specific post-fuel load verifications for these matters, the Commission, by rule, is reserving the right to impose these limited license conditions for post-fuel load verification activities for portions of the plant within the scope of the design certification.

Section 4(d) reserves to the Commission the right to determine whether and in what manner this design certification may be referenced by an applicant for a construction permit or operating license under 10 CFR Part 50. This determination may occur in the context of a subsequent rulemaking modifying Part 52 or this design certification rule, or on a case-by-case basis in the context of a specific application for a Part 50 construction permit or operating license.

E. Applicable regulations.

The purpose of Section 5 of this appendix is to identify the regulations that are applicable and in effect at the time that this design certification was issued. These regulations consist of the technically relevant regulations identified in paragraph (a), except for the regulations in paragraph (b) that are not applicable, and the new regulations in paragraph (c) that are applicable to this standard design.

Paragraph (a) identifies the regulations in 10 CFR Parts 20, 50, 73, and 100 that are applicable to the U.S. ABWR design. Since the NRC staff completed its review with the issuance of the FSER for the U.S. ABWR design (July 1994), the Commission has amended several existing regulations and adopted several new regulations in those Parts of Title 10 of the Code of Federal Regulations. The Commission has reviewed these regulations to determine if they are applicable to this design and, if so, to confirm that the design meets these regulations. The Commission finds that the U.S. ABWR design either meets the requirements of these regulations or that these regulations are not applicable to the design, as discussed below.

10 CFR Part 73, Protection Against Malevolent Use of Vehicles at Nuclear Power Plants (59 FR 38889; August 1, 1994).

The objective of this regulation is to modify the design basis threat for radiological sabotage to include use of a land vehicle by adversaries for transporting personnel and their hand-carried equipment to the proximity of vital areas and to include a land vehicle bomb. This regulation also requires reactor licensees to install vehicle control measures, including vehicle barrier systems, to protect against the malevolent use of a land vehicle. The Commission has determined that this regulation will be addressed in the COL applicant's site-specific security plan. Therefore, no additional actions are required for this design.

10 CFR 19 and 20, Radiation Protection Requirements: Amended Definitions and Criteria (60 FR 36038; July 13, 1995).

The objective of this regulation is to revise the radiation protection training requirement so that it applies to workers who are likely to receive,

in a year, occupational dose in excessive of 100 mrem (1 mSv); revise the definition of the "Member of the public" to include anyone who is not a worker receiving an occupational dose; revise the definition of "Occupational Dose" to delete reference to location so that the occupational dose limit applies only to workers whose assigned duties involve exposure to radiation and not to members of the public; revise the definition of the "Public Dose" to apply to dose received by members of the public from material released by a licensee or from any other source of radiation under control of the licensee; assure that prior dose is determined for anyone subject to the monitoring requirements in 10 CFR Part 20, or in other words, anyone likely to receive, in a year, 10 percent of the annual occupational dose limit; and retain a requirement that known overexposed individuals receive copies of any reports of the exposure that are required to be submitted to the NRC. The Commission has determined that these requirements will be addressed in the COL applicant's operational radiation protection program. Therefore, no additional actions are required for this design.

10 CFR 50, Technical Specifications (60 FR 36953; July 19, 1995).

The objective of this revised regulation is to codify criteria for determining the content of technical specification (TS). The four criteria were first adopted and discussed in detail in the Final Policy Statement on Technical Specification Improvements for Nuclear Power Reactors (58 FR 39132; July 22, 1993). The Commission has determined that these requirements will be addressed in the COL applicant's technical specifications. Therefore, no additional actions are required for this design.

10 CFR 73, Changes to Nuclear Power Plant Security Requirements Associated with Containment Access Control (60 FR 46497; September 7, 1995).

The objective of this revised regulation is to delete certain security requirements for controlling the access of personnel and materials into reactor containment during periods of high traffic such as refueling and major maintenance. This action relieves nuclear power plant licensees of requirement to separately control access to reactor containments during these periods. The Commission has determined that this regulation will be addressed in the COL applicant's site-specific security plan. Therefore, no additional actions are required for this design.

10 CFR Part 50, Primary Reactor Containment Leakage Testing for Water-Cooled Power Reactors (60 FR 49495; September 26, 1995).

The objective of this revised regulation is to provide a performance-based option for leakage-rate testing of containments of light-water-cooled nuclear power plants. This performance-based option, option B to Appendix J, is available for voluntary adoption by licensees in lieu of compliance with the prescriptive requirements contained in the current regulation. Appendix J includes two options, A and B, either of which can be chosen for meeting the requirements of this appendix. The Commission has determined that option B to

Appendix J has no impact on the U.S. ABWR design, because GE elected to comply with option A.

10 CFR Parts 50, 70, and 72, Physical Security Plan Format (60 FR 53507; October 16, 1995).

The objective of this revised regulation is to eliminate the requirement for applicants for power reactor, Category I fuel cycle, and spent fuel storage licenses to submit physical security plans in two parts. This action is necessary to allow for a quicker and more efficient review of the physical security plans. The Commission has determined that this revised regulation will be addressed in the COL applicant's site-specific security plan. Therefore, no additional action is required for this design.

10 CFR Part 50, Fracture Toughness Requirements for Light Water Reactor Pressure Vessels (60 FR 65456; December 19, 1995).

The objective of this revised regulation is to clarify several items related to fracture toughness requirements for reactor pressure vessels (RPV). This regulation clarifies the pressurized thermal shock (PTS) requirements, makes changes to the fractures toughness requirements and the reactor vessel material surveillance program requirements, and provides new requirements for thermal annealing of a reactor pressure vessel. The Commission has determined that 10 CFR 50.61 only applies to pressurized water reactors for which an operating license has been issued. Likewise, 10 CFR 50.66 applies only to those light-water reactors where neutron radiation has reduced the fracture toughness of the reactor vessel materials. As the U.S. ABWR design is not a pressurized water reactor and has not been licensed, neither §§ 50.61 nor 50.66 apply to this design or to applicants referencing this appendix.

In paragraph (b), the Commission identified the regulations that do not apply to the U.S. ABWR design. The Commission has determined that the U.S. ABWR design should be exempt from portions of 10 CFR 50.34(f), and Part 100, as described in the final safety evaluation report (NUREG-1503) and summarized below:

(1) Paragraph (f)(2)(iv) of 10 CFR 50.34 - Separate Plant Safety Parameter Display Console.

10 CFR 50.34(f)(2)(iv) requires that an application provide a plant safety parameter display console that will display to operators a minimum set of parameters defining the safety status of the plant, be capable of displaying a full range of important plant parameters and data trends on demand, and be capable of indicating when process limits are being approached or exceeded.

The purpose of the requirement for a safety parameter display system (SPDS), as stated in NUREG-0737, "Clarification of TMI Action Plan Requirements," Supplement 1, is to ". . . provide a concise display of critical plant variables to the control room operators to aid them in rapidly and reliably determining the safety status of the plant. . . and in assessing whether abnormal conditions warrant corrective action by operators to avoid a degraded core."

GE committed to meet the intent of this requirement. However, the functions of the SPDS will be integrated into the control room design rather than on a separate "console." GE has made the following commitments in the generic DCD:

- Section 18.2(6) states that the functions of the SPDS will be integrated into the design,
- Section 18.4.2.1(14) states that the SPDS function will be part of the plant summary information which is continuously displayed on the fixed-position displays on the large display panel,
- Section 18.4.2.8 states that the information presented in the fixed-position displays includes the critical plant parameter information, and
- Section 18.4.2.11 describes the SPDS for the ABWR and states that the displays of critical plant variables sufficient to provide information to plant operators about the following critical safety functions are continuously displayed on the large display panel as an integral part of the fixed-position displays:
 - (a) Reactivity control,
 - (b) Reactor core cooling and heat removal from the primary system,
 - (c) Reactor coolant system integrity,
 - (d) Radioactivity control, and
 - (e) Containment conditions.

In view of the above, the Commission has determined that an exemption from the requirement for an SPDS "console" is justified based upon (1) the description in the generic DCD of the intent to incorporate the SPDS function as part of the plant status summary information which is continuously displayed on the fixed-position displays on the large display panel; and (2) a separate "console" is not necessary to achieve the underlying purpose of the SPDS rule which is to display to operators a minimum set of parameters defining the safety status of the plant. Therefore, the Commission concludes that an exemption from 10 CFR 50.34(f)(2)(iv) is justified by the special circumstances set forth in 10 CFR 50.12(a)(2)(ii).

(2) Paragraph (f)(2)(viii) of 10 CFR 50.34 - Post-Accident Sampling for Boron, Chloride, and Dissolved Gases.

In SECY-93-087, the NRC staff recommended that the Commission approve its position that for evolutionary and passive ALWRs of boiling water reactor design there would be no need for the post-accident sampling system (PASS) to analyze dissolved gases in accordance with the requirements of 10 CFR 50.34(f)(2)(viii) and Item III.B.3 of NUREG-0737. In its April 2, 1993, SRM, the Commission approved the recommendation to exempt the PASS for the evolutionary and passive ALWRs of boiling water reactor design from analyzing dissolved gases in accordance with the requirements of 10 CFR 50.34(f)(2)(viii) and Item III.B.3 of NUREG-0737. In SECY-93-087, the NRC staff also recommended that the Commission approve the deviation from the requirements of Item II.B.3 of NUREG-0737 with regard to the requirements for sampling reactor

coolant for boron concentration and activity measurements using the PASS in evolutionary and passive ALWRs. The modified requirement would require the capability to take boron concentration samples and activity measurements 8 hours and 24 hours, respectively, following the accident. In its April 2, 1993, SRM, the Commission approved the recommendation to require the capability to take boron concentration samples and activities measurements 8 hours and 24 hours, respectively, following the accident.

The U.S. ABWR design will have PASS which meets the requirements of 10 CFR 50.34(f)(2)(viii) and Item II.B.3 of NUREG-0737 with the modifications described in SECY-93-087. The system will have the capability to sample and analyze for activity in the reactor coolant and containment atmosphere 24 hours following the accident. This information is needed for evaluating the conditions of the core and will be provided during the accident management phase by the containment high-range area monitor, the containment hydrogen monitor and the reactor vessel water level indicator. The need for PASS activity measurements will arise only during the accident recovery phase and therefore, 24 hours sampling time is adequate. PASS will also be able to determine boron concentration in the reactor coolant. It will be capable of making this determination within 8 hours following the accident. Knowledge of the concentration of boron is required for providing insights for accident mitigation measures. Immediately after the accident this information will be obtained by the neutron flux monitoring instrumentation which is designed to comply with the criteria of RG 1.97, and which has fully qualified redundant channels capable of monitoring flux over the full power range. Boron concentration measurements therefore will not be required for the first 8 hours after the accident.

For the U.S. ABWR, whenever core uncovering is suspected, the reactor vessel is depressurized to approximately the pressure within the wetwell and the drywell which results in partial release of the dissolved gases. Under these conditions, pressurized samples would not yield meaningful data. Therefore, application of the regulation in this particular circumstance would not serve the underlying purpose of the rule. During accidents when the reactor vessel has not been depressurized (such as when a small amount of cladding damage has occurred), reactor coolant samples can be obtained by the process sampling system.

With regards to the need for chloride analysis, determination of chloride concentrations is of a secondary importance because it is needed only for determining the likelihood of accelerated primary system corrosion which is a slow-occurring phenomenon. Chloride analyses can be performed on the samples taken by the process sampling system. In this case, the intended purpose of the rule can be achieved without the need for the PASS to have chloride sampling capabilities.

Accordingly, the Commission has determined that special circumstances required by 10 CFR 50.12(2)(ii) exist for the U.S. ABWR in that the regulation would not serve the underlying purpose of the rule in one circumstance and is not necessary in the other circumstance because the intent of rule could be met with alternate design requirements proposed by the applicant. On this basis, the Commission concludes that the exemption from analyzing dissolved gases and chlorides in the reactor coolant sample is justified.

(3) Paragraph (f)(3)(iv) of 10 CFR 50.34 - Dedicated Containment Penetration.

Paragraph (3)(iv) of 10 CFR 50.34(f) requires one or more dedicated containment penetrations, equivalent in size to a single .91-m (3-ft) diameter opening, in order not to preclude future installation of systems to prevent containment failure such as a filtered vented containment system. This requirement is intended to ensure provision of a containment vent design feature with sufficient safety margin well ahead of a need that may be perceived in the future to mitigate the consequences of a severe accident situation. The NRC staff's evaluation of ABWR compliance with the requirement is limited to the effective penetration size for venting provided in the U.S. ABWR primary containment design.

The NRC staff found that the size of the primary containment penetration that could be used during a severe accident for venting the containment was smaller than the specific size identified in the previous paragraph. However, in the generic DCD (Section 19A.2.44), GE states that the containment overpressure protection system (COPS) precludes the need for a dedicated penetration equivalent in size to a single 0.91-m (3-ft) diameter opening. The COPS is part of the atmospheric control system and is discussed in DCD Section 6.2.5.6. The COPS consists of two 200-mm (8-in.) diameter rupture disks mounted in series in a 250-mm (10-in.) line and is sized to allow 35 kg/sec (15.86 lbm/sec) of steam flow at the opening pressure of 6.3 kg/cm²g (90 psig), which corresponds to an energy flow of about 2.4 percent of rated power. The DCD states that the COPS is capable of keeping containment pressures below ASME Service Level C limits for an anticipated transient without scram (ATWS) event with failure of the standby liquid control system (SLCS) and containment heat removal systems.

Although the diameter of the COPS pathway is only 200 mm (8 in.), the NRC staff determined that this exception from the requirement of a 0.91-m (3-ft) diameter opening is acceptable because: (1) the limiting diameter of the COPS pathway is adequate to permit the needed vent relief path, and (2) a need for venting capability beyond that provided by the COPS has not been identified. The Commission has determined that GE's approach adequately addresses the requirements of this TMI item for the ABWR design. Therefore, an exemption in accordance with 10 CFR 50.12(a)(2)(ii) is justified because the COPS provides sufficient venting capability to preclude the need for a 0.91 m (3-ft) diameter equivalent dedicated containment penetration.

(4) Paragraph VI(a)(2) of Appendix A to 10 CFR Part 100 - Operating Basis Earthquake Design Consideration.

Appendix A to 10 CFR Part 100 requires, in part, that all structures, systems, and components (SSCs) of the nuclear power plant necessary for continued operation without undue risk to the health and safety of the public shall be designed to remain functional and within applicable stress and deformation limits when subject to an operating basis earthquake (OBE). In addition 10 CFR Part 100, Appendix A requires that the maximum vibratory ground acceleration of the OBE be at least one-half the maximum vibratory ground acceleration of the safe-shutdown earthquake (SSE).

In SECY-90-016, "Evolutionary Light Water Reactor Certification Issues and Their Relationship to Current Regulatory Requirements," dated January 12, 1990, the NRC staff requested the Commission's approval to decouple the level of the OBE ground motion from that of the SSE. The Commission approved this position in its staff requirements memorandum (SRM) of June 26, 1990. In

SECY-93-087, "Policy, Technical, and Licensing Issues Pertaining to Evolutionary and Advanced Light-Water Reactor (ALWR) Designs," dated April 2, 1993, the NRC staff further requested that the Commission approve eliminating the OBE from the design of SSCs in both evolutionary and passive advanced reactors designs. The Commission approved this recommendation in its SRM of July 21, 1993.

The purpose of designing SSCs necessary for continued operation without undue risk to the health and safety of the public to withstand an OBE is to ensure that these SSCs remain functional and within applicable stress and deformation limits when subjected to the effects of the OBE vibratory ground motion. However, Appendix A to Part 100 also requires that these SSCs be designed to withstand the SSE and remain functional. Thus, when these SSCs are designed to remain functional for the SSE, they will also remain functional at a lesser earthquake level (one-third the SSE) provided all design functions at the OBE are accounted for. The basis for selecting one-third of the SSE as the earthquake level at which the plant will be required to shutdown and be inspected for damage was that, at this level, the likelihood of damage and the frequency of earthquakes occurring was judged to be low based on actual earthquake experience. It should be noted that certain design functions had been verified only for the OBE loads in the past. These design functions were the evaluations of fatigue damage caused by earthquake cycles and relative seismic anchor motions in piping systems. With the elimination of the OBE from design, these design functions would not have been explicitly verified. Consequently, for the Advanced Boiling Water Reactor (ABWR) these design functions will be verified in conjunction with the SSE using applicable stress and deformation limits as described in Section 3.1.1.2 of NUREG-1503, Vol. 1, "Final Safety Evaluation Report Related to the Certification of the Advanced Boiling Water Reactor Design - Main Report."

Accordingly, the special circumstances described by 10 CFR 50.12(a)(2)(ii) exist in that the regulation need not be applied in this particular circumstance to achieve the underlying purpose of the rule because GE has proposed acceptable alternative analysis methods that accomplish the intent of the regulation. On this basis, the Commission has determined that the exemption is justified because the alternative analyses performed for the SSE and the need to perform an inspection of the plant following an earthquake at or above one-third of the SSE accomplish the design objectives of the OBE design analyses.

Paragraph (b)(3) of 10 CFR 50.49 - Environmental Qualification of Post-Accident Monitoring Equipment

In the generic DCD, GE stated that the design of the information systems important to safety will be in conformance with the guidelines of Regulatory Guide (RG) 1.97, "Instrumentation for Light-Water-Cooled Nuclear Power Plants to Assess Plant and Environs Conditions During and Following an Accident," Revision 3. However, the footnote for § 50.49(b)(3) references Revision 2 of RG 1.97 for selection of the types of post-accident monitoring equipment. As a result, the proposed design certification rule provided an exemption to this requirement.

In section C.1 of its comments, dated August 4, 1995, ABB-CE stated that it did not believe that an exemption from paragraph (b)(3) of 10 CFR 50.49 is needed or required. The Commission agrees with ABB-CE's assertion that

Revision 2 of RG 1.97 is identified in footnote 4 of 10 CFR 50.49 and should not be viewed as binding in this instance. Therefore, even though GE did not raise this concern, the Commission has determined that there is no need for an exemption from paragraph (b)(3) of 10 CFR 50.49 and has removed it from Section 5(b) of this appendix.

In paragraph (c), the Commission identified the new regulations that are applicable to the U.S. ABWR design for the purposes of 10 CFR 52.48, 52.54, 52.59, and 52.63. The new regulations cover the following subjects:

1. Intersystem LOCA
2. Inservice Testing of Pumps and Valves
3. Digital Instrumentation and Control Systems
4. Alternate Offsite Power Source to Non-Safety Equipment
5. Offsite Power Source to Safety Divisions
6. Post-Fire Safe Shutdown
7. Analysis of External Events
8. Alternate AC Power Source
9. Core Debris Cooling
10. High Pressure Core Melt Ejection
11. Equipment Survivability
12. Containment Performance
13. Shutdown Risk

A detailed discussion and comment analysis for each new regulation is contained in Section II.A.4. The new regulations have the same effect as any other regulation, except for the additional compliance-backfit standard described in Section 8(c) of this appendix.

F. Issue resolution for this design certification.

The purpose of Section 6 of this appendix is to identify the scope of issues that are resolved by the Commission in this rulemaking and; therefore, are "matters resolved" within the meaning and intent of 10 CFR 52.63(a)(4). The section is divided into four parts: (a) the Commission's safety findings in adopting this appendix, (b) the scope and nature of issues which are resolved by this rulemaking, (c) the backfit restrictions applicable to the Commission with respect to this appendix, and (d) availability of secondary references.

Paragraph (a) describes in general terms the nature of the Commission's findings, and makes the finding required by 10 CFR 52.54 for the Commission's approval of this final design certification rule. Furthermore, paragraph (a) explicitly states the Commission's determination that this design provides adequate protection to the public health and safety.

Paragraph (b) sets forth the scope of issues which may not be challenged as a matter of right in subsequent proceedings. The introductory phrase of paragraph (b) clarifies that issue resolution as described in the remainder of the paragraph extends to the delineated NRC proceedings referencing this appendix. The remaining portion of paragraph (b) describes the general categories of information for which there is issue resolution.

Specifically, paragraph (b)(1) provides that all nuclear safety issues arising from the Atomic Energy Act of 1954, as amended, that are associated with the information in the NRC staff's FSER, the applicant's DCD, and the rulemaking record for this appendix are resolved within the meaning of § 52.63(a)(4). These issues include the information referenced in the DCD that

are requirements (i.e., "secondary references"), as well as all issues arising from proprietary and safeguards information which are intended to be requirements. Paragraph (b)(2) provides for issue preclusion of proprietary and safeguards information. As discussed in section II.A.1 of this SOC, the inclusion of proprietary and safeguards information within the scope of issues resolved within the meaning of § 52.63(a)(4) represents a change from the Commission's intent during the proposed rule. Paragraph (b)(3) clarifies that departures from the DCD which are accomplished in compliance with the relevant procedures and criteria in Section 8 of this Appendix continue to be matters resolved in connection with this rulemaking. Paragraph (b)(4) provides that, for those plants located on sites whose site parameters do not exceed those assumed in the Technical Support Document (December 1994), all issues with respect to severe accident design alternatives arising under the National Environmental Policy Act of 1969 associated with the information in the Environmental Assessment for this design and the information regarding severe accident design alternatives in the applicant's Technical Support Document (December 1994) are also resolved within the meaning and intent of § 52.63(a)(4).

Paragraph (c) simply reiterates the restrictions (contained in 10 CFR 52.63 and Section 8 of this appendix) placed upon the Commission in ordering generic or plant-specific modifications, changes or additions to structures, systems or components, design features, design criteria, and ITAAC within the scope of the standard design. While the Commission does not believe that this rule language is necessary, the Commission has included such language in Section 6 to provide a concise statement of the scope and finality of this design certification rule.

Paragraph (d) provides the procedure for an interested member of the public to obtain access to proprietary and safeguards information for the U.S. ABWR design, in order to request and participate in proceedings identified in Section 6(b)(1) of this appendix, viz., proceedings involving licenses and applications which reference this appendix. As set forth in paragraph (d), access must first be sought from the design certification applicant. If GE Nuclear Energy refuses to provide the information, the person seeking access must request access from the Commission or the presiding officer, as applicable. Access to the proprietary and safeguards information may be ordered by the Commission, but shall be subject to an appropriate non-disclosure agreement.

G. Duration of this design certification.

The purpose of Section 7 of this appendix is in part to specify the time period during which this design certification may be referenced by an applicant for a combined license, pursuant to 10 CFR 52.55. This section also states that the design certification remains valid for an applicant or licensee that references the design certification until the application is withdrawn or the license expires. Therefore, if an application references this design certification during the 15-year period, then the design certification continues in effect until the application is withdrawn or the license issued on that application expires. Also, the design certification continues in effect for the referencing license if the license is renewed. The Commission intends for this appendix to remain valid for the life of the plant that references the design certification to achieve the benefits of

standardization and licensing stability. This means that changes to or plant-specific departures from information in the plant-specific DCD must be made pursuant to the change processes in Section 8 of this appendix for the life of the plant.

In its comments, dated August 3, 1995, GE noted that the proposed design certification rule for the U.S. ABWR design indicated that the duration was for a period of 15 years from May 8, 1995, which is inconsistent with the provisions of 10 CFR Part 52. The date of May 8, 1995, was inserted into the proposed rule as a result of an administrative error by the Office of the Federal Register. The duration in the final rule is for a period of 15 years from the date of effectiveness of the final rule, which is in accordance with 10 CFR Part 52.

H. Processes for changes and departures.

The purpose of Section 8 of this appendix is to set forth the processes for generic changes to or plant-specific departures (including exemptions) from this appendix. The Commission adopted this restrictive change process in order to achieve a more stable licensing process for applicants and licensees that reference a design certification rule. Section 8 is divided into three paragraphs, which correspond to Tier 1, Tier 2, and backfitting for compliance with any of the additional applicable regulations identified in Section 5(c) of this appendix. The language of Section 8 distinguishes between generic *changes to* the DCD versus plant-specific *departures from* the DCD. Generic *changes* must be accomplished by rulemaking because the intended subject of the change is the design certification rule itself, as is contemplated by 10 CFR 52.63(a)(1). Consistent with 10 CFR 52.63(a)(2), any generic rulemaking changes are applicable to all plants, absent circumstances which render the change ("modification" in the language of § 52.63(a)(2)) "technically irrelevant." By contrast, plant-specific *departures* could be either a Commission-issued order to one or more applicants or licensees; or an applicant or licensee-initiated departure applicable only to that applicant's or licensee's plant(s), *i.e.*, a § 50.59-like departure or an exemption. Because these plant-specific departures will result in a DCD that is unique for that plant, Section 10 of this appendix requires an applicant or licensee to maintain a plant-specific DCD. For purposes of brevity, this discussion refers to both generic changes and plant-specific departures as "change processes."

Both Section 8 and this SOC refer to an "exemption" from one or more aspects of this appendix and the criteria for granting an exemption. The Commission cautions that where the exemption involves an underlying substantive requirement ("applicable regulation"), then the applicant or licensee requesting the exemption must also show that an exemption from the underlying applicable requirement meets the criteria of 10 CFR 50.12.

Tier 1.

The change processes for Tier 1 information are covered in paragraph 8(a). Generic changes to Tier 1 are accomplished by rulemaking that amends the generic DCD and are governed by the standards in 10 CFR 52.63(a)(1). This provision provides that the Commission may not modify, change, rescind, or

impose new requirements by rulemaking except where necessary either to bring the certification into compliance with the Commission's regulations applicable and in effect at the time of issuance of the design certification or to assure adequate protection of the public health and safety or common defense and security. The rulemakings must include an opportunity for hearing with respect to the proposed change, as required by 10 CFR 52.63(a)(1), and the hearings will be conducted in accordance with 10 CFR Part 2, Subpart H. Departures from Tier 1 may occur in two ways: (1) the Commission may *order* a licensee to depart from Tier 1, as provided in paragraph (a)(3); and (2) an applicant or licensee may request an *exemption* from Tier 1, as provided in paragraph (a)(4). If the Commission seeks to order a licensee to depart from Tier 1, paragraph (a)(3) requires that the Commission find both that the departure is necessary for adequate protection or for compliance, and that special circumstances as defined in 10 CFR 50.12(a) are present. Paragraph (a)(4) provides that exemptions from Tier 1 requested by an applicant or licensee are governed by the requirements of 10 CFR 52.63(b)(1) and 52.97(b), which provide an opportunity for a hearing.

Tier 2.

The change processes for the three different categories of Tier 2 information, *viz.*, Tier 2, Tier 2*, and Tier 2* with a time of expiration are set forth in paragraph 8(b). The change process for Tier 2 has the same elements as the Tier 1 change process, but some of the standards for plant-specific orders and exemptions are different. The Commission also adopted a "\$ 50.59-like" change process in accordance with its SRMs on SECY-90-377 and SECY-92-287A.

The process for generic Tier 2 changes (including changes to Tier 2* and Tier 2* with a time of expiration) tracks the process for generic Tier 1 changes. As set forth in paragraph (b)(1), generic Tier 2 changes are accomplished by rulemaking amending the generic DCD, and are governed by the standards in 10 CFR 52.63(a)(1). This provision provides that the Commission may not modify, change, rescind or impose new requirements by rulemaking except where necessary either to bring the certification into compliance with the Commission's regulations applicable and in effect at the time of issuance of the design certification or to assure adequate protection of the public health and safety or common defense and security.

Departures from Tier 2 may occur in five ways: (1) the Commission may order a plant-specific departure, as set forth in paragraph (b)(3); (2) an applicant or licensee may request an exemption from a Tier 2 requirement as set forth in paragraph (b)(4); (3) a licensee may make a departure without prior NRC approval in accordance with paragraph (b)(5) [the "\$ 50.59-like" process]; (4) the licensee may request NRC approval for proposed departures which do not meet the requirements in paragraph (b)(5) as provided in paragraph (b)(5)(iv); and (5) the licensee may request NRC approval for a departure from Tier 2* information, in accordance with paragraph (b)(6).

Similar to Commission-ordered Tier 1 departures and generic Tier 2 changes, Commission-ordered Tier 2 departures cannot be imposed except where necessary either to bring the certification into compliance with the Commission's regulations applicable and in effect at the time of issuance of

the design certification or to assure adequate protection of the public health and safety or common defense and security, as set forth in paragraph 8(b)(3).

An applicant or licensee may request an exemption from Tier 2 information as set forth in paragraph (b)(4) of this Appendix. The applicant or licensee must establish that the exemption complies with 10 CFR 50.12. If the exemption is requested by an applicant for a combined license, the exemption is subject to litigation in the same manner as other issues in the combined license hearing, consistent with 10 CFR 52.63(b)(1).

Paragraph (b)(5) allows an applicant or licensee to depart from Tier 2 information without prior NRC approval if the proposed departure does not involve a change to or departure from Tier 1 or Tier 2* information, technical specifications, or involves an unreviewed safety question (USQ) as defined in paragraphs (b)(5)(ii) and (iii). The technical specifications identified in this paragraph are the technical specifications that will be developed during the COL review. Prior to issuance of the COL, an applicant is not controlled by the technical specifications under development but should be cognizant of the technical specifications in Chapter 16 of the generic DCD. The definition of a USQ in paragraph (b)(5)(ii) is similar to the definition in 10 CFR 50.59 and it applies to all information in Tier 2 except for the information, identified in paragraph (b)(5)(ii), that resolves the severe accident issues. The process for evaluating proposed tests or experiments not described in Tier 2 will be incorporated into the change process for the portion of the design that is outside the scope of this design certification. Although paragraph (b)(5) does not specifically state, the Commission notes that departures must also comply with all applicable regulations unless an exemption or other relief is obtained.

The Commission believes that it is important to preserve and maintain the resolution of severe accident issues just like all other safety issues that were resolved during the design certification review (refer to SRM on SECY-90-377). However, because of the increased uncertainty in severe accident issue resolutions, the Commission has adopted separate criteria for determining whether a departure from information that resolves severe accident issues constitutes a USQ. The new criteria in paragraph (b)(5)(iii) will only apply to Tier 2 information in the sections of the generic DCD identified in paragraph (b)(5)(iii). If the proposed departure from Tier 2 information involves the resolution of other safety issues in addition to the severe accident issues, then the USQ determination for those issues should be based upon the criteria in Section 8(b)(5)(ii) of this appendix. An applicant or licensee that plans to depart from Tier 2 information, under Section 8(b)(5), must prepare a safety evaluation which provides the bases for the determination that the proposed change does not involve an unreviewed safety question, a change to Tier 1 or Tier 2* information, or a change to the technical specifications. In order to achieve the Commission's goals for design certification, the evaluation needs to consider all of the matters that were resolved in the DCD, such as generic issue resolutions that are relevant to the proposed departure. The benefits of the early resolution of safety issues would be lost if departures from the DCD were made that violated these resolutions without appropriate review. The evaluation of the relevant resolved issues needs to consider the proposed departure over the full range of power operation from startup to shutdown, including issues resolved under the heading of shutdown risk, as it relates to anticipated operational occurrences, transients, design basis accidents, and severe accidents. The

evaluation should consider the tables in Sections 14.3 and 19.8 of the DCD to ensure that the proposed change does not impact Tier 1. These tables contain various cross-references from the plant safety analyses in Tier 2 to the important parameters that were included in Tier 1. Although many issues and analyses could have been cross-referenced, the listings in these tables were developed only for key plant safety analyses for the design. GE provided more detailed cross-references to Tier 1 for these analyses in a letter dated March 31, 1994, and ABB-CE provided more detailed cross-references in a letter dated June 10, 1994. If a proposed departure from Tier 2 involves a change to or departure from Tier 1 or Tier 2* information, technical specifications, or otherwise constitutes a USQ, then the applicant or licensee must obtain NRC approval through the appropriate process set forth in this appendix before implementing the proposed departure. The NRC does not endorse NSAC-125, "Guidelines for 10 CFR 50.59 Safety Evaluations," for performing safety evaluations required by Section 8(b)(5) of this appendix. However, the NRC will work with industry, if it is desired, to develop an appropriate guidance document for processing proposed changes under Section 8(b).

A party to an adjudicatory proceeding (e.g., for issuance of a combined license) who believes that an applicant or licensee has not complied with Section 8(b)(5) when departing from Tier 2 information, may petition to admit such a contention into the proceeding. As set forth in paragraph (b)(5)(vi), the petition must comply with the requirements of § 2.714(b)(2) and show that the departure does not comply with paragraph (b)(5). Any other party may file a response to the petition. If on the basis of the petition and any responses, the presiding officer in the proceeding determines that the required showing has been made, the matter shall be certified to the Commission for its final determination. In the absence of a proceeding, petitions alleging non-conformance with paragraph (b)(5) requirements applicable to Tier 2 departures will be treated as petitions for enforcement action under 10 CFR 2.206.

Certain Tier 2* information listed in paragraph (b)(6)(iii) is no longer designated as Tier 2* information after full power operation is first achieved following the Commission finding in 10 CFR 52.103(g). Thereafter, that information is deemed to be Tier 2 information that is subject to the departure requirements in paragraph (b)(5). By contrast, the Tier 2* information identified in paragraph (b)(6)(ii) retains its Tier 2* designation throughout the term of the combined license, including any period of renewal. Any requests for departures from Tier 2* information that affect Tier 1 must also comply with the requirements in Section 8(a) of this appendix.

Regardless of the way in which a departure is achieved, the Commission has determined that it is not necessary to impose an additional limitation, similar to that imposed on Tier 1 departures by 10 CFR 52.63(a) and paragraph 8(a)(3) and (4) of this appendix, whether the special circumstances in § 50.12(a) outweigh any decrease in safety that may result from the reduction in standardization. This type of additional limitation would unnecessarily restrict the flexibility of applicants and licensees with respect to Tier 2, which by its nature is not as safety significant as Tier 1.

Backfitting for Compliance with Additional Applicable Regulations

Paragraph (c) sets forth the criteria which must be met if the Commission is to require a backfit to either this appendix or, for a plant referencing this appendix, that portion of the plant subject to the appendix, where the backfit is for compliance with an "additional applicable regulation" in Section 5(c) of this appendix. Such backfitting can occur either by rulemaking amending this appendix (and may be initiated by the Commission either at its own instance or upon petition); or by Commission issuing an order to one or more plants referencing this appendix. Any backfit intended to achieve compliance with an "additional applicable regulation" must meet stringent criteria. First, the Commission must find that the asserted non-compliance constitutes a "substantial reduction in protection" to the public health and safety or common defense and security. If such is the case, the Commission must tailor the backfit to return to approximately the level of protection originally embodied at the time the new applicable regulation was first adopted; the Commission does not intend to impose such "compliance backfits" to achieve a level of protection greater than that intended when it adopted the "additional applicable regulation". Finally, the Commission must determine that the costs, both direct and indirect, of the implementation of the backfit are "justified in view of [the] compensating increase in protection." The Commission regards these criteria as stringent enough to ensure that marginal compliance backfits are not imposed, thereby addressing the industry concerns about unfettered compliance backfits with new applicable regulations. The Commission would nonetheless be able to correct those significant non-compliances which result in the appendix (and any plant referencing this appendix) not achieving the level of protection to the public that was originally intended when the Commission adopted the additional applicable regulation.

I. Inspections, tests, analyses, and acceptance criteria (ITAAC).

The purpose of Section 9 of this Appendix is to set forth how the ITAAC in Tier 1 of this design certification rule are to be treated in a combined license proceeding. Paragraph (a) restates the responsibilities of the combined license applicant and holder in performing and successfully completing ITAAC, and notifying the NRC of such completion. Paragraph (a)(1) makes it clear that an applicant for a COL may proceed at its own risk with design and procurement activities subject to ITAAC, and that a COL holder may proceed at its own risk with design, procurement, construction, and preoperational testing activities subject to an ITAAC, even though the NRC may not have found that any particular ITAAC has been successfully completed. Paragraph (a)(2) requires the licensee to notify the NRC that the required inspections, tests, and analyses in the ITAAC have been completed and that the acceptance criteria have been met. Paragraphs (b)(1) and (2) essentially reiterate the NRC's responsibilities with respect to ITAAC as set forth in 10 CFR 52.99 and 52.103, as explained in II.C.1. Finally, paragraph (b)(3) states that ITAAC do not constitute regulatory requirements either for subsequent plant modifications within the scope of this design certification rule, or for renewal of the combined license. However, subsequent modifications must comply with the Tier 1 design descriptions unless the applicable requirements in 10 CFR 52.97 and Section 8 of this appendix have been complied with. As discussed in II.B.9, the Commission will defer a determination of the applicability of ITAAC and their effect in terms of issue

resolution in 10 CFR Part 50 licensing proceedings to such time, if any, that a Part 50 applicant decides to reference this appendix.

J. Records and Reporting.

The purpose of Section 10 of this appendix is to set forth the requirements for maintaining records of changes to and departures from the generic DCD, which are to be reflected in the plant-specific DCD. Section 10 also sets forth the requirements for submitting reports (including updates to the plant-specific DCD) to the NRC. This section of the appendix is similar to the requirements for records and reports in 10 CFR Part 50, except for minor differences in information collection and reporting requirements, as discussed in section V below. Section 10(a)(1) of this appendix requires that a generic DCD and the proprietary and safeguards information referenced in the generic DCD be maintained by the applicant for this rule. The generic DCD was developed, in part, to meet the requirements for incorporation by reference, including availability requirements. Therefore, the proprietary and safeguards information could not be included in the generic DCD because it is not publicly available. However, the proprietary and safeguards information was reviewed by the NRC and, as stated in Section 6(b)(2) of this appendix, the Commission considers the information to be resolved within the meaning of 10 CFR 52.63(a)(4). Because this information is not in the generic DCD, the proprietary and safeguards information, or its equivalent, is required to be provided by an applicant for a combined license. Therefore, to ensure that this information will be available, a requirement to maintain the proprietary and safeguards information was added to Section 10(a)(1) of this appendix. The acceptable version of the proprietary and safeguards information is identified in the version of the DCD that is incorporated into this rule. The generic DCD and the acceptable version of the proprietary and safeguards information must be maintained for the period of time that this rule may be referenced.

Sections 10(a)(2) and (a)(3) of this appendix place record-keeping requirements on the applicant or licensee that references this design certification to maintain its plant-specific DCD to accurately reflect both generic changes to the generic DCD and plant-specific departures made pursuant to Section 8 of this appendix. The term "plant-specific" was added to Section 10(a)(2) and other Sections of this appendix to distinguish between the generic DCD that is incorporated by reference into this appendix, and the plant-specific DCD that the applicant is required to submit under Section 4(a)(2)(i) of this appendix. The requirement to maintain the generic changes to the generic DCD is explicitly stated to ensure that these changes are not only reflected in the generic DCD, which will be maintained by the applicant for design certification, but that the changes are also reflected in the plant-specific DCD. Therefore, records of generic changes to the DCD will be required to be maintained by both entities to ensure that both entities have up-to-date DCDs.

Section 10(a) of this appendix does not place record-keeping requirements on site-specific information that is outside the scope of this rule. As discussed in section III.D, the final safety analysis report (§ 52.79) will contain the plant-specific DCD and the site-specific information for a facility that references this rule. The phrase "site-specific portion of the final safety analysis report" in section 10(b)(3)(iv) of this appendix

refers to the information that is contained in the final safety analysis report for a facility but is not part of the plant-specific DCD, i.e. required by Subpart C of Part 52 and Section 4 of this appendix. Therefore, this rule does not require that duplicate documentation be maintained by an applicant or licensee that references this rule, because the plant-specific DCD is part of the final safety analysis report for the facility (refer to the discussion on DOE's comment in section II.C.3).

Section 10(b)(1) and (b)(2) of this appendix establishes reporting requirements for applicants or licensees that reference this rule that are similar to the reporting requirements in 10 CFR Part 50. For currently operating plants, a licensee is required to maintain records of the basis for any design changes to the facility made under 10 CFR 50.59. Section 50.59(b)(2) requires a licensee to provide a summary report of these changes to the NRC annually, or along with updates to the facility final safety analysis report under 10 CFR 50.71(e). Section 50.71(e)(4) requires that these updates be submitted annually, or 6 months after each refueling outage if interval between successive updates does not exceed 24 months.

The reporting requirements vary according to four different time periods during facilities' lifetime as specified in Section 10(b)(3) of this appendix. Section 10(b)(3)(i) requires that if an applicant that references this rule decides to make departures from the generic DCD, then the departures and any updates to the plant-specific DCD must be submitted with the initial application for a combined license. Under Section 10(b)(3)(ii), the applicant may submit any subsequent reports and updates along with its amendments to the application provided that the submittals are made at least once per year. Because amendments to an application are typically made more frequently than once a year, this should not be an unnecessary burden on the applicant.

Section 10(b)(3)(iii) requires that the reports be submitted quarterly during the period of facility construction. This increase in frequency of summary reports of departures from the plant-specific DCD is in response to the Commission's guidance on reporting frequency in its SRM on SECY-90-377, dated February 15, 1991. NEI stated in its comments (Attachment B, p. 116) that ... "the requirement for quarterly reporting imposes unnecessary additional burdens on licensees and the NRC." NEI recommended that the Commission adopt a "less onerous" requirement (e.g., semi-annual reports). The NRC does not agree with the NEI request because it does not provide for sufficiently timely notification of design changes during the critical period of facility construction. The NRC disagrees that the reports are an onerous burden because they are only summary reports, which describe the design changes, rather than detailed evaluations of the changes and determinations. The detailed evaluations remain available for audit on site, consistent with the requirements of 10 CFR Part 50. Quarterly reporting of design changes during the period of construction is necessary to closely monitor the status and progress of the construction of the plant. To make its finding under 10 CFR 52.99, the NRC must monitor the design changes made in accordance with Section 8 of this appendix. The ITAAC verify that the as-built facility conforms with the approved design and emphasizes design reconciliation and design verification. Quarterly reporting of design changes is particularly important in times where the number of design changes could be significant, such as during the procurement of components and equipment, detailed design of the plant at the start of construction, and during pre-operational testing. The frequency of updates to the plant-specific DCD is not increased during

facility construction. After the facility begins operation, the frequency of reporting reverts to the requirement in Section 10(b)(3)(iv), which is consistent with the requirement for plants licensed under 10 CFR Part 50.

IV. Finding of No Significant Environmental Impact: Availability

The Commission has determined under the National Environmental Policy Act of 1969, as amended (NEPA), and the Commission's regulations in 10 CFR Part 51, Subpart A, that this design certification rule is not a major Federal action significantly affecting the quality of the human environment and, therefore, an environmental impact statement (EIS) is not required. The basis for this determination, as documented in the final environmental assessment, is that this amendment to 10 CFR Part 52 does not authorize the siting, construction, or operation of a facility using the U.S. ABWR design; it only codifies the U.S. ABWR design in a rule. The NRC will evaluate the environmental impacts and issue an EIS as appropriate in accordance with NEPA as part of the application(s) for the construction and operation of a facility.

In addition, as part of the final environmental assessment for the U.S. ABWR design, the NRC reviewed GE's evaluation of various design alternatives to prevent and mitigate severe accidents that was submitted in GE's "Technical Support Document for the ABWR." The Commission finds that GE's evaluation provides a sufficient basis to conclude that there are no additional severe accident design alternatives beyond that currently incorporated into the U.S. ABWR design which are cost-beneficial, whether considered at the time of the approval of the U.S. ABWR design certification or in connection with the licensing of a future facility referencing the U.S. ABWR design certification, where the plant referencing this appendix is located on a site whose site parameters do not exceed those assumed in the Technical Support Document. These issues are considered resolved for the U.S. ABWR design.

The final environmental assessment, upon which the Commission's finding of no significant impact is based, and the Technical Support Document for the U.S. ABWR design are available for examination and copying at the NRC Public Document Room, 2120 L Street, NW. (Lower Level), Washington, DC. Single copies are also available from Mr. Dino C. Scaletti, Mailstop O-11 H3, U.S. Nuclear Regulatory Commission, Washington, DC 20555, (301) 415-1104.

V. Paperwork Reduction Act Statement

This final rule amends information collection requirements that are subject to the Paperwork Reduction Act of 1995 (44 U.S.C. 3501 et seq.). These requirements were approved by the Office of Management and Budget, approval number 3150-0151. Should an application be received, the additional public reporting burden for this collection of information, above those contained in Part 52, is estimated to average 8 hours per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments on any aspect of this collection of information, including suggestions for reducing the burden, to the Information and Records Management Branch (T-6 F33), U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by Internet electronic mail at BJS1@NRC.GOV; and

to the Desk Officer, Office of Information and Regulatory Affairs, NEOB-10202, (3150-0151), Office of Management and Budget, Washington, DC 20503.

Public Protection Notification

The NRC may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number.

VI. Regulatory Analysis

The NRC has not prepared a regulatory analysis for this final rule. The NRC prepares regulatory analyses for rulemakings that establish generic regulatory requirements applicable to all licensees. Design certifications are not generic rulemakings in the sense that design certifications do not establish standards or requirements for which all licensees must comply. Rather, design certifications are Commission approvals of specific nuclear power plant designs by rulemaking. Furthermore, design certification rulemakings are initiated by an applicant for a design certification, rather than the NRC. Preparation of a regulatory analysis in this circumstance would not be useful because the design to be certified is proposed by the applicant rather than the NRC. For these reasons, the Commission concludes that preparation of a regulatory analysis is neither required nor appropriate.

VII. Regulatory Flexibility Act Certification

In accordance with the Regulatory Flexibility Act of 1980, 5 U.S.C. 605(b), the Commission certifies that this rulemaking will not have a significant economic impact upon a substantial number of small entities. The rule provides certification for a nuclear power plant design. Neither the design certification applicant nor prospective nuclear power plant licensees who reference this design certification rule fall within the scope of the definition of "small entities" set forth in the Regulatory Flexibility Act, 15 U.S.C. 632, or the Small Business Size Standards set out in regulations issued by the Small Business Administration in 13 CFR Part 121. Thus, this rule does not fall within the purview of the act.

VIII. Backfit Analysis

The Commission has determined that the backfit rule, 10 CFR 50.109, does not apply to this final rule because these amendments do not impose requirements on existing 10 CFR Part 50 licensees. Therefore, a backfit analysis was not prepared for this rule.

List of Subjects in 10 CFR Part 52

Part 52 - Administrative practice and procedure, Antitrust, Backfitting, Combined license, Early site permit, Emergency planning, Fees, Incorporation by reference, Inspection, Limited work authorization, Nuclear power plants and reactors, Probabilistic risk assessment, Prototype, Reactor siting criteria, Redress of site, Reporting and record keeping requirements, Standard design, Standard design certification.

For the reasons set out in the preamble and under the authority of the Atomic Energy Act of 1954, as amended; the Energy Reorganization Act of 1974, as amended; and 5 U.S.C. 552 and 553; the NRC is adopting the following amendments to 10 CFR Part 52.

1. The authority citation for 10 CFR Part 52 continues to read as follows:

AUTHORITY: Secs. 103, 104, 161, 182, 183, 186, 189, 68 Stat. 936, 948, 953, 954, 955, 956, as amended, sec. 234, 83 Stat. 1244, as amended (42 U.S.C. 2133, 2201, 2232, 2233, 2236, 2239, 2282); secs. 201, 202, 206, 88 Stat. 1243, 1244, 1246, 1246, as amended (42 U.S.C. 5841, 5842, 5846).

2. In § 52.8, paragraph (b) is revised to read as follows:

§ 52.8 Information collection requirements: OMB approval.

* * * * *

(b) The approved information collection requirements contained in this part appear in §§ 52.15, 52.17, 52.29, 52.45, 52.47, 52.57, 52.75, 52.77, 52.78, 52.79, Appendix A, and Appendix B.

3. A new Appendix A to 10 CFR Part 52 is added to read as follows:

Appendix A To Part 52--Design Certification Rule
for the U.S. Advanced Boiling Water Reactor

1. Introduction.

Appendix A constitutes the standard design certification for the U.S. Advanced Boiling Water Reactor (ABWR) design, in accordance with 10 CFR Part 52, Subpart B. The applicant for certification of the U.S. ABWR design was GE Nuclear Energy.

2. Definitions.

As used in this part:

(a) *Generic design control document* (generic DCD) means the document that contains the generic Tier 1 and Tier 2 information that is incorporated by reference into this appendix.

(b) *Plant-specific DCD* means the document, maintained by an applicant or licensee who references this design certification rule, consisting of the information in the generic DCD, as modified and supplemented by the plant-specific departures and exemptions made under Section 8 of this appendix.

(c) *Tier 1* means the portion of the design-related information contained in the generic DCD that is approved and certified by this design certification rule (hereinafter Tier 1 information). The design descriptions, interface requirements, and site parameters are derived from Tier 2 information. Tier 1 information includes:

- (1) Definitions and general provisions;
- (2) Design descriptions;
- (3) Inspections, tests, analyses, and acceptance criteria (ITAAC);
- (4) Significant site parameters; and

(5) Significant interface requirements.

(d) *Tier 2* means the portion of the design-related information contained in the generic DCD that is approved but not certified by this design certification rule (hereinafter *Tier 2* information). Compliance with *Tier 2* is required, but generic changes to and plant-specific departures from *Tier 2* are governed by Section 8 of this appendix. *Tier 2* information includes:

(1) Information required by 10 CFR 52.47, with the exception of technical specifications and conceptual design information;

(2) Information required for a final safety analysis report under 10 CFR 50.34;

(3) Supporting information on the inspections, tests, and analyses that will be performed to demonstrate that the acceptance criteria in the ITAAC have been met; and

(4) Combined license (COL) action items (COL license information), which identify certain matters that shall be addressed in the site-specific portion of the final safety analysis report by an applicant who references this appendix. These items constitute information requirements but do not otherwise constitute substantive requirements for judging the adequacy of the information submitted.

(e) *Tier 2** means the portion of the *Tier 2* information, designated as such in the generic DCD, which is subject to the change process in Section 8(b)(6) of this appendix. This designation expires for some *Tier 2** information pursuant to Section 8(b)(6).

(f) All other terms in this appendix have the meaning set out in 10 CFR 50.2, 10 CFR 52.3, or Section 11 of the Atomic Energy Act of 1954, as amended, as applicable.

3. Scope and contents of this design certification.

(a) *Tier 1* and *Tier 2* in the U.S. ABWR Design Control Document, GE Nuclear Energy, Revision _____ are approved for incorporation by reference by the Director of the Office of the Federal Register on [Insert date of approval] in accordance with 5 U.S.C. 552(a) and 1 CFR Part 51. Copies of the generic DCD may be obtained from [Insert name and address of applicant or organization designated by the applicant]. Copies are also available for examination and copying at the NRC Public Document Room, 2120 L Street NW. (Lower Level), Washington, DC 20555, and for examination at the NRC Library, 11545 Rockville Pike, Rockville, Maryland 20852-2738.

(b) An applicant or licensee referencing this appendix, in accordance with Section 4 of this appendix, shall comply with the requirements of this appendix, including *Tier 1* and *Tier 2*, except as otherwise provided in this appendix.

(c) If there is a conflict between *Tier 1* and *Tier 2* of the DCD, then *Tier 1* controls.

(d) If there is a conflict between the generic DCD and either the application for design certification for the U.S. ABWR design or NUREG-1503, "Final Safety Evaluation Report related to the Certification of the Advanced Boiling Water Reactor Design," dated July 1994 (FSER) and any supplements thereto, then the generic DCD controls.

(e) Conceptual design information and generic technical specifications, as set forth in the generic DCD, are not part of this appendix.

4. Applications and licenses referencing this design certification: additional requirements and restrictions.

(a) An applicant for a combined license that wishes to reference this Appendix shall, in addition to complying with the requirements of 10 CFR 52.77, 52.78, and 52.79, comply with the following requirements:

(1) Incorporate by reference, as part of its application, this appendix;

(2) Include, as part of its application:

(i) A plant-specific DCD containing the same information and utilizing the same organization and numbering as the generic DCD for the U.S. ABWR design, as modified and supplemented by the applicant's exemptions and departures;

(ii) The reports on departures from and updates to the plant-specific DCD required by Section 10(b) of this Appendix;

(iii) Technical specifications for the plant that are required by § 50.36 and § 50.36a;

(iv) Information demonstrating compliance with the site parameters and interface requirements;

(v) Information that addresses the COL action items; and

(vi) The information required by 10 CFR 52.47(a) that is not within the scope of this rule.

(vii) Descriptions of the initial 120-month in-service testing (IST) and in-service inspection (ISI) programs for pumps and valves subject to the test requirements set forth in 10 CFR 50.55a(f), which utilize:

(A) Non-intrusive techniques available twelve months prior to the date of the COL application to detect degradation and monitor performance characteristics of check valves; and

(B) A method to determine the frequency necessary for disassembly and inspection of each pump and valve to detect degradation that would prevent the component from performing its safety function and which cannot be detected through the use of non-intrusive techniques;

(viii) A description of a program for outage planning and control that ensures:

(A) The availability and functional capability during shutdown and low power operations of features important to safety during such operations; and

(B) The consideration of fire, flood, and other hazards during shutdown and low power operations; and

(ix) A description of a design reliability assurance program that:

(A) Includes the program's scope, purpose, and objectives;

(B) Evaluates the structures, systems, and components in the design, to determine their degree of risk-significance;

(C) Generates a list of structures, systems, and components designated as risk-significant;

(D) For those structures, systems, and components designated as risk-significant, considers both:

(AA) Industry-wide experience, analytical models, and applicable requirements to determine dominant failure modes; and

(BB) Industry-wide operational, maintenance, and monitoring experience to identify key assumptions and risk insights from probabilistic, deterministic, and other analytical methods; and

(E) Considers the dominant failure modes, incorporates the risk insights, and preserves the key assumptions identified in paragraph

(a)(2)(ix)(BB) of this Section in the design.

(3) Physically include, in the plant-specific DCD, the proprietary information and safeguards information referenced in the U.S. ABWR DCD; and

(4) Implement the design reliability assurance program required by paragraph (a)(2)(ix) of this Section.

(b) A holder of a combined license that references this appendix shall, in addition to complying with the requirements in 10 CFR 52.83, and 52.99 comply with the following requirements:

(1) Implement the portions of the IST and ISI programs required by paragraph (a)(2)(vii) of this section, as approved by the Commission and include in each successive 120-month IST testing program non-intrusive techniques available twelve months prior to the date of the start of each 120-month interval to detect degradation and monitor performance characteristics of check valves.

(2) Implement the program for outage planning and control required by paragraph (a)(2)(viii) of this Section; and

(3) Implement the design reliability assurance program required by paragraph (a)(2)(ix) of this Section

(c) Facility operation is not within the scope of this appendix, and the Commission reserves the right to impose requirements for facility operation on holders of licenses referencing this appendix by rule, regulation, order, or license condition.

(d) The Commission reserves the right to determine whether, and in what manner, this appendix may be referenced by an applicant for a construction permit or operating license under 10 CFR Part 50.

5. Applicable regulations.

(a) Except as indicated in paragraphs (b) and (c) of this section, the regulations that apply to the U.S. ABWR design are in 10 CFR Parts 20, 50, 73, and 100 codified as of [insert the date 30 days after the publication date] that are applicable and technically relevant, as described in the FSER and any associated supplements.

(b) The U.S. ABWR design is exempt from portions of the following regulations, as described in the FSER (index provided in Section 1.6 of the FSER):

(1) Paragraph (f)(2)(iv) of 10 CFR 50.34 - Separate Plant Safety Parameter Display Console;

(2) Paragraph (f)(2)(viii) of 10 CFR 50.34 - Post-Accident Sampling for Boron, Chloride, and Dissolved Gases;

(3) Paragraph (f)(3)(iv) of 10 CFR 50.34 - Dedicated Containment Penetration; and

(4) Paragraph VI(a)(2) of 10 CFR Part 100, Appendix A - Operating Basis Earthquake Design Consideration.

(c) In addition to the regulations specified in paragraph (a) of this section, the following new regulations are applicable for the purposes of 10 CFR 52.48, 52.54, 52.59 and 52.63:

(1) The low-pressure piping systems and subsystems of this design that interface with the reactor coolant pressure boundary must be designed for a normal operating pressure of at least 40 percent of the normal reactor operating pressure, to the extent practical as determined on [insert date of Commission approval].

(2) Piping systems of this design associated with pumps and valves subject to the test requirements set forth in 10 CFR 50.55a(f) must be designed to allow for:

- (i) Full flow testing of pumps at maximum design flow,
- (ii) Flow testing of check valves at flows sufficient to fully-open the valve, provided the valve's full-open position can be positively confirmed, or with the maximum design basis accident flowrate, and
- (iii) Testing of motor operated valves under conditions as specified in section 3.9 of the DCD, up to design basis differential pressure, to demonstrate the capability of the valves to operate under design basis conditions.

(3) The digital instrumentation and control systems of this design must provide for:

- (i) defense-in-depth and diversity,
- (ii) adequate defense against common-mode failures, and
- (iii) independent backup manual controls and displays for critical safety functions in the control room.

(4) The electric power system of this design must include an alternate offsite power source that has sufficient capacity and capability to provide power to non-safety equipment sufficient to provide the operator with the capability to bring the plant to a safe shutdown, following a loss of the normal power supply and reactor trip.

(5) The electric power system of this design must include at least one offsite circuit for supplying power to each redundant safety division. This circuit shall be designed such that non-safety loads do not have any significant adverse affect on the capability of the offsite circuit to provide power to each safety division.

(6) All structures, systems, and components of this design important to safe shutdown, except for the main steam tunnel, must be designed to ensure that:

(i) Safe shutdown can be achieved assuming that all equipment in any one fire area will be rendered inoperable by fire and that re-entry into the fire area for repairs and operator actions is not possible, except that this provision does not apply to (1) the main control room, provided that an alternative shutdown capability exists and is physically and electrically independent of the main control room, and (2) the reactor containment;

(ii) Smoke, hot gases, or fire suppressant will not migrate from one fire area into another to the extent they could adversely affect safe-shutdown capabilities, including operator actions; and

(iii) In the reactor containment, redundant shutdown systems must be provided with fire protection capabilities and means to limit fire damage such that, to the extent practical as of [insert date of Commission approval], one shutdown division be free of fire damage.

(7) The probabilistic risk assessment (PRA) required by 10 CFR 52.47(a)(1)(v) must include an assessment of internal and external events. For external events, simplified (bounding) probabilistic methods and margins methods may be used instead of detailed PRA analyses to identify potential vulnerabilities and important safety insights for the design in order to incorporate the insights in the design. Simplified bounding risk analyses for fires and floods may be performed when detailed design information, such as pipe and cable routing, is not available. For earthquakes, the seismic

margins analysis must be based on a review earthquake level of one and two-thirds the acceleration of the safe-shutdown earthquake (i.e., review earthquake level of 0.5g.)

(8) The electric power system of this design must include an on-site alternate AC power source of diverse design capable of providing power to at least one complete set of equipment sufficient to achieve and maintain safe-shutdown in the event of a station blackout.

(9) For the severe accident sequences identified in Section 19E of the DCD, this design must include the following design features that, in combination with other design features, ensure that environmental conditions (pressure and temperature) described in Section 19E of the DCD resulting from interactions of molten core debris with containment structures do not exceed ASME Code Service Level C for steel containments or Factored Load Category for concrete containments for a time from the initiation of the accident sequence sufficient to mitigate them in view of their probability of occurrence and the uncertainties in severe accident progression and phenomenology:

(i) A minimum of 79 m² of unobstructed reactor cavity floor space for molten core debris spreading;

(ii) A passive flooder system and an ac-independent water addition system capable of directly or indirectly flooding the reactor cavity for cooling molten core debris; and

(iii) Concrete to protect portions of the lower drywell containment liner and the reactor pedestal.

(10) This design must include:

(i) a safety-related or other highly reliable means to depressurize the reactor coolant system and

(ii) cavity design features to reduce the amount of ejected core debris that may reach the upper containment.

(11) This design must include analyses based on analytical techniques in use as of [insert date of Commission approval], to demonstrate that:

(i) Electrical and mechanical equipment that prevents or mitigates the consequences of a severe accident must be capable of performing their functions for a time period sufficient to prevent or mitigate the consequences of that severe accident under the environmental conditions (e.g., pressure, temperature, radiation) described in Section 19E.2.1.2.3 of the DCD for that severe accident; and

(ii) Instrumentation that monitors plant conditions during a severe accident must be capable of performing its function for a time period sufficient to prevent or mitigate the consequences of that severe accident under the environmental conditions (e.g., pressure, temperature, radiation) described in Section 19E.2.1.2.3 of the DCD for that severe accident.

(12) This design must include design features intended to limit the conditional containment failure probability to less than 0.1 for the severe accident sequences identified in Section 19E of the DCD.

(13) This design must include assessments of:

(i) Features that minimize shutdown risk;

(ii) The reliability of decay heat removal systems;

(iii) Features that mitigate vulnerabilities resulting from other design features; and

(iv) Features that assure the operator's ability to shut down the plant safely and maintain it in a safe condition in the event of fires and floods occurring with the plant in modes other than full power.

6. Issue resolution for this design certification.

(a) The Commission has determined that the structures, systems, components, and design features of the U.S. ABWR design comply with the provisions of the Atomic Energy Act of 1954, as amended, and the applicable regulations identified in Section 5 of this appendix, and therefore, provide adequate protection to the health and safety of the public. A conclusion that a matter is resolved includes the finding that additional or alternative structures, systems, components, design features, design criteria, testing, analyses, acceptance criteria, or justifications are not necessary for the U.S. ABWR design.

(b) The Commission considers the following matters resolved within the meaning of 10 CFR 52.63(a)(4) in subsequent proceedings for issuance of a combined license, amendment of a combined license, or renewal of a combined license, proceedings held pursuant to 10 CFR 52.103, and enforcement proceedings where these proceedings reference this appendix:

(1) All nuclear safety issues associated with the information in the FSER and any associated supplements, the generic DCD (including referenced information which the context indicates is intended as requirements), and the rulemaking record for certification of the U.S. ABWR design;

(2) All nuclear safety and safeguards issues associated with the information in proprietary and safeguards documents referenced and in context is intended as requirements in the generic DCD for the U.S. ABWR design;

(3) Except as provided in Section 8(b)(5)(vi) of this appendix, all departures from Tier 2 pursuant to and in compliance with the change processes in Section 8(b)(5) of this appendix that do not require prior NRC approval;

(4) All environmental issues concerning severe accident design alternatives associated with the information in the NRC's final environmental assessment for the U.S. ABWR design and Revision 1 of the Technical Support Document for the U.S. ABWR, dated December 1994, for plants referencing this appendix whose site parameters are within those specified in the Technical Support Document.

(c) Except in accordance with the change processes in Section 8 of this appendix, the Commission may not require an applicant or licensee who references this appendix to:

(1) Modify structures, systems, components, or design features as described in the generic DCD;

(2) Provide additional or alternative structures, systems, components, or design features not discussed in the generic DCD; or

(3) Provide additional or alternative design criteria, testing, analyses, acceptance criteria, or justification for structures, systems, components, or design features discussed in the generic DCD.

(d) Persons who wish to review proprietary and safeguards information or other secondary references in the DCD for the U.S. ABWR design, in order to request or participate in the hearing required by 10 CFR 52.85 or the hearing provided under 10 CFR 52.103, or to request or participate in any other hearing relating to the certified design in which interested persons have

adjudicatory hearing rights, shall first request access to such information from GE Nuclear Energy. The request must state *with particularity*:

- (i) the nature of the proprietary or other information sought;
- (ii) the reason why the information currently available to the public in the NRC's public document room is insufficient;
- (iii) the relevance of the requested information to the hearing issue(s) which the person proposes to raise; and
- (iv) a showing the requesting person has the capability to understand and utilize the requested information.

(3) If a person claims that the information is necessary to prepare a request for hearing, the request must be filed no later than 15 days after publication in the Federal Register of the notice required either by 10 CFR 52.85 or 10 CFR 52.103. If GE Nuclear Energy declines to provide the information sought, GE Nuclear Energy shall send a written response within ten (10) days of receiving the request to the requesting person setting forth with particularity the reasons for its refusal. The person may then request the Commission (or presiding officer, if a proceeding has been established) to order disclosure. The person shall include copies of the original request (and any subsequent clarifying information provided by the requesting party to the applicant) and the applicant's response. The Commission and presiding officer shall base their decisions *solely* on the person's original request (including any clarifying information provided by the requesting person to GE Nuclear Energy), and GE Nuclear Energy's response. The Commission and presiding officer may order GE Nuclear Energy to provide access to some or all of the requested information, subject to an appropriate non-disclosure agreement.

7. Duration of this design certification.

This design certification may be referenced for a period of 15 years from [insert the date 30 days after the publication date], except as provided for in 10 CFR 52.55(b) and 52.57(b). This design certification remains valid for an applicant or licensee who references this appendix until the application is withdrawn or the license expires, including any period of extended operation under a renewed license.

8. Processes for changes and departures.

(a) Tier 1 information.

(1) Generic changes to Tier 1 information are governed by the requirements in 10 CFR 52.63(a)(1).

(2) Generic changes to Tier 1 information are applicable to all plants referencing the design certification as set forth in 10 CFR 52.63(a)(2).

(3) Departures from Tier 1 information that are imposed by the Commission through plant-specific orders are governed by the requirements in 10 CFR 52.63(a)(3).

(4) Exemptions from Tier 1 information are governed by the requirements in 10 CFR 52.63(b)(1) and § 52.97(b).

(b) Tier 2 information.

(1) Generic changes to Tier 2 information shall be governed by the same requirements in 10 CFR 52.63(a)(1) that govern generic changes to Tier 1.

(2) Generic changes to Tier 2 information are applicable to all plants referencing the design certification as set forth in 10 CFR 52.63(a)(2).

(3) The Commission may not impose new requirements on Tier 2 by plant-specific order while the design certification is in effect under §§ 52.55 or 52.61, unless:

(i) A modification is necessary to secure compliance with the Commission's regulations applicable and in effect at the time the certification was issued, as set forth in Section 5 of this Appendix, or to assure adequate protection of the public health and safety or the common defense and security; and

(ii) Special circumstances as defined in 10 CFR 50.12(a) are present.

(4) An applicant or licensee who references the design certification may request an exemption from Tier 2 information. The Commission may grant such a request only if it determines that the exemption will comply with the requirements of 10 CFR 50.12(a). The granting of such an exemption must be subject to litigation in the same manner as other issues in the combined license hearing.

(5)(i) An applicant or licensee who references the design certification may depart from Tier 2 information, without prior NRC approval, unless the proposed departure involves a change to or departure from Tier 1 information, Tier 2* information, or the technical specifications, or involves an unreviewed safety question as defined in paragraphs (b)(5)(ii) and (b)(5)(iii) of this section. When evaluating the proposed departure, an applicant or licensee shall consider all matters described in the plant-specific DCD.

(ii) A proposed departure from Tier 2, other than one affecting resolution of a severe accident issue identified in Section 19E of the plant-specific DCD including attachments EA through EE, involves an unreviewed safety question if:

(A) The probability of occurrence or the consequences of an accident or malfunction of equipment important to safety previously evaluated in the plant-specific DCD may be increased;

(B) A possibility for an accident or malfunction of a different type than any evaluated previously in the plant-specific DCD may be created; or

(C) The margin of safety as defined in the basis for any technical specification is reduced.

(iii) A proposed departure from Tier 2 affecting resolution of a severe accident issue identified in Section 19E of the plant-specific DCD, including attachments EA through EE, involves an unreviewed safety question if:

(A) There is a substantial increase in the probability of a severe accident such that a particular severe accident previously reviewed and determined to be not credible could become credible; or

(B) There is a substantial increase in the consequences to the public of a particular severe accident previously reviewed.

(iv) If a departure involves an unreviewed safety question as defined in paragraph (b)(5) of this section, it is governed by 10 CFR 50.90 and 92.

(v) A departure from Tier 2 information that is made under paragraph (b)(5) of this section does not require an exemption from this Appendix.

(vi) A party to an adjudicatory proceeding for either the issuance, amendment, or renewal of a combined license or for operation under 10 CFR 52.103(a), who believes that an applicant or licensee has not complied with paragraph (b)(5) of this Section when departing from Tier 2 information, may petition to admit into the proceeding such a contention. In addition to compliance with the general requirements of 10 CFR 2.714(b)(2), the petition must demonstrate that the departure does not comply with paragraph (b)(5) of

this Section. Any other party may file a response thereto. If, on the basis of the petition and any response, the presiding officer determines that a sufficient showing has been made, the presiding officer shall certify the matter directly to the Commission for determination of the admissibility of the contention. The Commission may admit such a contention if it determines the petition raises a genuine issue of fact regarding compliance with paragraph (b)(5) of this Section.

(6)(i) An applicant for a combined license may not depart from Tier 2* information, which is designated with italicized text or brackets and an asterisk in the generic DCD, without NRC approval. The departure will not be considered a resolved issue, within the meaning of Section 6 of this appendix and 10 CFR 52.63(a)(4).

(ii) A holder of a combined license may not depart from the following Tier 2* matters without prior NRC approval. A request for a departure will be treated as a request for a license amendment under 10 CFR §§ 50.90 and 50.92.

- (A) Equipment seismic qualification methods.
- (B) Piping design acceptance criteria.
- (C) Fuel burnup limit.
- (D) Fuel licensing acceptance criteria (4B of DCD).
- (E) Control rod licensing acceptance criteria (4C of DCD).
- (F) Human factors engineering design and implementation process.

(iii) A holder of a combined license may not, before the plant first achieves full power following the finding required by 10 CFR 52.103(g), depart from the following Tier 2* matters except in accordance with paragraph (b)(6)(ii) of this Section. After the plant first achieves full power, the following Tier 2* matters revert to Tier 2 status and are thereafter subject to the departure provisions in paragraph (b)(5) of this Section.

- (A) ASME Boiler & Pressure Vessel Code, Section III.
- (B) ANSI/AISC N-690 and ACI 349.
- (C) Motor-operated valves.
- (D) Fuel system and assembly design (4.2 of DCD), except burnup limit.
- (E) Fuel evaluation methods and results (4.2 of DCD).
- (F) Nuclear design (4.3 of DCD).
- (G) Equilibrium cycle and control rod patterns (4A of DCD).
- (H) Instrument setpoint methodology.
- (I) EMS performance specifications and architecture.
- (J) SSLC hardware and software qualification.
- (K) Self-test system design testing features and commitments.

(iv) Departures from Tier 2* information that are made under paragraph (b)(6) of this section do not require an exemption from this appendix.

(c) Additional applicable regulations.

The Commission may not modify or rescind existing requirements or impose new requirements on either this appendix or a plant referencing this appendix, whether on the Commission's own motion or in response to a petition from any person, on the basis that either the DCD or the referencing plant fails to comply with an additional applicable regulation in Section 5(c) of this appendix, unless the Commission determines that:

(1) the failure to comply results in a substantial reduction in the protection of public health and safety or common defense and security;

(2) the new requirements provide a compensating increase in protection not exceeding the level of protection originally embodied in the additional applicable regulation; and

(3) the direct and indirect costs of implementation are justified in view of this compensating increase in protection.

9. Inspections, tests, analyses, and acceptance criteria (ITAAC).

(a)(1) An applicant or licensee who references the design certification shall perform and demonstrate conformance with the ITAAC before fuel load. With respect to activities subject to an ITAAC, an applicant for a COL may proceed at its own risk with design and procurement activities, and a licensee may proceed at its own risk with design, procurement, construction, and preoperational activities, even though the NRC may not have found that any particular ITAAC has been satisfied.

(2) The licensee shall notify the NRC that the required inspections, tests, and analyses in the ITAAC have been successfully completed and that the corresponding acceptance criteria have been met.

(3) In the event that an activity is subject to an ITAAC, and the applicant or licensee has not demonstrated that the ITAAC has been satisfied, the applicant or licensee may either take corrective actions to successfully complete that ITAAC, request an exemption from the ITAAC in accordance with Section 8 of this appendix and 10 CFR 52.97(b), or petition for rulemaking to amend this appendix by changing the requirements of the ITAAC, under 10 CFR 2.802 and 52.97(b). Such rulemaking changes to the ITAAC must meet the requirements of Section 8(a)(1) of this appendix.

(b)(1) The NRC shall ensure that the required inspections, tests, and analyses in the ITAAC are performed. The NRC shall verify that the inspections, tests, and analyses referenced by the licensee have been successfully completed and, based solely thereon, find the prescribed acceptance criteria have been met. At appropriate intervals during construction, the NRC shall publish notices of the successful completion of ITAAC in the *Federal Register*.

(2) In accordance with 10 CFR 52.99 and 52.103(g), the Commission shall find that the acceptance criteria in the ITAAC for the combined license are met before fuel load.

(3) After the Commission has made the finding required by 10 CFR 52.103(g), the ITAAC do not constitute regulatory requirements either for subsequent plant modifications during operation, or for renewal of the combined license. However, subsequent modifications must comply with the Tier 1 and Tier 2 design descriptions in the plant-specific DCD unless the licensee has complied with the applicable requirements of 10 CFR 52.97 and Section 8 of this appendix.

10. Records and Reporting.

(a) Records.

(1) The applicant for this design certification rule shall maintain a copy of the generic DCD that includes all generic changes to Tier 1 and Tier 2. The applicant shall maintain the proprietary and safeguards information referenced in the generic DCD for the period that this appendix may be referenced, as specified in Section 7 of this appendix.

(2) An applicant or licensee who references this design certification shall maintain the plant-specific DCD to accurately reflect both generic changes to the generic DCD and plant-specific departures made pursuant to

Section 8 of this appendix throughout the period of application and for the term of the license (including any period of renewal).

(3) An applicant or licensee who references this design certification shall prepare and maintain written safety evaluations which provide the bases for the determinations required by Section 8(b) of this appendix. These evaluations must be retained throughout the period of application and for the term of the license (including any period of renewal).

(b) Reporting.

(1) An applicant or licensee who references this design certification rule shall submit a report to the NRC containing a brief description of any departures from the plant-specific DCD, including a summary of the safety evaluation of each. This report must be filed in accordance with the filing requirements applicable to reports in 10 CFR 50.4.

(2) An applicant or licensee shall submit updates to its plant-specific DCD, which reflect the generic changes to the generic DCD and the plant-specific departures made pursuant to Section 8 of this appendix. These updates shall be filed in accordance with the filing requirements applicable to final safety analysis report updates in 10 CFR 50.4 and 50.71(e).

(3) The reports and updates required by Section 10(b)(1) and (2) above must be submitted as follows:

(i) On the date that an application for a combined license referencing this design certification rule is submitted, the application shall include the report and any updates to the plant-specific DCD.

(ii) During the interval from the date of application to the date of issuance of a combined license, the report and any updates to the plant-specific DCD must be submitted annually and may be submitted along with amendments to the application.

(iii) During the interval from the date of issuance of a combined license to the date the Commission makes its findings under 10 CFR 52.103(g), the report must be submitted quarterly. Updates to the plant-specific DCD must be submitted annually.

(iv) After the Commission has made its finding under 10 CFR 52.103(g), reports and updates to the plant-specific DCD may be submitted annually or along with updates to the site-specific portion of the final safety analysis report for the facility at the intervals required by 10 CFR 50.71(e), or at shorter intervals as specified in the combined license.

Dated at Rockville, Maryland, this ___ day of ____, 1996.

For the Nuclear Regulatory Commission.

John C. Hoyle,
Secretary of the Commission

FINAL ENVIRONMENTAL ASSESSMENT
BY THE OFFICE OF NUCLEAR REACTOR REGULATION
U.S. NUCLEAR REGULATORY COMMISSION

RELATING TO THE CERTIFICATION OF THE
U.S. ADVANCED BOILING WATER REACTOR DESIGN

DOCKET NO. 52-001

TABLE OF CONTENTS

1.0	INTRODUCTION AND SUMMARY	1
2.0	THE NEED FOR THE PROPOSED ACTION	2
3.0	ALTERNATIVES TO THE PROPOSED ACTION	2
3.1	Severe Accident Design Alternatives	3
3.2	Estimate of Risk for U.S. ABWR	4
3.3	Identification of Potential Design Alternatives	5
3.4	Description of Design Alternatives	5
3.5	Risk Reduction Potential of Design Alternatives	9
3.6	Conclusions	13
4.0	THE ENVIRONMENTAL IMPACT OF THE PROPOSED ACTION	14
5.0	AGENCIES AND PERSONS CONSULTED, AND SOURCES USED	15
6.0	FINDING OF NO SIGNIFICANT IMPACT	15
Table 1	Summary of GE's Assessment of Risk Reduction for Candidate Design Improvements	17
Table 2	Potential Design Improvements and Associated Costs (GE)	18

1.0 INTRODUCTION AND SUMMARY

The U.S. Nuclear Regulatory Commission (NRC or the Commission) has issued a design certification for the U.S. advanced boiling water reactor (ABWR) design. Design certification is a rulemaking that amends Part 52 of Title 10 of the Code of Federal Regulations (10 CFR Part 52). To comply with the requirements of the National Environmental Policy Act of 1969 (NEPA), as amended, the NRC must consider the environmental impacts of issuing this amendment to 10 CFR Part 52. In addition, the NRC decided to consider severe accident mitigation design alternatives (SAMDAs) as part of this final environmental assessment (EA) to resolve SAMDAs for NEPA on a generic basis for the U.S. ABWR design. The EA for this rulemaking is contained herein and is prepared in accordance with NEPA and 10 CFR Part 51. This EA only addresses the environmental impacts of issuing a design certification for the U.S. ABWR and SAMDAs for the U.S. ABWR design. The environmental impacts of construction and operation of a facility at a particular site will be evaluated as part of the application(s) for siting, construction, and operation of that facility.

In an application dated September 29, 1987, the GE Nuclear Energy (GE) company applied for certification of the U.S. ABWR standard design by the NRC. The application was made in accordance with the procedures of 10 CFR Part 50, Appendix O, and the Policy Statement on Nuclear Power Plant Standardization, dated September 15, 1987. The application was docketed by the NRC staff on February 22, 1988 (Docket No. STN 50-605). On December 20, 1991, GE requested that its application be considered as an application for design approval and subsequent design certification pursuant to 10 CFR 52.45. Accordingly, the NRC staff assigned a new docket number (52-001) to the application on March 13, 1992.

The NRC has determined that the issuance of this design certification is not a major Federal action significantly affecting the quality of the human environment, and therefore, has decided not to prepare an environmental impact statement (EIS) in connection with this action. The finding of no significant impact is based on the fact that the certification rule itself would not authorize the siting, construction or operation of the U.S. ABWR design; it would only codify the U.S. ABWR design in a rule that could be referenced in a construction permit (CP), early site permit (ESP), combined license (COL), or operating license (OL) application. Further, because the action is a rule, there are no resources involved which would have alternative uses.

The NRC also reviewed, pursuant to NEPA, GE's evaluation of design alternatives to prevent and mitigate severe accidents. Based on the review, the NRC finds that the evaluation provides a sufficient basis to conclude that there is reasonable assurance that an amendment to 10 CFR Part 52 certifying the U.S. ABWR design will not exclude SAMDAs for a future facility that would have been cost beneficial had they been considered as part of the original design certification application. These issues are considered resolved for the U.S. ABWR design certification.

2.0 THE NEED FOR THE PROPOSED ACTION

The NRC has long sought the safety benefits of commercial nuclear power plant standardization, as well as the early resolution of design issues and finality of design issue resolution. The NRC plans to achieve these goals by certification of standard plant designs. Subpart B to 10 CFR Part 52 allows for certification by rule of an essentially complete nuclear plant design.

The proposed action would amend 10 CFR Part 52 to certify the U.S. ABWR design. The amendment would allow prospective applicants for a combined license (COL) under Part 52 or for a CP under Part 50 to reference the certified U.S. ABWR design. Those portions of the U.S. ABWR design included in the scope of the design certification would not be subject to further regulatory review or approval. In addition, the amendment would resolve the issue of consideration of SAMDAs for any future facilities that reference the U.S. ABWR design.

3.0 ALTERNATIVES TO THE PROPOSED ACTION

The alternatives to certifying the U.S. ABWR design in an amendment to 10 CFR Part 52 are either (1) no action approving the design or (2) issuing a final design approval (FDA), but not certifying the design. These alternatives in and of themselves would not have a significant impact affecting the quality of the human environment because they do not authorize the siting, construction, or operation of a facility.

In the first case, the design would not be approved. Therefore, a facility to be built as a U.S. ABWR would be required to be licensed under 10 CFR Part 50 or 10 CFR Part 52, Subpart C, as a custom plant application. All design issues would have to be considered as part of each application to construct and operate a U.S. ABWR facility at a particular site. This alternative would not achieve the benefits of standardization, provide early resolution of design issues, or provide finality of design issue resolution.

In the second case, the U.S. ABWR would be issued an FDA under 10 CFR Part 52, Appendix O, but the design would not be certified in a rulemaking. Therefore, although the NRC would have approved the design, the design could be modified and thus require re-evaluation as part of each application to construct and operate a U.S. ABWR facility at a particular site. This alternative would provide early resolution of issues, but would not achieve the benefits of standardization or provide finality of design issue resolution.

The NRC sees no advantage in either of the alternatives compared to the design certification rulemaking proposed for the U.S. ABWR. Although neither the alternatives nor the proposed design certification rulemaking would have a significant impact affecting the quality of the human environment in and of themselves, the rulemaking provides for standardization, as well as early resolution of design issues and finality of design issue resolution for design issues that are within the scope of the design certification, including SAMDAs. Therefore, the NRC concludes that the alternatives to rulemaking would not achieve the objectives the Commission intended by certification of the U.S. ABWR design pursuant to 10 CFR Part 52, Subpart B.

3.1 Severe Accident Design Alternatives

The Commission decided to evaluate design alternatives for severe accidents as part of the design certification for the U.S. ABWR design, consistent with its objectives of achieving early resolution of issues for the design and standardization. The Commission, in a 1985 policy statement, defined the term "severe accident" as those events which are "beyond the substantial coverage of design basis events" and includes those for which there is substantial damage to the reactor core whether or not there are serious offsite consequences. Design basis events are considered to be those analyzed in accordance with the NRC's Standard Review Plan (NUREG-0800) and documented in Chapter 15 of the ABWR Design Control Document (DCD).

As part of its design certification application, GE performed a probabilistic risk assessment (PRA) for the ABWR design to (1) identify the dominant severe accident sequences and associated source terms for the design; (2) modify the design, based on PRA insights, to prevent or mitigate severe accidents and reduce the risk of severe accidents; and (3) provide a basis for concluding that all reasonable steps have been taken to reduce the chances of occurrence, and to mitigate the consequences, of severe accidents. GE's analysis is documented in Chapter 19 of the ABWR standard safety analysis report (SSAR).

In addition to considering alternatives to the rulemaking process as discussed in Section 3, applicants for reactor design approvals or CPs must also consider alternative design features for severe accidents based on (1) the requirements of 10 CFR Part 50 and (2) a court ruling relating to NEPA. These requirements can be summarized as follows:

- 10 CFR 50.34(f)(1)(i) requires the applicant to perform a plant/site specific probabilistic risk assessment, the aim of which is to seek such improvements in the reliability of core and containment heat removal systems as are significant and practical and do not impact excessively on the plant.
- The U.S. Court of Appeals decision, in Limerick Ecology Action v. NRC, 869 F.2d 719 (3rd Cir. 1989), effectively requires the NRC to include consideration of certain severe-accident-mitigation design alternatives (SAMDA) in the environmental impact review performed under Section 102(2)(c) of NEPA as part of the OL application.

Although these two requirements are not directly related, the purpose is the same: to consider alternatives to the proposed design, to evaluate potential alternatives for improvements in the plant design for increased safety performance during severe accidents, and to prevent viable alternatives from being foreclosed. It should be noted that the Commission is not required to consider alternatives to the design in this EA on the rulemaking; however, as a matter of discretion, the Commission has determined that consideration of SAMDA is consistent with the intent of 10 CFR Part 52 for early resolution of issues, finality of design issue resolution, and enhancing the benefits of standardization.

In its decision in *Limerick*, the Court of Appeals for the Third Circuit expressed its opinion that it was likely that evaluation of SAMDAs for NEPA purposes would be difficult to perform on a generic basis. However, the NRC has determined that generic evaluation of SAMDAs for the U.S. ABWR standard design is warranted because (1) the design and construction of all plants referencing the certified U.S. ABWR design will be governed by the rule certifying a single design, and (2) the site parameters specified in the rule and in the "Technical Support Document" (TSD) dated December 1994, establish the consequences for a reasonable set of SAMDAs for the ABWR. The low residual risk of the ABWR and limited potential for further risk reductions provides high confidence that additional cost beneficial SAMDAs would not be found. Should the actual site parameters for a particular site exceed those assumed in the rule and the TSD, SAMDAs would have to be re-evaluated in the site-specific environmental report and EIS.

GE initially submitted its response to 10 CFR 50.34(f) in SSAR Section 19P as part its application for a final design approval (FDA) and subsequent design certification for the ABWR. The NRC issued an FDA for the ABWR in July 1994, and provided its evaluation of SSAR Section 19P in FSER Section 20.5.1. Subsequently, as part of its preparation of the DCD for the design certification rulemaking, GE updated and relocated Section 19P of the SSAR to Attachment A of the TSD for the ABWR" (see letter from J. Quirk (GE) to R.W. Borchardt (NRC), December 21, 1994). GE submitted the TSD to meet the Commission's requirement to consider SAMDAs as part of the design certification application.

3.2 Estimate of Risk for U.S. ABWR

In response to 10 CFR 50.34(f)(1)(i), GE provided an evaluation of the U.S. ABWR design improvements in SSAR Section 19P. GE's evaluation of risk was based on the risk-reduction potential for internal events only. The limited scope was a consequence of GE's use of alternative analyses for external events. The staff's evaluation of this approach to external events is in FSER Section 19.1.3. The staff's evaluation of design alternatives considering risk from external events is discussed in Section 3.5.5 of this EA.

Risk was defined in terms of person-Sieverts (Sv), and was calculated by multiplying the probability of an event per year by its consequences (the whole body exposure to the population within 50 miles of the release) over 60 years. GE used the CRAC2 code to estimate offsite consequences at five different sites, each representing a different geographic region of the U.S. Offsite consequences were calculated for each release class from the U.S. ABWR Level 2 probabilistic risk assessment (PRA) which contained accident progression analysis and source term analysis following the Level 1 PRA accident sequence analysis. The meteorological and population data were obtained from previously developed information contained in Sandia National Laboratories' "Technical Guidance for Siting Criteria Development" (NUREG/CR-2239, December 1986). The source terms were determined using the MAAP code for each of the release categories as discussed in Chapter 19 of the final safety evaluation report (FSER). The results of the five sets of consequence calculations were averaged together to represent a typical site in the U.S.

GE's estimate of the cumulative offsite risk to the population within 50 miles of the site appears in Table 1 of GE's TSD. GE calculated the total cumulative exposure from all analyzed accidents to be about 0.003 person-Sieverts (Sv) (0.3 person-rem) over a 60-year plant life. The extremely small level of risk calculated by GE is primarily due to the low estimated core-damage frequency for the U.S. ABWR (1.6×10^{-7} per reactor-year). This means that even if all core-damage accidents led to the worst release, on the basis of GE's core-damage frequency estimates for internal events, the total exposure would be only about 0.3 person-Sv (30 person-rem). The risk calculated in the analysis supported GE's conclusion that none of the design improvements beyond those already incorporated in the U.S. ABWR design are cost beneficial.

As a result of the low estimated core-damage frequency and associated risk levels for the U.S. ABWR, any modifications costing more than a few dollars would not be cost effective, even if the design modification totally eliminated the severe accidents or their consequences.

3.3 Identification of Potential Design Alternatives

GE's evaluation of potential design improvements in response to the requirements of 10 CFR 50.34(f)(1)(i) also gives a technical basis for the staff to evaluate the SAMDAs, as required by the Limerick decision. The staff's review of GE's evaluation is presented below.

By surveying previous industry- and NRC-sponsored studies of features to prevent and mitigate severe accidents, GE prepared a set of potential severe-accident design alternatives for the U.S. ABWR and developed a composite list of 68 potential design alternatives, organized into 14 categories. The list of potential design alternatives considered for the U.S. ABWR is presented in Table 2 of the TSD.

GE eliminated certain design alternatives from further consideration because they were not applicable to the U.S. ABWR (e.g., post accident inerting system, hydrogen control by venting), were considered as part of another alternative (e.g., diverse injection system, fuel cells), or were already incorporated in the design. Examples of design alternatives already included in the design were improved low-pressure injection system (fire pump), reactor water clean-up decay heat removal, low-flow vent (unfiltered), and combustible gas control (pre-inerted containment). These and additional U.S. ABWR design features that contribute to low core-damage frequency and risk for the U.S. ABWR design are discussed further in FSER Section 19.1. After this screening, 21 potential design alternatives applicable to the design, covering 12 of the 14 categories, remained for further consideration.

3.4 Description of Design Alternatives

The design alternatives selected by GE for cost-benefit evaluation are described in Sections A.3 and A.4 of the TSD. The design alternatives are summarized below.

- (1) Emergency procedures guidelines (EPGs) and accident management guidelines (AMGs) for severe accidents — Expand the EPGs and emergency

operating procedures (EOPs) to address arrest of a core melt, emergency planning, radiological release assessment, and other areas related to severe accidents. This modification would make manual actions in response to core-damage events more reliable.

- (2) Computer-aided instrumentation — Apply expert system-based improvements to plant status monitoring, including human-engineered displays of important variables in the EPGs and AMGs, and displays of procedural options for operators to evaluate during severe accidents. This modification would make manual actions to prevent core damage more reliable.
- (3) Improved maintenance procedures and manuals — Improve maintenance manuals and give more information about U.S. ABWR components important to reducing risk. These manuals and this information would make equipment important for preventing and mitigating accidents more reliable.
- (4) Passive high-pressure system — Add an isolation condenser-type high-pressure system for removing decay heat from both the core and the containment. The modification would be equivalent to adding another reactor core isolation cooling (RCIC) system and containment heat removal system.
- (5) Improved depressurization — Supply manually controlled, seismically protected air operators to permit manual reactor pressure vessel depressurization in the event of loss of dc control power or control air events. Improved depressurization would reduce the threat of containment failure due to high-pressure melt ejection and allow more reliable access to low-pressure systems.
- (6) Suppression pool jockey pump — Add a small, ac-independent makeup pump to allow low-pressure decay heat removal from the reactor pressure vessel (RPV) using suppression pool water as the source. This modification would have the same benefits as the ac-independent "fire-water" addition mode of residual heat removal (RHR), but without the associated long-term containment water inventory buildup concerns.
- (7) Safety-related condensate storage tank (CST) — Upgrade the structure of the CST so that it could supply makeup water to the reactor after a large seismic event. This modification would enhance core injection capabilities in seismic events by giving an alternative to the suppression pool as a source of water for injection.
- (8) Larger-volume containment — Increase the volume of containment by a factor of two. This modification would reduce the peak pressures associated with an energetic event, making drywell head failure less likely, and would reduce the rate of long-term containment pressurization, thereby delaying fission product release.

- (9) Increased containment pressure capacity — Increase the ultimate pressure capacity of containment (including seals) to a level at which all release modes except normal containment leakage are eliminated.
- (10) Improved vacuum breakers — Add a second vacuum breaker valve in each of the eight drywell-to-wetwell vacuum breaker lines to make these valves redundant. This modification would reduce the potential for suppression pool bypass due to stuck-open or leaking vacuum breaker valves.
- (11) Improved bottom head penetration design — Change the transition piece (used to connect the stainless steel RPV drainline to the RPV) from carbon steel to a material with a higher melting point, such as Inconel. Also establish external welds or restraints on the control rod drives external to the vessel so that the drives would not be ejected in the event the internal welds fail. This modification would delay reactor vessel failure by several hours, thereby increasing the potential to arrest core damage in vessel, but might also make the lower head more likely to fail grossly on overpressure.
- (12) Larger-volume suppression pool — Increase the size of the suppression pool to reduce pool heatup rates. This modification would reduce the frequency of core melt from Class II sequences (loss of containment heat removal) and anticipated transients without scram (ATWS) sequences by giving operators more time to act and heat removal systems more time to recover.
- (13) Low-flow filtered vent — Add a filter system external to the containment to further reduce the magnitude of radioactive releases via containment venting. The system would be similar to the multiple-venturi scrubbing systems in some plants in Europe. The system filters would scrub fission products better than the suppression pool at present, but would not affect releases due to drywell head failure and containment bypass sequences.
- (14) Drywell head flooding — Provide an additional line to permit intentional flooding of the upper drywell head using the existing firewater addition system. Drywell head flooding would cool the drywell head seal, preventing its failure, and scrub fission products in the event of drywell head leakage. Instrumentation and controls to permit manual control from the control room to accomplish drywell head flooding were included in the evaluation as part of this modification.
- (15) Additional service water pump — Add another service water cooling loop (pump and heat exchanger) to make the service water network more reliable. This loop could remove heat from any one of the three ECCS systems, making failure of injection due to loss of component cooling less frequent.
- (16) Steam-driven turbine generator — Add a steam-driven turbine generator that uses reactor steam and exhausts to the suppression pool. This modification would reduce the frequency of station blackout sequences in the same way that adding another gas turbine generator would.

- (17) Alternate pump power source — Add a separate diesel generator and supporting auxiliaries to power the feedwater or condensate pumps. This modification would remove the reliance of these pumps on offsite power and permit them to be used as a backup to the high-pressure core flooder (HPCF) and the low-pressure core flooder (LPCF).
- (18) Dedicated dc power supply — Add a separate, diverse dc power source (fuel cell or separate battery) to supply a dc motor-pump combination for RPV and containment cooling. This modification would further reduce the risk from loss of offsite power and station blackout.
- (19) ATWS-sized vent — Provide a wetwell vent line capable of passing the steam flow from an ATWS. The system would be significantly larger than the existing containment overpressure protection system (COPS) design and could be manually initiated from the control room. This system would prevent a containment overpressure failure in ATWS events thus preventing failure of other containment systems and thereby preventing core damage.
- (20) Reactor building sprays — Modify the fire-water spray system in the reactor building to spray in areas vulnerable to fission product release. This modification would reduce the risk associated with releases into the reactor building, such as drywell head failures and containment bypass events, but would not affect releases via COPS.
- (21) Flooded rubble bed — Provide a bed of refractory pebbles that would be flooded with water. The rubble bed would impede the flow of molten corium to the concrete drywell structures and increase the available heat transfer area, thereby enhancing debris coolability. This modification would further reduce the potential for core-concrete interactions in the U.S. ABWR. A major drawback of the modification is that additional experimental testing would be necessary to validate the concept for the U.S. ABWR application.

The NRC staff has reviewed the set of potential design alternatives identified by GE in the TSD and finds the set to constitute a reasonable range of design alternatives. The list includes all alternatives identified in the NRC containment performance improvement (CPI) program and in the NRC review of SAMDAs for the Limerick Generating Station, that would be applicable to the U.S. ABWR. Although the list does not include one of the SAMDAs considered as part of the NRC's review of SAMDAs for Comanche Peak, namely, improved instrumentation for containment bypass sequences, this improvement would not significantly reduce risk potential for the U.S. ABWR since the level of residual risk is already low compared to operating plants and in absolute terms. The NRC notes that the set of design alternatives is not all inclusive, since additional, possibly even less expensive, design alternatives can always be postulated. However, the NRC concludes that the benefits of any additional modifications are unlikely to exceed the benefits of the modifications evaluated and that the alternative improvements would not likely cost less than the least expensive alternatives evaluated, when the subsidiary costs associated with maintenance, procedures, and training are considered.

On this basis, the NRC concludes that the set of potential design alternatives identified by GE is acceptable.

3.5. Risk Reduction Potential of Design Alternatives

3.5.1 GE Evaluation of Risk Reduction Potential

GE used the estimated reduction in cumulative risk of accidents occurring during the life of the plant resulting from the above design changes to estimate the benefits of plant improvements. Estimates of risk reduction were developed by determining the approximate effect of each modification on the frequency of the various release classes in the probabilistic risk assessment (PRA). GE's basis for estimating the risk reduction for each design improvement is given in TSD Section A.4 and summarized in Table 1 of this EA.

The NRC staff has reviewed GE's bases for estimating how much the various design alternatives would reduce risks. The NRC staff notes that GE exercised considerable judgment in estimating the risk reduction potential but that, in general, the rationale and assumptions on which the risk reduction estimates are based (center column of Table 1) are reasonable and in many cases conservative (as described below, the NRC staff did not analyze individual SAMDA potential risk reduction, but made bounding assumptions). However, this is not to say that the estimates of person-Sv averted are conservative, because the staff does not completely agree with GE's characterization of baseline risk. For example, the risk reduction potential of improved vacuum breakers appears to be underestimated in GE's analysis. GE estimates that improved vacuum breakers (addition of a second vacuum breaker valve in series with each of the existing valves) would reduce risk by about 4×10^{-7} person-Sv (4×10^{-5} person-rem). This value is largely due to significant credit for fission-product removal by wetwell sprays (when available) and to the failure to consider the impact of the design improvement on bypass scenarios in which sprays are unavailable. GE's risk reduction estimate for this improvement would increase by at least three orders of magnitude if the latter factor were taken into account. Nevertheless, the risk reduction would remain small since the probability of the events involved is on the order of 1×10^{-10} per reactor-year.

3.5.2 Staff Evaluation of Risk Reduction Potential

In view of the extremely small residual risk for the U.S. ABWR, rather than separately assess risk-reduction potential of each U.S. ABWR design improvement, the NRC staff used a bounding assumption that each improvement would eliminate all of the risk for internal events for the U.S. ABWR (0.01 person-Sv (1 person-rem) for the 60-year plant life). This approach tends to overestimate the benefits of each individual SAMDA because the U.S. ABWR risk profile reflects contributions from several unique types of sequences (e.g., station blackout, containment bypass, loss-of-coolant accidents). An individual design improvement would generally reduce or eliminate some of these contributors but would not be effective on others. Moreover, many different modes of containment failure must be dealt with to ensure containment integrity in a severe accident. Thus, a carefully selected set of plant improvements

would be needed, each one acting on particular components of risk, to effectively and significantly reduce total risk.

3.5.3 Costs of SAMDAs

GE determined the approximate costs for each design improvement. The costing methodology and assumptions are described in TSD Section A.1.3.1. The cost of each plant improvement is given in Table 4 of the TSD and in TSD Section A.5 on an item-by-item basis.

GE indicated that the cost estimates represent the incremental costs that would be incurred in a new plant, rather than costs incurred in backfit. GE also stated that it intentionally biased costs on the low side, but that it took all known or reasonably expected costs into account to arrive at a reasonable minimum cost.

For modifications that reduce core-damage frequency, GE reduced the costs of the design alternatives by an amount proportional to the reduction in the present worth of the risk of averted onsite costs. The onsite costs that were considered include replacement power at \$0.013/kwh differential cost, direct accident costs including onsite cleanup at \$2 billion, and the economic loss of the facility at \$1.4 billion. The resulting costs for each of the design alternatives are given in Table 4 of the TSD.

The NRC staff reviewed the bases for GE's cost estimates and finds them acceptable. For certain alternatives, the NRC staff also compared GE's cost estimates with estimates developed elsewhere for similar alternatives, even though the bases for some of these cost estimates were different. The NRC staff considered the cost estimates developed as part of the evaluation of design alternatives for GESSAR II (NUREG-0979, Supplement 4) and the review of SAMDAs for Limerick and Comanche Peak (NUREG-0974 and -0775, respectively).

The NRC staff noted a number of inconsistencies in the cost estimates. For example, GE's cost estimates for improved vacuum breakers (\$100,000), modified reactor building sprays (\$100,000), and ATWS-sized vent (\$300,000) were considerably less than expected, whereas the costs for SAMDAs such as improved bottom head penetration design (\$750K) and flooded rubble bed (approximately \$19 million) were much higher than expected. As explained in the sensitivity analysis in Section 3.5.5, none of the SAMDAs are within two orders of magnitude of being cost beneficial. Thus, even if those cost estimates that appear high were reduced by a factor of ten, the SAMDAs would still not be cost beneficial. Accordingly, the NRC staff has used GE's cost estimates in the cost/benefit comparison analysis below.

Only rough approximations of the costs of specific alternatives are possible at this time. Large uncertainties exist because detailed designs are not available and because experience with construction and licensing problems that could surface in this type of work is limited. However, even though the U.S. ABWR design is still in the design phase, relatively large costs are anticipated for many of the design alternatives, which would involve first-of-a-kind engineering and would need to be integrated into the existing design. In

addition, the introduction of a new system initiates a series of related requirements such as incremental training, procedural changes, and possible licensing requirements. These are all legitimate costs and must be considered in a comprehensive cost estimate.

Therefore, the NRC staff considers GE's approximate cost estimates as adequate, given the uncertainties surrounding the underlying cost estimates, and the level of precision necessary given the greater uncertainty inherent on the benefit side, with which these costs were compared.

3.5.4 Cost/Benefit Comparison

GE compared costs and benefits to determine whether any of the potential severe accident design features were justifiable. GE's estimates of the cost per person-Sv (person-rem) averted for the various design alternatives are presented in Table 2 of this EA. The GE values are based on the risk-reduction estimates reported in Table 1 of this EA, whereas the NRC staff values are based on the conservative assumption that each design improvement would eliminate all of the residual risk (0.01 person-Sv (1 person-rem) over the 60-year plant life).

In accordance with former NRC practice (NUREG-3568), GE used a screening criterion of \$100,000 per person-Sv (\$1000 per person-rem) averted to determine whether any of the design alternatives could be cost effective. According to GE's evaluation as shown in Table 2, the potential cost per averted person-Sv ranges from about \$170 million to \$2 billion for the various suggested modifications, far exceeding the former \$100,000 per person-Sv (\$1000 per person-rem) criterion. On this basis, GE concluded that no additional modifications to the U.S. ABWR design are warranted.

The NRC staff agrees that none of the design alternatives are cost effective. The NRC staff notes that using the least expensive modifications (estimated to cost about \$100,000), and conservatively assuming that all risk is averted (0.01 person-Sv (1 person-rem)), the resulting cost/benefit would be \$10 million per person-Sv (i.e., $\$100,000/0.01 \text{ person-Sv} = \$10 \text{ million/person-Sv}$) (\$100,000/person-rem), which is well in excess of the \$100,000 per person-Sv (\$1000 per person-rem) criterion. Realistically, individual design alternatives only partly reduce the residual risk for the U.S. ABWR, resulting in a much higher cost/benefit ratio for even the most cost beneficial case.

Therefore, the NRC concludes that, because of the low residual risk for the U.S. ABWR and the \$100,000 per person-Sv (\$1000 per person-rem) criterion, none of the modifications evaluated would be cost effective.

3.5.5 Further Considerations

The NRC staff has reviewed the assumptions on which this conclusion is based and has considered the effect of uncertainties in estimating core-damage frequency, the use of alternative cost-benefit criteria, and the inclusion of external events within the scope of the analysis.

GE's uncertainty analyses for the Level 1 portion of the PRA (see FSER Section 19.1.3.2.5) showed the 95th-percentile core-damage frequency (CDF) to be 4.5×10^{-7} per reactor-year. This is higher by a factor of three than the mean value on which the cost-benefit analysis is based, but is still very low compared to operating plants (CDF range of 10^{-4} - 10^{-5} per reactor-year) and in absolute terms. Even if the benefits of the various design alternatives were requantified on the basis of this upper bound value, none of the alternatives would become cost beneficial. This would remain the case even if the cost-benefit criterion was also increased by a factor of 10 to \$1 million per person-Sv (\$10,000 per person-rem) averted, since the most cost beneficial design alternative is still at least an order of magnitude greater than this criterion (e.g., cost/benefit = $\$0.1\text{M}/0.00060$ person-Sv = \$170 million per person-Sv averted).

If external events are included, the estimate of U.S. ABWR risk could be one or possibly two orders of magnitude higher than considered in this analysis. For example, considering the NRC staff review of GE's original seismic PRA, as documented in the draft SER, the total risk from internal and seismic events for the 60-year plant life would range from about 0.4 to 2 person-Sv (40 to 200 person-rem), depending on the site population. The values for the final U.S. ABWR design are actually somewhat less, since these estimates do not consider plant improvements incorporated in the design after the original PRA analysis, including upgrading the seismic capability of the diesel-driven firewater pump. However, even without taking credit for these features, the cost/benefit analysis would not justify incorporation of additional SAMDAs. Because most external event analyses submitted to the NRC show that seismic events dominate risk for external events, the NRC staff assessed the design alternatives using seismic risk as a bounding analysis for other external events, including fires and internal floods.

Even assuming the highest estimate of total risk (2 person-Sv (200 person-rem)) and complete elimination of all risk, any design modifications or combinations costing more than \$200,000 would not be cost beneficial (2 person-Sv averted risk \times \$100,000/person-Sv = \$200,000). (This assumption of complete elimination of all risk is very conservative as evidenced by GE's analysis, which shows that modifications estimated to cost less than \$200,000 have a relatively low risk-reduction potential and would eliminate less than 10-percent of the residual risk.)

For the four design modifications costing less than \$200,000, drywell head flooding appears to be the most cost beneficial at \$170 million/person-Sv averted. Conservatively assuming a total residual risk of 2 person-Sv (200 person-rem) for the ABWR, drywell head flooding would have to eliminate 50-percent (1 person-Sv (100 person-rem)) or more of this risk to be considered cost beneficial. However, based on the analysis of internal events, drywell head flooding accounts for only a small reduction (a few percent) in risk. The risk reduction for external events is also expected to be small, since this modification affects only one of the numerous contributors to risk. This design improvement, therefore, would not be cost beneficial. Based on an inspection of Table 2 of this report, the other three design modifications also would not yield significant risk reductions and therefore would not be cost beneficial.

Since the draft EA was issued in April 1995, the NRC has issued "Regulatory Analysis Guidelines of the U.S. Nuclear Regulatory Commission" (NUREG/BR-0058, Revision 2, November 1995). This policy document adopts a \$2000 per person-rem conversion factor, subject to present worth considerations and is limited in scope to health effects. Limiting the conversion factor solely to health effects requires that the regulatory analysis include an additional dollar allowance for averted offsite property damage. By adopting the new \$2000 per person-rem conversion factor and a \$3000 per person-rem supplemental allowance for offsite property (see NUREG/CR-6349, "Cost benefit Considerations in Regulatory Analysis"), and assuming a base case 7% real discount rate as prescribed in NUREG/BR-0058, Revision 2, the present value of the health and safety benefits attributable to the Drywell Head Flooder approximate \$233,000. This is a factor of about 1.2 times higher than the earlier \$200,000 estimate. A comparable estimate for the health and safety benefits of this SAMDA based on a 3% real discount rate, which is recommended for sensitivity analysis purposes, is \$460,000 or 2.3 times greater than the earlier \$200,000 estimate. Given that the Drywell Head Flooder is estimated to cost on the order of \$100,000, under either the 3% or 7% discount rate scenario, this design alternative would have to eliminate at least 22% or 43% respectively, of the total lifetime risk. Since the drywell head flooder is estimated to only account for less than 10% of the total risk, even for this most cost beneficial SAMDA, the total costs continue to be well in excess of the total benefits.

In summary, the NRC concludes that with the significant margins in the results of the cost-benefit analysis, consideration the new values provided in NUREG/BR-0058 would not change the findings of the analysis.

3.6 Conclusions

As discussed in FSER Chapter 19, GE has extensively used the results of a PRA to arrive at a final U.S. ABWR design. Based on the insights obtained from the PRA for the U.S. ABWR standard design, design features have been incorporated into the design to reduce risk, including risk from severe accidents. Consequently, the estimated core-damage frequency and risk calculated for the U.S. ABWR are very low both relative to operating plants and in absolute terms. The low core-damage frequency and risk for the U.S. ABWR reflects GE's efforts to systematically minimize the effect of initiators and sequences that have contributed to risk in previous BWR PRAs. GE has done so largely by incorporating a number of hardware improvements in the U.S. ABWR design. These include the provision of three separated divisions of the emergency core cooling system (ECCS), a diverse and independent combustion gas turbine capable of providing ac power to any of the three divisions, an ac-independent water addition system, and a fine-motion control rod drive system as a backup to the hydraulic drive system. Several additional design features have also been incorporated in the U.S. ABWR design to mitigate the consequences of a core-damage event, including inerting of the containment atmosphere, a lower drywell flooder system and a containment overpressure protection (vent) system, the use of basaltic concrete in the lower drywell, and an increased containment ultimate pressure capacity.

Because the U.S. ABWR design already includes numerous plant features to reduce core-damage frequency and risk, additional plant improvements would be unable to significantly reduce the risk of either internally or externally initiated events. For example, the U.S. ABWR seismic design basis (0.3 g safe-shutdown earthquake) has been shown to result in an ability to withstand earthquakes well beyond the design basis, as characterized by a high confidence with low probability of failure (HCLPF) value of at least 0.6 g. Moreover, with the features already incorporated in the U.S. ABWR design, the ability to estimate core-damage frequency and risk approaches the limitations of probabilistic techniques. Specifically, when core-damage frequencies of 1 in 100,000 or 1 million years are estimated in a PRA, the areas of the PRA where modeling is least complete or supporting data is sparse or even nonexistent could actually contribute most to risk. Areas not modeled or incompletely modeled include human reliability, sabotage, rare initiating events, construction or design errors, and systems interactions. Although improvements in the modeling of these areas may introduce additional contributors to core-damage frequency and risk estimates, the NRC staff does not expect that they would be significant in absolute terms.

In 10 CFR 50.34(f)(1)(i), the Commission requires the applicant to perform a plant- or site-specific probabilistic risk assessment, the aim of which is to seek such improvements in the reliability of core and containment heat removal systems as are significant and practical and do not impact excessively on the plant. The NRC evaluated GE's response to this item in Section 20.5.1 of the FSER. In view of the foregoing, the NRC concludes that the PRA and GE's use of the insights of this study to improve the design of the U.S. ABWR meet this requirement for purpose of design certification pursuant to 10 CFR Part 52. The NRC concurs with GE's conclusion that none of the potential design modifications evaluated are justified on cost-benefit considerations. The NRC further concludes that any other design changes are unlikely to be justifiable on the basis of person-Sv exposure considerations because the estimated core-damage frequencies would remain very low on an absolute scale.

4.0 THE ENVIRONMENTAL IMPACT OF THE PROPOSED ACTION

The issuance of an amendment to 10 CFR Part 52 certifying the U.S. ABWR design would not constitute a significant environmental impact. The amendment would only codify the results of the NRC's review and approval of the U.S. ABWR design as defined in the FSER, dated July 1994 (NUREG-1503). Further, because the action is a rule, there are no resources involved that would have alternative uses.

In Section 3 of this EA the NRC reviewed alternatives to the design certification rulemaking and alternative design features related to the prevention and mitigation of severe accidents. Consideration of alternatives under NEPA were necessary for two reasons: (1) to show that the design certification rule is the appropriate course of action, and (2) to ensure that there are no cost-beneficial design changes relating to the prevention and mitigation of severe accidents that were excluded from the design, as codified in the design certification rule. The NRC concludes that the alternatives to design certification did not provide for resolution of issues as did the proposed design certification rulemaking.

This design certification rulemaking is in keeping with the Commission's intent in the Standardization and Severe Accident Policy Statements, and 10 CFR Part 52, to make future plants safer than the current generation plants, to achieve early resolution of licensing issues, and to enhance the safety benefits of standardization. Through its own independent analysis, the NRC also concludes that GE adequately considered an appropriate set of SAMDAs and none were found to be cost-beneficial. Although no design changes resulted from the SAMDAs review, GE did make changes to the U.S. ABWR design based on the results of the PRA. These changes were related to severe accident prevention and mitigation, but were not considered in the SAMDA evaluation because they were already part of the design. See FSER Section 19.1.3.2.2, "PRA as a Design Tool."

The certification rule by itself would not authorize the siting, construction, or operation of an U.S. ABWR design nuclear power plant. The issuance of a CP, ESP, COL, or OL for the U.S. ABWR design will require a prospective applicant to address the environmental impacts of construction and operation at a specific site. At that time, the NRC will evaluate the environmental impacts and issue an EIS in accordance with NEPA. The SAMDAs analysis for the U.S. ABWR, however, has been completed as part of this EA and will not need to be to be evaluated again as part of an EIS related to siting, construction, or operation.

5.0 AGENCIES AND PERSONS CONSULTED, AND SOURCES USED

The NRC concludes that design certification rulemaking does not result in a significant environmental impact because the action does not authorize the construction and operation of a facility at a particular site. Therefore, the NRC staff did not issue this EA for comment by Federal, State, and local agencies. However, the NRC's finding of no significant environmental impact, was published in the Federal Register on April 7, 1995, with the proposed ABWR design certification rule and there were no comments received related to this EA.

The sources for this EA include the "Technical Support Document for the ABWR," Revision 1, December 1994 (Attachment to a letter, J.F. Quirk (GE) to R.W. Borchardt (NRC), December 21, 1994); GE's U.S. "ABWR Standard Safety Analysis Report," as amended, July 1994; and the NRC's "Final Safety Evaluation Report Related to the Certification of the Advanced Boiling Water Reactor Design" (NUREG-1503, Volumes 1 and 2), July 1994.

6.0 FINDING OF NO SIGNIFICANT IMPACT

The Director, Office of Nuclear Reactor Regulation (NRR), has determined under the National Environmental Policy Act of 1969, as amended, and the NRC's regulations in 10 CFR Part 51, Subpart A, that this rule is not a major Federal action significantly affecting the quality of the human environment, and therefore, an EIS not required.

The basis for the determination, as documented in this final EA, is that the amendment to 10 CFR Part 52 would not authorize the siting, construction, or operation of a facility using the U.S. ABWR design; it would only codify the

U.S. ABWR design in a rule. The NRC will evaluate the environmental impacts and issue an EIS as appropriate in accordance with NEPA as part of the application(s) for the siting, construction, or operation of a facility.

In addition, as part of this final EA, the NRC reviewed, pursuant to NEPA, GE's evaluation of various design alternatives to prevent and mitigate severe accidents that was submitted in GE's "Technical Support Document for the ABWR." The Director of NRR finds that GE's evaluation provides a sufficient basis to conclude that there is reasonable assurance that an amendment to 10 CFR Part 52 certifying the U.S. ABWR design will not exclude a severe accident design alternative for a facility referencing the certified design that would have been cost beneficial had it been considered as part of the original design certification application. The evaluation of these issues under NEPA is considered resolved for the U.S. ABWR design.

Table 1 Summary of GE's Assessment of Risk Reduction for Candidate Design Improvements

POTENTIAL ABWR DESIGN MODIFICATION	GE'S BASIS FOR ESTIMATING RISK REDUCTION	PERSON-SV (PERSON-REM) AVERTED
Accident Management Severe accident EPGs/AMGs Computer-aided instrumentation Improved maintenance procedures/manuals	10% reduction in failure rates for manually initiated mitigative actions 10% reduction in failure rates for manually initiated preventive actions 10% improvement in reliability of HPCF, RCIC, RHR, LPCF	0.00015 (0.015) 0.00010 (0.01) 0.00016 (0.016)
Decay Heat Removal Passive high-pressure system Improved depressurization system Suppression pool jockey pump Safety-related condensate storage tank	Equivalent to adding a diverse RCIC and RHR system with 10% unavailability Factor of 2 reduction in depressurization failure rates 10% improvement in reliability of low-pressure makeup (resulting in 2% reduction in core damage frequency from low-pressure sequences) Engineering judgement	0.00069 (0.069) 0.00042 (0.042) 0.00002 (0.002) 0.00010 (0.01)
Containment Capability Larger-volume containment Increased containment pressure capacity Improved vacuum breakers Improved bottom head penetration design	Elimination of all containment release modes involving drywell head failure (Cases 3, 6, 7, 8, 9) Elimination of all containment release modes except normal containment leakage Elimination of releases from Release Class 2 Factor of 2 increase in the probability of arresting core damage in vessel	0.00150 (0.15) 0.0016 (0.16) 0.0000004 (0.00004) 0.00057 (0.057)
Containment Heat Removal Larger-volume suppression pool	Elimination of Class II Sequences	0.000002 (0.0002)
Containment Mass Removal Low-flow filtered vent	Elimination of the risk associated with releases via COPS	0.00014 (0.014)
Containment Spray Systems Drywell head flooding	Elimination of drywell head overtemperature failures and reduction in releases from drywell head overpressure failures	0.00060 (0.06)
Prevention Concepts Additional service water loop	10% increase in reliability of HPCF, RCIC, RHR, LPCF	0.00016 (0.016)
AC Power Supplies Steam-driven turbine generator Alternate pump power source	80% reduction in the diesel generator common-mode failure rate Equivalent to adding a diverse RCIC system	0.00052 (0.052) 0.00069 (0.069)
DC Power Supplies Dedicated dc power supply	Factor of 10 increase in RCIC availability in LOOP and SBO sequences	0.00069 (0.069)
ATWS Capability ATWS-sized vent	Elimination of risk from ATWS (Case 9)	0.00030 (0.03)
System Simplification Reactor building sprays	10% reduction in risk from releases through the reactor building	0.00017 (0.017)
Core Retention Devices Flooded rubble bed	Elimination of sequences with core concrete interactions, except those with failure of containment heat removal (1% of Cases 1, 6, and 7)	0.000010 (0.001)

Table 2
Potential Design Improvements and Associated Costs (GE)

Modification	Estimated Cost (\$M)	Person-Sv (Person-Rem) Averted	Cost(\$M)/ Person-Sv (Person-Rem) Averted
1. Accident Management			
1a. Severe accident EPGs	0.60	0.00015 (0.015)	4,000 (40)
1b. Computer-aided instrumentation	0.60	0.00010 (0.01)	>4,000 (>40)
1c. Improved maintenance procedures and manuals	0.30	0.00016 (0.016)	1,870 (18.7)
2. Decay Heat Removal			
2a. Passive high-pressure system	1.7	0.00069 (0.069)	2,530 (25.3)
2b. Improved depressurization	0.60	0.00042 (0.042)	1,430 (14.3)
2c. Suppression pool jockey pump	0.12	0.00002 (0.002)	>4,000 (>40)
2d. Safety-related condensate storage tank	1.0	0.00010 (0.01)	>4,000 (>40)
3. Containment Capability			
3a. Larger-volume containment	8.0	0.00150 (0.15)	>4,000 (>40)
3b. Increased containment pressure capacity	12.0	0.0016 (0.16)	>4,000 (>40)
3c. Improved vacuum breakers	0.10	0.0000004 (0.00004)	>4,000 (>40)
3d. Improved bottom head penetration design	0.75	0.00057 (0.057)	1,320 (13.2)
4. Containment Heat Removal			
4a. Larger-volume suppression pool	8.0	0.000002 (0.0002)	>4,000 (>40)
5. Containment Atmosphere Mass Removal			
5.a Low-flow filtered vent	3.0	0.00014 (0.014)	>4,000 (>40)
7. Containment Spray Systems			
7a. Drywell head flooding	0.10	0.00060 (0.06)	170 (1.7)
8. Prevention Concepts			
8a. Additional service water loop	6.0	0.00016 (0.016)	>4,000 (>40)
9. AC Power Supplies			
9a. Steam driven turbine generator	6.0	0.00052 (0.052)	>4,000 (>40)
9b. Alternate pump power source	1.2	0.00069 (0.069)	1,730 (17.3)
10. DC Power Supplies			
10a. Dedicated RHR dc power supply	3.0	0.00069 (0.069)	>4,000 (>40)
11. ATWS Capability			
11a. ATWS-sized vent	0.30	0.00030 (0.03)	1,000 (10)
13. System Simplification			
13a. Reactor building sprays	0.10	0.00017 (0.017)	590 (5.9)
14. Core Retention Devices			
14a. Flooded rubble bed	18.8	0.00001 (0.001)	>4,000 (>40)

**NRC CERTIFIES GE NUCLEAR ENERGY'S
ADVANCED BOILING WATER REACTOR DESIGN**

The Nuclear Regulatory Commission (NRC) is amending its regulations to certify the U.S. Advanced Boiling Water Reactor (ABWR) design developed by GE Nuclear Energy. The certification will be valid for 15 years.

No application for a license using the U.S. ABWR standard design has been filed with the NRC, and issuance of this regulation does not authorize construction of any specific new nuclear power plant. However, a utility that wishes to build and operate a new nuclear power plant may choose to use the design and reference it in an application for a license. Safety issues within the scope of the certified design are not subject to litigation, although site-specific environmental impacts associated with building and operating the plant at a particular location would be litigable.

Future applicants for a license could make plant-specific changes to portions of the standard U.S. ABWR design by following the procedures set out in the rule. The applicant or licensee would be required to maintain records of all such changes until the license is terminated.

The NRC published a proposed rule on this subject in the Federal Register on April 7 for public comment and held public meetings to explain the proposal on May 11 and December 4, 1995. Responses to the comments received are discussed in the Federal Register notice on the final rule published on _____.

The agency also offered an opportunity to request a hearing on the proposed certification of the U.S. ABWR design. No requests were received.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

The Honorable Dan Schaefer, Chairman
Subcommittee on Energy and Power
Committee on Commerce
United States House of Representatives
Washington, DC 20515

Dear Mr. Chairman:

The NRC has sent to the Office of the Federal Register for publication the enclosed final amendment to the Commission's regulations for commercial nuclear power plants. Specifically, this rule adds a new Appendix to 10 CFR Part 52. This rule will certify the U.S. Advanced Boiling Water Reactor (ABWR) design, which was submitted to the NRC for its review by GE Nuclear Energy. This amendment is necessary to fulfill the objectives of Part 52, which are to provide licensing stability, early resolution of licensing issues, and to foster standardization while allowing sufficient flexibility to incorporate advancements in technology and equipment. Those wishing to obtain a license to build or operate the U.S. ABWR design will be able to do so by referencing the design certification in Appendix A to 10 CFR Part 52.

Sincerely,

Dennis K. Rathbun, Director
Office of Congressional Affairs

Enclosure:
Federal Register Notice

cc: Representative Frank Pallone



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

The Honorable Lauch Faircloth, Chairman
Subcommittee on Clean Air, Wetlands, Private
Property and Nuclear Safety
Committee on Environment and Public Works
United States Senate
Washington, DC 20510

Dear Mr. Chairman:

The NRC has sent to the Office of the Federal Register for publication the enclosed final amendment to the Commission's regulations for commercial nuclear power plants. Specifically, this rule adds a new Appendix to 10 CFR Part 52. This rule will certify the U.S. Advanced Boiling Water Reactor (ABWR) design, which was submitted to the NRC for its review by GE Nuclear Energy. This amendment is necessary to fulfill the objectives of Part 52, which are to provide licensing stability, early resolution of licensing issues, and to foster standardization while allowing sufficient flexibility to incorporate advancements in technology and equipment. Those wishing to obtain a license to build or operate the ABWR design will be able to do so by referencing the design certification in Appendix A to 10 CFR Part 52.

Sincerely,

Dennis K. Rathbun, Director
Office of Congressional Affairs

Enclosure:
Federal Register Notice

cc: Senator Bob Graham

NUCLEAR REGULATORY COMMISSION
10 CFR PART 52
RIN 3150 - AF15

**Standard Design Certification
for the System 80+ Design**

AGENCY: Nuclear Regulatory Commission.

ACTION: Final rule.

SUMMARY: The Nuclear Regulatory Commission (NRC or Commission) is amending its regulations to certify the System 80+ design. The NRC is adding a new provision to its regulations that approves the System 80+ design by rulemaking. This action is necessary so that applicants for a combined license that intend to construct and operate the System 80+ design may do so by appropriately referencing this regulation. The applicant for certification of the System 80+ design was Combustion Engineering, Inc. (ABB-CE).

EFFECTIVE DATE: The effective date of this rule is [insert the date 30 days after the publication date]. The incorporation by reference of certain publications listed in the regulations is approved by the Director of the Federal Register as of [insert the date 30 days after the publication date].

FOR FURTHER INFORMATION CONTACT: Jerry N. Wilson, Office of Nuclear Reactor Regulation, telephone (301) 415-3145, Harry S. Tovmassian, Office of Nuclear Regulatory Research, telephone (301) 415-6231, or Geary S. Mizuno, Office of the General Counsel, telephone (301) 415-1639, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

SUPPLEMENTARY INFORMATION:

Table of Contents

- I. Background.
- II. Public comment summary and resolution.
 - A. Principal Issues.
 - 1. Issue Resolution (Issue Finality).
 - 2. Tier 2 Change Process.
 - 3. Need for Applicable Regulations.
 - 4. Analysis of New Applicable Regulations.
 - B. Responses to specific requests for comment from proposed rule.
 - C. Other Issues.
 - 1. NRC Verification of ITAAC Determinations.
 - 2. DCD Introduction.
 - 3. Duplicate documentation in design certification rule.
- III. Section-by-section discussion of this design certification rule.
 - A. Introduction (Section 1).
 - B. Definitions (Section 2).

- C. Scope and contents of this design certification (Section 3).
- D. Applications and licenses referencing this design certification: additional requirements and restrictions (Section 4).
- E. Applicable regulations (Section 5).
- F. Issue resolution for this design certification (Section 6).
- G. Duration of this design certification (Section 7).
- H. Processes for changes and departures (Section 8).
- I. Inspections, tests, analyses, and acceptance criteria (Section 9).
- J. Records and Reporting (Section 10).
- IV. Finding of no significant environmental impact: availability.
- V. Paperwork Reduction Act statement.
- VI. Regulatory analysis.
- VII. Regulatory Flexibility Act certification.
- VIII. Backfit analysis.

I. Background

On March 30, 1989, Combustion Engineering, Inc. applied for certification of the System 80+ standard design with the NRC. The application was made in accordance with the procedures specified in 10 CFR Part 50, Appendix O, and the Policy Statement on Nuclear Power Plant Standardization, dated September 15, 1987.

On May 18, 1989 (54 FR 15372), the NRC added 10 CFR Part 52 to its regulations to provide for the issuance of early site permits, standard design certifications, and combined licenses for nuclear power reactors. Subpart B of 10 CFR Part 52 established the process for obtaining design certifications. A major purpose of this rule was to achieve early resolution of licensing issues and to enhance the safety and reliability of nuclear power plants.

On August 21, 1989, Combustion Engineering, Inc. requested that its application, originally submitted pursuant to 10 CFR Part 50, Appendix O, be considered as an application for design approval and subsequent design certification pursuant to Subpart B of 10 CFR Part 52. The application was docketed on May 1, 1991, and assigned Docket No. 52-002. Correspondence relating to the application prior to this date was also addressed to docket number STN 50-470 and Project No. 675. By letter dated May 26, 1992, Combustion Engineering, Inc. notified the NRC that it is a wholly owned subsidiary of Asea Brown Boveri, Inc., and the appropriate abbreviation for the company is ABB-CE. Therefore, ABB-CE will be used for Combustion Engineering, Inc. throughout the statements of consideration (SOC).

The NRC staff issued a final safety evaluation report (FSER) related to the certification of the System 80+ design in August 1994 (NUREG-1462). The FSER documents the results of the NRC staff's safety review of the System 80+ design against the requirements of 10 CFR Part 52, Subpart B, and delineates the scope of the technical details considered in evaluating the proposed design. A copy of the FSER may be obtained from the Superintendent of Documents, U. S. Government Printing Office, Mail Stop SSOP, Washington, DC 20402-9328 or the National Technical Information Service, Springfield, VA 22161. A final design approval for System 80+ was issued on July 26, 1994, and published in the Federal Register on August 2, 1994 (59 FR 39371).

The NRC staff originally proposed a conceptual design certification rule for evolutionary standard plant designs in SECY-92-287, "Form and Content for a Design Certification Rule." Subsequently, the NRC staff modified the draft

rule language proposed in SECY-92-287 to incorporate Commission guidance and published a draft-proposed design certification rule in the Federal Register on November 3, 1993 (58 FR 58665), as an Advanced Notice of Proposed Rulemaking (ANPR) for public comment. In accordance with the Administrative Procedure Act (APA), Part 52 provides the opportunity for the public to submit written comments on proposed design certification rules. However, Part 52 went beyond the requirements of the APA by providing the public with an opportunity to request a hearing before an Atomic Safety and Licensing Board in a design certification rulemaking. Therefore, on April 7, 1995 (60 FR 17924), the NRC published a proposed rule in the Federal Register which invited public comment and provided the public with the opportunity to request an informal hearing before an Atomic Safety and Licensing Board. The NRC staff conducted public meetings on the development of this design certification rule on November 23, 1993, May 11, 1995, and December 4, 1995, in order to enhance public participation. The period within which an informal hearing could be requested expired on August 7, 1995. The NRC did not receive any requests for an informal hearing during this period.

The Commission has considered the comments received and made appropriate modifications to this design certification rule, as discussed in Sections II and III. With these modifications, the Commission adopts as final this design certification rule, 10 CFR Part 52, Appendix B, for the System 80+ design.

II. Public Comment Summary and Resolution

The public comment period for the proposed design certification rule, the design control document, and the environmental assessment for the System 80+ design expired on August 7, 1995. The NRC received twenty letters containing public comments on the proposed rule. The most extensive comments were provided by the Nuclear Energy Institute (NEI), which provided comments on behalf of the industry. In general, NEI commended the NRC for its efforts to provide standard design certifications but expressed serious concerns about aspects of the proposed rule that would, in NEI's view, undermine the goals of design certification. These concerns are addressed in the following responses to the public comments. Fourteen utilities and three vendors also provided comments. All of these comment letters endorsed the NEI comments and some provided additional comments. The Department of Energy and the Ohio Citizens for Responsible Energy, Inc. (OCRE) also submitted comment letters. OCRE provided two sets of comments, the first addressed the NRC's specific requests for comment and the second addressed OCRE's concerns about certain aspects of the U.S. ABWR design.

The NRC received other letters that were entered into the docket file and are part of the record of the rulemaking proceeding. An August 4, 1995 letter from NEI to the Chairman of the NRC, which submitted a copy of the Executive Summary of their public comment letter, and a May 11, 1995 letter, which provided suggestions on finality, secondary references, and other explanatory material. Also, the NRC received a second letter from the General Electric Company, which commented on the comments provided by OCRE, and a second letter from Combustion Engineering, Inc. (ABB-CE), which provided proposed Statements of Consideration (SOC) that conformed with its comments.

On February 6, 1996, the NRC staff issued SECY-96-028, "Two Issues for Design Certification Rules," which requested the Commission's approval of the staff's position on two major issues raised by NEI in its comments on the

proposed design certification rules. The staff issued this paper because of fundamental disagreements with industry on the need for applicable regulations and the matters to be considered in verifying inspections, tests, analyses, and acceptance criteria (ITAAC). Both NEI and DOE commented on SECY-96-028 in letters dated March 5 and 13, 1996, respectively.

On March 8, 1996, the Commission conducted a public meeting in which industry representatives and NRC staff presented their views on SECY-96-028. During this meeting, NEI and the staff both indicated agreement on the ITAAC verification issue. Subsequently, in a staff requirements memorandum (SRM) dated March 21, 1996, the Commission requested the staff to meet again with industry to try to resolve the issue of applicable regulations. The staff met with representatives of ABB-CE, GE Nuclear Energy, and NEI in a public meeting on March 25, 1996 and proposed various means to reduce or otherwise resolve the need for new applicable regulations. The industry, represented by NEI, neither provided a proposal for resolution of applicable regulations (other than to eliminate them altogether) nor indicated any support for the staff's proposals. As a result, the staff has provided revised resolutions of applicable regulations and ITAAC determinations in the following discussion (sections II.A.3, II.A.4, and II.C.1) that supersede the proposals in SECY-96-028. In addition to the formally scheduled meetings noted above, there have also been numerous less formal interactions between NRC and industry representatives.

The following discussion is separated into three groups: (1) resolution of the principle issues raised by the commenters, (2) resolution of the NRC's specific requests for comment from the proposed rule, and (3) resolution of other issues raised by the commenters.

A. Principal Issues.

1. Issue Resolution (Issue Finality).

Comment Summary. The applicant and NEI criticized Section 6 of the proposed appendix, which describes the scope of issues that were proposed to be resolved by this design certification rulemaking. In brief, both commenters argued that:

- The scope of issues accorded finality is too narrow;
- Changes made in accordance with the change process are not accorded finality; and
- The rule does not provide finality in all subsequent proceedings.

These comments are found in NEI Comment, Attachment B, pp. 1-23 and ABB-CE Comment, B.1. The applicant and NEI provided specific language for a redrafted Section 6 which addresses their criticisms. With the exception of the industry position regarding the exclusion of Tier 2 departures from an opportunity for a hearing, the Commission generally agrees with the applicant and NEI.

Response: Scope of issues accorded finality.

The applicant and NEI took issue with the proposed rule's language limiting the scope of nuclear safety issues resolved to those issues "associated with" the information in the FSER or Design Control Document

(DCD). Each argued that there were many other documents which included and/or addressed issues whose status should be regarded as "resolved in connection with" this design certification rulemaking. These additional documents include "secondary references" (i.e., DCD references to documents and information which are not contained in the DCD, including secondary references containing proprietary and safeguards information), docketed material, and the entire rulemaking record (refer to NEI Comments, Attachment B, pp. 6-9).

The Commission has reconsidered its position and decided that the ambit of issues resolved by this rulemaking should be the information that is reviewed and approved in the design certification rulemaking, which includes the rulemaking record for the standard design. This position reflects the Commission's SRM on SECY-90-377, dated February 15, 1991. Also, the Commission concludes that the set of issues resolved should be those that were addressed (or could have been addressed if they were considered significant) as part of the design certification rulemaking process. However, the Commission does not agree that all matters submitted on the docket for design certification should be accorded finality under 10 CFR 52.63(a)(4). Some of this information was neither reviewed nor approved and some was not directly related to the scope of issues resolved by this rulemaking. Therefore, the final rule provides finality for all nuclear safety issues associated with the information in the FSER and any supplements to it, the generic DCD including referenced information that is intended as requirements, and the rulemaking record.

In adopting this final design certification rulemaking, the Commission also finds that the design certification does not require any additional or alternative design criteria, design features, structures, systems, components, testing, analyses, acceptance criteria, or additional justifications in support of these matters. Inherent in the concept of design certification by rulemaking is that all these issues which were addressed, or could have been addressed, in this rulemaking are resolved and therefore, may not be raised in a subsequent NRC proceeding. If this were not the case and one could always argue in a subsequent proceeding that an additional, alternative, or modified system, structure or component of a previously-certified design was needed, or additional justification was necessary, or a modification to the testing and acceptance criteria is necessary, there would be little regulatory certainty and stability associated with a design certification. The underlying benefits of certification of individual designs by rulemaking, e.g., early Commission consideration and resolution of design issues and early Commission consideration and agreement on the methods and criteria for demonstrating completion of detailed design and construction in compliance with the certified design, would be virtually negated. Thus, in accord with the views of the applicant and NEI, the Commission clarifies and makes explicit its previously implicit determination that the scope of issues resolved in connection with the design certification rulemaking includes the lack of need for alternative, additional or modified design criteria, design features, structures, systems, components, or inspections, tests, analyses, acceptance criteria or justifications, and such matters may not be raised in subsequent NRC proceedings.

In the SOC for the proposed rule, the Commission proposed that issues associated with "requirements" in secondary references, not specifically approved for incorporation by reference by the Office of the Federal Register (OFR) because they contained proprietary information, would not be considered

resolved in the design certification rulemaking within the meaning of 10 CFR 52.63(a)(4) (See 60 FR 17924, 17934). NEI took exception to this position, arguing that issues arising from secondary references should be included in the set of issues resolved (See NEI Comments, Attachment B, pp. 6-9). The Commission has determined that the set of issues resolved by this rulemaking embraces those issues arising from secondary references that are requirements for the certified design, including those containing proprietary information. This is consistent with the intent of 10 CFR Part 52 that issues related to the design certification should be considered and resolved in the design certification rulemaking. However, since OFR does not approve of "incorporation by reference" of proprietary information, even though it was available to potential commenters on this proposed design certification rule (see 60 FR 17924; April 7, 1995), the Commission has included in Section 6(d) of this appendix, a process for obtaining proprietary information at the time that notice of a hearing in connection with issuance of a combined license is published in the Federal Register. Such persons will have actual notice of the requirements contained in the proprietary information and, therefore, will be subject to the issue finality provisions of Section 6 of this appendix.

Changes made in accordance with the change process.

The proposed design certification rule included a change process similar to that provided in 10 CFR 50.59. Specifically, Section 8(b)(5) provided "that such changes open the possibility for challenge in a hearing" for Tier 2 changes in accordance with the Commission's guidance in its SRM on SECY-90-377, dated February 15, 1991. The NRC also believed that providing an opportunity for a hearing would serve to discourage changes that could erode the benefits of standardization. The applicant and NEI argued that Tier 2 departures under the "§ 50.59-like" process should not be subject to any opportunity for hearing but may only be challenged *via* a 10 CFR 2.206 petition; and, therefore should be subject to the backfit restrictions of 10 CFR 52.63(a).

The Commission has reconsidered and changed its position on issue resolution in connection with Tier 2 departures under the "§ 50.59-like" process. Section 50.59 was originally adopted by the Commission to afford a Part 50 operating license holder greater flexibility in changing the facility as described in the FSAR while still assuring that safety-significant changes of the facility would be subject to prior NRC review and approval [refer to 27 FR 5491, 5492 (first column); June 9, 1962]. The "unreviewed safety question" definition was intended by the Commission to exclude from prior regulatory consideration those licensee-initiated changes from the previously NRC-approved FSAR that could not be viewed as having safety significance sufficient to warrant prior NRC licensing review and approval. To put it another way, any change properly implemented pursuant to § 50.59 should continue to be regarded as within the envelope of the original safety finding by the NRC. Moreover, the departure process for Tier 2 information, as specified in Section 8(b), includes additional restrictions derived from 10 CFR 52.63(b)(2), *viz.*, the Tier 2 change must not involve a change to Tier 1 information. Thus, the departure process of Section 8(b)(5), *if properly implemented by an applicant or licensee*, must logically result in departures which are both "within the envelope" of the Commission's safety finding for

the design certification rule and for which the Commission has no safety concern. Therefore, it follows that *properly implemented* departures from Tier 2 should continue to be accorded the same extent of issue resolution as that of the original Tier 2 information from which it was "derived." Section 8(b)(5) has been amended to reflect the Commission's determination on issue resolution for Tier 2 changes made in accordance with the departure process and Section 6 has been amended to provide backfit protection for changes made in accordance with the processes of Section 8 of this appendix.

However, the converse of this reasoning leads the Commission to reject the applicant's and NEI's contention that *no* part of the applicant's or licensee's implementation of the Section 8(b)(5) departure process should be open to challenge in a subsequent licensing proceeding, but instead should be raised as a petition for enforcement action under 10 CFR 2.206. Because §2.206 applies to holders of licenses and is considered a request for enforcement action (thereby presenting some potential difficulties when attempting to apply this in the context of a combined license applicant), it is unclear why an applicant or licensee who departs from the design certification rule in noncompliance with the Section 8(b)(5) process should nonetheless reap the benefits of issue resolution stemming from the design certification rule. An incorrect departure from the requirements of this appendix essentially places the departure outside of the scope of the Commission's safety finding in the design certification rulemaking. It follows that properly-founded contentions alleging such incorrectly-implemented departures cannot be considered "resolved" by this rulemaking. The industry also appears to oppose an opportunity for a hearing on the basis that there is no "remedy" available to the Commission in a licensing proceeding that would not also constitute a violation of the Tier 2 [Section 8(b)] backfitting restrictions applicable to the Commission and that in a comparable situation with an operating plant the proper remedy is enforcement action. However, for purposes of issue finality the focus should be on the initial licensing proceeding where the result of an improper change evaluation would simply be that the change is not considered resolved and no enforcement action is needed. Neither the applicant nor NEI provided compelling reasons why contentions alleging that applicants or licensees have not properly implemented the Section 8(b)(5) departure process should be entirely precluded from consideration in an appropriate licensing proceeding where they are relevant to the subject of the proceeding.

Although the Commission disagrees with the applicant and NEI over the admissibility of contentions alleging incorrect implementation of the departure process, the Commission acknowledges that they have a valid concern regarding whether the scope of the contentions will incorrectly focus on the substance of correctly-performed departures and the possible lengthened time necessary to litigate such matters in a hearing (See, e.g., Transcript of December 4, 1995 Public Meeting, p. 47). Therefore, the Commission has included in Section 8(b)(5)(vi) an expedited review process, similar to that provided in 10 CFR 2.758, for considering the admissibility of such contentions. Persons who seek a hearing on whether an applicant has departed from Tier 2 information in noncompliance with the applicable requirements must submit a petition, together with information required by 10 CFR 2.714(b)(2), to the presiding officer. If the presiding officer concludes that a *prima facie* case has been presented, he or she shall certify the petition and the

responses to the Commission for final determination as to admissibility.

Finality in all subsequent proceedings.

NEI proposed that Section 6 of the proposed rule be expanded to include a more detailed statement regarding the findings, issues resolved, and restrictions on the Commission's ability to "backfit" this appendix. The Commission agrees that the industry's proposal has some merit, and has revised Section 6 of this appendix, beginning with the general subjects embodied in NEI's proposed redraft of Section 6, but restructured the NEI proposal into three sections to reflect the scope of issues resolved, change process, and rulemaking findings, thereby conforming the language to reflect the conventions of the appendix (e.g., generic *changes* versus plant-specific *departures*), and making minor editorial changes for clarity and consistency. However, one area in which the Commission declines to adopt the industry's proposal is the inclusion of a statement in Section 6 which extends issue finality to *all* subsequent proceedings.

Section 52.63(a)(4) explicitly states that issues resolved in a design certification rulemaking have finality in combined license proceedings, proceedings under § 52.103, and operating license proceedings. There are other NRC proceedings not mentioned in § 52.63(a)(4), e.g., combined license amendment proceedings and enforcement proceedings, in which the design certification should logically be afforded issue resolution and, therefore, will be included in Section 6. However, NEI listed NRC proceedings such as design certification renewal proceedings, for which issue finality would not be appropriate. Moreover, it should be understood that to say that this design certification rule is accorded "issue finality" does not eliminate changes properly made under the change restrictions in Section 8. Therefore, the Commission declines to adopt in its entirety the industry proposal that issue finality should extend to all subsequent NRC proceedings.

2. Tier 2 Change Process.

Comment Summary. NEI provided many comments in its Attachment B on the following aspects of the Tier 2 change process:

- Scope of the Section 8(b)(5) change process;
- Post-design certification rulemaking changes to Tier 2 information;
- Restrictions on Tier 2* information;
- Technical Specifications; and
- Additional aspects of the change process.

Response. The proposed design certification rule provided a change process for Tier 2 information that has the same elements as the Tier 1 change process in order to implement the two-tiered rule structure that was requested by industry. Specifically, the Tier 2 change process in Section 8(b) provides for generic changes, plant-specific changes, and exemptions similar to the provisions in 10 CFR 52.63, except that some of the standards for plant-specific orders and exemptions are different. Section 8(b) also has a provision similar to 10 CFR 50.59 that allows for departures from Tier 2 information by an applicant or licensee, without prior NRC approval, subject to certain restrictions, in accordance with the Commission's SRM on SECY-90-

377, dated February 15, 1991.

Scope of the Section 8(b)(5) change process.

In its comments in Attachment B, pp. 67-82, NEI raised a concern regarding application of the § 50.59-like change process to severe accident information, and stated:

Instead of applying the § 50.59-like process to all of Chapter 19, we propose (1) that the process be applied only to those sections that identify features that contribute significantly to the mitigation or prevention of severe accidents (i.e., Section 19.8 for the ABWR and Section 19.15 for the System 80+), and (2) that changes in these sections should constitute unreviewed safety questions only if they would result in a substantial increase in the probability or consequences of a severe accident.

The Commission agrees that departures from Tier 2 information that describe the resolution of severe accident issues should use a criteria that is different from the criteria in 10 CFR 50.59 for determining if a departure constitutes an unreviewed safety question (USQ). Because of the increased uncertainty in severe accident issue resolutions, the NRC has included a "substantial increase" criteria in Section 8(b)(5)(iii) of this Appendix for Tier 2 information that is associated with the resolution of severe accident issues. The (§ 50.59-like) criteria in Section 8(b)(5)(ii), for determining if a departure constitutes a USQ, will apply to the remaining Tier 2 information. If the proposed departure from Tier 2 information involves the resolution of other safety issues in addition to the severe accident issues, then the USQ determination must use the criteria in Section 8(b)(5)(ii) of this appendix.

However, NEI has misidentified the sections of the DCD that describe the resolutions of the severe accident issues. Section 19.8 for the U.S. ABWR and Section 19.15 for the System 80+ design identify important features that were derived from various analyses of the design, such as seismic analyses, fire analyses, and the probabilistic risk assessment. This information was used in preparation of the Tier 1 information and, as stated in the proposed rule, it should be used to ensure that departures from Tier 2 information do not impact Tier 1 information. For these reasons, the Commission rejects the contention that the severe accident resolutions are contained in Chapter 19.15 of the generic DCD.

Post-design certification rulemaking changes to Tier 2 information.

In its comments in Attachment B, pp. 83-89, NEI requested that the NRC add a § 50.59-like provision to the change process that would allow design certification applicants to make generic changes to Tier 2 information prior to the first license application. These applicant-initiated, post-certification Tier 2 changes would be binding upon all referencing applicants and licensees (i.e., referencing applicants and licensees must comply with all such changes) and would continue to enjoy "issue preclusion" (i.e., issues with respect to the adequacy of the change could not be raised in a subsequent proceeding as a matter of right). However, the changes would not be subject

to public notice and comment. Instead NEI proposed that the changes would be considered resolved and final (not subject to further NRC review) six months after submission, unless the NRC staff informs the design certification applicant that it disagrees with the determination that no unreviewed safety question exists.

The Commission declines to adopt the NEI proposal. The applicant-initiated Tier 2 changes proposed by NEI have the essential attributes of a "rule," and the process of NRC review and "approval" (negative consent) would appear to be "rulemaking," as these terms are defined in Section 551 of the APA. Section 553(b) of the APA requires public notice in the Federal Register and an opportunity for public comment for all rulemakings, except in certain situations delineated in Section 553(b)(A) and (B) which do not appear to be applicable here. The NEI proposal appears to be in conflict with the rulemaking requirements of the APA. If the NEI proposal is based upon a desire to permit the applicant to disseminate worthwhile Tier 2 changes, there are three alternatives already afforded by Part 52 and this rule. The applicant (as any member of the public) may submit a petition for rulemaking pursuant to 10 CFR Part 2, Subpart H, to modify this design certification rule to incorporate the proposed changes to Tier 2. If the Commission grants the petition and adopts a final rule, the change is binding on all referencing applicants and licensees in accordance with Section 8(b)(2) of this rule. Also, the applicant could develop acceptable documentation to support a Tier 2 (including Tier 2*) departure in accordance with Section 8(b)(5) [or 8(b)(6)]. This documentation could be submitted for NRC staff review and approval, similar to the manner in which the NRC staff reviews topical reports¹. And finally, the applicant could provide its proposed changes to a COL applicant who could seek approval as part of its COL application review. The Commission regards these regulatory approaches to be preferable to the NEI proposal, which is fraught with the difficulties identified above. However, if NEI is requesting that the Commission change its preliminary determination, as set forth in its February 15, 1991 SRM on SECY 90-377, that generic Tier 2 rulemaking changes be subject to the same restrictive standard as generic Tier 1 changes, the Commission declines to do so. The Commission believes that maintaining a high standard for generic changes to both Tier 1 and Tier 2 will ensure that the benefits of standardization are appropriately achieved.

Restrictions on Tier 2* information.

In its comments in Attachment B, pp. 119-123, NEI requested that the

¹Topical reports, which are usually submitted by vendors such as GE, Westinghouse, and Combustion Engineering, request NRC staff review and approval of generic information and approaches for addressing one or more of the Commission's requirements. If the topical report is approved by the NRC staff, it issues a safety evaluation setting forth the bases for the staff's approval together with any limitations on referencing by individual applicants and licensees. Applicants and licensees may incorporate by reference topical reports in their applications, in order to facilitate timely review and approval of their applications or responses to requests for information. However, limitations in NRC resources may affect review schedules for these topical reports.

restriction on departures from all Tier 2* information expire at first full power and, in any event, the expiration of the restrictions should be consistent for both the U.S. ABWR and System 80+ designs. As stated in the proposed design certification rule, the restriction on changing Tier 2* information resulted from the development of the Tier 1 information in the generic DCD. During the development of the Tier 1 information, the applicant for design certification requested that the amount of information in Tier 1 be minimized to provide additional flexibility for an applicant or licensee who references this design certification. Also, many codes, standards, and design processes, which were not specified in Tier 1, that are acceptable for meeting ITAAC were specified in Tier 2. The result of these actions is that certain significant information only exists in Tier 2 and the NRC does not want this significant information to be changed without prior NRC approval. This Tier 2* information is identified in the generic DCD with italicized text and brackets and the change restriction has compensated for industry's desire to minimize the amount of information in Tier 1.

Although the Tier 2* designation was originally intended to last for the lifetime of the facility, like Tier 1 information, the NRC staff reevaluated the duration of the change restriction for Tier 2* information during the preparation of the proposed rule. The NRC staff determined that some of the Tier 2* information could expire when the plant first achieves full (100%) power, after the finding required by 10 CFR 52.103(g), while other Tier 2* information must remain in effect throughout the life of the plant that references this rule. The determining factors were the Tier 1 information that would govern these areas after first full power and the NRC staff's judgement on whether prior approval was required before implementation of the change due to the significance of the information.

As a result of NEI's comment, the NRC has again reevaluated the durations of the Tier 2* change restrictions. The NRC agrees with NEI that expiration of Tier 2* information for the two evolutionary designs should be consistent, unless there is a design-specific reason for a different treatment. One area of Tier 2* information that had different expiration dates was equipment seismic qualification methods. The NRC has determined that, due to its significance, changes to the qualification methodology must be approved before implementation. Therefore, the Tier 2* designation for this information will not expire for either design.

For reactor core acceptance criteria, the licensing criteria for fuel and control rods had not been developed sufficiently when ABB-CE's DCD was developed and, therefore, the Tier 2* designation was not applied to licensing acceptance criteria for the System 80+ but was applied to specific parameters of the initial core load. Consequently, many changes to ABB-CE fuel designs, including relatively minor changes and reload calculations, must be submitted to the NRC staff for review following the first fuel cycle.

Recent industry proposals for currently operating core fuel designs have indicated a desire to modify the fuel burnup limit design parameter. However, operational experience with fuel with extended fuel burnup has indicated that cores should not be allowed to operate beyond the burnup limits specified in the generic DCDs without NRC approval. This experience is summarized in a Commission memorandum from James M. Taylor, "Reactivity Transients and High Burnup Fuel," dated September 13, 1994, including Information Notice (IN) 94-64, "Reactivity Insertion Transient and Accident Limits for High Burnup Fuel," dated August 31, 1994. Experimental data on the performance of high burnup

fuel under reactivity insertion conditions became available in mid-1993. The NRC issued IN 94-64 and IN 94-64, Supplement 1, on April 6, 1995, to inform industry of the data. The unexpectedly low energy deposition to initiation of fuel failure in the first test rod (at 62 Gwd/MTU) led to a re-evaluation of the licensing basis assumptions in the NRC's standard review plan (SRP). The NRC performed a preliminary safety assessment and concluded that there was no immediate safety issue for currently operating cores because of the low to medium burnup status of the fuel (refer to Commission Memorandum from James M. Taylor, "Reactivity Transients and Fuel Damage Criteria for High Burnup Fuel," dated November 9, 1994, including an NRR safety assessment and the joint NRR/RES action plan). Therefore, the NRC has determined that additional actions by industry are not needed to justify current burnup limits for operating reactor fuel designs.

However, the NRC is working with industry and fuel vendors to assess fuel performance for high burnup fuel and reevaluate current SRP licensing acceptance criteria. Because the fuel failure threshold may decline with increasing burnup, the NRC is assessing licensing-basis design acceptance criteria as a function of burnup or a performance-based design criteria. Therefore, the NRC has determined that it needs to carefully consider any proposed changes to the fuel burnup parameter in the generic DCDs for these fuel designs until further experience is gained with extended fuel burnup characteristics. Requests for extension of these burnup limits will be evaluated based on supporting experimental data and analyses, as appropriate, for current and advanced fuel designs. Therefore, the NRC has determined that the Tier 2* designation for the fuel burnup parameters should not expire for the lifetime of a referencing facility.

Technical Specifications.

In its comments in Attachment B, pp. 124-129, NEI requested that the NRC establish a single set of integrated technical specifications governing the operation of each plant that references this design certification and that the technical specifications be controlled by a single change process. The NRC included the technical specifications for the standard designs in the generic DCD in order to maximize the standardization of the technical specifications for plants that reference this design certification. As a result, a plant that references this design certification would have two sets of technical specifications associated with its license: (1) technical specifications from Chapter 16 of Tier 2 of the generic DCD and applicable to the standardized portion of the plant, and (2) those technical specifications applicable to the site-specific portion for the plant. While each portion of the technical specifications would be subject to a different change process, the substantive aspects of the change processes would be essentially the same.

Although a potential loss in standardization may result, the Commission has decided not to require COL applicants to conform with the technical specifications in Chapter 16 of the generic DCD. These technical specifications will not be part of Tier 2 and will be treated like conceptual design information. Applicants who reference this appendix will be able to develop new technical specifications for their plant as part of their COL application and the NRC will consider future operating experience when it reviews the new technical specifications. However, the NRC expects that COL applicants will develop their new technical specifications based on the

technical specifications in Chapter 16 that were prepared for this standard design. The change process for the new technical specifications will be similar to the current process in § 50.90 and § 50.92, provided that the changes do not affect the information in the DCD. A consequence of this decision is that there will not be any issue resolution for the technical specifications developed during this design certification review.

Additional aspects of the change process.

In its comments in Attachment B, pp. 109-118, NEI raised some additional concerns with the Tier 2 change process. The first concern was with the process for determining if a departure from Tier 2 information constituted an unreviewed safety question. Specifically, NEI identified the following statement in section III.H of the proposed rule. ". . . if the change involves an issue that the NRC staff has not previously approved, then NRC approval is required." A clarification of this statement was provided in the May 11, 1995 public meeting on design certification (pp. 12-14 of meeting transcript), when the NRC staff stated that the NRC was not creating a new criterion for determining unreviewed safety questions but was explaining existing criteria. A further discussion of this statement took place between the staff and counsel to GE Nuclear Energy at the December 4, 1995 public meeting on design certification (pp. 53-56 of meeting transcript), in which counsel for GE Nuclear Energy agreed that a departure which creates an issue that was not previously reviewed by the NRC would be evaluated against the existing criteria for determining whether there was an unreviewed safety question. With this clarification at the public meeting, the Commission does not believe there is a need for a change to the language of this appendix.

NEI also requested that Section 8(b) of this appendix be revised to state that exemptions are not required for changes to the technical specifications or Tier 2* information that do not involve an unreviewed safety question. The Commission has determined that this is consistent with the Commission's intent that permitted departures from Tier 2* under Section 8(b) of this appendix should not also require an exemption, unless otherwise required by, or implied by extension from 10 CFR Part 52, Subpart B and, accordingly, has revised Section 8(b) of this appendix. As discussed above, the technical specifications in Chapter 16 of the generic DCD are not requirements of this appendix and, therefore, the issue of exemptions to these technical specifications is moot. NEI also raised a concern with the requirement for quarterly reporting of design changes during the construction period. This issue is discussed in section III.J.

Finally, NEI raised a concern with the status of 10 CFR 52.63(b)(2) in the two-tiered rule structure that has been implemented in this appendix and claimed that 10 CFR 52.63(b) clearly embodies a two-tier structure. NEI's claim is not correct. The Commission adopted a two-tiered design certification rule structure (Commission SRM on SECY-90-377, dated February 15, 1991) and created a change process for Tier 2 information that has the same elements as the Tier 1 change process. In addition, the Tier 2 change process includes a provision that is similar to 10 CFR 50.59, namely Section 8(b)(5). Therefore, as stated in section II (Topic 6) of the proposed rule, there is no need for 10 CFR 52.63(b)(2) in the two-tiered change process that has been implemented for this Appendix.

3. Need for Applicable Regulations.

Comment Summary. NEI and the other industry commenters criticized Section 5(c) of the proposed design certification rule, which designated additional applicable regulations for the purposes of 10 CFR 52.48, 52.54, 52.59, and 52.63 (refer to NEI Comment, Attachment B, pp. 24-56).

Response. In its first group of comments, NEI stated that there is no requirement in 10 CFR Part 52 that compels the Commission to adopt these new applicable regulations, that the new applicable regulations are not necessary for adequate protection or to improve the safety of the standard designs, and that the applicable regulations are inconsistent with the Commission's SRM, dated September 14, 1993. Although the Commission was not compelled to adopt new applicable regulations, it has been developing them in accordance with the goals of 10 CFR Part 52 and to achieve the purposes of 10 CFR 52.48, 52.54, 52.59, and 52.63 (refer to SECY-96-028, dated February 6, 1996). The Commission chose design-specific rulemaking rather than generic rulemaking for the new technical and severe accident issues. The Commission adopted this approach early in the design certification review process because it was concerned that generic rulemakings would cause significant delay in the design certification reviews and it was thought that the new requirements would be design-specific. In its SRM on SECY-91-262, dated January 28, 1992, the Commission approved the NRC staff's recommendation to proceed with design-specific rulemakings through individual design certifications to resolve these technical and severe accident issues for the U.S. ABWR and System 80+ designs and continued to support this approach, as stated in its SRM on SECY-93-226, dated September 14, 1993. However, the Commission delayed its decision on the need for generic rulemaking for advanced LWRs. It is this later guidance that NEI appears to have misunderstood.

In its second group of comments, NEI stated that the applicable regulations are unnecessary because the NRC staff has applied these technical positions in reviewing and approving the standard designs. In addition, each of these positions has corresponding staff-approved provisions in the respective design control documents (DCD) and these provisions already serve the purpose of applicable regulations for all of the situations identified by the NRC staff. NEI's statement that information in the DCD will constitute an applicable regulation confuses the difference between design descriptions approved by rulemaking and the regulations (safety standards) that are used as the basis to approve the design. During a meeting on April 25, 1994, and in a letter from Mr. Dennis Crutchfield (NRC) to Mr. William Rasin (NEI), dated July 25, 1994, the NRC staff stated that design information cannot function as a surrogate for the new (design-specific) applicable regulations because this information describes only one method for meeting the regulation and would not provide a basis for evaluating proposed changes to the previously approved design descriptions. The NRC needs the applicable regulations to evaluate proposed changes (§ 52.63) and requests for renewals (§ 52.59). Also, the technical positions that form the basis for the new applicable regulations were used during the reviews because the design-specific rulemaking for the new applicable regulations has been established in parallel with the design certification rulemaking, in accordance with Commission guidance.

In its third group of comments, NEI is concerned that "broadly stated" applicable regulations could be used in the future by the NRC staff to impose backfits on applicants and licensees that could not otherwise be justified on

the basis of adequate protection of public health and safety. However, NEI acknowledged in its comments that the NRC staff did not intend to reinterpret the applicable regulations to impose compliance backfits and because implementation of the applicable regulations was approved in the DCD, the NRC staff could not impose a backfit on the approved implementation without meeting the standards in the change process. In response to NEI's comments, the final design certification rules state that the standard designs meet the applicable regulations and by approving the design information that describes how these regulations were met, the potential for differing interpretations of the new applicable regulations has been minimized. Despite these assurances, the Commission has decided to include a special provision in Section 8(c) of this appendix for compliance backfits to the additional applicable regulations identified in Section 5(c) of this appendix.

Finally, in response to the comment that portions of some of the additional applicable regulations are requirements on an applicant or licensee who references this appendix, the Commission has removed those requirements from the new applicable regulations in Section 5(c) of this appendix and moved them to Section 4 of this appendix. Section 4 sets forth additional requirements applicable to applicants and licensees who reference this appendix.

4. Analysis of New Applicable Regulations.

In response to question 4 in the proposed design certification rules, NEI provided additional comments on the specific wording of each new applicable regulation. The following discussion responds to NEI's comments in the order that the new applicable regulations are listed in Section 5(c) of this appendix. Statements, in the following discussion, that indicate Commission approval of staff positions in SECY papers constitute "tentative" approval subject to the Commission's final decision in this design certification rulemaking.

Intersystem LOCA

Section 5(c)(1) imposes a requirement on the designer to reduce the possibility of a loss of coolant accident (LOCA) outside containment by designing as much of the systems and subsystems connected to the reactor coolant system (RCS) as possible to an ultimate rupture strength at least equal to the normal RCS operating pressure.

The requirements for resolving GSI 105, "Interfacing System LOCA at LWRs," were established in SECY-90-016, "Evolutionary Light Water Reactor (LWR) Certification Issues and Their Relationship to Current Regulatory Requirements," dated January 12, 1990, and the Staff Requirements Memorandum (SRM) dated June 26, 1990. The Commission position regarding ISLOCA protection is that future ALWR designs should reduce the possibility of a LOCA outside containment by designing, to the extent practicable, all systems and subsystems connected to the RCS to a pressure that would ensure reasonable protection against burst failure should the low-pressure system be subjected to full RCS pressure.

The Commission has determined that using a design pressure equal to 40 percent of the normal operating RCS pressure resolves this issue for the design because that value will provide sufficient design margin such that (1) the likelihood of rupture of the pressure boundary is low, (2) the likelihood

of intolerable leakage of flange joints or valve bonnets is reasonably low, and (3) an acceptably small number of piping components might undergo gross yielding. The Commission also notes that the degree of isolation or number of barriers (e.g., three isolation valves) is not sufficient justification for using low-pressure components that are practical to design to a higher pressure. For example, piping runs should always be designed to meet the higher pressure, as should all associated flanges, connectors, and packings, including valve stem seals, pump seals, heat exchanger tubes, valve bonnets, and RCS drain and vent lines. The design should attempt to reduce the level of pressure challenge to all systems and subsystems connected to the RCS should an ISLOCA occur. The Commission does recognize, however, that all systems must eventually interface with atmospheric pressure and that it would be difficult or prohibitively expensive to design certain large tanks and heat exchangers to a higher pressure.

ABB-CE provided acceptable justification for each interfacing system and component not designed to the higher pressure by demonstrating that it is not practicable to reduce the pressure challenge any further. ABB-CE also demonstrated a compensating isolation capability for each such interface. In NUREG-1462, "Final Safety Evaluation Report [FSER] Related to the Certification of the System 80+ Design," the NRC concluded that the System 80+ design meets the criteria of SECY-90-016 regarding ISLOCA prevention and mitigation. Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(1) of this appendix.

Comment Summary. NEI raised the following objections to the proposed wording:

- The phrases "the effects . . . shall be minimized" and "to the extent practical" are vague and subject to numerous interpretations. The state-of-the-art may change over time, and what is infeasible today may be practical in the future. If so, NRC's proposed language could be used to require a backfit to the standard design even though such a backfit would not be needed for adequate protection. This result would be destabilizing and contrary to the intent of design certification.

- Additionally, the phrase "the effects . . . shall be minimized" is inconsistent with "to the extent practical." It also deviates from the staff position in SECY-90-16 that the Commission approved in a Staff Requirements Memorandum (SRM) dated June 26, 1990, which does not require the effects of intersystem LOCAs to "be minimized."

- Finally, "withstand" has no standard definition, and could be subject to future reinterpretation.

Response. In response to the comments from NEI, the Commission has removed the phrases "the effects...shall be minimized," and "withstand" and has reworded the regulation to make it clearer and consistent with SECY-90-016. Finally, the term "to the extent practical" was modified to reflect that the Commission intends to define practicality as the capabilities and means available at the time of design certification.

Inservice Testing of Pumps and Valves

Section 5(c)(2) imposes a requirement on the designer to allow for proper testing of pumps and valves. This requirement is necessary to ensure

that adequate testing to verify operability can be conducted. For check valves in particular, the important issue is the ability to adequately monitor or assess the condition of the valve.

In the FSER, the staff states that a licensee will periodically test the performance and measure performance parameters of safety-related pumps and valves in accordance with ASME Code Section XI, as required by 10 CFR 50.55a(f). Periodic measurements of various parameters will be compared to baseline measurements to detect long-term degradation of the pump or valve performance. The tests, measurements, and comparisons will ensure the operational readiness of these pumps and valves. However, as discussed in SECY-90-016, the staff determined that ASME Code Section XI requirements do not assure the necessary level of component operability that is desired for evolutionary LWR designs. Accordingly, in SECY-90-016, as supplemented by the staff's April 27, 1990, response to comments by the ACRS, the staff recommended criteria to the Commission to be used to supplement Section XI of the ASME Code. In its SRM of June 26, 1990, on SECY-90-016, the Commission approved the staff's recommendations. Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(2) of this appendix.

Comment Summary. NEI raised the following objections to the proposed wording:

- With respect to paragraph (i), it is not always possible to test check valves at maximum design flow. Some check valves can only be tested at full system flow. Thus, paragraph (i) is not possible to implement fully.

- Paragraph (ii) relates to the inservice testing program, not to the design. Inservice testing programs are the responsibility of the applicant/licensee, and are not appropriate as an "applicable regulation" for the standard design. If the NRC believes that the requirements in this paragraph should be imposed on applicants and licensees, it should initiate rulemaking to amend Part 50 to do so.

- Additionally, the term "advanced non-intrusive techniques" is vague and its application will change as the state-of-the-art changes. Therefore, this provision is particularly susceptible to changing interpretations and potential backfits over time. This result would be destabilizing and contrary to the intent of design certification.

Response. The staff agrees with NEI's first comment. Paragraph (i) of the rule was rewritten to allow for less than maximum design flow. The staff believes that it is acceptable to exercise check valves with sufficient flow to fully-open the valve, provided the valve's full-open position can be positively confirmed, or with the maximum required accident flowrate.

With regard to NEI's second comment regarding the appropriateness of addressing applicant/licensee issues in the design certification rulemaking, the Commission has reconsidered its position and moved these issues to Section 4 of this appendix which sets forth requirements for applicants and licensees referencing this design certification rule. While it would be possible to amend 10 CFR 50.55a to reflect these IST requirements, the Commission believes it is better to consolidate the design certification-specific technical requirements which are applicable to plants referencing this design certification rule in the design certification rule itself.

Digital Instrumentation and Control Systems

Section 5(c)(3) imposes a requirement on the designer to consider the unique concerns related to the use of digital instrumentation and control (I&C) systems. The I&C systems of this design are microprocessor-based systems that share processing functions (software) and process equipment (hardware). Therefore, a hardware design error, a software design error, or a software programming error may cause redundant equipment to fail. The Commission is concerned that the use of digital computer technology could result in safety-significant common-mode failures (CMFs). CMFs could both defeat the redundancy achieved by the hardware architectural structure and result in the loss of more than one echelon of defense-in-depth provided by the I&C system. The two principal factors for defense against CMFs are quality and diversity. The Commission position on defense-in-depth and diversity for ALWRs, as discussed in the dated July 21, 1993, SRM in response to SECY-93-087, is as follows:

(1) The vendor or applicant shall assess the defense-in-depth and diversity of the proposed instrumentation and control system to demonstrate that vulnerabilities to CMFs have been adequately addressed.

(2) In performing the assessment, the vendor or applicant shall analyze each postulated event that is in the accident analysis section of the SAR using best-estimate methods. The vendor or applicant shall demonstrate adequate diversity within the design for each of these events.

(3) If a postulated CMF could disable a safety function, then a diverse means, with a documented basis that the diverse means is unlikely to be subject to the same CMF, shall be required to perform either the same function or a different function. The diverse or different function may be performed by a non-safety system if the system is of sufficient quality to perform the necessary function under the associated event conditions.

(4) A set of displays and controls located in the main control room (MCR) shall be provided for system-level actuation and control of critical safety functions. The displays and controls shall be independent and diverse from the safety computer system identified in items 1 and 3.

Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(3) of this appendix.

Comment Summary. NEI commented that the terms "adequate defense" and "critical safety functions" are vague and subject to numerous interpretations.

Response. The Commission does not agree with NEI's comment. The terms are widely used in industry standards and the Commission has clearly found the design acceptable as it is.

Alternate Offsite Power Source to Non-Safety Equipment

Section 5(c)(4) imposes a requirement on the designer to include a second offsite power source and to ensure that it has sufficient capacity and capability to provide power to non-safety equipment sufficient to provide the operator with the capability to bring the plant to a safe shutdown, following a loss of the normal power supply and plant trip. The second offsite power source will significantly reduce the number of plant trips that involve a loss of power to the non-safety loads and require that the plant be shut down under natural circulation. Such an additional source of power would improve plant safety, because these events continue to be identified as more severe than the turbine-trip-only event in standard plant safety analysis reports.

The requirement for alternate sources of power for non-safety-related loads arose from an NRC policy issue. In SECY-91-078, the staff recommended that the Commission approve the staff's position that an evolutionary plant design should include an alternate power source to the non-safety-related loads, unless it can be demonstrated that the design margins are so great that transients resulting from a loss of non-safety power event are no more severe than those associated with the turbine-trip-only event in current existing plant designs. In its August 15, 1991 SRM, the Commission approved the staff's position. The staff, in its safety evaluation report (SER) for the EPRI Evolutionary Utility Requirements Document (URD) clarified the intent of this position by stating that: "...an alternate power source be provided to a sufficient string of non-safety loads so that forced circulation could be maintained, and the operator would have available to him the complement of non-safety equipment that would most facilitate his ability to bring the plant to a stable shutdown condition, following a loss of the normal power supply and plant trip." The staff believes that this issue provides defense-in-depth. Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(4) of this appendix.

Comment Summary. NEI commented that the terms "most facilitate" and "necessary complement of non-safety equipment" are vague and subject to numerous interpretations.

Response. The Commission has decided to modify the words to more specifically define the non-safety equipment required.

Offsite Power Source to Safety Divisions

Section 5(c)(5) imposes a requirement on the designer to ensure that faults from non-safety loads will not effect safety buses. Powering safety buses directly from an offsite power source is an NRC policy issue. The issue was raised by the staff because feeding safety buses from the offsite power sources through non-safety buses is not the most reliable configuration. In this configuration, the safety loads are subjected to transients caused by the non-Class 1E loads and add additional failure points between the offsite power sources and safety loads. To overcome these shortcomings, the staff recommended energizing the safety buses directly from the offsite power source's transformers.

In its August 15, 1991, SRM, on SECY-91-078, the Commission approved the position that an evolutionary plant design should include at least one offsite circuit to each redundant safety division supplied directly from one of the offsite power sources with no intervening non-safety buses in such a manner that the offsite source can power the safety buses upon a failure of any non-safety bus. Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(5) of this appendix.

Comment Summary. NEI commented that although the staff found the designs acceptable, it is possible that in the future members of the NRC staff could determine that the designs do not satisfy the literal language of the NRC's proposed applicable regulation.

Response. The Commission has decided to modify the words to clarify design requirements for the offsite circuit to more clearly reflect the original intent.

Post-Fire Safe Shutdown

Section 5(c)(6) imposes a requirement on the designer to ensure that, among other things, the plant can be shutdown safely after a fire that renders all equipment in any one fire area inoperable.

As background information, the NRC established fire protection requirements for nuclear power plants in GDC 3, 10 CFR 50.48, and Appendix R to 10 CFR Part 50. The Commission considered Sections III.G, III.J, and III.O, and Appendix R to be of particular importance. In July 1981, NRC revised BTP APCS 9.5-1 (SRP Section 9.5.1) to include these provisions from Appendix R.

The Commission has also issued supplemental guidance on fire protection in documents such as Generic Letter (GL) 81-12 (45 FR 76602, November 19, 1981), dated February 20, 1981, and GL 86-10, dated April 24, 1986. GL 81-12 presents information on safe-shutdown methodology and GL 86-10 presents technical information on conformance with National Fire Protection Association codes and standards.

The Commission has concluded that fire protection issues raised through operating experience and through the External Events Program must be resolved for evolutionary ALWRs. To minimize fire as a significant contributor to the likelihood of severe accidents for advanced plants, the Commission concluded that current NRC guidance must be enhanced. The enhanced guidelines are discussed in SECY-90-016, "Evolutionary Light Water Reactor (LWR) Certification Issues and Their Relationship to Current Regulatory Requirements," dated January 12, 1990 and in SECY-93-087, "Policy, Technical, and Licensing Issues Pertaining to Evolutionary and Advanced Light Water Reactor (ALWR) Designs".

The Commission expects any new reactor design to propose fire protection systems based on the best technology available, not on the methods allowed for plants already operating or in the advanced stages of design and construction. Specifically, the Commission expects that the new designs will have improved separation of fire areas and that physical separation within an area will not generally be relied on. Therefore, the Commission evaluated the fire protection system of the standard designs against the new criteria of SRP Section 9.5.1 (BTP CMEB 9.5-1 Rev. 2), which meets the requirements of GDC 3.

Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(6) of this appendix.

Comment Summary NEI raised the following objections to the proposed wording:

- The reference in paragraph (i) to 10 CFR 50.48 is unnecessary. Section 50.48 is already applicable to plants that reference the ABWR or System 80+ through Section 52.83. Therefore, this reference is redundant and confusing.
- The reference to structures, systems and components "important to safety" in paragraphs (i) and (ii) is inappropriate and incorrect. Part 50, Appendix R, Section III.G.1.a, applies to structures, systems, and components "important to safe shutdown." Furthermore, this applicable regulation does not reflect the language in SECY-90-016, as approved by the Commission in the SRM dated June 26, 1990, which refers to "safe shutdown", not "important to safety" or "safety-related".

- The proposed "applicable regulation" contained in the ABWR FSER, p. 9-57, and in the System 80+ FSER, p. 9-57, recognized that because of "unique design layout", areas other than the containment and control room might be accepted on an individual basis. This provision was deleted in the proposed rule. As discussed on pages 9-59 to 9-61 of the ABWR FSER, the ABWR has certain exceptions to the general provision on separation (e.g., in the main steam tunnel), and the NRC has found this to be acceptable. Without the allowance for "unique design layout," the currently-approved ABWR design might be found to be inconsistent with the "applicable regulation" on fire protection.

- System 80+ does not have 3-hour fire barrier separation between redundant shutdown equipment inside the annulus, as discussed on pg. 9-61 of the FSER. The staff concluded that the design is acceptable, however, because sufficient separation between redundant equipment exists in the annulus. Although protection is provided by separation in the annulus, deletion of the allowance for ". . . unique design layout. . ." for areas other than the containment and control room could allow the adequacy of the separation provisions in the annulus to be challenged.

- Furthermore, because the allowance for "unique design layout" was in SECY-90-016, as approved by the Commission in the SRM dated June 26, 1990, the "applicable regulation" is inconsistent with the Commission's previous directions.

- The term "to the extent practical" is vague and subject to numerous interpretations. Additionally, as the state-of-the-art evolves, what is "practical" will evolve, resulting in the potential for destabilizing backfits to the standard design.

Response The Commission has decided to modify the wording. Paragraph (i) of the regulation has been deleted in response to the first comment. The references to SSCs that are "important to safety" have been changed to "important to safe shutdown" in response to the second comment. The exception for the containment annulus was added to address the third and fifth comments. Finally, the term "to the extent practical" was modified to reflect that the Commission intends to define practicality as the capabilities and means available at the time of design certification.

Analysis of External Events

Section 5(c)(7) imposes a requirement on the designer to include both internal and external events in the design-specific probabilistic risk assessment. In its July 21, 1993 SRM on SECY-93-087, the Commission approved several positions related to this topic including: (1) the requirement that the analyses submitted in accordance with 10 CFR 52.47 include an assessment of internal events; (2) the use of 1.67 times the design basis safe shutdown earthquake for a margin-type assessment of seismic events; and (3) the requirement that the ALWR vendors should perform bounding analyses of site-specific external events likely to be a challenge to the plant. In Generic Letter 88-20, "Individual Plant Examinations for Severe Accident Vulnerabilities - 10 CFR 50.54(f)" and its supplements, the NRC staff stated that construction permit holders and power reactor licensees should consider the safety implications of both internal and external events. Such consideration should involve performing separate individual plant examinations

(IPEs) and individual plant examinations for external events. PRAs and IPEs that have evaluated both internal and external events generally estimate the risks from external events to be the same order of magnitude as internal events. Therefore, the Commission concluded that the design-specific PRAs required in 10 CFR 52.47 should include an assessment of both internal and external events.

Lessons from past risk-based studies indicate that fire, internal floods, and seismic events can be important potential contributors to core damage. However, the estimates of the core damage frequencies for fire and seismic events continue to include considerable uncertainty. Consequently, the Commission concluded that fire and seismic events can be evaluated using simplified (bounding) probabilistic methods and margin methods similar to those developed for existing plants, supported by insights from internal event PRAs, including ALWR design-specific PRAs.

The Commission determined that the plant designer can best determine the seismic capability of the plant through a combined approach that takes advantage of the strengths of both PRA and margins methods. This approach (based on an internal events PRA, its existing event and fault trees, and its random failures and human errors) allows for a comprehensive and integrated treatment of the plant's response to an earthquake. This approach should yield meaningful measures of a proposed design's seismic capability.

The major difference between a seismic PRA and the proposed PRA-based margins approach is that the latter does not combine fragility curves with hazard curves. Rather, the PRA-based margins approach measures the robustness of the plant to withstand earthquakes of a given ground acceleration level. This method eliminates the need to deal with uncertainty in the seismic hazard curve for the site and identifies potential design-specific seismic vulnerabilities. Understanding these vulnerabilities may be useful in developing the reliability assurance programs, identifying operator training requirements, and focus on accident management capabilities.

The Commission believes that it is important to fully understand potentially significant seismic vulnerabilities and other seismic insights. The Commission concluded that this information would be captured by a PRA-based seismic margins analysis that considers sequence-level high confidence in low probability of failure (HCLPF) values and fragilities for all sequences leading to core damage or containment failures up to approximately one and two-thirds of the SSE.

Based on the FSER, the Commission concludes that the design-specific PRA submitted by ABB-CE satisfies Section 5(c)(7) of this appendix.

Comment Summary. There were no technical comments on this applicable regulation.

Alternate AC Power Source

Section 5(c)(8) imposes a requirement on the designer to include an on-site alternate AC power source in the design to deal with station blackout conditions. As background information, the staff developed a policy issue in SECY-90-016, dated January 12, 1990, that was approved by the Commission on June 26, 1990, which requires that the evolutionary ALWRs meet the requirements of the station blackout (SBO) rule by including an alternate AC power source (e.g., CTG) of diverse design capable of powering at least one

complete set of normal shutdown loads and to back up the EDGs. The Commission's policy is that a coping analysis or a less capable alternate AC source would not be acceptable because the CTG provides the operator with power to more equipment to cope with the event, and does not require complicated operator actions to shed loads. Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(8) of this appendix.

Comment Summary. NEI commented that the NRC staff's language does not reflect the specifics of each of the standard designs. Moreover NEI stated that, as written, the "applicable regulation" appears to conflict with the regulation that already governs use of an alternate AC power source, § 50.63.

Response. The Commission did not necessarily intend that the language for each regulation be different for each design. The staff clearly stated the requirement that the designs were evaluated against. This requirement is meant to be more restrictive than 50.63 in that an alternate AC source that is fully capable of powering at least one complete set of equipment necessary to achieve and maintain safe-shutdown is the required approach.

Core Debris Cooling

Section 5(c)(9) imposes requirements on the designer to include features to enhance core debris cooling in the design. As background information, core debris coolability and quenchability have been the subject of extensive research over the past decade; however, much uncertainty still exists relative to this phenomenon which will most likely not be resolved in the near future. Because of this uncertainty, the Commission decided that the question is not whether coolability or quenchability has been achieved or can be achieved; but rather, what is the impact on the containment design if they are not achieved.

Corium-concrete interaction (CCI) is a severe-accident phenomenon that involves the melting and decomposition of concrete in contact with molten core debris. This phenomenon may occur following accident sequences which result in molten core debris breaching the reactor vessel and spreading onto the floor of the reactor cavity. The thickness of the layer of core debris within the reactor cavity depends upon the amount of core debris, its spreadability, and the area of the reactor cavity floor. Once on the reactor cavity floor, the molten core debris may react with the concrete and any available water producing non-condensable gases, water vapor, and heat from exothermic reactions.

CCI can challenge the containment by various mechanisms including: pressurization from non-condensable gas and steam generated, destruction of structural support members, and melt-through of the containment liner. Non-condensable gases, primarily carbon dioxide, carbon monoxide, and hydrogen, are released from the concrete as it decomposes and are formed from reactions between water and metals within the molten core debris. The core debris and concrete are heated from the combined effects of decay heat and exothermic chemical reactions.

In its July 21, 1993, SRM on SECY-93-087, the Commission approved the position that both the evolutionary and passive LWR designs meet the following criteria: (1) provide reactor cavity floor space to enhance debris spreading; (2) provide a means to flood the reactor cavity to assist in the cooling process; (3) protect the containment liner and other structural members with concrete if necessary; and (4) ensure that the best-estimate environmental

conditions (pressure and temperature) resulting from core-concrete interactions do not exceed ASME Code Service Level C limits for steel containments or factored load category for concrete containments, for approximately 24 hours. In addition, ensure that the containment capability has margin to accommodate uncertainties in the environmental conditions from CCIs.

Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(9) of this appendix.

Comment Summary. NEI raised the following objections to the proposed wording:

- The terms "reduce the potential for," "enhance," "assist in the cooling process," and "most significant" are vague and subject to numerous interpretations.
- The term "structural members" lacks specificity.
- The term "best-estimate" is open-ended, and could lead to needless recalculations of "estimates" as the state-of-the-art evolves.

Response The Commission has decided to modify the wording. The specific severe accident sequences have been identified instead of using the term "most significant." The size of the reactor cavity floor space and the actual structural members of concern have also been identified. To address the comment on the term "best estimate," the section of the DCD that defines the environmental conditions is now cited.

High Pressure Core Melt Ejection

Section 5(c)(10) imposes a requirement on the designer to include a means to depressurize the reactor coolant system and cavity design features to mitigate the effects of a high pressure core melt ejection accident. As background information, in its June 26, 1990, SRM on SECY-90-016, the Commission approved the position that evolutionary LWR designs should have a depressurization system and cavity design features to contain ejected core debris. In addition, the Commission stated that the cavity design, as a mitigating feature, should not unduly interfere with such operations as refueling, maintenance, or surveillance.

In its July 21, 1993, SRM on SECY-93-087, the Commission modified its position slightly and approved the general criteria that the evolutionary LWR designs should have a reliable depressurization system and cavity design features to decrease the amount of ejected core debris that reaches the upper containment.

On the basis of engineering judgment, the Commission believes that examples of cavity design features that will decrease the amount of ejected core debris reaching the upper containment are ledges or walls that would deflect core debris and a tortuous path from the reactor cavity to the upper containment.

Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(10) of this appendix.

Comment Summary. NEI commented that the terms "reliable means" and "reduce the amount" are vague and subject to numerous interpretations. NEI also stated that what is considered "reliable" may change as the state-of-the-

art changes, leading to the potential for destabilizing backfits to the standard designs.

Response. The Commission has decided to modify the wording to allow for a safety-related depressurization system for this application. The Commission did not remove the phrase "reduce the amount" because it believes that it is the most appropriate wording based on the engineering judgement involved in the review.

Equipment Survivability

Section 5(c)(11) imposes a requirement on the designer to perform analyses to demonstrate that certain equipment and instrumentation can function under severe accident environmental conditions. As background information, in its SRM of July 21, 1983, on SECY-93-087, the Commission approved the position that for the review of the credible severe-accident scenarios for ALWRs, the Commission will evaluate the design certification applicant's identification of the equipment needed to perform mitigative functions as well as the conditions under which the mitigative systems must operate.

Beyond design basis events can generally be categorized into in-vessel and ex-vessel severe accidents. The environmental conditions resulting from these events are generally more limiting than those from design bases events. The Commission established a criterion to provide a reasonable level of confidence that the necessary equipment will function in the severe accident environment for the time span for which it is needed. This criterion is commonly referred to as "equipment survivability" and is fundamentally different from equipment qualification.

The applicable criteria for mechanical and electrical equipment and instrumentation required for recovery from in-vessel severe accidents are provided in 10 CFR 50.34(f).

- Part 50.34(f)(2)(ix)(c) states that equipment necessary for achieving and maintaining safe shutdown of the plant and maintaining containment integrity will perform its safety function during and after being exposed to the environmental conditions attendant with the release of hydrogen generated by the equivalent of a 100 percent fuel-clad metal-water reaction including the environmental conditions created by activation of the hydrogen control system.

- Part 50.34(f)(3)(v) states that systems necessary to ensure containment integrity shall be demonstrated to perform their function under conditions associated with an accident that releases hydrogen generated from 100 percent fuel-clad metal-water reaction.

- Part 50.34(f)(2)(xvii) requires instrumentation to measure containment pressure, containment water level, containment hydrogen concentration, containment radiation intensity, and noble gas effluents at all potential accident release points.

- Part 50.34(f)(2)(xix) requires instrumentation adequate for monitoring plant conditions following an accident that includes core damage.

The applicable criteria for mechanical and electrical equipment required to mitigate the consequences of ex-vessel severe accidents are discussed in the Equipment Survivability section of SECY-90-016. In its SRM of June 26, 1990, relating to SECY-90-016, the Commission approved the position that

features provided only for severe-accident protection, prevention and mitigation (i.e. not required for design basis accidents) need not be subject to the 10 CFR 50.49 environmental qualification requirements; 10 CFR Part 50, Appendix B quality assurance requirements; and 10 CFR Part 50, Appendix A redundancy/diversity requirements. The reason for this judgement is that the Commission believes that severe core damage accidents should not be treated as design basis accidents (DBAs).

However, mitigation features must be designed to provide reasonable assurance that they will operate in the severe-accident environment for which they are intended and over the time span for which they are needed. In cases where safety-related equipment (equipment provided for DBAs) is relied upon to cope with severe accident situations, there should be reasonable assurance that this equipment will survive accident conditions for the period that is needed to perform its intended function.

Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(11) of this appendix.

Comment Summary. NEI raised the following objections to the proposed wording:

- The term "needed" is inappropriate because severe accident features are not "needed" to satisfy NRC regulations or assure the adequate protection of public health and safety.

- Further, the term "best available" and "best-estimate" are open-ended, and could lead to needless re-evaluations and the potential for backfits as the state-of-the-art evolves. Such a result is very likely to occur, because research regarding the effects of severe accidents is still in its infancy, and knowledge of severe accident phenomena is rapidly increasing. Additionally, requirements for use of the "best-available" method and "best-estimates" deviate from the provision in SECY-90-16 that was approved by the Commission in the SRM dated June 26, 1990, which only required "reasonable assurance" of equipment survivability.

Response. The Commission has decided to modify the words in response to these comments. The analytical techniques available at the time of the design certification were deemed to be acceptable and the specific environmental conditions were referenced.

Containment Performance

Section 5(c)(12) imposes a requirement on the designer to include features intended to limit the conditional containment failure probability. As background information, the Commission's approach for ensuring containment survivability from severe accident challenges consists of requiring inclusion of accident prevention and consequence mitigation features and the containment performance goal (CPG). The CPG ensures that the containment would perform its function in the face of most severe-accident challenges and that the design (including its mitigation features) would be adequate if called upon to mitigate a severe accident.

Two alternative CPGs were identified in SECY-90-016: a conditional containment failure probability (CCFP) of 0.1 or a deterministic CPG that offers comparable protection. In its June 26, 1990, SRM, the Commission approved the use of the 0.1 CCFP as a basis for establishing regulatory

guidance for evolutionary ALWRs. In assessing the probability of containment failure, two definitions of containment failure were considered. These include a CCFP based on structural integrity and on a dose definition. The Commission also directed that the use of a 0.1 CCFP should not be imposed as a requirement, and that the use of the CCFP should not discourage accident prevention.

The FSER contains the staff's analysis of the design features that contribute to limiting the CCFP and their evaluation of the severe accident phenomena that are mitigated by these design features. Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(12) of this appendix.

Comment Summary. NEI commented that the terms "limit" and "more likely" are vague and subject to numerous interpretations.

Response. The Commission has decided to modify the wording. The new regulation defines the CCFP limit as 0.1 and identifies the DCD section which lists the severe accident sequences that are subject to this requirement.

Shutdown Risk

Section 5(c)(13) imposes a requirement on the designer to perform specific assessments of the design with regard to shutdown risk. As background information, various incidents occurring at nuclear power plants during low power and shutdown operation modes over the past several years have raised Commission concerns regarding plant vulnerability during these operating modes. The Commission conducted a comprehensive review of low-power and shutdown operations including hot shutdown, cold shutdown, and refueling at all nuclear plants and other shutdown-related issues identified by foreign regulatory organizations and the NRC. The findings of the review were published in NUREG-1449, "Shutdown and Low Power Operation at Commercial Nuclear Power Plants in the United States."

In SECY-90-016, the Commission identified reduced inventory operation as a significant safety issue. In SECY-93-190, "Regulatory Approach to Shutdown and Low-Power Operations," the Commission discussed the advantages and disadvantages of a proposed rulemaking to establish new regulatory requirements for shutdown and low-power operations in the following areas: outage planning and control, technical specifications, fire protection, and instrumentation.

Based on the above, the Commission required that the designer perform a systematic examination of shutdown risk, including evaluation of specific design features that minimize shutdown risk, quantification of the reliability of the decay heat removal systems, identification of any vulnerabilities introduced by new design features and consideration of fires and floods with the plant in modes other than full power.

The Commission reviewed the applicant's submittals and found that the PRA shutdown risk evaluation was acceptable. Further, the Commission concluded that the designer adequately addressed the shutdown risk concerns in NUREG-1449 and has demonstrated that the design will not introduce significant risk during shutdown operations. Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(13) of this appendix.

Comment Summary. NEI raised the following objections to the proposed wording:

- The terms "systematic," "minimize," "new design features," and "modes other than full power" are vague and subject to numerous interpretations.
- Paragraph (ii) relates to the COL applicant, not the standard design. It is not appropriate as an "applicable regulation" for the standard design. If the NRC believes that the requirements in this paragraph should be imposed on applicants and licensees, it should initiate a rulemaking to amend Part 50 to do so.
- In this regard, NRC has already initiated a rulemaking proceeding to amend Part 50 to include requirements related to shutdown conditions. (See 59 Fed. Reg. 52707 (October 19, 1994).) The NRC should not pre-empt or prejudice the results of that rulemaking by imposing an "applicable regulation" on shutdown conditions.

Response. The Commission has decided to modify the wording. In response to the first comment, the wording has been made more specific where possible. In response to the second and third comments regarding the appropriateness of addressing applicant/licensee issues in the design certification rulemaking, the Commission has reconsidered its position and moved these issues to Section 4 of this appendix which sets forth requirements for applicants and licensees referencing this design certification rule. While the Commission has initiated a rulemaking proceeding to amend Part 50 to include requirements related to shutdown conditions, the Commission believes it is better to consolidate the design certification-specific technical requirements which are applicable to plants referencing this design certification rule in the design certification rule itself.

Steam Generator Tube Ruptures

Section 5(c)(14) imposes a requirement on the designer to perform a systematic evaluation of plant response to a steam generator tube rupture (SGTR). As background information, during a steam generator tube rupture event, the potential exists for lifting of SG safety or relief valves and discharging primary system radioactive inventory outside the containment. Such a containment bypass is undesirable for either a design-basis event or a postulated severe accident. Consequently, the Commission believes that possible mitigation of this containment challenge should be considered.

In its June 26, 1990, SRM on SECY-90-016, the Commission required designers of ALWRs to reduce the potential for conditional containment failure through use of quantitative guidelines or alternative deterministic objectives. In addition, with respect to design-basis events, in the URD, EPRI states that PWR containments should be designed to produce a leak-tight barrier to prevent uncontrolled release of radioactivity in the event of a postulated accident. Containment bypass due to SG tube ruptures would potentially violate containment integrity and hamper meeting both the severe-accident (SECY-90-016) and EPRI containment performance goals.

In its July 21, 1993, SRM on SECY-93-087, the Commission decided that evolutionary PWR designers should consider potential design features that would reduce the amount of containment bypass leakage from such a scenario. The three design features presented were:

- incorporating a highly reliable (closed-loop) SG, shell-side, heat removal system that relies on natural circulation and stored water sources
- piping some SG relief valve discharge back into the primary containment

- increasing the SG shell-side pressure capacity with a corresponding increase in the safety valve setpoints

ABB-CE performed a study to evaluate certain automatic design features that can be used to enable the plant to mitigate SGTR consequences. Sections 3 and 4 of DCD Appendix 5F describe these analyses and provide an evaluation of the attendant benefits and limitations of each of these automatic design features. The realistic analyses were performed for a five-tube rupture case and a single-tube rupture case. ABB-CE assessed the three design alternatives identified in SECY-93-087 in a report dated September 23, 1993 and titled, "Design Alternatives for the System 80+ Nuclear Power Plant," and found these alternatives to be cost prohibitive.

As a result of these analyses, some features have been added to the System 80+ design to reduce the potential containment bypass leakage from the SGTR events. These features include: (1) a design modification to the component cooling water system (CCWS) to ensure continued cooling of the instrument air compressors after a safety injection actuation signal (SIAS), (2) addition of two nitrogen-16 (N-16) radiation monitors (one per SG) in the steamlines, (3) implementation of technical specifications and ITAACs related to N-16 monitors, and (4) emergency operations guidelines (EOGs) improvements. The Commission has determined that this issue has been properly addressed with these enhancements. In arriving at this conclusion, the Commission considered whether the System 80+ design provides sufficient time, diagnostic information, mitigation capability, and proper EOGs for operator coping actions following an SGTR event to mitigate the consequence. Based on the FSER, the Commission concludes that the design satisfies Section 5(c)(14) of this appendix.

Comment Summary. NEI commented that the phrases "best-estimate, systematic evaluation" and "mitigate the amount of" are vague and subject to various interpretations. In addition, what constitutes a best-estimate evaluation is likely to change as evaluation methods evolve. It is also noted that this applicable regulation as stated in the FSER requires evaluation of potential design improvements "which are significant and practical and do not impact excessively on the plant." That phrase does not appear in the applicable regulation as stated in the proposed rules, thereby making the scope of the existing evaluation more vulnerable to challenge. For these reasons, this applicable regulation is destabilizing and contrary to the intent of design certification.

Response. The Commission has decided to modify the words to address NEI's comments and make it consistent with the statements in the FSER.

B. Responses to specific requests for comment.

Only two commenters addressed the specific requests for comments that were set forth in section IV of the proposed rule. These commenters were NEI and the Ohio Citizens for Responsible Energy, Inc. (OCRE). The following discussion provides a summary of the comments and the Commission's response to each of the specific requests.

1. Should the requirements of 10 CFR 52.63(c) be added to a new 10 CFR 52.79(e)?

Comment Summary. OCRE agreed that the requirements of 10 CFR 52.63(c) should be added to a new 10 CFR 52.79(e) and NEI had no objection, as long as the substantive requirements in § 52.63(c) were not changed.

Response. Because there is no objection to adding the requirements of 10 CFR 52.63(c) to Subpart C of Part 52, as 10 CFR 52.79(e), the Commission will consider this amendment as part of a future review of Part 52. This future review will also consider lessons learned from this rulemaking and will determine if 10 CFR 52.63(c) should be deleted from Subpart B of Part 52.

2. Are there other words or phrases that should be defined in Section 2 of the proposed rule?

Comment Summary. Neither NEI nor OCRE suggested other words or phrases that need to be added to the definition section. However, NEI recommended expanded definitions for specific terms in Section 2 of the proposed rule.

Response. The Commission has revised Section 2 of this appendix as a result of comments from NEI and DOE. A discussion of these changes is provided in section II.C.2 and II.C.3.

3. What change process should apply to design-related information developed by a combined license (COL) applicant or holder that references this design certification rule?

Comment Summary. OCRE recommended the change process in Section 8(b)(5)(i) of the proposed rule and stated that it is essential that any design-related COL information including the plant-specific PRA (and changes thereto) developed by the COL applicant or holder not have issue preclusion and be subject to litigation in any COL hearing. NEI recommended that the COL information be controlled by 10 CFR 50.54 and 50.59 but recognized that the COL applicant or holder must also consider impacts on Tier 1 and Tier 2 information.

Response. The Commission will develop a change process for the plant-specific information submitted in a COL application that references this design certification as part of a future review of Part 52. The Commission expects that the change process for the plant-specific portion of the COL application will be similar to Section 8(b)(5). This approach is generally consistent with the recommendations of OCRE and NEI.

The Commission agrees with OCRE that the plant-specific portion of the COL application will not have issue preclusion in the COL proceeding. A discussion of the information that will have issue preclusion is provided in section II.A.1.

4. Are each of the applicable regulations set forth in Section 5(c) of the proposed rule justified?

Comment Summary. OCRE found each of the applicable regulations to be justified and stated that these requirements are responsive to issues arising from operating experience and will greatly reduce the risk of severe accidents for plants using these standard designs. NEI believes that none of the applicable regulations are justified and stated that they are legally and technically unnecessary, could give rise to unwarranted backfits, are destabilizing and, therefore, contrary to the purpose of 10 CFR Part 52.

Response. The Commission has determined that applicable regulations are necessary, as described in section II.A.3. The justification for the specific wording of each applicable regulation is described in section II.A.4

5. Section 8(b)(5)(i) authorizes an applicant or licensee who references the design certification to depart from Tier 2 information without prior NRC approval if the applicant or licensee makes a determination that the change does not involve a change to Tier 1 or Tier 2* information, as identified in the DCD; the technical specifications; or an unreviewed safety question, as defined in Sections 8(b)(5)(ii) and (iii). Where Section 8(b)(5)(i) states that a change made pursuant to that paragraph will no longer be considered as a matter resolved in connection with the issuance or renewal of a design certification within the meaning of 10 CFR 52.63(a)(4), should this mean that the determination may be challenged as not demonstrating that the change may be made without prior NRC approval or that the change itself may be challenged as not complying with the Commission's requirements?

Comment Summary. OCRE believes that the process for making plant-specific departures from Tier 2, as well as the substantive aspect of the change itself, should be open to challenge, although OCRE believes that the second aspect is the more important. By contrast, NEI argued that neither the departure process nor the change should be subject to litigation in any licensing hearing. Rather, NEI argued that any person who wished to challenge the change should raise the matter in a petition for an enforcement action under 10 CFR 2.206.

Response. The Commission has determined that an interested person should be provided the opportunity to challenge, in an appropriate licensing proceeding, whether the licensee properly complied with the Tier 2 departure process. Therefore, Section 8(b)(5) of this Appendix has been modified. The scope of finality for plant-specific departures is discussed in greater detail in section II.A.1 above.

6. How should the determinations made by an applicant or licensee that changes may be made under Section 8(b)(5)(i) without prior NRC approval be made available to the public in order for those determinations to be challenged or for the changes themselves to be challenged?

Comment Summary. OCRE recommends that the determinations and descriptions of the changes be set forth in the COL application and that they should be submitted to the NRC after COL issuance. Any person wishing to challenge the determinations or changes should file a petition pursuant to 10 CFR 2.206. NEI recommends submitting periodic reports that summarize departures made under Section 8(b)(5) to the NRC pursuant to Section 9(b) of the proposed design certification rules, consistent with the existing process for NRC notifications by licensees under 10 CFR 50.59. These reports will be available in the NRC's Public Document Room.

Response. The Tier 2 departure process in Section 8(b)(5) and the respective reporting requirements in Section 9(b) of the proposed design certification rule [Section 10(b) of this appendix] were based on 10 CFR 50.59. It therefore seems reasonable that the information collection and reporting requirements that should be used to control Tier 2 departures made in accordance with Section 8(b)(5) should generally follow the regulatory scheme in 10 CFR 50.59 (except that the requirements should also be applied to

COL applicants), absent countervailing considerations unique to the design certification and combined license regulatory scheme in Part 52. OCRE's proposal raises policy considerations which are not unique to this design certification, but are equally applicable to the Part 50 licensing scheme. In fact, OCRE has submitted a petition (see 59 FR 30308; June 13, 1994) which raises the generic matter of public access to licensee-held information. In view of the generic nature of OCRE's concern and the pendency of OCRE's petition, which independently raises this matter, the Commission concludes that this rulemaking should not address and resolve this matter.

7. What is the preferred regulatory process (including opportunities for public participation) for NRC review of proposed changes to Tier 2* information and the commenter's basis for recommending a particular process?

Comment Summary. OCRE recommends either an amendment to the license application or an amendment to the license, with the requisite hearing rights. NEI recommends NRC approval by letter with an opportunity for public hearing only for those Tier 2* changes that also involve either a change in Tier 1 or technical specifications, or an unreviewed safety question.

Response. The Commission has developed a change process for Tier 2* information, as described in sections II.A.2 and III.H, which essentially treats the proposed departure as a request for a license amendment with an opportunity for hearing. Since Tier 2* departures require NRC review and approval, and involve a licensee departing from the requirements of this appendix, the Commission regards such requests for departures as analogous to license amendments. Accordingly, Section 8(b)(6) specifies that such requests will be treated as requests for license amendments, and that the proposed Tier 2* departure shall not be considered to be matters resolved by this rulemaking.

8. Should determinations of whether proposed changes to severe accident issues constitute an unreviewed safety question use different criteria than for other safety issues resolved in the design certification review and, if so, what should those criteria be?

Comment Summary. OCRE supports the concept behind the criteria in the proposed rule for determining if a proposed change to severe accident issues constitutes an unreviewed safety question, but proposes changes to the criteria. NEI agrees with the criteria in the proposed rule but recommends an expansion of the scope of information that would come under the special criteria for determining an unreviewed safety question.

Response. The Commission disagrees with the recommendations of both NEI and OCRE. The Commission has decided to retain the special change process in Section 8(b)(5) of the proposed rule for severe accident information, as described in section II.A.2.

9. (a)(1) Should construction permit applicants under 10 CFR Part 50 be allowed to reference design certification rules to satisfy the relevant requirements of 10 CFR Part 50?

(2) What, if any, issue preclusion exists in a subsequent operating license stage and NRC enforcement, after the Commission authorizes a construction permit applicant to reference a design certification rule?

(3) Should construction permit applicants referencing a design certification rule be either permitted or required to reference the ITAAC? If so, what are the legal consequences, in terms of the scope of NRC review and approval and the scope of admissible contentions, at the subsequent operating license proceeding?

(4) What would distinguish the "old" 10 CFR Part 50 2-step process from the 10 CFR Part 52 combined license process if a construction permit applicant is permitted to reference a design certification rule and the final design and ITAAC are given full issue preclusion in the operating license proceeding? To the extent this circumstance approximates a combined license, without being one, is it inconsistent with Section 189(b) of the Atomic Energy Act (added by the Energy Policy Act of 1992) providing specifically for combined licenses?

(b)(1) Should operating license applicants under 10 CFR Part 50 be allowed to reference design certification rules to satisfy the relevant requirements of 10 CFR Part 50?

(2) What should be the legal consequences, from the standpoints of issue resolution in the operating license proceeding, NRC enforcement, and licensee operation if a design certification rule is referenced by an applicant for an operating license under 10 CFR Part 50?

(c) Is it necessary to resolve these issues as part of this design certification, or may resolution of these issues be deferred without adverse consequence (e.g., without foreclosing alternatives for future resolution).

Comment Summary. OCRE argued that a construction permit applicant should be allowed to reference design certifications and that the applicant be required to reference ITAAC because they are Tier 1. OCRE indicated that in a construction permit hearing, those issues representing a challenge to the design certification rule would be prohibited pursuant to 10 CFR 2.758. At the operating license stage, only an applicant whose construction permit referenced a design certification rule should be allowed to reference the design certification. In the operating license hearing, issues would be limited to whether the ITAAC have been met. Requiring a construction permit applicant to reference the ITAAC would not be the same as a combined license under Part 52, in OCRE's view, apparently because the specific hearing provisions of 10 CFR 52.103 would not be employed. Finally, OCRE argued that resolution of these issues could be safely deferred because the circumstances with which these issues attend are not likely to be faced.

NEI also argued that a construction permit applicant should be allowed to reference design certifications. However, NEI believed that the applicant should be permitted, but not required, to reference the ITAAC. If the applicant did not reference the ITAAC, then "construction-related issues" would be subject to both NRC review and an opportunity for hearing at the operating license stage in the same manner as construction-related issues in current Part 50 operating license proceedings. NEI reiterated its view that design certification issues should be considered resolved in all subsequent NRC proceedings. With respect to deferring a Commission decision on the matter, NEI suggested that these issues be resolved now because the industry wishes to "reinforce" the permissibility of using a design certification in a Part 50 proceeding. Further, NEI argues that deletion of all mention of construction permits and operating licenses in the design certification rule could be construed as indicating the Commission's desire to preclude a

construction permit or operating license applicant from referencing a design certification.

Response. Although Part 52 provides for referencing of design certification rules in Part 50 applications and licenses, the Commission wishes to reserve for future consideration whether a Part 50 applicant should be permitted to reference this design certification and, if so, should be permitted or required to reference the ITAAC. This decision is due to the manner in which ITAAC were developed for this appendix and recognition of the lack of experience with design certifications in combined licenses, in particular the implementation of ITAAC. Therefore, the Commission has decided to defer a decision on this matter. Section 4 of this Appendix contains an explicit reservation of this matter in order to avoid any uncertainty with respect to the Commission's intent.

C. Other Issues

1. NRC Verification of ITAAC Determinations.

Comment Summary. In Attachment B of its comments (pp. 58-66), NEI raised an industry concern regarding the matters to be considered by the NRC in verifying inspections, tests, analyses, and acceptance criteria (ITAAC) determinations pursuant to 10 CFR 52.99, specifically citing quality assurance and quality control (QA/QC) deficiencies. Although this issue was not specifically addressed in the proposed design certification rule, the following response is provided because of its importance relative to future considerations of the successful performance of ITAAC for a nuclear power facility.

Response. The NRC disagrees with any assertion that QA/QC deficiencies have no relevance to the NRC determination of whether ITAAC have been successfully completed. Simply confirming that an ITAAC had been performed in some manner and a result obtained apparently showing that the acceptance criteria had been met would not be sufficient to support a determination that the ITAAC had been successfully completed. The manner in which an ITAAC is performed can be relevant and material to the results of the ITAAC. For example, in conducting an ITAAC to verify a pump's flow rate, it is logical, even if not explicitly specified in the ITAAC, that the gauge used to verify the pump flow rate must be calibrated in accordance with relevant QA/QC requirements and that the test configuration is representative of the final as-built plant conditions (i.e. valve or system line-ups, gauge locations, system pressures or temperatures). Otherwise, the acceptance criteria for pump flow rate in the ITAAC could apparently be met while the actual flow rate in the system could be much less than that required by the approved design.

The NRC has determined that a QA/QC deficiency may be considered in determining whether an ITAAC has been successfully completed if: (1) the QA/QC deficiency is directly and materially related to one or more aspects of the relevant ITAAC (or supporting Tier 2 information); and (2) the deficiency (considered by itself, with other deficiencies, or with other information known to the NRC) leads the NRC to question whether there is a reasonable basis for concluding that the relevant aspect of the ITAAC has been successfully completed. This approach is consistent with the NRC's current methods for verifying initial test programs. The NRC recognizes that there may be programmatic QA/QC deficiencies that are not relevant to one or more aspects

of a given ITAAC under review and, therefore, should not be relevant to or considered in the NRC's determination as to whether an ITAAC has been successfully completed. Similarly, individual QA/QC deficiencies unrelated to an aspect of the ITAAC in question would not form the basis for an NRC determination that an ITAAC has not been met. Using the ITAAC for pump flow rate example, a specific QA deficiency in the calibration of pump gauges would not preclude an NRC determination of successful ITAAC completion if the licensee could demonstrate that the original deficiency was properly corrected (e.g., analysis, scope of effect, root cause determination, and corrective actions as appropriate), or that the deficiency could not have materially affected the test in question.

Furthermore, although the Tier 1 information was developed to focus on the performance of the structures, systems, and components of the design, the information contains implicit quality standards. For example, the design descriptions for reactor and fluid systems describe which systems are "safety-related"; important piping systems are classified as "Seismic Category I" and identify the ASME Code Class; and important electrical and instrumentation and control systems are classified as "Class 1E". The use of these terms by the evolutionary plant designers was meant to ensure that the systems would be built and maintained to the appropriate standards. Quality assurance deficiencies for these systems would be assessed for their impact on the performance of the ITAAC, based on their safety significance to the system. The QA requirements of 10 CFR Part 50, Appendix B, apply to safety-related activities. Therefore, the Commission anticipates that, because of the special significance of ITAAC related to verification of the facility, the licensee will implement similar QA processes for ITAAC activities that are not safety-related.

During the ITAAC development, the design certification applicants determined that it was impossible (or extremely burdensome) to provide all details relevant to verifying all aspects of ITAAC (e.g., QA/QC) in Tier 1 or Tier 2. Therefore, the NRC staff accepted the applicants' proposal that top-level design information be stated in the ITAAC to ensure that it was verified, with an emphasis on verification of the design and construction details in the "as-built" facility. To argue that consideration of underlying information which is relevant and material to determining whether ITAAC have been successfully completed ignores the history of ITAAC development. In summary, the Commission concludes that information such as QA/QC deficiencies which are relevant and material to ITAAC may be considered by the NRC in determining whether the ITAAC have been successfully completed. Despite this conclusion, the Commission has decided to add a provision to Section 9(b) of this appendix, which was requested by NEI. This provision requires the NRC's findings that the prescribed acceptance criteria have been met to be based solely on the inspections, tests, and analyses. The Commission has added this provision, which is fully consistent with 10 CFR Part 52, with the understanding that it does not affect the manner in which the NRC intends to implement 10 CFR 52.99 and 52.103(g), as described above.

Licensee Documentation of ITAAC Verification

A related concern was raised by Mr. R. P. McDonald of the Advanced Reactor Corporation at the public meeting on December 4, 1995, regarding the type and quantity of information that must be submitted by a licensee to

certify that an ITAAC has been successfully completed. While this issue also was not addressed in the proposed rule, this response is provided because of its importance to the industry regarding the performance of ITAAC. This response represents current NRC thinking on this subject and is not part of the Commission's binding determination in this rulemaking.

The documentation requirements for a facility that is licensed under 10 CFR Part 52 are similar to the documentation requirements under Part 50. The difference is that under Part 52 the documentation should be formatted to demonstrate the bases for completion of ITAAC. In general, sufficient information must be submitted to the NRC to adequately document the bases for the conclusion that the ITAAC have been successfully performed and the acceptance criteria have been met. However, this information is expected to be summarized because the NRC does not intend that all the details of the inspections, tests, and analyses related to a specific ITAAC must be submitted.

The licensee should certify to the NRC that an ITAAC has been successfully completed and that the acceptance criteria have been met. The certification letter should identify the specific ITAAC(s) that have been completed; it should identify, in summary form, the bases for the conclusion that the ITAAC have been met; and it should identify the location of any supporting documentation that is available for audit. The supporting documentation may include items such as test reports, engineering analyses, calculations, drawings, vendor component tests, inspections, quality assurance records, and other facility records. NEI provided a preliminary conceptual example of this type of letter in a meeting with the NRC staff on March 15, 1995, as documented in a meeting summary dated April 7, 1995. However, the specific bases for satisfaction of any particular ITAAC must be established by each licensee.

The design descriptions and functional system drawings available for review during the design certification and COL application stages were sufficient to perform licensing reviews and make final safety determinations but are not adequate for actual construction or construction inspection activities. Therefore, before construction begins on any given portion of the facility, the licensee must ensure that the certified design plus site-specific design information in the COL application, including that required by the design acceptance criteria (DAC), has been translated into detailed, plant-specific, design and construction drawings. The level of detail in the certified design and the use of DAC allow for some variation in implementing the certified design. The applicant or licensee also has some flexibility in completing the final design for Tier 2 design information, by means of the Tier 2 change process. The ITAAC will verify that the as-built facility will operate in accordance with the approved design and applicable regulations. Therefore, the licensee should ensure that the drawings and other documentation reflect the final as-built configuration of the facility so that they can be used as part of the bases, where appropriate, for completion of the ITAAC.

NRC Inspection

The licensee bears the responsibility for performing ITAAC. The NRC must verify through its inspection program that the ITAAC have been performed by the licensee in an acceptable manner, thereby ensuring there is reasonable

assurance that the facility has been built and will operate in accordance with the license and applicable regulations. SECY-94-294, "Construction Inspection and ITAAC Verification," discussed the development of a construction inspection program to accommodate the requirements of future reactors licensed under Part 52 and to incorporate lessons learned from experience with the current construction inspection program. One of the objectives of this inspection program will be to inspect the licensee's process for performing ITAAC and to inspect the licensee's program for ensuring ITAAC requirements are met. This could include the results of the pre-operational test program, quality assurance program, and various facility construction programs. The NRC expects that there will be increased interaction between the licensee and the NRC throughout the facility construction stage.

Facility ITAAC Verification

The NRC must find that all acceptance criteria specified in the license are met before facility operation. Because ITAAC are the sole source of acceptance criteria, the COL for a facility must include, all those implementation issues sufficiently important to require satisfactory resolution before fuel loading. Thus, the COL ITAAC include the ITAAC in the DCD for a referenced design plus plant-specific ITAAC derived from the COL proceeding. Plant-specific ITAAC comprise ITAAC associated with site-specific design information and other significant issues submitted by the COL applicant, as approved by the NRC staff.

2. DCD Introduction.

Comment Summary. The proposed rule incorporated Tier 1 and Tier 2 information into the DCD but did not include the introduction to the DCD. The SOC for the proposed rule (60 FR 17924) indicated that this was a deliberate decision, stating:

The introduction to the DCD is neither Tier 1 nor Tier 2 information, and is not part of the information in the DCD that is incorporated by reference into this design certification rule. Rather, the DCD introduction constitutes an explanation of requirements and other provisions of this design certification rule. If there is a conflict between the explanations in the DCD introduction and the explanations of this design certification rule in these statements of consideration (SOC), then this SOC is controlling.

Both the applicant and NEI took strong exception to this statement. They both argued that the language of the DCD introduction was the subject of careful discussion and negotiation between the NRC staff, NRC's Office of the General Counsel, and representatives of the applicant and NEI. They, therefore, suggested that the definition of the DCD in Section 2(a) of the proposed rule be amended to explicitly include the DCD Introduction and that Section 4(a) of the proposed rule be amended to generally require that applicants or licensees comply with the entire DCD. However, in the event that the Commission rejected their suggestion, NEI alternatively argued that the substantive provisions of the DCD Introduction be directly incorporated into the design

certification rule's language (refer to NEI Comments, Attachment B, pp. 90-108; ABB-CE Comments, Attachment A).

Response. The DCD Introduction was created to be a convenient explanation of some provisions of the design certification rule and was not intended to become rule language itself. Therefore, the Commission has adopted NEI's alternative suggestion of incorporating substantive procedural and administrative requirements into the design certification rule. It is the Commission's view that the substantive procedural and administrative provisions described in the DCD Introduction should be included in, and be an integrated part of, the design certification rule which is published in the Federal Register and codified in the Code of Federal Regulations. The portion of the rule that is published in the Federal Register contains the bulk of the rule's procedural and administrative requirements. It would be better from the standpoint of form and convenience to include the appropriate provisions into a single part of the rule. As a result, Sections 2, 4, 6, 8, and 10 have been revised and Section 9 of this Appendix was created to adopt appropriate provisions from the DCD Introduction. In some cases, the wording of these provisions has been modified to conform with the final design certification rule. Therefore, the applicant for this design certification must revise its DCD Introduction to conform with the final rule.

In section C.2 of its comments, dated August 4, 1995, ABB-CE stated that all tables within Section 19.7, "External Events Analysis," of the DCD should be deleted. ABB-CE stated that the probabilistic numerical results in these tables were included in its DCD as a result of a printing error. The Commission has determined that the deletion of these tables from Section 19.7 of the DCD is acceptable because a site-specific version of this information will be created by a COL applicant that references this design certification. Therefore, ABB-CE can delete this information when it prepares the final version of the generic DCD that conforms with the final rule.

3. Duplicate documentation in design certification rule.

Comment Summary. On page 4 of its comments, dated August 7, 1995, the Department of Energy (DOE) recommended that the process for preparing the design certification rule be simplified by eliminating the DCD, which DOE claims is essentially a repetition of the Standard Safety Analysis Report (SSAR). DOE's concern, which was further clarified during a public meeting on December 4, 1995, is that the NRC will require separate copies of the DCD and SSAR to be maintained. During the public meeting DOE, also expressed a concern that § 52.79(b) could be confusing to an applicant for a combined license because it currently states ... "The final safety analysis report and other required information may incorporate by reference the final safety analysis report for a certified standard design." ...

Response. The NRC does not require duplicate documentation for this design certification rule. The DCD is the document that is incorporated by reference into this appendix in order to meet the requirements of Subpart B of Part 52. The SSAR supports the final design approval that was issued under Appendix O to 10 CFR Part 52. The DCD was developed to meet the requirements for incorporation by reference and to conform with requests from the industry such as deletion of the quantitative portions of the design-specific probabilistic risk assessment. Because the DCD terminology was not envisioned at the time that Part 52 was developed, the Commission will consider modifying

§ 52.79(b), as part of its future review of Part 52, in order to clarify the use of the term "final safety analysis report." In the records and reporting requirements in Section 10 of this rule, additional terms were used to distinguish between the documents to be maintained by the applicant for this design certification rule and the document to be maintained by an applicant or licensee who references this appendix. These new terms are defined in Section 2 of this appendix and further described in the section-by-section discussion on records and reporting requirements in section III.J.

III. Section-by-section discussion of the design certification rule.

A. Introduction.

The purpose of Section 1 of this appendix is to identify the standard plant design that is approved by this design certification rule and the applicant for certification of the standard design. The implementation of 10 CFR 52.63(c) depends on whether an applicant for a COL contracts with the design certification applicant to provide the generic DCD and supporting design information. If the COL applicant does not use the design certification applicant to provide this information, then the COL applicant will have to meet the requirements in 10 CFR 52.63(c). Also, Section 10(a)(1) of this appendix imposes a requirement on the design certification applicant to maintain the generic DCD throughout the time period in which this appendix may be referenced. Therefore, identification of the design certification applicant is necessary to implement this appendix.

B. Definitions (Section 2).

The terms Tier 1, Tier 2, Tier 2*, and COL action items (license information) are defined in Section 2 of this appendix because these concepts were not envisioned when 10 CFR Part 52 was developed. The design certification applicants and the NRC staff used these terms in implementing the two-tiered rule structure that was proposed by industry after the issuance of 10 CFR Part 52. In addition, during consideration of the comments received on the proposed rule, the Commission determined that it would be useful to distinguish between the "plant-specific DCD," in order to clarify the obligations of applicants and licenses that reference this appendix, and the "generic DCD," which is incorporated by reference into this appendix and remains unaffected by plant-specific departures. Therefore, appropriate definitions for these two additional terms are included in the final rule.

The Tier 1 portion of the design-related information contained in the DCD is *certified* and required by this appendix. This information consists of an introduction to Tier 1, the design descriptions and corresponding inspections, tests, analyses, and acceptance criteria (ITAAC) for systems and structures of the design, design material applicable to multiple systems of the design, significant interface requirements, and significant site parameters for the design. The design descriptions, interface requirements, and site parameters in Tier 1 were derived entirely from Tier 2, but may be more general than the Tier 2 information. The NRC staff's evaluation of the Tier 1 information, including a description of how this information was

developed is provided in Section 14.3 of the FSER. Changes to or departures from the Tier 1 information must comply with Section 8(a) of this Appendix.

The Tier 1 design descriptions serve as design commitments for the lifetime of a facility referencing the design certification. The ITAAC verify that the as-built facility conforms with the approved design and applicable regulations. In accordance with 10 CFR 52.103(g), the Commission must find that the acceptance criteria in the ITAAC are met before operation. After the Commission has made the finding required by 10 CFR 52.103(g), the ITAAC do not constitute regulatory requirements for subsequent modifications. However, subsequent modifications to the facility must comply with the Tier 1 design descriptions unless changes are made in accordance with the change process in Section 8 of this appendix. The Tier 1 interface requirements are the most significant of the interface requirements for systems that are wholly or partially outside the scope of the standard design, which were submitted in response to 10 CFR 52.47(a)(1)(vii) and must be met by the site-specific portions of a facility that references the design certification. The Tier 1 site parameters are the most significant site parameters, which were submitted in response to 10 CFR 52.47(a)(1)(iii), that must be addressed as part of the application for a combined license.

Tier 2 is the portion of the design-related information contained in the DCD that is *approved* and required by this appendix but is not certified. Tier 2 includes the information required by 10 CFR 52.47, with the exception of technical specifications and conceptual design information, and supporting information on the inspections, tests, and analyses that will be performed to demonstrate that the acceptance criteria in the ITAAC have been met. All of the information in Tier 2 is approved by the NRC, is required (except for the COL action items and conceptual design information) for those COL applicants and licensees whose applications reference this appendix, and is among the "matters resolved" under 10 CFR 52.63(a)(4). The definition of Tier 2 makes clear that Tier 2 information has been determined by the Commission, by virtue of its inclusion in this appendix and its designation as Tier 2 information, to be an approved ("sufficient") method for meeting Tier 1 requirements. However, there may be other acceptable ways of complying with Tier 1. The appropriate criteria for departing from Tier 2 information are set forth in Section 8 of this appendix.

Certain Tier 2 information has been designated in the generic DCD with brackets and italicized text as "Tier 2*" information. As discussed in greater detail in the section-by-section explanation for Section 8, a plant-specific departure from Tier 2* information requires prior NRC approval under Section 8(b)(6) of this appendix. However, the Tier 2* designation expires for some of this information when the facility first achieves full power after the finding required by 10 CFR 52.103(g). The process for changing Tier 2* information and the time at which its status as Tier 2* expires is set forth in Section 8(b)(6) of this appendix.

A definition of "combined license (COL) action items" (COL license information) has been added to clarify that COL applicants are required to address these matters in their license application, but the COL action items do not include substantive criteria for judging the sufficiency of the information submitted. Thus, an applicant for a combined license may be able to address particular COL action items by justifying, in appropriate circumstances, why no further action is necessary.

In developing the proposed design certification rule, the Commission contemplated that there would be both "master" DCDs (termed generic DCDs) maintained by the NRC and the design certification applicant, as well as individual plant-specific DCDs, maintained by each applicant and licensee who references this design certification rule. The master DCDs (identical to each other) would reflect generic changes to the version of the DCD approved in this design certification rulemaking. The generic changes would occur as the result of generic rulemaking by the Commission (subject to the change criteria in Section 8 of this Appendix). In addition, the Commission understood that each applicant and licensee referencing this Appendix would be required to submit and maintain a plant-specific DCD. This plant-specific DCD would contain (not just incorporate by reference) the information in the generic or master DCD. The plant-specific DCD would be updated as necessary to reflect the generic changes to the DCD that the Commission may adopt through rulemaking, any plant-specific departures from the generic DCD that the Commission imposed on the licensee by order, and any plant-specific departures which the licensee chose to make in accordance with the relevant processes in Section 8 of this appendix. However, the proposed rule defined only the concept of the "master" DCD. The Commission continues to believe that there should be both a "master" DCD and plant-specific DCDs. To clarify this matter, the proposed rule's definition of DCD has been redesignated as the "generic DCD," a new definition of "plant-specific DCD" has been added, and conforming changes have been made to the remainder of the rule. Further information on exemptions or departures from information in the DCD is provided in section III.H below. The Final Safety Analysis Report (FSAR) that is required by § 52.79(b) will consist of the plant-specific DCD, the site-specific portion of the FSAR, and the technical specifications.

C. Scope and contents of this design certification.

The purpose of Section 3 of this appendix is to describe and define the scope and contents of the standard design certification and to set forth how documentation discrepancies or inconsistencies are to be resolved. Paragraph (a) is the required statement of the Office of the Federal Register (OFR) for approval of the incorporation by reference of Tier 1 and Tier 2 into this appendix and paragraph (b) requires COL applicants and licensees to comply with the requirements of this appendix, including Tier 1 and Tier 2. The legal effect of incorporation by reference is that the material is treated as if it were published in the Federal Register. This material, like any other properly-issued regulation, has the force and effect of law. Tier 1 and Tier 2 information have been combined into a single document, called the design control document (DCD), in order to effectively control this information and facilitate its incorporation by reference into the rule. The DCD was prepared to meet the requirements of the OFR for incorporation by reference (1 CFR Part 51). The generic DCD for this design certification will be archived at NRC's central file with a matching copy at OFR. Copies of the up-to-date DCD will also be available at the NRC's Public Document Room. Questions concerning the accuracy of information in an application that references this Appendix will be resolved by checking the generic DCD in NRC's central file. If a generic change (rulemaking) is made to the DCD pursuant to the change process in Section 8 of this Appendix, then at the completion of the rulemaking the NRC will request approval of the Director, OFR for the changed

incorporation by reference and change its copies of the generic DCD and notify the OFR and the design certification applicant to change their copies. The Commission is requiring that the design certification applicant maintain an up-to-date copy under Section 10(a)(1) of this appendix because it is likely that most applicants intending to reference the standard design will likely obtain the generic DCD from the design certification applicant. Plant-specific changes to and departures from the DCD will be maintained by the applicant or licensee that references this design certification under Section 10(a)(2) of this appendix.

In order to meet the requirements of OFR for incorporation by reference, the design certification applicant must make the DCD available upon request after the final design certification rule is issued. Therefore, this Section states that copies of the DCD can be obtained from [the applicant or an organization designated by the applicant. If the applicant selects an organization, such as the National Technical Information Service, to distribute the generic DCD, then the applicant must provide that organization with an up-to-date copy.]

Paragraphs (c) and (d) set forth the manner in which potential conflicts are to be resolved. Paragraph (c) establishes the Tier 1 description in the DCD as controlling in the event of an inconsistency between the Tier 1 and Tier 2 information in the DCD. Paragraph (d) establishes the generic DCD as the controlling document in the event of an inconsistency between the DCD and either the application for certification of the standard design, or the final safety evaluation report (FSER) for the standard design.

Paragraph (e) clarifies that the conceptual design information and the technical specifications in the generic DCD are not considered to be part of this appendix. The conceptual design information is for those portions of the plant that are outside the scope of the standard design and are intermingled throughout Tier 2. As provided by 10 CFR 52.47(a)(1)(ix), these conceptual designs are not part of this appendix and, therefore, are not applicable to an application for a combined license that references this appendix. The technical specifications, which are provided in Chapter 16 of the generic DCD, are not part of this appendix but may be used to develop the technical specifications for a nuclear facility that references this appendix.

D. Applications and licenses referencing this design certification: additional requirements and restrictions.

Section 4 of this appendix is a new section which sets forth additional requirements and restrictions imposed upon the applicant or licensee who references this Appendix. Section 4(a) sets forth the additional information required of combined license applicants who reference this Appendix. This Appendix distinguishes between information and/or documents which must actually be *included* in the application or the DCD, versus those which may be *incorporated by reference* (i.e., referenced in the application as if the information or documents were actually included in the application), thereby reducing the bulk of the application. Any incorporation by reference in the application should be clear and should specify the title, date, edition, or version of a document, and the page number(s) and table(s) containing the relevant information to be incorporated by reference.

Paragraph (a)(1) requires an applicant to incorporate by reference this appendix. This appendix is legally-binding on any applicant or licensee who references this appendix. Paragraph (a)(2)(i) is intended to make clear that the initial application must include a plant-specific DCD. This assures, among other things, that the applicant commits to complying with both Tier 1 and Tier 2 of the DCD. This paragraph also requires the plant-specific DCD to use the same format as the generic DCD and to reflect the applicant's proposed departures and exemptions from the generic DCD as of the time of submission of the application. The Commission expects that the plant-specific DCD will become the basis for the plant's final safety analysis report (FSAR), by including within its pages, at the appropriate points, information such as site-specific information for the portions of the plant outside the scope of the referenced design, including related ITAAC, and other matters required to be included in an FSAR by 10 CFR 50.34. Integration of the plant-specific DCD and remaining information, as the plant's FSAR, will be easier to use and should minimize "duplicate documentation" and the attendant possibility for confusion. Paragraph (a)(2)(i) is also intended to make clear that the initial application must include the reports on departures and exemptions as of the time of submission of the application. Paragraph (a)(2)(ii) requires that the application include the reports required by Section 10(b) of this design certification rule for exemptions and departures proposed by the applicant as of the date of submission of its application. Paragraph (a)(2)(iii) requires submission of technical specifications for the plant in accordance with the requirements in effect at the time of the COL review. Paragraph (a)(2)(iv) makes clear that the applicant must provide information demonstrating that the proposed site falls within this rule's site parameters and that the plant-specific design complies with the interface requirements, as required by 10 CFR 52.79(b). Paragraph (a)(2)(v) requires submission of information addressing COL Action Items, which are identified in the generic DCD as COL License Information, in the COL application. The COL Action Items (COL License Information) identify matters that need to be addressed by an applicant or licensee that references this appendix, as required by 10 CFR 52.77 and 52.79. The COL applicant does not need to conform with the conceptual design information in the generic DCD that was provided by the design certification applicant in response to 10 CFR 52.47(a)(1)(ix). The conceptual design information, which are examples of site-specific design features, was required to facilitate the design certification review. Conceptual design information is neither Tier 1 nor 2. The introduction to the DCD identifies the location of the conceptual design information and explains that this information is not applicable to a COL application. Paragraph (a)(2)(vi) requires that the application include the information required by 10 CFR 52.47(a) that is not within the scope of this rule, such as generic issues that must be addressed by an applicant that references this rule. The detailed methodology and quantitative portions of the design-specific probabilistic risk assessment (PRA), as required by 10 CFR 52.47(a)(1)(v), was not included in the DCD. The NRC agreed with the design certification applicant's request to delete this information because conformance with the deleted portions of the PRA is not required. The NRC's position is also predicated in part upon NEI's acceptance, in conceptual form, of a future generic rulemaking that will require a COL applicant or licensee to have a plant-specific PRA that updates and supersedes the design-specific PRA and maintain it throughout the operational life of the plant.

Paragraph (a)(2)(vii) requires a COL applicant to include descriptions of in-service testing (IST) and in-service inspection (ISI) programs that include the features described in sub-paragraphs (A), and (B) in their application. This requirement was moved from Section 5(c) of this appendix in response to NEI comments that, since the programs are the responsibility of the applicant and licensee, it was not appropriate as a new applicable regulation. The Commission's views on ISI and IST have been evolving. The purpose of this requirement is to ensure that a licensee will use the best available methods and incorporate the techniques specified in this requirement.

Paragraph (a)(2)(viii) requires a COL applicant to include a description of their outage planning and control program that includes consideration of shutdown risk concerns. This requirement was moved from Section 5(c) of this appendix in response to NEI comments that, since the program is the responsibility of the applicant and licensee, it was not appropriate as a new applicable regulation. The purpose of the requirement is to ensure that, in light of the Commission's findings in NUREG-1449, the applicant's program for outage planning and control adequately addresses shutdown risk concerns.

Paragraph (a)(2)(ix) requires a COL applicant to include a description of a design reliability assurance program (DRAP) in their application. As background information, in SECY-89-013, "Design Requirements Related to the Evolutionary Advanced Light Water Reactors," dated January 19, 1989, the staff identified several issues for next-generation light water reactors that may go beyond present acceptance criteria defined in the SRP. The reliability assurance program (RAP), as one of these issues, was defined as a program to ensure that the design reliability of safety significant structures, systems, and components (SSCs) is maintained over the life of a plant. In SECY-93-087, the staff gave the Commission its interim position that a high-level commitment to a RAP should be required as a generic Tier 1 requirement with no associated inspections, tests, analyses, and acceptance criteria. DRAP involves a top-level program at the design stage that defines the scope, conceptual framework, and essential elements of an effective RAP. DRAP also implements those aspects of the program that are applicable to the design process. In addition, DRAP identifies the relevant aspects of plant operation, maintenance, and performance monitoring for the risk-significant SSCs for the operator's consideration.

The conceptual framework, program structure, and essential elements of the D-RAP are discussed in section 17.3 of the DCD. The DRAP should (1) identify and prioritize a list of risk-significant SSCs based on the design certification PRA and other sources, (2) ensure that the vendor's design organization determines that significant design assumptions, such as equipment that satisfies the design reliability and unavailability, are realistic and achievable, (3) provide input to the procurement process for obtaining equipment that satisfies the design reliability assumptions, and (4) provide these design assumptions as input to the COL applicant for consideration. A COL applicant would augment the design certification DRAP with site-specific design information and would implement the balance of the D-RAP, including input to the procurement process.

The staff's final position on RAP was presented in the Commission Paper on the Regulatory Treatment of Non-Safety Systems (RTNSS), SECY-94-084, dated March 28, 1994. The Commission approved this position in an SRM dated June

30, 1994. Note that in paragraph (a)(4)(iii)(B), the staff expects that the "other analytical methods" would include sound engineering judgement.

Paragraph (a)(3) requires the applicant to physically include, not simply reference, the proprietary information referenced in the System 80+ DCD, to assure that the applicant has actual notice of these requirements.

Paragraph (a)(4) requires an applicant to establish and implement a design reliability assurance program that includes the features specified in Section 4(a)(2)(ix) because additional design work will be performed by the COL applicant and DRAP must be implemented during this period before the COL application is approved by the Commission.

Paragraphs (b)(1), (b)(2) and (b)(3) require a holder of a COL to implement the programs described above. The NRC intends that the requirement of paragraph (b)(2) to implement the D-RAP program will apply from the date of COL issuance until the date of fuel load. The ISI, IST and outage planning and control programs are required to be implemented throughout the service life of the plant.

Section 4(c) reserves the right of the Commission to impose limited plant-specific requirements for post-fuel load operational safety, including verification activities, as license conditions for portions of the plant within the scope of this design certification, e.g. start-up and power ascension testing. The requirement to perform these testing programs is contained in Tier 1 information. However, ITAAC cannot be specified for these subjects because the matters to be addressed in these license conditions cannot be verified prior to fuel load and operation, when the combined license ITAAC are satisfied. As provided in Section 9(b)(3), ITAAC do not constitute regulatory requirements after the finding required by 10 CFR 52.103(g). Therefore, another regulatory vehicle is necessary to assure that holders of combined licenses comply with the matters contained in the license conditions. License conditions for these areas cannot be developed now because this requires the type of detailed design information that will be developed after design certification. In the absence of detailed design information to evaluate the need for and develop specific post-fuel load verifications for these matters, the Commission, by rule, is reserving the right to impose these limited license conditions for post-fuel load verification activities for portions of the plant within the scope of the design certification.

Section 4(d) reserves to the Commission the right to determine whether and in what manner this design certification may be referenced by an applicant for a construction permit or operating license under 10 CFR Part 50. This determination may occur in the context of a subsequent rulemaking modifying Part 52 or this design certification rule, or on a case-by-case basis in the context of a specific application for a Part 50 construction permit or operating license.

E. Applicable regulations.

The purpose of Section 5 of this appendix is to identify the regulations that are applicable and in effect at the time that this design certification was issued. These regulations consist of the technically relevant regulations identified in paragraph (a), except for the regulations in paragraph (b) that are not applicable, and the new regulations in paragraph (c) that are applicable to this standard design.

Paragraph (a) identifies the regulations in 10 CFR Parts 20, 50, 73, and 100 that are applicable to the System 80+ design. Since the NRC staff completed its review with the issuance of the FSER for the System 80+ design (August 1994), the Commission has amended several existing regulations and adopted several new regulations in those Parts of Title 10 of the Code of Federal Regulations. The Commission has reviewed these regulations to determine if they are applicable to this design and, if so, to confirm that the design meets these regulations. The Commission finds that the System 80+ design either meets the requirements of these regulations or that these regulations are not applicable to the design, as discussed below.

10 CFR Part 73, Protection Against Malevolent Use of Vehicles at Nuclear Power Plants (59 FR 38889; August 1, 1994).

The objective of this regulation is to modify the design basis threat for radiological sabotage to include use of a land vehicle by adversaries for transporting personnel and their hand-carried equipment to the proximity of vital areas and to include a land vehicle bomb. This regulation also requires reactor licensees to install vehicle control measures, including vehicle barrier systems, to protect against the malevolent use of a land vehicle. The Commission has determined that this regulation will be addressed in the COL applicant's site-specific security plan. Therefore, no additional actions are required for this design.

10 CFR 19 and 20, Radiation Protection Requirements: Amended Definitions and Criteria (60 FR 36038; July 13, 1995).

The objective of this regulation is to revise the radiation protection training requirement so that it applies to workers who are likely to receive, in a year, occupational dose in excess of 100 mrem (1 mSv); revise the definition of the "Member of the public" to include anyone who is not a worker receiving an occupational dose; revise the definition of "Occupational Dose" to delete reference to location so that the occupational dose limit applies only to workers whose assigned duties involve exposure to radiation and not to members of the public; revise the definition of the "Public Dose" to apply to dose received by members of the public from material released by a licensee or from any other source of radiation under control of the licensee; assure that prior dose is determined for anyone subject to the monitoring requirements in 10 CFR Part 20, or in other words, anyone likely to receive, in a year, 10 percent of the annual occupational dose limit; and retain a requirement that known overexposed individuals receive copies of any reports of the exposure that are required to be submitted to the NRC. The Commission has determined that these requirements will be addressed in the COL applicant's operational radiation protection program. Therefore, no additional actions are required for this design.

10 CFR 50, Technical Specifications (60 FR 36953; July 19, 1995).

The objective of this revised regulation is to codify criteria for determining the content of technical specification (TS). The four criteria were first adopted and discussed in detail in the Final Policy Statement on

Technical Specification Improvements for Nuclear Power Reactors (58 FR 39132; July 22, 1993). The Commission has determined that these requirements will be addressed in the COL applicant's technical specifications. Therefore, no additional actions are required for this design.

10 CFR 73, Changes to Nuclear Power Plant Security Requirements Associated with Containment Access Control (60 FR 46497; September 7, 1995).

The objective of this revised regulation is to delete certain security requirements for controlling the access of personnel and materials into reactor containment during periods of high traffic such as refueling and major maintenance. This action relieves nuclear power plant licensees of requirement to separately control access to reactor containments during these periods. The Commission has determined that this regulation will be addressed in the COL applicant's site-specific security plan. Therefore, no additional actions are required for this design.

10 CFR Part 50, Primary Reactor Containment Leakage Testing for Water-Cooled Power Reactors (60 FR 49495; September 26, 1995).

The objective of this revised regulation is to provide a performance-based option for leakage-rate testing of containments of light-water-cooled nuclear power plants. This performance-based option, option B to Appendix J, is available for voluntary adoption by licensees in lieu of compliance with the prescriptive requirements contained in the current regulation. As a result, Appendix J now includes two options, A & B, either of which can be chosen for meeting the requirements of this appendix to 10 CFR Part 52. The Commission has determined that option B to Appendix J has no impact on the System 80+ design because ABB-CE has chosen option A to Appendix J. However, the System 80+ design addresses primary reactor containment leakage testing in a manner different from that provided in option A, as described in the discussion on exemptions to Appendix J below. Therefore, no additional actions are required by this design.

10 CFR Parts 50, 70, and 72, Physical Security Plan Format (60 FR 53507; October 16, 1995).

The objective of this revised regulation is to eliminate the requirement for applicants for power reactor, Category I fuel cycle, and spent fuel storage licenses to submit physical security plans in two parts. This action is necessary to allow for a quicker and more efficient review of the physical security plans. The Commission has determined that this revised regulation will be addressed in the COL applicant's site-specific security plan. Therefore, no additional action is required for this design.

10 CFR Part 50, Fracture Toughness Requirements for Light Water Reactor Pressure Vessels (60 FR 65456; December 19, 1995).

The objective of this revised regulation is to clarify several items related to fracture toughness requirements for reactor pressure vessels (RPV).

This regulation clarifies the pressurized thermal shock (PTS) requirements, makes changes to the fractures toughness requirements and the reactor vessel material surveillance program requirements, and provides new requirements for thermal annealing of a reactor pressure vessel. The Commission has determined that 10 CFR 50.61 only applies to pressurized water reactors for which an operating license has been issued. Likewise, 10 CFR 50.66 applies only to those light-water reactors where neutron radiation has reduced the fracture toughness of the reactor vessel materials. Therefore, no additional actions are required by this design.

In paragraph (b), the Commission identified the regulations that do not apply to the System 80+ design. The Commission has determined that the System 80+ design should be exempt from portions of 10 CFR 50.34(f), Appendix J to Part 50, and Part 100, as described in the final safety evaluation report (NUREG-1462) and summarized below:

(1) Paragraph (f)(2)(iv) of 10 CFR 50.34 - Separate Plant Safety Parameter Display Console.

10 CFR 50.34(f)(2)(iv) requires that an application provide a plant safety parameter display console that will display to operators a minimum set of parameters defining the safety status of the plant, be capable of displaying a full range of important plant parameters and data trends on demand, and be capable of indicating when process limits are being approached or exceeded.

The purpose of the requirement for a safety parameter display system (SPDS), as stated in NUREG-0737, "Clarification of TMI Action Plan Requirements," Supplement 1, is to ". . . provide a concise display of critical plant variables to the control room operators to aid them in rapidly and reliably determining the safety status of the plant. . . and in assessing whether abnormal conditions warrant corrective action by operators to avoid a degraded core."

ABB-CE committed to meet the intent of this requirement. However, the functions of the SPDS will be integrated into the control room design rather than on a separate "console." ABB-CE has made the following commitments in the generic DCD:

- Section 18.7.1.8.1, Safety-Related Data, states that the Nuplex 80+ Advanced Control Complex provides a concise display of critical function and success path performance indications to control room operators via the Data Processing System (DPS),
- Section 18.7.1.8.1 states that the integrated process status overview (IPSO) big board display is a dedicated display which continuously shows all critical function alarms and key critical function and success path parameters,
- Section 18.7.1.8.1 describes the SPDS for the System 80+ and states that all five of the safety function elements are included in the DPS critical function hierarchy which forms the basis of the Nuplex 80+ SPDS function:

(a) Reactivity control

- (b) Reactor core cooling and heat removal from the primary system
 - (c) Reactor coolant system integrity
 - (d) Radioactivity control
 - (e) Containment conditions, and
- Section 18.7.1.8.2 states that the critical function and success path monitoring application in conjunction with the continuous IPSO display and the DPS CRTs meet SPDS requirements for Nuplex 80+ without using stand-alone monitoring and display systems.

In view of the above, the Commission has determined that an exemption from the requirement for an SPDS "console" is justified based upon (1) the description in the generic DCD of the intent of the System 80+ design to incorporate the SPDS function as part of the plant status summary information which is continuously displayed on the fixed-position displays on the large display panel; and (2) a separate "console" is not necessary to achieve the underlying purpose of the SPDS rule which is to display to operators a minimum set of parameters defining the safety status of the plant. Therefore, the Commission concludes that an exemption from 10 CFR 50.34(f)(2)(iv) is justified by the special circumstances set forth in 10 CFR 50.12(a)(2)(ii).

(2) Paragraphs (f)(2)(vii), (viii), (xxvi), and (xxviii) of 10 CFR 50.34- Accident Source Terms

10 CFR 50.34(f)(2)(xxviii) requires the evaluation of pathways that may lead to control room habitability problems "under accident conditions resulting in a TID 14844 source term release." Similar wording appears in subparagraphs (vii), (viii), and (xxvi). ABB-CE has implemented the new source term technology summarized in Draft NUREG-1465, "Accident Source Terms for Light-Water Nuclear Power Plants," dated June 1992, not the old TID 14844 source term cited in 10 CFR Part 50.

The NRC staff has encouraged the development and implementation of the new source term technology. The use of the revised source term technology is an important departure from previous practice. The new approach generally yields lower estimates of fission product releases to the environment and will employ a physically-based source term based on substantial research and experience gained over two decades. The TID-14844 non-mechanistic methodology intentionally employed conservative assumptions that were intended to ensure that future plants would provide sufficient safety margins even with the recognized uncertainties associated with accident sequences and equipment reliability. Although the new source term technology may lead to relaxation in some aspects of the design, it also provides safety benefits by removing unrealistically stringent testing requirements.

Based on the NRC staff's review and ABB-CE's commitments in Chapter 15 of the generic DCD, the Commission has determined that the special circumstances described in 10 CFR 50.12(a)(ii) exist in that the regulation need not be applied in this particular circumstance to achieve the underlying purpose because ABB-CE has proposed acceptable alternatives that accomplish the intent of the regulation. On this basis, the Commission concludes that an exemption from the requirements of paragraphs (f)(2)(vii), (viii), (xxvi), and (xxviii) of 10 CFR 50.34 is justified.

(3) Paragraph (f)(2)(viii) of 10 CFR 50.34 - Post-Accident Sampling for Hydrogen, Boron, Chloride, and Dissolved Gases.

In SECY-93-087, the NRC staff recommended that the Commission approve its position for evolutionary and passive ALWRs of the pressurized water reactor (PWR) type that they be required to have the capability to analyze for dissolved gases in the reactor coolant and for hydrogen in the containment atmosphere in accordance with the requirements of 10 CFR 50.34(f)(2)(viii) and Item III.B.3 of NUREG-0737. The NRC staff acknowledged that determination of chloride concentrations, although helpful in ensuring that plant personnel take appropriate actions to minimize the likelihood of accelerated primary system corrosion following the accident, is a secondary consideration because long-term samples could likely be taken at a low pressure. Therefore, it does not constitute a mandatory requirement of the post-accident sampling system (PASS). The time for taking these samples can be extended to 24 hours following the accident. The NRC staff also recommended that the Commission approve the deviation from the requirements of Item II.B.3 of NUREG-0737 with regard to requirements for sampling reactor coolant for boron concentration and activity measurements using the PASS in evolutionary and passive ALWRs.

The rationale is that both of these measurements are used only to confirm the accident mitigation measures and conditions of the core obtained by other methods and do not need to be performed in an early phase of an accident. Neutron flux monitoring instrumentation that complies with Category I criteria of RG 1.97, will have fully qualified, redundant channels that monitor neutron flux over the required power range. Therefore, sampling for boron concentration will not be needed for the first eight hours after an accident. Samples for activity measurements provide the information used in evaluating the condition of the core. However, this information will be made available during the accident management phase by monitoring other pertinent variables. Accordingly, sampling for activity measurement could be postponed until 24 hours following an accident.

In its July 21, 1993, Staff Requirements Memorandum (SRM), the Commission approved the recommendation to exempt the PASS for ALWRs of PWR design from determining the concentration of hydrogen in the containment atmosphere in accordance with the requirements of 10 CFR 50.34(f)(2)(viii) and Item III.B.3 of NUREG-0737. It also approved extending the time limit for analysis of the coolant for boron and activity to eight hours and 24 hours, respectively. The Commission modified the recommendations regarding evolutionary and passive ALWRs of the PWR type to have the capability to determine the gross amount of dissolved gases (not necessarily pressurized) as a means to meet the intent of 10 CFR 50.34(f)(2)(viii) and Item II.B.3 of NUREG-0737.

Accordingly, the Commission has determined that the special circumstances described in 10 CFR 50.12(a)(2)(ii) exist in that the regulation need not be applied in this particular circumstance to achieve the underlying purpose because ABB-CE has proposed acceptable alternatives that accomplish the intent of the regulation. On this basis, the Commission concludes an exemption from the requirements of Paragraph (f)(2)(viii) of 10 CFR 50.34 is justified.

(4) Paragraph (f)(3)(iv) of 10 CFR 50.34 - Dedicated Containment Penetration.

Paragraph (3)(iv) of 10 CFR 50.34(f) requires one or more dedicated containment penetrations, equivalent in size to a single 0.91 m (3 ft) diameter opening, in order not to preclude future installation of systems to prevent containment failure such as a filtered containment vent system. This requirement is intended to ensure provision of a containment vent design feature with sufficient safety margin well ahead of a need that may be perceived in the future to mitigate the consequences of a severe accident situation.

In the generic DCD, ABB-CE shows that the containment is sufficiently robust to not require venting before 24 hours. However, to further improve containment performance, the System 80+ containment is equipped with two 7.6-cm (3.0-in.) diameter hydrogen purge vents that can be used to relieve containment pressure before containment pressure reaches ASME Code Service Level C. With respect to core concrete interaction (CCI), the vent could be used to prevent catastrophic overpressurization failure of the containment for severe-accident sequences involving prolonged periods of CCI. The hydrogen purge vents are capable of opening when exposed to an internal pressure corresponding to ASME Code Service Level C, of 972 kPa (141 psia) at a temperature of 177 °C (350 °F), and can be powered by the alternate AC source.

ABB-CE has provided this venting capability; however, they have demonstrated that venting is not needed for most of the severe-accident events. For those sequences in which venting would aid in limiting the containment pressure below ASME Code Service Level C limits, venting would not be needed before 24 hours after the onset of core damage.

Based on the NRC staff's review and ABB-CE's commitments in Chapter 19 of the generic DCD, the Commission determined that the special circumstances described in 10 CFR 50.12(a)(ii) exist in that the regulation need not be applied in this particular circumstance to achieve the underlying purpose because ABB-CE has proposed acceptable alternatives that accomplish the intent of the regulation. On this basis, the Commission concludes that an exemption from the requirement of 10 CFR 50.34(f)(iv) is justified.

*(5) Paragraphs III.A.1(a) and III.C.3(b) of Appendix J to 10 CFR 50 -
Containment Leakage Testing*

(a) Paragraph III.A.1(a)

ABB-CE committed to containment leakage testing for the System 80+ design, in accordance with option A to the new Appendix J to 10 CFR Part 50, with the following exceptions:

- The COL applicant may use the mass point leak rate test method in ANSI/ANS 56.8-1987 as an alternative to Type A testing method specified in ANSI 45.4-1972, and
- Leaks occurring during the Type A test that could affect the test results will not prevent completion of this test if: (a) the leaks are isolated for the balance of the test; (b) the leaking component had a "pre-maintenance" local leak rate test whose results, when added to those from the Type A test, are in conformance with the acceptance criteria of Appendix J; or (c) a "post-maintenance" local leak rate test of the leaking component(s) is performed and the results, when added to

those from the Type A test, conform to the acceptance criteria of Appendix J.

The first exception is acceptable because the current version of Section III.A.3 of Appendix J to 10 CFR Part 50 includes the ANSI/ANS 56.8-1987 method (mass point method) as an acceptable alternative. The second exception does not conform to the requirements of Appendix J to 10 CFR Part 50. Section III.A.1.(a) of Appendix J requires that a Type A test, defined as a test to measure the primary containment overall integrated leakage rate be terminated if, during this test, potentially excessive leakage paths are identified which would either interface with satisfactory completion of the test or which would result in the Type A tests not meeting the applicable acceptance criteria of Section III.A.4(b) or III.A.5(b). Section III.A.1(a) further requires that, after terminating a Type A test due to potentially excessive leakage, the leakage through the potentially excessive leakage paths be measured using local leakage testing methods and repairs and/or adjustments to the affected equipment be made. The Type A test shall then be conducted. ABB-CE proposed that the test not be terminated when leakage is found during a Type A test. Instead, ABB-CE proposed that leaks be isolated and the Type A test continued. After completion of the modified Type A test (i.e., a Type A test with the leakage paths isolated), local leakage rates of those paths isolated during the modified Type A test will be measured before or after the maintenance to those paths.

ABB-CE proposed that the adjusted "as-found" leakage rate for the Type A test be determined by adding the local leakage rates measured before maintenance to those previously isolated leakage paths, to the containment integrated leakage rate determined in the modified Type A test. This adjusted "as-found" leakage rate is to be used in determining the scheduling of the periodic Type A tests in accordance with Section III.A.6 of Appendix J.

Finally, ABB-CE proposed that the acceptability of the modified Type A test be determined by calculating the adjusted "as-left" containment overall integrated leakage rate and comparing this to the acceptance criteria of Appendix J. The adjusted "as-left" Type A leakage rate is determined by adding the local leakage rates measured after any maintenance to those previously isolated leakage paths, to the leakage rate determined in the modified Type A test.

The differences between the proposed leak testing and the requirements in Section III.A.1(a) of Appendix J are that: (1) the potentially excessive leakage paths will be repaired and/or adjusted after completion of the Type A test rather than before the test; and (2) the Type A test leakage rate is partially determined by calculation rather than by direct measurement. With respect to the first issue, the NRC staff does not identify any significant difference in the end result (i.e., the "as-left" local leakage rates will be maintained within an acceptable range). With respect to the second issue, the measured "as-left" local leakage rates will represent a relatively small correction to the containment overall integrated leakage rate measured in the modified Type A test. Accordingly, there will be insignificant differences between the calculated "as-left" containment leakage rate (i.e., a modified Type A test) and one that would be directly measured in compliance with the requirements of Section III.A.1.(a).

In view of the above, the Commission has determined that the special circumstances described in 10 CFR 50.12(a)(2)(ii) exist in that the regulation

need not be applied in this particular circumstance to achieve the underlying purpose because ABB-CE has proposed acceptable alternatives that accomplish the intent of the regulation. On this basis, the Commission concludes that a partial exemption from the requirements of Paragraph III.A.1.(a) of Appendix J to 10 CFR Part 50 is justified.

(b) Paragraph III.C.3(b)

In Section 6.2.6 and Table 6.2.4-1 of the generic DCD, ABB-CE presented information on the System 80+ containment leakage testing program, including the planned leak test data for specific containment isolation valves (CIVs). In Table 6.2.4-1, ABB-CE lists those CIVs which are vented and drained for the Type A test and those CIVs which are subject to the Type C test, and justifies those CIVs not included in the Type C test program. ABB-CE presented the following justifications for not performing CIV Type C tests:

1. CIVs on piping connected to the secondary side of the steam generator would leak into the containment because, during a design-basis LOCA, the secondary side pressure is higher than the primary-side pressure.

2. The water always present in the in-containment refueling water storage tank (IRWST) seals CIVs on piping connected directly to the IRWST.

3. The discharge pressure from the safety injection pump effectively seals against leakage for CIVs on pump discharge (or injection) lines.

4. The shutdown cooling system (SCS) with these CIVs must maintain safe shutdown conditions. These CIVs cannot be tested without compromising safety and therefore will be separately water tested as part of the RCS pressure boundary.

The NRC staff did not find justifications 3 and 4 acceptable because multiple systems would allow the CIVs on one loop to be tested while the others are available. The two 100-percent redundant SCS would ensure safe shutdown with one system operating while the CIVs in the other are being leak tested. If the safety injection pump fails and the system switches from cold-leg to hot-leg injection, any leakage from the system safety injection pump CIVs would pass to the environment. Therefore, the NRC staff concluded that both the SCS and safety injection pump system CIVs should be tested for leaks in accordance with 10 CFR Part 50, Appendix J.

ABB-CE rearranged valve elevations so that safety injection system (SIS) valves SI-602, 603, 616, 626, 636, and 646 are approximately 1.2 m (4 ft) below the minimum IRWST water level and SCS valves SI-600 and 601 are approximately 0.44 m (1.5 ft) below the minimum water level. The minimum IRWST water level is at elevation 24.5 m (80.5 ft) which is determined by the calculated minimum IRWST water level following a large LOCA. By using this valve rearrangement, the IRWST will provide a manometer effect to establish a water seal at the valves because the containment pressure is exerted on the surface of the IRWST liquid and the SIS forms a closed loop with containment following a pipe break. ABB-CE states that it complies with the intent of the regulation in 10 CFR Part 50, Appendix J, in maintaining water-sealed valves.

The NRC staff has reviewed the proposed alternative. Appendix J to 10 CFR Part 50, Section III.C.3(b) states that the installed isolation valve seal

water system fluid inventory is sufficient to assure the sealing function for at least 30 days at a pressure of 1.1 Pa. The proposed design of water-sealed isolation valves conforms to the requirement of 30-day water inventory but not on the sealing pressure of 1.1 Pa. However, the NRC staff finds that the closed loop and the manometer effect provide sufficient water sealing as long as the integrity of the closed loop and the elevation differential between the valves and the water level are maintained. As a result of the review, ABB-CE has committed to provide: (1) periodic pressure testing as described in DCD Sections 3.9.6 and 6.6 to ensure the integrity of the closed loop SIS outside containment is being maintained; and (2) a pre-operational test as described in DCD Section 14.2 to ensure the existence of the water seal.

Based on the NRC staff review and ABB-CE's commitment to the above periodic and pre-operational tests, the Commission has determined that the special circumstances described in 10 CFR 50.12(a)(2)(ii) exist in that the regulation need not be applied in this particular circumstance to achieve the underlying purpose because ABB-CE has proposed acceptable alternatives that accomplish the intent of the regulation. On this basis, the Commission concludes that a partial exemption from the requirements of Section III.C.3(b) is justified because the alternative water-sealed-valve design accomplishes the objectives of the regulatory requirement of sealing pressure of 1.1 Pa.

(6) Paragraph VI(a)(2) of Appendix A to 10 CFR Part 100 - Operating Basis Earthquake Design Consideration.

Appendix A to 10 CFR Part 100 requires, in part, that all structures, systems, and components (SSCs) of the nuclear power plant necessary for continued operation without undue risk to the health and safety of the public shall be designed to remain functional and within applicable stress and deformation limits when subject to an operating basis earthquake (OBE). In addition 10 CFR Part 100, Appendix A requires that the maximum vibratory ground acceleration of the OBE be at least one-half the maximum vibratory ground acceleration of the safe-shutdown earthquake (SSE).

In SECY-90-016, "Evolutionary Light Water Reactor Certification Issues and Their Relationship to Current Regulatory Requirements," dated January 12, 1990, the NRC staff requested the Commission's approval to decouple the level of the OBE ground motion from that of the SSE. The Commission approved this position in its staff requirements memorandum (SRM) of June 26, 1990. In SECY-93-087, "Policy, Technical, and Licensing Issues Pertaining to Evolutionary and Advanced Light-Water Reactor (ALWR) Designs," dated April 2, 1993, the NRC staff further requested that the Commission approve eliminating the OBE from the design of SSCs in both evolutionary and passive advanced reactors designs. The Commission approved this recommendation in its SRM of July 21, 1993.

The purpose of designing SSCs necessary for continued operation without undue risk to the health and safety of the public to withstand an OBE is to ensure that these SSCs remain functional and within applicable stress and deformation limits when subjected to the effects of the OBE vibratory ground motion. However, Appendix A to Part 100 also requires that these SSCs be designed to withstand the SSE and remain functional. Thus, when these SSCs are designed to remain functional for the SSE, they will also remain functional at a lesser earthquake level (one-third the SSE) provided all design functions at the OBE are accounted for. The basis for selecting one-

third of the SSE as the earthquake level at which the plant will be required to shutdown and be inspected for damage was that, at this level, the likelihood of damage and the frequency of earthquakes occurring was judged to be low based on actual earthquake experience. It should be noted that certain design functions had been verified only for the OBE loads in the past. These design functions were the evaluations of fatigue damage caused by earthquake cycles and relative seismic anchor motions in piping systems. With the elimination of the OBE from design, these design functions would not have been explicitly verified. Consequently, for System 80+, these design functions will be verified in conjunction with the SSE using applicable stress and deformation limits as described in Section 3.1.1 of NUREG-1462, "Final Safety Evaluation Report Related to the Certification of the System 80+ Design," dated August 1994.

Accordingly, the special circumstances described by 10 CFR 50.12(a)(2)(ii) exist in that the regulation need not be applied in this particular circumstance to achieve the underlying purpose of the rule because ABB-CE has proposed acceptable alternative analysis methods that accomplish the intent of the regulation. On this basis, the Commission has determined that the exemption is justified because the alternative analyses performed for the SSE and the need to perform an inspection of the plant following an earthquake at or above one-third of the SSE accomplish the design objectives of the OBE design analyses.

Paragraph (b)(3) of 10 CFR 50.49 - Environmental Qualification of Post-Accident Monitoring Equipment

In the generic DCD, ABB-CE stated that the design of the information systems important to safety will be in conformance with the guidelines of Regulatory Guide (RG) 1.97, "Instrumentation for Light-Water-Cooled Nuclear Power Plants to Assess Plant and Environs Conditions During and Following an Accident," Revision 3. However, the footnote for § 50.49(b)(3) references Revision 2 of RG 1.97 for selection of the types of post-accident monitoring equipment. As a result, the proposed design certification rule provided an exemption to this requirement.

In section C.1 of its comments, dated August 4, 1995, ABB-CE stated that it did not believe that an exemption from paragraph (b)(3) of 10 CFR 50.49 is needed or required. ABB-CE stated that:

The specific issue in question is a footnote to that regulation which identifies Revision 2 of RG 1.97 for guidance as to the types of variables to be monitored. RG 1.97 is clearly identified as a guidance document only and, therefore, the use of RG 1.97, Revision 3 for System 80+ -- at the request of the Staff and with the agreement of ABB-CE -- is not counter to any regulation, and does not require an exemption from any regulation.

The Commission agrees with ABB-CE's assertion that Revision 2 of RG 1.97 is identified in footnote 4 of 10 CFR 50.49 and should not be viewed as binding in this instance. Therefore, the Commission has determined that there is no need for an exemption from paragraph (b)(3) of 10 CFR 50.49 and has removed it from Section 5(b) of this appendix.

In paragraph (c), the Commission identified the new regulations that are applicable to the System 80+ design for the purposes of 10 CFR 52.48, 52.54, 52.59, and 52.63. The new regulations cover the following subjects:

1. Intersystem LOCA
2. Inservice Testing of Pumps and Valves
3. Digital Instrumentation and Control Systems
4. Alternate Offsite Power Source to Non-Safety Equipment
5. Offsite Power Source to Safety Divisions
6. Post-Fire Safe Shutdown
7. Analysis of External Events
8. Alternate AC Power Source
9. Core Debris Cooling
10. High Pressure Core Melt Ejection
11. Equipment Survivability
12. Containment Performance
13. Shutdown Risk
14. Steam Generator Tube Rupture

A detailed discussion and comment analysis for each new regulation is contained in Section II.A.4. The new regulations have the same effect as any other regulation, except for the additional compliance-backfit standard described in Section 8(c) of this appendix.

F. Issue resolution for this design certification.

The purpose of Section 6 of this appendix is to identify the scope of issues that are resolved by the Commission in this rulemaking and; therefore, are "matters resolved" within the meaning and intent of 10 CFR 52.63(a)(4). The section is divided into four parts: (a) the Commission's safety findings in adopting this appendix, (b) the scope and nature of issues which are resolved by this rulemaking, (c) the backfit restrictions applicable to the Commission with respect to this appendix, and (d) availability of secondary references.

Paragraph (a) describes in general terms the nature of the Commission's findings, and makes the finding required by 10 CFR 52.54 for the Commission's approval of this final design certification rule. Furthermore, paragraph (a) explicitly states the Commission's determination that this design provides adequate protection to the public health and safety.

Paragraph (b) sets forth the scope of issues which may not be challenged as a matter of right in subsequent proceedings. The introductory phrase of paragraph (b) clarifies that issue resolution as described in the remainder of the paragraph extends to the delineated NRC proceedings referencing this appendix. The remaining portion of paragraph (b) describes the general categories of information for which there is issue resolution.

Specifically, paragraph (b)(1) provides that all nuclear safety issues arising from the Atomic Energy Act of 1954, as amended, that are associated with the information in the NRC staff's FSER, the applicant's DCD, and the rulemaking record for this appendix are resolved within the meaning of § 52.63(a)(4). These issues include the information referenced in the DCD that are requirements (i.e., "secondary references"), as well as all issues arising from proprietary information which are intended to be requirements. Paragraph (b)(2) provides for issue preclusion of proprietary information. As discussed in section II.A.1 of this SOC, the inclusion of proprietary information within

the scope of issues resolved within the meaning of § 52.63(a)(4) represents a change from the Commission's intent during the proposed rule. Paragraph (b)(3) clarifies that departures from the DCD which are accomplished in compliance with the relevant procedures and criteria in Section 8 of this Appendix continue to be matters resolved in connection with this rulemaking. Paragraph (b)(4) provides that, for those plants located on sites whose site parameters do not exceed those assumed in the Technical Support Document (January 1995), all issues with respect to severe accident design alternatives arising under the National Environmental Policy Act of 1969 associated with the information in the Environmental Assessment for this design and the information regarding severe accident design alternatives in the applicant's Technical Support Document (January 1995) are also resolved within the meaning and intent of § 52.63(a)(4).

Paragraph (c) simply reiterates the restrictions (contained in 10 CFR 52.63 and Section 8 of this appendix) placed upon the Commission in ordering generic or plant-specific modifications, changes or additions to structures, systems or components, design features, design criteria, and ITAAC within the scope of the standard design. While the Commission does not believe that this rule language is necessary, the Commission has included such language in Section 6 to provide a concise statement of the scope and finality of this design certification rule.

Paragraph (d) provides the procedure for an interested member of the public to obtain access to proprietary information for the System 80+ design, in order to request and participate in proceedings identified in Section 6(b)(1) of this appendix, viz., proceedings involving licenses and applications which reference this appendix. As set forth in paragraph (d), access must first be sought from the design certification applicant. If ABB-CE refuses to provide the information, the person seeking access must request access from the Commission or the presiding officer, as applicable. Access to the proprietary information may be ordered by the Commission, but shall be subject to an appropriate non-disclosure agreement.

G. Duration of this design certification.

The purpose of Section 7 of this appendix is in part to specify the time period during which this design certification may be referenced by an applicant for a combined license, pursuant to 10 CFR 52.55. This section also states that the design certification remains valid for an applicant or licensee that references the design certification until the application is withdrawn or the license expires. Therefore, if an application references this design certification during the 15-year period, then the design certification continues in effect until the application is withdrawn or the license issued on that application expires. Also, the design certification continues in effect for the referencing license if the license is renewed. The Commission intends for this appendix to remain valid for the life of the plant that references the design certification to achieve the benefits of standardization and licensing stability. This means that changes to or plant-specific departures from information in the plant-specific DCD must be made pursuant to the change processes in Section 8 of this appendix for the life of the plant.

H. Processes for changes and departures.

The purpose of Section 8 of this appendix is to set forth the processes for generic changes to or plant-specific departures (including exemptions) from this appendix. The Commission adopted this restrictive change process in order to achieve a more stable licensing process for applicants and licensees that reference a design certification rule. Section 8 is divided into three paragraphs, which correspond to Tier 1, Tier 2, and backfitting for compliance with any of the additional applicable regulations identified in Section 5(c) of this appendix. The language of Section 8 distinguishes between generic *changes to* the DCD versus plant-specific *departures from* the DCD. Generic *changes* must be accomplished by rulemaking because the intended subject of the change is the design certification rule itself, as is contemplated by 10 CFR 52.63(a)(1). Consistent with 10 CFR 52.63(a)(2), any generic rulemaking changes are applicable to all plants, absent circumstances which render the change ("modification" in the language of § 52.63(a)(2)) "technically irrelevant." By contrast, plant-specific *departures* could be either a Commission-issued order to one or more applicants or licensees; or an applicant or licensee-initiated departure applicable only to that applicant's or licensee's plant(s), *i.e.*, a § 50.59-like departure or an exemption. Because these plant-specific departures will result in a DCD that is unique for that plant, Section 10 of this appendix requires an applicant or licensee to maintain a plant-specific DCD. For purposes of brevity, this discussion refers to both generic changes and plant-specific departures as "change processes."

Both Section 8 and this SOC refer to an "exemption" from one or more aspects of this appendix and the criteria for granting an exemption. The Commission cautions that where the exemption involves an underlying substantive requirement ("applicable regulation"), then the applicant or licensee requesting the exemption must also show that an exemption from the underlying applicable requirement meets the criteria of 10 CFR 50.12.

Tier 1.

The change processes for Tier 1 information are covered in paragraph 8(a). Generic changes to Tier 1 are accomplished by rulemaking that amends the generic DCD and are governed by the standards in 10 CFR 52.63(a)(1). This provision provides that the Commission may not modify, change, rescind, or impose new requirements by rulemaking except where necessary either to bring the certification into compliance with the Commission's regulations applicable and in effect at the time of issuance of the design certification or to assure adequate protection of the public health and safety or common defense and security. The rulemakings must include an opportunity for hearing with respect to the proposed change, as required by 10 CFR 52.63(a)(1), and the hearings will be conducted in accordance with 10 CFR Part 2, Subpart H. Departures from Tier 1 may occur in two ways: (1) the Commission may *order* a licensee to depart from Tier 1, as provided in paragraph (a)(3); and (2) an applicant or licensee may request an *exemption* from Tier 1, as provided in paragraph (a)(4). If the Commission seeks to order a licensee to depart from Tier 1, paragraph (a)(3) requires that the Commission find both that the departure is necessary for adequate protection or for compliance, and that special circumstances as defined in 10 CFR 50.12(a) are present. Paragraph (a)(4) provides that exemptions from Tier 1 requested by an applicant or

licensee are governed by the requirements of 10 CFR 52.63(b)(1) and 52.97(b), which provide an opportunity for a hearing.

Tier 2.

The change processes for the three different categories of Tier 2 information, *viz.*, Tier 2, Tier 2*, and Tier 2* with a time of expiration are set forth in paragraph 8(b). The change process for Tier 2 has the same elements as the Tier 1 change process, but some of the standards for plant-specific orders and exemptions are different. The Commission also adopted a "§ 50.59-like" change process in accordance with its SRMs on SECY-90-377 and SECY-92-287A.

The process for generic Tier 2 changes (including changes to Tier 2* and Tier 2* with a time of expiration) tracks the process for generic Tier 1 changes. As set forth in paragraph (b)(1), generic Tier 2 changes are accomplished by rulemaking amending the generic DCD, and are governed by the standards in 10 CFR 52.63(a)(1). This provision provides that the Commission may not modify, change, rescind or impose new requirements by rulemaking except where necessary either to bring the certification into compliance with the Commission's regulations applicable and in effect at the time of issuance of the design certification or to assure adequate protection of the public health and safety or common defense and security.

Departures from Tier 2 may occur in five ways: (1) the Commission may order a plant-specific departure, as set forth in paragraph (b)(3); (2) an applicant or licensee may request an exemption from a Tier 2 requirement as set forth in paragraph (b)(4); (3) a licensee may make a departure without prior NRC approval in accordance with paragraph (b)(5) [the "§ 50.59-like" process]; (4) the licensee may request NRC approval for proposed departures which do not meet the requirements in paragraph (b)(5) as provided in paragraph (b)(5)(iv); and (5) the licensee may request NRC approval for a departure from Tier 2* information, in accordance with paragraph (b)(6).

Similar to Commission-ordered Tier 1 departures and generic Tier 2 changes, Commission-ordered Tier 2 departures cannot be imposed except where necessary either to bring the certification into compliance with the Commission's regulations applicable and in effect at the time of issuance of the design certification or to assure adequate protection of the public health and safety or common defense and security, as set forth in paragraph 8(b)(3).

An applicant or licensee may request an exemption from Tier 2 information as set forth in paragraph (b)(4) of this Appendix. The applicant or licensee must establish that the exemption complies with 10 CFR 50.12. If the exemption is requested by an applicant for a combined license, the exemption is subject to litigation in the same manner as other issues in the combined license hearing, consistent with 10 CFR 52.63(b)(1).

Paragraph (b)(5) allows an applicant or licensee to depart from Tier 2 information without prior NRC approval if the proposed departure does not involve a change to or departure from Tier 1 or Tier 2* information, technical specifications, or involves an unreviewed safety question (USQ) as defined in paragraphs (b)(5)(ii) and (iii). The technical specifications identified in this paragraph are the technical specifications that will be developed during the COL review. Prior to issuance of the COL, an applicant is not controlled by the technical specifications under development but should be cognizant of the technical specifications in Chapter 16 of the generic DCD. The definition

of a USQ in paragraph (b)(5)(ii) is similar to the definition in 10 CFR 50.59 and it applies to all information in Tier 2 except for the information, identified in paragraph (b)(5)(ii), that resolves the severe accident issues. The process for evaluating proposed tests or experiments not described in Tier 2 will be incorporated into the change process for the portion of the design that is outside the scope of this design certification. Although paragraph (b)(5) does not specifically state, the Commission notes that departures must also comply with all applicable regulations unless an exemption or other relief is obtained.

The Commission believes that it is important to preserve and maintain the resolution of severe accident issues just like all other safety issues that were resolved during the design certification review (refer to SRM on SECY-90-377). However, because of the increased uncertainty in severe accident issue resolutions, the Commission has adopted separate criteria for determining whether a departure from information that resolves severe accident issues constitutes a USQ. The new criteria in paragraph (b)(5)(iii) will only apply to Tier 2 information in the sections of the generic DCD identified in paragraph (b)(5)(iii). If the proposed departure from Tier 2 information involves the resolution of other safety issues in addition to the severe accident issues, then the USQ determination for those issues should be based upon the criteria in Section 8(b)(5)(ii) of this appendix. An applicant or licensee that plans to depart from Tier 2 information, under Section 8(b)(5), must prepare a safety evaluation which provides the bases for the determination that the proposed change does not involve an unreviewed safety question, a change to Tier 1 or Tier 2* information, or a change to the technical specifications. In order to achieve the Commission's goals for design certification, the evaluation needs to consider all of the matters that were resolved in the DCD, such as generic issue resolutions that are relevant to the proposed departure. The benefits of the early resolution of safety issues would be lost if departures from the DCD were made that violated these resolutions without appropriate review. The evaluation of the relevant resolved issues needs to consider the proposed departure over the full range of power operation from startup to shutdown, including issues resolved under the heading of shutdown risk, as it relates to anticipated operational occurrences, transients, design basis accidents, and severe accidents. The evaluation should consider the tables in Sections 14.3 and 19.8 of the DCD to ensure that the proposed change does not impact Tier 1. These tables contain various cross-references from the plant safety analyses in Tier 2 to the important parameters that were included in Tier 1. Although many issues and analyses could have been cross-referenced, the listings in these tables were developed only for key plant safety analyses for the design. GE provided more detailed cross-references to Tier 1 for these analyses in a letter dated March 31, 1994, and ABB-CE provided more detailed cross-references in a letter dated June 10, 1994. If a proposed departure from Tier 2 involves a change to or departure from Tier 1 or Tier 2* information, technical specifications, or otherwise constitutes a USQ, then the applicant or licensee must obtain NRC approval through the appropriate process set forth in this appendix before implementing the proposed departure. The NRC does not endorse NSAC-125, "Guidelines for 10 CFR 50.59 Safety Evaluations," for performing safety evaluations required by Section 8(b)(5) of this appendix. However, the NRC will work with industry, if it is desired, to develop an appropriate guidance document for processing proposed changes under Section 8(b).

A party to an adjudicatory proceeding (e.g., for issuance of a combined license) who believes that an applicant or licensee has not complied with Section 8(b)(5) when departing from Tier 2 information, may petition to admit such a contention into the proceeding. As set forth in paragraph (b)(5)(vi), the petition must comply with the requirements of § 2.714(b)(2) and show that the departure does not comply with paragraph (b)(5). Any other party may file a response to the petition. If on the basis of the petition and any responses, the presiding officer in the proceeding determines that the required showing has been made, the matter shall be certified to the Commission for its final determination. In the absence of a proceeding, petitions alleging non-conformance with paragraph (b)(5) requirements applicable to Tier 2 departures will be treated as petitions for enforcement action under 10 CFR 2.206.

Certain Tier 2* information listed in paragraph (b)(6)(iii) is no longer designated as Tier 2* information after full power operation is first achieved following the Commission finding in 10 CFR 52.103(g). Thereafter, that information is deemed to be Tier 2 information that is subject to the departure requirements in paragraph (b)(5). By contrast, the Tier 2* information identified in paragraph (b)(6)(ii) retains its Tier 2* designation throughout the term of the combined license, including any period of renewal. Any requests for departures from Tier 2* information that affect Tier 1 must also comply with the requirements in Section 8(a) of this appendix.

Regardless of the way in which a departure is achieved, the Commission has determined that it is not necessary to impose an additional limitation, similar to that imposed on Tier 1 departures by 10 CFR 52.63(a) and paragraph 8(a)(3) and (4) of this appendix, whether the special circumstances in § 50.12(a) outweigh any decrease in safety that may result from the reduction in standardization. This type of additional limitation would unnecessarily restrict the flexibility of applicants and licensees with respect to Tier 2, which by its nature is not as safety significant as Tier 1.

Backfitting for Compliance with Additional Applicable Regulations

Paragraph (c) sets forth the criteria which must be met if the Commission is to require a backfit to either this appendix or, for a plant referencing this appendix, that portion of the plant subject to the appendix, where the backfit is for compliance with an "additional applicable regulation" in Section 5(c) of this appendix. Such backfitting can occur either by rulemaking amending this appendix (and may be initiated by the Commission either at its own instance or upon petition); or by Commission issuing an order to one or more plants referencing this appendix. Any backfit intended to achieve compliance with an "additional applicable regulation" must meet stringent criteria. First, the Commission must find that the asserted non-compliance constitutes a "substantial reduction in protection" to the public health and safety or common defense and security. If such is the case, the Commission must tailor the backfit to return to approximately the level of protection originally embodied at the time the new applicable regulation was first adopted; the Commission does not intend to impose such "compliance backfits" to achieve a level of protection greater than that intended when it adopted the "additional applicable regulation". Finally, the Commission must determine that the costs, both direct and indirect, of the implementation of

the backfit are "justified in view of [the] compensating increase in protection." The Commission regards these criteria as stringent enough to ensure that marginal compliance backfits are not imposed, thereby addressing the industry concerns about unfettered compliance backfits with new applicable regulations. The Commission would nonetheless be able to correct those significant non-compliances which result in the appendix (and any plant referencing this appendix) not achieving the level of protection to the public that was originally intended when the Commission adopted the additional applicable regulation.

I. Inspections, tests, analyses, and acceptance criteria (ITAAC).

The purpose of Section 9 of this Appendix is to set forth how the ITAAC in Tier 1 of this design certification rule are to be treated in a combined license proceeding. Paragraph (a) restates the responsibilities of the combined license applicant and holder in performing and successfully completing ITAAC, and notifying the NRC of such completion. Paragraph (a)(1) makes it clear that an applicant for a COL may proceed at its own risk with design and procurement activities subject to ITAAC, and that a COL holder may proceed at its own risk with design, procurement, construction, and preoperational testing activities subject to an ITAAC, even though the NRC may not have found that any particular ITAAC has been successfully completed. Paragraph (a)(2) requires the licensee to notify the NRC that the required inspections, tests, and analyses in the ITAAC have been completed and that the acceptance criteria have been met. Paragraphs (b)(1) and (2) essentially reiterate the NRC's responsibilities with respect to ITAAC as set forth in 10 CFR 52.99 and 52.103, as explained in II.C.1. Finally, paragraph (b)(3) states that ITAAC do not constitute regulatory requirements either for subsequent plant modifications within the scope of this design certification rule, or for renewal of the combined license. However, subsequent modifications must comply with the Tier 1 design descriptions unless the applicable requirements in 10 CFR 52.97 and Section 8 of this appendix have been complied with. As discussed in II.B.9, the Commission will defer a determination of the applicability of ITAAC and their effect in terms of issue resolution in 10 CFR Part 50 licensing proceedings to such time, if any, that a Part 50 applicant decides to reference this appendix.

J. Records and Reporting.

The purpose of Section 10 of this appendix is to set forth the requirements for maintaining records of changes to and departures from the generic DCD, which are to be reflected in the plant-specific DCD. Section 10 also sets forth the requirements for submitting reports (including updates to the plant-specific DCD) to the NRC. This section of the appendix is similar to the requirements for records and reports in 10 CFR Part 50, except for minor differences in information collection and reporting requirements, as discussed in section V below. Section 10(a)(1) of this appendix requires that a generic DCD and the proprietary information referenced in the generic DCD be maintained by the applicant for this rule. The generic DCD was developed, in part, to meet the requirements for incorporation by reference, including availability requirements. Therefore, the proprietary information could not be included in the generic DCD because it is not publicly available. However,

the proprietary information was reviewed by the NRC and, as stated in Section 6(b)(2) of this appendix, the Commission considers the information to be resolved within the meaning of 10 CFR 52.63(a)(4). Because this information is not in the generic DCD, the proprietary information, or its equivalent, is required to be provided by an applicant for a combined license. Therefore, to ensure that this information will be available, a requirement to maintain the proprietary information was added to Section 10(a)(1) of this appendix. The acceptable version of the proprietary information is identified in the version of the DCD that is incorporated into this rule. The generic DCD and the acceptable version of the proprietary information must be maintained for the period of time that this rule may be referenced.

Sections 10(a)(2) and (a)(3) of this appendix place record-keeping requirements on the applicant or licensee that references this design certification to maintain its plant-specific DCD to accurately reflect both generic changes to the generic DCD and plant-specific departures made pursuant to Section 8 of this appendix. The term "plant-specific" was added to Section 10(a)(2) and other Sections of this appendix to distinguish between the generic DCD that is incorporated by reference into this appendix, and the plant-specific DCD that the applicant is required to submit under Section 4(a)(2)(i) of this appendix. The requirement to maintain the generic changes to the generic DCD is explicitly stated to ensure that these changes are not only reflected in the generic DCD, which will be maintained by the applicant for design certification, but that the changes are also reflected in the plant-specific DCD. Therefore, records of generic changes to the DCD will be required to be maintained by both entities to ensure that both entities have up-to-date DCDs.

Section 10(a) of this appendix does not place record-keeping requirements on site-specific information that is outside the scope of this rule. As discussed in section III.D, the final safety analysis report (§ 52.79) will contain the plant-specific DCD and the site-specific information for a facility that references this rule. The phrase "site-specific portion of the final safety analysis report" in section 10(b)(3)(iv) of this appendix refers to the information that is contained in the final safety analysis report for a facility but is not part of the plant-specific DCD, i.e. required by Subpart C of Part 52 and Section 4 of this appendix. Therefore, this rule does not require that duplicate documentation be maintained by an applicant or licensee that references this rule, because the plant-specific DCD is part of the final safety analysis report for the facility (refer to the discussion on DOE's comment in section II.C.3).

Section 10(b)(1) and (b)(2) of this appendix establishes reporting requirements for applicants or licensees that reference this rule that are similar to the reporting requirements in 10 CFR Part 50. For currently operating plants, a licensee is required to maintain records of the basis for any design changes to the facility made under 10 CFR 50.59. Section 50.59(b)(2) requires a licensee to provide a summary report of these changes to the NRC annually, or along with updates to the facility final safety analysis report under 10 CFR 50.71(e). Section 50.71(e)(4) requires that these updates be submitted annually, or 6 months after each refueling outage if interval between successive updates does not exceed 24 months.

The reporting requirements vary according to four different time periods during facilities' lifetime as specified in Section 10(b)(3) of this appendix. Section 10(b)(3)(i) requires that if an applicant that references this rule

decides to make departures from the generic DCD, then the departures and any updates to the plant-specific DCD must be submitted with the initial application for a combined license. Under Section 10(b)(3)(ii), the applicant may submit any subsequent reports and updates along with its amendments to the application provided that the submittals are made at least once per year. Because amendments to an application are typically made more frequently than once a year, this should not be an unnecessary burden on the applicant.

Section 10(b)(3)(iii) requires that the reports be submitted quarterly during the period of facility construction. This increase in frequency of summary reports of departures from the plant-specific DCD is in response to the Commission's guidance on reporting frequency in its SRM on SECY-90-377, dated February 15, 1991. NEI stated in its comments (Attachment B, p. 116) that ... "the requirement for quarterly reporting imposes unnecessary additional burdens on licensees and the NRC." NEI recommended that the Commission adopt a "less onerous" requirement (e.g., semi-annual reports). The NRC does not agree with the NEI request because it does not provide for sufficiently timely notification of design changes during the critical period of facility construction. The NRC disagrees that the reports are an onerous burden because they are only summary reports, which describe the design changes, rather than detailed evaluations of the changes and determinations. The detailed evaluations remain available for audit on site, consistent with the requirements of 10 CFR Part 50. Quarterly reporting of design changes during the period of construction is necessary to closely monitor the status and progress of the construction of the plant. To make its finding under 10 CFR 52.99, the NRC must monitor the design changes made in accordance with Section 8 of this appendix. The ITAAC verify that the as-built facility conforms with the approved design and emphasizes design reconciliation and design verification. Quarterly reporting of design changes is particularly important in times where the number of design changes could be significant, such as during the procurement of components and equipment, detailed design of the plant at the start of construction, and during pre-operational testing. The frequency of updates to the plant-specific DCD is not increased during facility construction. After the facility begins operation, the frequency of reporting reverts to the requirement in Section 10(b)(3)(iv), which is consistent with the requirement for plants licensed under 10 CFR Part 50.

IV. Finding of No Significant Environmental Impact: Availability

The Commission has determined under the National Environmental Policy Act of 1969, as amended (NEPA), and the Commission's regulations in 10 CFR Part 51, Subpart A, that this design certification rule is not a major Federal action significantly affecting the quality of the human environment and, therefore, an environmental impact statement (EIS) is not required. The basis for this determination, as documented in the final environmental assessment, is that this amendment to 10 CFR Part 52 does not authorize the siting, construction, or operation of a facility using the System 80+ design; it only codifies the System 80+ design in a rule. The NRC will evaluate the environmental impacts and issue an EIS as appropriate in accordance with NEPA as part of the application(s) for the construction and operation of a facility.

In addition, as part of the final environmental assessment for the System 80+ design, the NRC reviewed ABB-CE's evaluation of various design

alternatives to prevent and mitigate severe accidents that was submitted in its Technical Support Document. The Commission finds that ABB-CE's evaluation provides a sufficient basis to conclude that there are no additional severe accident design alternatives beyond that currently incorporated into the System 80+ design which are cost-beneficial, whether considered at the time of the approval of the System 80+ design certification or in connection with the licensing of a future facility referencing the System 80+ design certification, where the plant referencing this appendix is located on a site whose site parameters do not exceed those assumed in the Technical Support Document. These issues are considered resolved for the System 80+ design.

The final environmental assessment, upon which the Commission's finding of no significant impact is based, and the Technical Support Document for the System 80+ design are available for examination and copying at the NRC Public Document Room, 2120 L Street, NW. (Lower Level), Washington, DC. Single copies are also available from Mr. Dino C. Scaletti, Mailstop O-11 H3, U.S. Nuclear Regulatory Commission, Washington, DC 20555, (301) 415-1104.

V. Paperwork Reduction Act Statement

This final rule amends information collection requirements that are subject to the Paperwork Reduction Act of 1995 (44 U.S.C. 3501 et seq.). These requirements were approved by the Office of Management and Budget, approval number 3150-0151. Should an application be received, the additional public reporting burden for this collection of information, above those contained in Part 52, is estimated to average 8 hours per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments on any aspect of this collection of information, including suggestions for reducing the burden, to the Information and Records Management Branch (T-6 F33), U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by Internet electronic mail at BJS1@NRC.GOV; and to the Desk Officer, Office of Information and Regulatory Affairs, NEOB-10202, (3150-0151), Office of Management and Budget, Washington, DC 20503.

Public Protection Notification

The NRC may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number.

VI. Regulatory Analysis

The NRC has not prepared a regulatory analysis for this final rule. The NRC prepares regulatory analyses for rulemakings that establish generic regulatory requirements applicable to all licensees. Design certifications are not generic rulemakings in the sense that design certifications do not establish standards or requirements for which all licensees must comply. Rather, design certifications are Commission approvals of specific nuclear power plant designs by rulemaking. Furthermore, design certification rulemakings are initiated by an applicant for a design certification, rather than the NRC. Preparation of a regulatory analysis in this circumstance would not be useful because the design to be certified is proposed by the applicant

rather than the NRC. For these reasons, the Commission concludes that preparation of a regulatory analysis is neither required nor appropriate.

VII. Regulatory Flexibility Act Certification

In accordance with the Regulatory Flexibility Act of 1980, 5 U.S.C. 605(b), the Commission certifies that this rulemaking will not have a significant economic impact upon a substantial number of small entities. The rule provides certification for a nuclear power plant design. Neither the design certification applicant nor prospective nuclear power plant licensees who reference this design certification rule fall within the scope of the definition of "small entities" set forth in the Regulatory Flexibility Act, 15 U.S.C. 632, or the Small Business Size Standards set out in regulations issued by the Small Business Administration in 13 CFR Part 121. Thus, this rule does not fall within the purview of the act.

VIII. Backfit Analysis

The Commission has determined that the backfit rule, 10 CFR 50.109, does not apply to this final rule because these amendments do not impose requirements on existing 10 CFR Part 50 licensees. Therefore, a backfit analysis was not prepared for this rule.

List of Subjects in 10 CFR Part 52

Part 52 - Administrative practice and procedure, Antitrust, Backfitting, Combined license, Early site permit, Emergency planning, Fees, Incorporation by reference, Inspection, Limited work authorization, Nuclear power plants and reactors, Probabilistic risk assessment, Prototype, Reactor siting criteria, Redress of site, Reporting and record keeping requirements, Standard design, Standard design certification.

For the reasons set out in the preamble and under the authority of the Atomic Energy Act of 1954, as amended; the Energy Reorganization Act of 1974, as amended; and 5 U.S.C. 552 and 553; the NRC is adopting the following amendments to 10 CFR Part 52.

1. The authority citation for 10 CFR Part 52 continues to read as follows:

AUTHORITY: Secs. 103, 104, 161, 182, 183, 186, 189, 68 Stat. 936, 948, 953, 954, 955, 956, as amended, sec. 234, 83 Stat. 1244, as amended (42 U.S.C. 2133, 2201, 2232, 2233, 2236, 2239, 2282); secs. 201, 202, 206, 88 Stat. 1243, 1244, 1246, 1246, as amended (42 U.S.C. 5841, 5842, 5846).

2. In § 52.8, paragraph (b) is revised to read as follows:

§ 52.8 Information collection requirements: OMB approval.

* * * * *

(b) The approved information collection requirements contained in this part appear in §§ 52.15, 52.17, 52.29, 52.45, 52.47, 52.57, 52.75, 52.77, 52.78, 52.79, Appendix A, and Appendix B.

3. A new Appendix B to 10 CFR Part 52 is added to read as follows:

Appendix B To Part 52--Design Certification Rule for the System 80+ design

1. Introduction.

Appendix B constitutes design certification for the System 80+¹ standard plant design, in accordance with 10 CFR Part 52, Subpart B. The applicant for certification of the System 80+ design was Combustion Engineering, Inc. (ABB-CE).

2. Definitions.

As used in this part:

(a) *Generic design control document* (generic DCD) means the document that contains the generic Tier 1 and Tier 2 information that is incorporated by reference into this appendix.

(b) *Plant-specific DCD* means the document, maintained by an applicant or licensee who references this design certification rule, consisting of the information in the generic DCD, as modified and supplemented by the plant-specific departures and exemptions made under Section 8 of this appendix.

(c) *Tier 1* means the portion of the design-related information contained in the generic DCD that is approved and certified by this design certification rule (hereinafter Tier 1 information). The design descriptions, interface requirements, and site parameters are derived from Tier 2 information. Tier 1 information includes:

- (1) Definitions and general provisions;
- (2) Design descriptions;
- (3) Inspections, tests, analyses, and acceptance criteria (ITAAC);
- (4) Significant site parameters; and
- (5) Significant interface requirements.

(d) *Tier 2* means the portion of the design-related information contained in the generic DCD that is approved but not certified by this design certification rule (hereinafter Tier 2 information). Compliance with Tier 2 is required, but generic changes to and plant-specific departures from Tier 2 are governed by Section 8 of this appendix. Tier 2 information includes:

- (1) Information required by 10 CFR 52.47, with the exception of technical specifications and conceptual design information;
- (2) Information required for a final safety analysis report under 10 CFR 50.34;

(3) Supporting information on the inspections, tests, and analyses that will be performed to demonstrate that the acceptance criteria in the ITAAC have been met; and

(4) Combined license (COL) action items (COL license information), which identify certain matters that shall be addressed in the site-specific portion of the final safety analysis report by an applicant who references this

¹"System 80+" is a trademark of Combustion Engineering, Inc.

appendix. These items constitute information requirements but do not otherwise constitute substantive requirements for judging the adequacy of the information submitted.

(e) *Tier 2** means the portion of the Tier 2 information, designated as such in the generic DCD, which is subject to the change process in Section 8(b)(6) of this appendix. This designation expires for some Tier 2* information pursuant to Section 8(b)(6).

(f) All other terms in this appendix have the meaning set out in 10 CFR 50.2, 10 CFR 52.3, or Section 11 of the Atomic Energy Act of 1954, as amended, as applicable.

3. Scope and contents of this design certification.

(a) Tier 1 and Tier 2 in the System 80+ Design Control Document, ABB-CE, dated _____ are approved for incorporation by reference by the Director of the Office of the Federal Register on [Insert date of approval] in accordance with 5 U.S.C. 552(a) and 1 CFR Part 51. Copies of the generic DCD may be obtained from [Insert name and address of applicant or organization designated by the applicant]. Copies are also available for examination and copying at the NRC Public Document Room, 2120 L Street NW. (Lower Level), Washington, DC 20555, and for examination at the NRC Library, 11545 Rockville Pike, Rockville, Maryland 20582-2738.

(b) An applicant or licensee referencing this appendix, in accordance with Section 4 of this appendix, shall comply with the requirements of this appendix, including Tier 1 and Tier 2, except as otherwise provided in this appendix.

(c) If there is a conflict between Tier 1 and Tier 2 of the DCD, then Tier 1 controls.

(d) If there is a conflict between the generic DCD and either the application for design certification for the System 80+ design or NUREG-1462, "Final Safety Evaluation Report related to the Certification of the System 80+ Design," dated August 1994 (FSER) and any supplements thereto, then the generic DCD controls.

(e) Conceptual design information and generic technical specifications, as set forth in the generic DCD, are not part of this appendix.

4. Applications and licenses referencing this design certification: additional requirements and restrictions.

(a) An applicant for a combined license that wishes to reference this Appendix shall, in addition to complying with the requirements of 10 CFR 52.77, 52.78, and 52.79, comply with the following requirements:

- (1) Incorporate by reference, as part of its application, this appendix;
- (2) Include, as part of its application:

(i) A plant-specific DCD containing the same information and utilizing the same organization and numbering as the generic DCD for the System 80+ design, as modified and supplemented by the applicant's exemptions and departures;

(ii) The reports on departures from and updates to the plant-specific DCD required by Section 10(b) of this Appendix;

(iii) Technical specifications for the plant that are required by § 50.36 and § 50.36a;

- (iv) Information demonstrating compliance with the site parameters and interface requirements;
- (v) Information that addresses the COL action items; and
- (vi) The information required by 10 CFR 52.47(a) that is not within the scope of this rule.
- (vii) Descriptions of the initial 120-month in-service testing (IST) and in-service inspection (ISI) programs for pumps and valves subject to the test requirements set forth in 10 CFR 50.55a(f), which utilize:
 - (A) Non-intrusive techniques available twelve months prior to the date of the COL application to detect degradation and monitor performance characteristics of check valves; and
 - (B) A method to determine the frequency necessary for disassembly and inspection of each pump and valve to detect degradation that would prevent the component from performing its safety function and which cannot be detected through the use of non-intrusive techniques;
- (viii) A description of a program for outage planning and control that ensures:
 - (A) The availability and functional capability during shutdown and low power operations of features important to safety during such operations; and
 - (B) The consideration of fire, flood, and other hazards during shutdown and low power operations; and
 - (ix) A description of a design reliability assurance program that:
 - (A) Includes the program's scope, purpose, and objectives;
 - (B) Evaluates the structures, systems, and components in the design to determine their degree of risk-significance;
 - (C) Generates a list of structures, systems, and components designated as risk-significant;
 - (D) For those structures, systems, and components designated as risk-significant, considers both:
 - (AA) Industry-wide experience, analytical models, and applicable requirements to determine dominant failure modes; and
 - (BB) Industry-wide operational, maintenance, and monitoring experience to identify key assumptions and risk insights from probabilistic, deterministic, and other analytical methods; and
 - (E) Considers the dominant failure modes, incorporates the risk insights, and preserves the key assumptions identified in paragraph (a)(2)(ix)(BB) of this Section in the design.
- (3) Physically include, in the plant-specific DCD, the proprietary information referenced in the System 80+ DCD; and
- (4) Implement the design reliability assurance program required by paragraph (a)(2)(ix) of this Section.
- (b) A holder of a combined license that references this appendix shall, in addition to complying with the requirements in 10 CFR 52.83, and 52.99 comply with the following requirements:
 - (1) Implement the portions of the IST and ISI programs required by paragraph (a)(2)(vii) of this section, as approved by the Commission and include in each successive 120-month IST testing program non-intrusive techniques available twelve months prior to the date of the start of each 120-month interval to detect degradation and monitor performance characteristics of check valves.
 - (2) Implement the program for outage planning and control required by paragraph (a)(2)(viii) of this Section; and

(3) Implement the design reliability assurance program required by paragraph (a)(2)(ix) of this Section

(c) Facility operation is not within the scope of this appendix, and the Commission reserves the right to impose requirements for facility operation on holders of licenses referencing this appendix by rule, regulation, order, or license condition.

(d) The Commission reserves the right to determine whether, and in what manner, this appendix may be referenced by an applicant for a construction permit or operating license under 10 CFR Part 50.

5. Applicable regulations.

(a) Except as indicated in paragraphs (b) and (c) of this section, the regulations that apply to the System 80+ design are in 10 CFR Parts 20, 50, 73, and 100 codified as of [insert the date 30 days after the publication date] that are applicable and technically relevant, as described in the FSER and any associated supplements.

(b) The System 80+ design is exempt from portions of the following regulations, as described in the FSER (index provided in Section 1.6 of the FSER):

(1) Paragraph (f)(2)(iv) of 10 CFR 50.34 - Separate Plant Safety Parameter Display Console;

(2) Paragraphs (f)(2)(vii), (viii), (xxvi), and (xxviii) of 10 CFR 50.34 - Accident Source Terms;

(3) Paragraph (f)(2)(viii) of 10 CFR 50.34 - Post-Accident Sampling for Hydrogen, Boron, Chloride, and Dissolved Gases;

(4) Paragraph (f)(3)(iv) of 10 CFR 50.34 - Dedicated Containment Penetration;

(5) Paragraphs III.A.1(a) and III.C.3(b) of Appendix J to 10 CFR 50 - Containment Leakage Testing; and

(6) Paragraph VI(a)(2) of 10 CFR Part 100, Appendix A - Operating Basis Earthquake Design Consideration.

(c) In addition to the regulations specified in paragraph (a) of this section, the following new regulations are applicable for the purposes of 10 CFR 52.48, 52.54, 52.59 and 52.63:

(1) The low-pressure piping systems and subsystems of this design that interface with the reactor coolant pressure boundary must be designed for a normal operating pressure of at least 40 percent of the normal reactor operating pressure, to the extent practical as determined on [insert date of Commission approval].

(2) Piping systems of this design associated with pumps and valves subject to the test requirements set forth in 10 CFR 50.55a(f) must be designed to allow for:

(i) Full flow testing of pumps at maximum design flow,

(ii) Flow testing of check valves at flows sufficient to fully-open the valve, provided the valve's full-open position can be positively confirmed, or with the maximum design basis accident flowrate, and

(iii) Testing of motor operated valves under conditions as specified in section 3.9 of the DCD, up to design basis differential pressure, to demonstrate the capability of the valves to operate under design basis conditions.

(3) The digital instrumentation and control systems of this design must provide for:

- (i) defense-in-depth and diversity,
- (ii) adequate defense against common-mode failures, and
- (iii) independent backup manual controls and displays for critical safety functions in the control room.

(4) The electric power system of this design must include an alternate offsite power source that has sufficient capacity and capability to provide power to non-safety equipment sufficient to provide the operator with the capability to bring the plant to a safe shutdown, following a loss of the normal power supply and reactor trip.

(5) The electric power system of this design must include at least one offsite circuit for supplying power to each redundant safety division. This circuit shall be designed such that non-safety loads do not have any significant adverse affect on the capability of the offsite circuit to provide power to each safety division.

(6) All structures, systems, and components of this design important to safe shutdown, except for the containment annulus, must be designed to ensure that:

(i) Safe shutdown can be achieved assuming that all equipment in any one fire area will be rendered inoperable by fire and that re-entry into the fire area for repairs and operator actions is not possible, except that this provision does not apply to (1) the main control room, provided that an alternative shutdown capability exists and is physically and electrically independent of the main control room, and (2) the reactor containment;

(ii) Smoke, hot gases, or fire suppressant will not migrate from one fire area into another to the extent they could adversely affect safe-shutdown capabilities, including operator actions; and

(iii) In the reactor containment, redundant shutdown systems must be provided with fire protection capabilities and means to limit fire damage such that, to the extent practical as of [insert date of Commission approval], one shutdown division be free of fire damage.

(7) The probabilistic risk assessment (PRA) required by 10 CFR 52.47(a)(1)(v) must include an assessment of internal and external events. For external events, simplified (bounding) probabilistic methods and margins methods may be used instead of detailed PRA analyses to identify potential vulnerabilities and important safety insights for the design in order to incorporate the insights in the design. Simplified bounding risk analyses for fires and floods may be performed when detailed design information, such as pipe and cable routing, is not available. For earthquakes, the seismic margins analysis must be based on a review earthquake level of one and two-thirds the acceleration of the safe-shutdown earthquake (i.e., review earthquake level of 0.5g.)

(8) The electric power system of this design must include an on-site alternate AC power source of diverse design capable of providing power to at least one complete set of equipment sufficient to achieve and maintain safe-shutdown in the event of a station blackout.

(9) For the severe accident sequences identified in Section 19.11 of the DCD, this design must include the following design features that, in combination with other design features, ensure that environmental conditions (pressure and temperature) described in Section 19.11 of the DCD resulting

from interactions of molten core debris with containment structures do not exceed ASME Code Service Level C for steel containments or Factored Load Category for concrete containments for a time from the initiation of the accident sequence sufficient to mitigate them in view of their probability of occurrence and the uncertainties in severe accident progression and phenomenology:

(i) A minimum of 79 m² of unobstructed reactor cavity floor space for molten core debris spreading;

(ii) A system capable of directly or indirectly flooding the reactor cavity for cooling molten core debris; and

(iii) Concrete to protect portions of the containment liner and the reactor pedestal.

(10) This design must include:

(i) a safety-related or other highly reliable means to depressurize the reactor coolant system and

(ii) cavity design features to reduce the amount of ejected core debris that may reach the upper containment.

(11) This design must include analyses based on analytical techniques in use as of [insert date of Commission approval], to demonstrate that:

(i) Electrical and mechanical equipment that prevents or mitigates the consequences of a severe accident must be capable of performing their functions for a time period sufficient to prevent or mitigate the consequences of that severe accident under the environmental conditions (e.g., pressure, temperature, radiation) described in Section 19.11.4.4.1 of the DCD for that severe accident; and

(ii) Instrumentation that monitors plant conditions during a severe accident must be capable of performing its function for a time period sufficient to prevent or mitigate the consequences of that severe accident under the environmental conditions (e.g., pressure, temperature, radiation) described in Section 19.11.4.4.1 of the DCD for that severe accident.

(12) This design must include design features intended to limit the conditional containment failure probability to less than 0.1 for the severe accident sequences identified in Section 19.11 of the DCD.

(13) This design must include assessments of:

(i) Features that minimize shutdown risk;

(ii) The reliability of decay heat removal systems;

(iii) Features that mitigate vulnerabilities resulting from other design features; and

(iv) Features that assure the operator's ability to shut down the plant safely and maintain it in a safe condition in the event of fires and floods occurring with the plant in modes other than full power.

(14) This design must include a systematic evaluation of plant response to a steam generator tube rupture (SGTR) to:

(i) Identify potential design vulnerabilities;

(ii) Assess potential design improvements that reduce the amount of containment bypass leakage that could result from a SGTR; and

(iii) Incorporate in the design those design improvements that are significant and practical and do not impact excessively on the plant.

6. Issue resolution for this design certification.

(a) The Commission has determined that the structures, systems, components, and design features of the System 80+ design comply with the provisions of the Atomic Energy Act of 1954, as amended, and the applicable regulations identified in Section 5 of this appendix, and therefore, provide adequate protection to the health and safety of the public. A conclusion that a matter is resolved includes the finding that additional or alternative structures, systems, components, design features, design criteria, testing, analyses, acceptance criteria, or justifications are not necessary for the System 80+ design.

(b) The Commission considers the following matters resolved within the meaning of 10 CFR 52.63(a)(4) in subsequent proceedings for issuance of a combined license, amendment of a combined license, or renewal of a combined license, proceedings held pursuant to 10 CFR 52.103, and enforcement proceedings where these proceedings reference this appendix:

(1) All nuclear safety issues associated with the information in the FSER and any associated supplements, the generic DCD (including referenced information which the context indicates is intended as requirements), and the rulemaking record for certification of the System 80+ design;

(2) All nuclear safety issues associated with the information in proprietary documents referenced and in context is intended as requirements in the generic DCD for the System 80+ design;

(3) Except as provided in Section 8(b)(5)(vi) of this appendix, all departures from Tier 2 pursuant to and in compliance with the change processes in Section 8(b)(5) of this appendix that do not require prior NRC approval;

(4) All environmental issues concerning severe accident design alternatives associated with the information in the NRC's final environmental assessment for the System 80+ design and Revision 2 of the Technical Support Document for the System 80+ design, dated January 1995, for plants referencing this appendix whose site parameters are within those specified in the Technical Support Document.

(c) Except in accordance with the change processes in Section 8 of this appendix, the Commission may not require an applicant or licensee who references this appendix to:

(1) Modify structures, systems, components, or design features as described in the generic DCD;

(2) Provide additional or alternative structures, systems, components, or design features not discussed in the generic DCD; or

(3) Provide additional or alternative design criteria, testing, analyses, acceptance criteria, or justification for structures, systems, components, or design features discussed in the generic DCD.

(d) Persons who wish to review proprietary information or other secondary references in the DCD for the System 80+ design, in order to request or participate in the hearing required by 10 CFR 52.85 or the hearing provided under 10 CFR 52.103, or to request or participate in any other hearing relating to the certified design in which interested persons have adjudicatory hearing rights, shall first request access to such information from ABB-CE. The request must state *with particularity*:

(i) the nature of the proprietary or other information sought;

(ii) the reason why the information currently available to the public in the NRC's public document room is insufficient;

(iii) the relevance of the requested information to the hearing issue(s) which the person proposes to raise; and

(iv) a showing the requesting person has the capability to understand and utilize the requested information.

(3) If a person claims that the information is necessary to prepare a request for hearing, the request must be filed no later than 15 days after publication in the Federal Register of the notice required either by 10 CFR 52.85 or 10 CFR 52.103. If ABB-CE declines to provide the information sought, ABB-CE shall send a written response within ten (10) days of receiving the request to the requesting person setting forth with particularity the reasons for its refusal. The person may then request the Commission (or presiding officer, if a proceeding has been established) to order disclosure. The person shall include copies of the original request (and any subsequent clarifying information provided by the requesting party to the applicant) and the applicant's response. The Commission and presiding officer shall base their decisions *solely* on the person's original request (including any clarifying information provided by the requesting person to ABB-CE), and ABB-CE's response. The Commission and presiding officer may order ABB-CE to provide access to some or all of the requested information, subject to an appropriate non-disclosure agreement.

7. Duration of this design certification.

This design certification may be referenced for a period of 15 years from [insert the date 30 days after the publication date], except as provided for in 10 CFR 52.55(b) and 52.57(b). This design certification remains valid for an applicant or licensee who references this appendix until the application is withdrawn or the license expires, including any period of extended operation under a renewed license.

8. Processes for changes and departures.

(a) Tier 1 information.

(1) Generic changes to Tier 1 information are governed by the requirements in 10 CFR 52.63(a)(1).

(2) Generic changes to Tier 1 information are applicable to all plants referencing the design certification as set forth in 10 CFR 52.63(a)(2).

(3) Departures from Tier 1 information that are imposed by the Commission through plant-specific orders are governed by the requirements in 10 CFR 52.63(a)(3).

(4) Exemptions from Tier 1 information are governed by the requirements in 10 CFR 52.63(b)(1) and § 52.97(b).

(b) Tier 2 information.

(1) Generic changes to Tier 2 information shall be governed by the same requirements in 10 CFR 52.63(a)(1) that govern generic changes to Tier 1.

(2) Generic changes to Tier 2 information are applicable to all plants referencing the design certification as set forth in 10 CFR 52.63(a)(2).

(3) The Commission may not impose new requirements on Tier 2 by plant-specific order while the design certification is in effect under §§ 52.55 or 52.61, unless:

(i) A modification is necessary to secure compliance with the Commission's regulations applicable and in effect at the time the certification was issued, as set forth in Section 5 of this Appendix, or to

assure adequate protection of the public health and safety or the common defense and security; and

(ii) Special circumstances as defined in 10 CFR 50.12(a) are present.

(4) An applicant or licensee who references the design certification may request an exemption from Tier 2 information. The Commission may grant such a request only if it determines that the exemption will comply with the requirements of 10 CFR 50.12(a). The granting of such an exemption must be subject to litigation in the same manner as other issues in the combined license hearing.

(5)(i) An applicant or licensee who references the design certification may depart from Tier 2 information, without prior NRC approval, unless the proposed departure involves a change to or departure from Tier 1 information, Tier 2* information, or the technical specifications, or involves an unreviewed safety question as defined in paragraphs (b)(5)(ii) and (b)(5)(iii) of this section. When evaluating the proposed departure, an applicant or licensee shall consider all matters described in the plant-specific DCD.

(ii) A proposed departure from Tier 2, other than one affecting resolution of a severe accident issue identified in Section 19.11 of the plant-specific DCD including appendices 19.11A through 19.11L, involves an unreviewed safety question if:

(A) The probability of occurrence or the consequences of an accident or malfunction of equipment important to safety previously evaluated in the plant-specific DCD may be increased;

(B) A possibility for an accident or malfunction of a different type than any evaluated previously in the plant-specific DCD may be created; or

(C) The margin of safety as defined in the basis for any technical specification is reduced.

(iii) A proposed departure from Tier 2 affecting resolution of a severe accident issue identified in Section 19.11 of the plant-specific DCD, including appendices 19.11A through 19.11L, involves an unreviewed safety question if:

(A) There is a substantial increase in the probability of a severe accident such that a particular severe accident previously reviewed and determined to be not credible could become credible; or

(B) There is a substantial increase in the consequences to the public of a particular severe accident previously reviewed.

(iv) If a departure involves an unreviewed safety question as defined in paragraph (b)(5) of this section, it is governed by 10 CFR 50.90 and 92.

(v) A departure from Tier 2 information that is made under paragraph (b)(5) of this section does not require an exemption from this Appendix.

(vi) A party to an adjudicatory proceeding for either the issuance, amendment, or renewal of a combined license or for operation under 10 CFR 52.103(a), who believes that an applicant or licensee has not complied with paragraph (b)(5) of this Section when departing from Tier 2 information, may petition to admit into the proceeding such a contention. In addition to compliance with the general requirements of 10 CFR 2.714(b)(2), the petition must demonstrate that the departure does not comply with paragraph (b)(5) of this Section. Any other party may file a response thereto. If, on the basis of the petition and any response, the presiding officer determines that a sufficient showing has been made, the presiding officer shall certify the matter directly to the Commission for determination of the admissibility of the contention. The Commission may admit such a contention if it determines

the petition raises a genuine issue of fact regarding compliance with paragraph (b)(5) of this Section.

(6)(i) An applicant for a combined license may not depart from Tier 2* information, which is designated with italicized text or brackets and an asterisk in the generic DCD, without NRC approval. The departure will not be considered a resolved issue, within the meaning of Section 6 of this appendix and 10 CFR 52.63(a)(4).

(ii) A holder of a combined license may not depart from the following Tier 2* matters without prior NRC approval. A request for a departure will be treated as a request for a license amendment under 10 CFR §§ 50.90 and 50.92.

(A) Equipment seismic qualification methods.

(B) Piping design acceptance criteria.

(C) Fuel burnup limit.

(D) Control room human factors engineering.

(iii) A holder of a combined license may not, before the plant first achieves full power following the finding required by 10 CFR 52.103(g), depart from the following Tier 2* matters except in accordance with paragraph (b)(6)(ii) of this Section. After the plant first achieves full power, the following Tier 2* matters revert to Tier 2 status and are thereafter subject to the departure provisions in paragraph (b)(5) of this Section.

(A) ASME Boiler & Pressure Vessel Code, Section III.

(B) AISC N-690 and ACI 349 Industrial Codes.

(C) Motor-operated valves.

(D) First cycle fuel and control rod design, except burnup limit.

(E) Instrumentation and controls setpoint methodology.

(F) Instrumentation and controls hardware and software changes.

(G) Instrumentation and controls environmental qualification.

(iv) Departures from Tier 2* information that are made under paragraph (b)(6) of this section do not require an exemption from this appendix.

(c) Additional applicable regulations.

The Commission may not modify or rescind existing requirements or impose new requirements on either this appendix or a plant referencing this appendix, whether on the Commission's own motion or in response to a petition from any person, on the basis that either the DCD or the referencing plant fails to comply with an additional applicable regulation in Section 5(c) of this appendix, unless the Commission determines that:

(1) the failure to comply results in a substantial reduction in the protection of public health and safety or common defense and security;

(2) the new requirements provide a compensating increase in protection not exceeding the level of protection originally embodied in the additional applicable regulation; and

(3) the direct and indirect costs of implementation are justified in view of this compensating increase in protection.

9. Inspections, tests, analyses, and acceptance criteria (ITAAC).

(a)(1) An applicant or licensee who references the design certification shall perform and demonstrate conformance with the ITAAC before fuel load. With respect to activities subject to an ITAAC, an applicant for a COL may proceed at its own risk with design and procurement activities, and a licensee may proceed at its own risk with design, procurement, construction, and preoperational activities, even though the NRC may not have found that any particular ITAAC has been satisfied.

(2) The licensee shall notify the NRC that the required inspections, tests, and analyses in the ITAAC have been successfully completed and that the corresponding acceptance criteria have been met.

(3) In the event that an activity is subject to an ITAAC, and the applicant or licensee has not demonstrated that the ITAAC has been satisfied, the applicant or licensee may either take corrective actions to successfully complete that ITAAC, request an exemption from the ITAAC in accordance with Section 8 of this appendix and 10 CFR 52.97(b), or petition for rulemaking to amend this appendix by changing the requirements of the ITAAC, under 10 CFR 2.802 and 52.97(b). Such rulemaking changes to the ITAAC must meet the requirements of Section 8(a)(1) of this appendix.

(b)(1) The NRC shall ensure that the required inspections, tests, and analyses in the ITAAC are performed. The NRC shall verify that the inspections, tests, and analyses referenced by the licensee have been successfully completed and, based solely thereon, find the prescribed acceptance criteria have been met. At appropriate intervals during construction, the NRC shall publish notices of the successful completion of ITAAC in the *Federal Register*.

(2) In accordance with 10 CFR 52.99 and 52.103(g), the Commission shall find that the acceptance criteria in the ITAAC for the combined license are met before fuel load.

(3) After the Commission has made the finding required by 10 CFR 52.103(g), the ITAAC do not constitute regulatory requirements either for subsequent plant modifications during operation, or for renewal of the combined license. However, subsequent modifications must comply with the Tier 1 and Tier 2 design descriptions in the plant-specific DCD unless the licensee has complied with the applicable requirements of 10 CFR 52.97 and Section 8 of this appendix.

10. Records and Reporting.

(a) Records.

(1) The applicant for this design certification rule shall maintain a copy of the generic DCD that includes all generic changes to Tier 1 and Tier 2. The applicant shall maintain the proprietary information referenced in the generic DCD for the period that this appendix may be referenced, as specified in Section 7 of this appendix.

(2) An applicant or licensee who references this design certification shall maintain the plant-specific DCD to accurately reflect both generic changes to the generic DCD and plant-specific departures made pursuant to Section 8 of this appendix throughout the period of application and for the term of the license (including any period of renewal).

(3) An applicant or licensee who references this design certification shall prepare and maintain written safety evaluations which provide the bases for the determinations required by Section 8(b) of this appendix. These evaluations must be retained throughout the period of application and for the term of the license (including any period of renewal).

(b) Reporting.

(1) An applicant or licensee who references this design certification rule shall submit a report to the NRC containing a brief description of any departures from the plant-specific DCD, including a summary of the safety

evaluation of each. This report must be filed in accordance with the filing requirements applicable to reports in 10 CFR 50.4.

(2) An applicant or licensee shall submit updates to its plant-specific DCD, which reflect the generic changes to the generic DCD and the plant-specific departures made pursuant to Section 8 of this appendix. These updates shall be filed in accordance with the filing requirements applicable to final safety analysis report updates in 10 CFR 50.4 and 50.71(e).

(3) The reports and updates required by Section 10(b)(1) and (2) above must be submitted as follows:

(i) On the date that an application for a combined license referencing this design certification rule is submitted, the application shall include the report and any updates to the plant-specific DCD.

(ii) During the interval from the date of application to the date of issuance of a combined license, the report and any updates to the plant-specific DCD must be submitted annually and may be submitted along with amendments to the application.

(iii) During the interval from the date of issuance of a combined license to the date the Commission makes its findings under 10 CFR 52.103(g), the report must be submitted quarterly. Updates to the plant-specific DCD must be submitted annually.

(iv) After the Commission has made its finding under 10 CFR 52.103(g), reports and updates to the plant-specific DCD may be submitted annually or along with updates to the site-specific portion of the final safety analysis report for the facility at the intervals required by 10 CFR 50.71(e), or at shorter intervals as specified in the combined license.

Dated at Rockville, Maryland, this ___ day of _____, 1996.

For the Nuclear Regulatory Commission.

John C. Hoyle,
Secretary of the Commission

FINAL ENVIRONMENTAL ASSESSMENT
BY THE OFFICE OF NUCLEAR REACTOR REGULATION
U.S. NUCLEAR REGULATORY COMMISSION
RELATING TO THE CERTIFICATION OF THE
SYSTEM 80+ STANDARD NUCLEAR PLANT DESIGN
DOCKET NO. 52-002

TABLE OF CONTENTS

	<u>Page</u>
1.0 INTRODUCTION AND SUMMARY	1
2.0 THE NEED FOR THE PROPOSED ACTION	2
3.0 ALTERNATIVES TO THE PROPOSED ACTION	2
3.1 Severe Accident Design Alternatives	3
3.2 Estimate of Risk for the System 80+	4
3.3 Identification of Potential Design Alternatives	5
3.4 Description of Design Alternatives	6
3.5 Risk Reduction Potential of Design Alternatives	9
3.6 Conclusions	13
4.0 THE ENVIRONMENTAL IMPACT OF THE PROPOSED ACTION	13
5.0 AGENCIES AND PERSONS CONSULTED AND SOURCES USED	14
6.0 FINDING OF NO SIGNIFICANT IMPACT	15
Table 1 Summary of ABB-CE'S Assessment of Risk Reduction for Candidate Design Improvements	16
Table 2 Potential Design Improvements and Associated Costs (ABB-CE) . .	17

1.0 INTRODUCTION AND SUMMARY

The U.S. Nuclear Regulatory Commission (NRC or Commission) has issued a design certification for the System 80+ standard nuclear plant design (System 80+). Design certification is a rulemaking that amends Part 52 of Title 10 of the Code of Federal Regulations (10 CFR Part 52). To comply with the requirements of the National Environmental Policy Act of 1969 (NEPA), the NRC must consider the environmental impacts of issuing this amendment to 10 CFR Part 52. In addition, the NRC decided to consider severe accident mitigation design alternatives (SAMDA) as part of this final environmental assessment (EA) to resolve SAMDA for NEPA on a generic basis for the System 80+ design. The EA for this rulemaking is contained herein and is prepared in accordance with NEPA and 10 CFR Part 51. This EA only addresses the environmental impacts of issuing a design certification for System 80+, and SAMDAs for the System 80+ design. The environmental impacts of construction and operation of a facility at a particular site will be evaluated as part of the application(s) for siting, construction, and operation of that facility.

In an application dated March 30, 1989, Combustion Engineering, Incorporated (CE) asked the NRC to certify the System 80+ design. The application was made in accordance with the procedures of Appendix O to 10 CFR Part 50. In a letter to the NRC dated August 21, 1989, Combustion Engineering, Inc., requested that its application be considered for design approval and subsequent design certification pursuant to 10 CFR Part 52. The application was docketed on May 1, 1991, and assigned Docket Number 52-002. Combustion Engineering, Inc., notified the NRC by letter dated May 26, 1992, that it is a wholly owned subsidiary of Asea Brown Boveri, Inc., and the appropriate abbreviation for the company is ABB-CE. Therefore, throughout this report Combustion Engineering, Inc., is referred to as ABB-CE.

The NRC has determined that the issuance of this design certification is not a major Federal action significantly affecting the quality of the human environment, and therefore, has decided not to prepare an environmental impact statement (EIS) in connection with this action. The finding of no significant impact (FONSI) is based on the fact that the certification rule itself would not authorize the siting, construction, or operation of the System 80+ design; it would only codify the System 80+ design in a rule that could be referenced in a construction permit (CP), early site permit (ESP), combined license (COL), or operating license (OL) application. Further, because the action is a rule, there are no resources involved which would have alternative uses.

The NRC also reviewed, pursuant to the NEPA, ABB-CE's evaluation of design alternatives to prevent and mitigate severe accidents. Based on the review, the NRC finds that the evaluation provides a sufficient basis to conclude that there is reasonable assurance that an amendment to 10 CFR Part 52 certifying the System 80+ design will not exclude SAMDAs for a future facility that would have been cost beneficial had they been considered as part of the original design certification application. These issues are considered resolved for the System 80+ design certification.

2.0 THE NEED FOR THE PROPOSED ACTION

The NRC has long sought the safety benefits of commercial nuclear power plant standardization, as well as the early resolution of design issues and finality of design issue resolution. The NRC plans to achieve these goals by certification of standard plant designs. Subpart B to 10 CFR Part 52 allows for certification by rule of an essentially complete nuclear plant design.

The proposed action would amend 10 CFR Part 52 to certify the System 80+ design. The amendment would allow prospective applicants for a COL under Part 52 or for a CP under Part 50 to reference the certified System 80+ design. Those portions of the System 80+ design included in the scope of the design certification would not be subject to further regulatory review or approval. In addition, the amendment would resolve the issue of consideration of SAMDAs for any future facilities that reference the System 80+ design.

3.0 ALTERNATIVES TO THE PROPOSED ACTION

The alternatives to certifying the System 80+ design in an amendment to 10 CFR Part 52 are either (1) no action approving the design or (2) issuing a final design approval (FDA), but not certifying the design. These alternatives in and of themselves would not have a significant impact affecting the quality of the human environment because they do not authorize the siting, construction, or operation of a facility.

In the first case, the design would not be approved. Therefore, a facility to be built as a System 80+ would be required to be licensed under 10 CFR Part 50 or 10 CFR Part 52, Subpart C, as a custom plant application. All design issues would have to be considered as part of each application to construct and operate a System 80+ facility at a particular site. This alternative would not achieve the benefits of standardization, provide early resolution of design issues, or provide finality of design issue resolution.

In the second case, the System 80+ would be issued an FDA under 10 CFR Part 52, Appendix O, but the design would not be certified in a rulemaking. Therefore, although the NRC would have approved the design, the design could be modified and thus require reevaluation as part of each application to construct and operate a System 80+ facility at a particular site. This alternative would provide early resolution of issues, but would not achieve the benefits of standardization or provide finality of design issue resolution.

The NRC sees no advantage in either of the alternatives compared to the design certification rulemaking proposed for the System 80+. Although neither the alternatives nor the proposed design certification rulemaking would have a significant impact affecting the quality of the human environment in and of themselves, the rulemaking provides for standardization, as well as early resolution of design issues and finality of design issue resolution for design issues that are within the scope of the design certification, including SAMDAs. Therefore, the NRC concludes that the alternatives to rulemaking would not achieve the objectives of the Commission intended by certification of the System 80+ design pursuant to 10 CFR Part 52, Subpart B.

3.1 Severe Accident Design Alternatives

The Commission decided to evaluate design alternatives for severe accidents as part of the design certification for the System 80+ design, consistent with its objectives of achieving early resolution of issues for the design and standardization. The Commission, in a 1985 policy statement, defined the term "severe accident" as those events which are "beyond the substantial coverage of design-basis events" and includes those for which there is substantial damage to the reactor core whether or not there are serious offsite consequences. Design-basis events are considered to be those analyzed in accordance with the NRC's Standard Review Plan (NUREG-0800) and documented in Chapter 15 of the System 80+ Design Control Document (DCD).

As part of its design certification application, ABB-CE performed a probabilistic risk assessment (PRA) for the System 80+ design to help (1) identify the dominant severe accident sequences and associated source terms for the design; (2) modify the design, based on PRA insights, to prevent or mitigate severe accidents and reduce the risk of severe accidents; and (3) provide a basis for concluding that all reasonable steps have been taken to reduce the chances of occurrence, and to mitigate the consequences, of severe accidents. ABB-CE's analysis is documented in Chapter 19 of the System 80+ Standard Safety Analysis Report - Design Certification (System 80+ CESSAR-DC).

In addition to considering alternatives to the rulemaking process as discussed in Section 3, applicants for reactor design approvals or construction permits must also consider alternative design features for severe accidents based on (1) the requirements of 10 CFR Part 50 and (2) a court ruling relating to NEPA. These requirements can be summarized as follows:

- 10 CFR 50.34(f)(1)(i) requires the applicant to perform a plant/site specific probabilistic risk assessment, the aim of which is to seek such improvements in the reliability of core and containment heat removal systems as are significant and practical and do not impact excessively on the plant.
- The U.S. Court of Appeals decision, in Limerick Ecology Action v. NRC, 869 F.2d 719 (3rd Cir. 1989), effectively requires the NRC to include consideration of certain severe-accident-mitigation design alternatives (SAMDA) in the environmental impact review performed as part of the OL application.

Although these two requirements are not directly related, the purpose is the same: to consider alternatives to the proposed design, to evaluate potential alternatives for improvements in the plant design for increased safety performance during severe accidents, and to prevent viable alternatives from being foreclosed. It should be noted that the Commission is not required to consider alternatives to the design in this EA on the proposed rulemaking; however, as a matter of discretion, the Commission has determined that consideration of SAMDA is consistent with the intent of 10 CFR Part 52 for early resolution of issues and enhancing the benefits of standardization.

In its decision in *Limerick*, the Court of Appeals for the Third Circuit expressed its opinion that it was likely that evaluation of SAMDAs for NEPA purposes would be difficult to perform on a generic basis. However, the NRC has determined that generic evaluation of SAMDAs for the System 80+ design is warranted because (1) the design and construction of all plants referencing the certified System 80+ design will be governed by the rule certifying a single design, and (2) the site parameters specified in the rule and in the "Technical Support Document [TSD] for Amendments to 10 CFR Part 51 Considering Severe Accidents Under NEPA For Plants Of System 80+ Design," dated January 5, 1995, establish the consequences for a reasonable set of SAMDAs for the System 80+ design. The low residual risk of the System 80+ design and limited potential for further risk reductions provides high confidence that additional cost beneficial SAMDAs would not be found. Should the actual site parameters for a particular site exceed those assumed in the rule and TSD, SAMDAs would have to be re-evaluated in the site-specific environmental report and EIS.

ABB-CE initially submitted its response to 10 CFR 50.34(f) in Appendix A to Chapter 19 of CESSAR-DC as part of its application for an FDA and subsequent design certification for the System 80+ design. The NRC issued an FDA for the System 80+ in July 1994, and provided its evaluation of Appendix A to Chapter 19 of CESSAR-DC in Section 19.4 of the "Final Safety Evaluation Report Related to the Certification of the System 80+ Design," (FSER) published as NUREG-1462 in August 1994. Subsequently, as part of its preparation of the DCD for the design certification rulemaking, ABB-CE updated and relocated the information in Appendix A to Chapter 19 of CESSAR-DC to the TSD. ABB-CE submitted the TSD to meet the Commission's requirement to consider SAMDAs as part of the design certification application.

3.2 Estimate of Risk for the System 80+

In response to 10 CFR 50.34(f)(1)(i), ABB-CE provided an evaluation of the System 80+ design improvements in Appendix A to Chapter 19 of CESSAR-DC. ABB-CE's evaluation of risk was based on the risk-reduction potential for internal events only. The limited scope was a consequence of ABB-CE's use of alternative analyses for external events. The staff's evaluation of this approach to external events is in FSER Section 19.4.6. This EA includes an evaluation of both internal and external events. The staff's evaluation of design alternatives considering risk from external events is discussed in Section 3.5.5 of this EA.

In estimating the risk, ABB-CE used the meteorological and population data from the reference site described in the "Advanced Light Water Reactor Utility Requirements Document, Volume II, ALWR Evolutionary Plant," Chapter 1, Appendix A, PRA Key Assumptions and Groundrules (KAG), Revision 3, EPRI, November 1991. The data from this reference site was developed by EPRI to conservatively bound 80 percent of existing reactor sites in the U.S.

ABB-CE based its risk estimate on four major elements: (1) the mean value core damage frequency (CDF) estimate from the Level 1 PRA described in Chapter 19 of CESSAR-DC; (2) source terms for each release class (RC) determined using a plant-specific version of the NRC-developed XSOR code;

(3) offsite consequences for the reference site calculated for each RC using the NRC-developed MACCS code; and (4) the MAAP code and supporting deterministic analyses for modeling accident progression, containment performance, and time and energy of release. A summary of 23 RCs appears in Table 4-1 in the TSD, and a ranking of the RCs based on risk to the general population appears in Table 4-2. ABB-CE's estimate of the cumulative offsite risk of severe accidents occurring in a System 80+ standard plant to the population within 50 miles of the reference site is 0.17 person-Sv (17 person-rem). A cumulative risk of 0.17 person-Sv (17 person-rem) is considered by the NRC to be low, and can be attributed to ABB-CE's efforts to minimize initiators by incorporating results of the PRA into the System 80+ design.

As discussed in Section 19.1 of the FSER, the NRC finds the approach used by ABB-CE for assessing CDF to be logical and sufficient for describing and quantifying potential core damage sequences. The NRC reviewed ABB-CE's source term estimates for the major RCs and found these predictions to be in reasonable agreement with estimates from NUREG-1150. ABB-CE submitted additional analyses using the NRC-developed MELCOR code to verify results obtained using the MAAP code. The NRC performed a number of independent severe accident confirmatory calculations described in Section 19.2 of the FSER. On the basis of these ABB-CE and NRC verification calculations, the NRC concludes that ABB-CE's characterization of accident progression and containment performance is acceptable. The NRC considers ABB-CE's use of the NRC-developed MACCS code in conjunction with the data from the reference site to be an acceptable basis for estimating the consequences associated with severe accident releases. In summary, the NRC finds the methods and computer codes used in estimating the total risk to be acceptable, and the results to be reasonable.

3.3 Identification of Potential Design Alternatives

ABB-CE's evaluation of potential design improvements in response to the requirements of 10 CFR 50.34(f)(1)(i) also gives a technical basis for the NRC staff to evaluate the SAMDAs, as required by the Limerick decision. The NRC staff's review of ABB-CE's evaluation is presented below.

By surveying previous industry- and NRC-sponsored studies of features to prevent and mitigate severe accidents, ABB-CE prepared a set of potential severe accident design alternatives for the System 80+ and developed a composite list of 62 potential design alternatives.

ABB-CE identified 40 of the 62 potential design alternatives for risk reduction cost-benefit analysis. Of the initial 62 design alternatives screened, 26 were modifications already incorporated into the System 80+ design. However, 4 of the 26 design alternatives (numbers 26 (A1), 44 (B7), 48 (A3), and 54 (E11) of TSD Table 4-5) already incorporated into the design were retained in the set of 40 design alternatives evaluated because they addressed important generic safety issues. These 40 design alternatives were divided into 5 groups. The first 4 groups prevent core damage by:

- (a) Increasing primary and secondary boundary integrity,
- (b) Increasing decay heat removal reliability,
- (c) Improving electrical power reliability,

- (d) Reducing the risk from anticipated transient without scram (ATWS) and external events.

The last group (e) protects the containment or reduces radioactive releases.

ABB-CE quantified the cost benefit ratio for 27 of the 40 design alternatives evaluated as reflected in TSD Table 5-1. The remaining 13 design alternatives were not quantified because 4 design alternatives were already implemented in the design and 9 design alternatives had very high costs or marginal risk reduction potential for the modification.

3.4 Description of Design Alternatives

The 40 design alternatives evaluated by ABB-CE are described in Section 4.7 of the TSD. The 27 design alternatives selected by ABB-CE for cost-benefit evaluation are summarized below. The numbers in parentheses correspond to the design alternative number in the TSD.

- (1) 100-Percent Steam Generator (SG) Inspection (A2) — Perform eddy-current testing on 100 percent of the SG tubes each refueling outage in order to reduce the frequency of steam generator tube rupture (SGTR) events.
- (2) Secondary Side Guard Pipes (A6) — Install guard pipes around the secondary piping between the containment and the main steam isolation valves in order to reduce the risk from SGTRs given a main steamline break initiating event.
- (3) Alternative Batteries and Emergency Feedwater System (EFWS) (B1) — Increase the capacity of the EFWS-related batteries so that the probability of a loss of decay heat removal due to battery depletion is reduced.
- (4) 12-Hour Batteries (B2) — Increase the battery size to accommodate a 12-hour rather than 8-hour duty cycle, thereby reducing the probability of failure to recover offsite power before core damage.
- (5) Alternative Pressurizer Auxiliary Spray (B3) — Increase the redundancy and diversity of the pressurizer spray valves and charging pump, so that the probability of failures of the auxiliary spray to successfully depressurize the primary system are reduced in SGTR sequences.
- (6) Alternative High-Pressure Safety Injection (HPSI) (B4) — Provide an alternative or improved HPSI system, so that the probabilities of all core-damage sequences involving HPSI failures are reduced.
- (7) Alternative Reactor Coolant System Depressurization (B5) — Increase the reliability and diversity of the safety depressurization valves so that the probabilities of all sequences in which the safety depressurization system fails are reduced.

- (8) Diesel-Driven Safety Injection (SI) Pumps (B6) — Replace two of the electric SI pumps with diesel-driven pumps to reduce common-cause failure of all four pumps and the risk from station blackout (SBO).
- (9) Extended In-Containment Refueling Water Storage Tank (IRWST) Source (B8) — Provide a separate borated water storage tank and pump for refilling the IRWST, thereby reducing the potential for IRWST depletion in un-isolated SGTR events.
- (10) Third Diesel Generator (DG) (C1) — Add a third, swing DG to lower the probability of SBO events and provide improved operational flexibility.
- (11) Tornado protection for Combustion Turbine (C2) — Provide tornado protection for the gas turbine generator and associated support systems to prevent loss of the system due to tornado and high-wind events.
- (12) Fuel Cells (C3) — Use fuel cells in lieu of conventional lead-acid batteries, thereby extending the availability of dc power.
- (13) Hookup for Portable Generators (C4) — Provide temporary connections so that portable generators could be used to power the turbine-driven EFW pump after the station batteries are depleted.
- (14) Alternative ATWS Pressure Relief Valves (D1) — Provide a system of relief valves that can prevent equipment damage from a primary coolant pressure spike in an ATWS sequence.
- (15) ATWS Injection System (D2) — Modify the reactor coolant pump seal cooling system to inject boron using existing sources of boron and existing piping and valves.
- (16) Diverse Plant Protection System (PPS) (D3) — Provide a third, diverse PPS to resolve instrumentation and control diversity concerns and reduce the frequency of ATWS events.
- (17) Alternative Containment Spray System (CSS) (E1) — Provide an independent CSS as a backup to the front-line CSS, so that frequency of late steam overpressure failures is reduced.
- (18) Filtered Containment Vent (E2) — Add a filtered containment vent similar to the multi-venturi scrubbing systems implemented in some plants in Europe to reduce the potential for late containment overpressure failures.
- (19) Alternative Concrete Composition (E3) — Use an advanced concrete composition in the reactor cavity or increase the thickness of the basemat concrete so that the probability of basemat melt-through is reduced.
- (20) Reactor Vessel Exterior Cooling (E4) — Provide the capability to submerge the reactor vessel lower head in water during severe accidents

in order to enhance heat removal from the lower head and reduce the probability of melt-through of the lower head.

- (21) Alternative Hydrogen Igniters (E5) — Provide dedicated batteries for the hydrogen mitigation system (HMS) in order to improve system reliability and further reduce the potential for containment failure from hydrogen combustion.
- (22) Passive Autocatalytic Recombiners (E6) — Provide passive autocatalytic recombiners in addition to the existing HMS to provide improved hydrogen control, particularly in SBO sequences.
- (23) Main Steam Safety Valve (MSSV) and Atmospheric Dump Valve (ADV) Scrubbing (E7) — Route the discharge from the MSSVs and ADVs through a structure where a water spray would condense the steam and remove most of the fission products, thereby reducing the consequences associated with a SGTR.
- (24) Alternative Containment Monitoring System (E8) — Improve the containment isolation valve position indication so that risk from containment bypass sequences and interfacing-systems loss-of-coolant accidents is reduced.
- (25) Cavity Cooling (E9) — Modify the reactor cavity configuration and the flow paths between the IRWST and reactor cavity so that heat from the reactor vessel lower head or ex-vessel core debris could be transported passively to the IRWST, thereby reducing the potential for reactor vessel failure, ex-vessel steam explosions, and core-concrete interactions.
- (26) Water-Cooled Rubble Bed (E12) — Provide a bed of refractory pebbles that would impede the flow of molten corium to the concrete drywell structures and increase the available heat transfer area, thereby enhancing debris coolability.
- (27) Refractory-Lined Crucible (E13) — Provide a ceramic-lined crucible and cooling system in the reactor cavity in order to reduce the potential for basemat melt-through.

The NRC staff has reviewed the set of potential design alternatives identified by ABB-CE in the TSD and finds the set to constitute a reasonable range of design alternatives. The list includes all alternatives identified in the NRC containment performance improvement (CPI) program and in the NRC review of SAMDAs for the Limerick Generating Station that would be applicable to System 80+. The NRC notes that the set of design alternatives is not all inclusive, since additional, possibly even less expensive, design alternatives can always be postulated. However, the NRC concludes that the benefits of any additional modifications are unlikely to exceed the benefits of the modifications evaluated and that the alternative improvements would not likely cost less than the least expensive alternatives evaluated, when the subsidiary costs associated with maintenance, procedures, and training are considered. On this basis, the NRC concludes that the set of potential design alternatives identified by ABB-CE is acceptable.

3.5 Risk Reduction Potential of Design Alternatives

3.5.1 ABB-CE's Evaluation of Risk Reduction Potential

ABB-CE used the reduction in cumulative risk of accidents occurring during the life of the plant as the basis for estimating the benefit that could be derived from plant improvements. Estimates of risk reduction were developed by determining the approximate effect of each design alternative on the frequency of the various release classes in the PRA. For those design alternatives that were preventative (reduced CDF), ABB-CE assumed that the design alternative would completely eliminate the sequence it addresses. In addition, ABB-CE conservatively assumed that each design alternative when employed worked perfectly (i.e., zero failure rate). A summary of ABB-CE's assessment of risk reduction for the candidate design improvements is provided in Table 1 of this EA.

The NRC staff reviewed ABB-CE's bases for estimating the risk reduction associated with the various design improvements. The NRC staff notes that considerable judgement was exercised in estimating the risk reduction potential, however, the rationale and assumptions on which the risk reductions are based appear to be sound.

3.5.2 NRC Staff Evaluation of Risk Reduction Potential

In view of the small residual risk for the System 80+ (0.17 person-Sv (17 person-rem)), rather than performing an independent assessment of the risk reduction potential of each of the 40 System 80+ design alternatives, the NRC staff used a screening-type approach for identifying the most promising alternatives. The set of potential design alternatives was initially screened by the NRC staff using a bounding assumption that each improvement would eliminate all the risk from internally-initiated events for the System 80+ (0.17 person-Sv (17 person-rem) for a 60-year life). This approach conservatively tends to over-estimate the benefits derived from each design alternative. For those design alternatives whose cost benefit ratio was found to be within a factor of 10 of the \$100,000/person-Sv-averted (\$1,000/person-rem-averted) criterion in the screening assessment, the NRC staff applied a more design-specific assessment, described below in Section 3.5.3 of this report.

3.5.3 Cost of SAMDAs

ABB-CE determined the approximate costs for each design alternative, using the methodology described in Section 4.3 of the TSD. The cost estimate for each design alternative represents the incremental costs that would be incurred in incorporating that design alternative in a new plant. These costs were intentionally biased on the low side, but all known or reasonably expected costs were accounted for. However, any annual costs associated with operation, testing, maintenance, and training were omitted. For design alternatives that reduced the CDF, ABB-CE reduced the costs of the design alternative by an amount proportional to the averted onsite costs (AOCs).

The NRC staff reviewed the bases for ABB-CE's cost estimates and found them reasonable. For certain design alternatives, the NRC staff also compared ABB-CE's cost estimate with estimates developed elsewhere for similar improvements, even though the bases for some were different. The NRC staff considered cost estimates developed in the evaluation of design improvements for GESSARII (NUREG-0979, Supplement 4), and the review of SAMDAs for Limerick and Comanche Peak (NUREG-9074 and -0775, respectively). The NRC staff noted that cost estimates were lower than expected for a number of SAMDAs, such as 12-hour batteries (\$300K) and reactor cavity cooling system (\$50K). However, the costs for other improvements were higher than expected, such as alternative concrete composition (\$5 million) and refractory-lined crucible (\$108 million). Nevertheless, the NRC staff views ABB-CE's approximate cost estimates as adequate, given the uncertainties surrounding the underlying cost estimates, and the level of precision necessary given the greater uncertainty inherent on the benefit side with which these costs were compared.

3.5.4 Cost-Benefit Comparison

ABB-CE performed a cost-benefit comparison to determine whether any of the design alternatives could be justified. The costing methodology and assumptions used by ABB-CE are described in the TSD and in CESSAR-DC Appendix 19A. The benefit of a particular design alternative was evaluated in terms of reduced risk to the general public in units of person-Sv/year (person-rem/year). The cost of a particular design alternative is a one-time initial capital cost in dollars. In order to compare the benefits with the costs, ABB-CE used the former \$100,000/person-Sv (\$1000/person-rem) criterion and multiplied by 60 years (plant lifetime), to convert the risk reduction into dollars. The cost-benefit ratio for each of the 27 design alternatives are shown in Table 2 of this EA and Table 5-1 of the TSD. As shown in the tables, the costs of the design alternatives range from about \$90 billion/person-Sv-averted (\$900 million/person-rem-averted) to about \$3 million/person-Sv-averted (\$30K/person-rem-averted). Consistent with former NRC practice, ABB-CE used a screening criterion of \$100,000/person-Sv-averted (\$1000/person-rem-averted) to identify whether any of the design alternatives could be cost effective. On this basis ABB-CE concluded that no additional design alternatives are warranted.

Section 4.1 of the TSD describes how AOCs were incorporated into the cost benefit equation. In this section, ABB-CE states that AOCs are included in the cost-benefit analyses of those design alternatives that reduce CDF as reductions in the cost of the design alternatives.

As discussed above in Section 3.5.2 of this report, the NRC staff used a screening-type approach for identifying the most promising design alternatives, and performed a more detailed assessment for only those whose cost-benefit ratio was found to be within a factor of 10 of the \$100,000/person-Sv (\$1,000/person-rem) criterion. On the basis of initial screening, only two design alternatives were retained for further analysis by the NRC staff:

- Hookup for Portable Generators (C4) — Provide temporary connections so that portable generators could be used to power the turbine-driven EFW pump after the station batteries are depleted; and

- Cavity Cooling (E9) — Modify the reactor cavity configuration and the flow paths between the IRWST and reactor cavity so that heat from the reactor vessel lower head or ex-vessel core debris could be transported passively to the IRWST, thereby reducing the potential for reactor vessel failure, ex-vessel steam explosions, and core-concrete interactions.

The NRC staff notes that for the two design alternatives identified in the screening, the assumption that all residual risk would be eliminated is overly conservative since these improvements will have little impact on the SGTR sequences that dominate risk for the System 80+. ABB-CE's risk reduction estimates, which take into account the actual plant risk profile, are judged by the NRC staff to be more appropriate for these design alternatives. ABB-CE's risk-reduction estimates for the portable generator hookup option (C4) assume complete elimination of all sequences in which EFW is lost after battery depletion, i.e., 0.0000187 person-Sv (0.00187 person-rem) averted per year. ABB-CE's risk-reduction estimates for the cavity flooding option (E9) assume complete elimination of reactor vessel melt-through, basemat attack, and steam explosions, i.e., 0.000307 person-Sv (0.0307 person-rem) averted per year. Furthermore, these SAMDAs are the lowest cost modifications evaluated by ABB-CE (\$10,000 and \$50,000, respectively), and the cost figures appear somewhat low. Additional costs associated with first-of-a-kind engineering are still to be anticipated for these and many of the other design alternatives. For example, the introduction of a design change would trigger a series of related requirements, such as incremental training, maintenance, procedural changes, and possible licensing requirements. These are all legitimate costs that require consideration in a comprehensive cost estimate. They were, however, conservatively omitted from both the NRC staff's and ABB-CE's cost-benefit analyses. The NRC staff concludes that, using the more realistic risk reduction estimates, and considering the additional cost factors, neither of these design alternatives would be cost effective. Furthermore, they would not substantially reduce overall risk for the System 80+ design since the improvements would not have an impact on the sequences that dominate risk for System 80+.

The cost-benefit ratio of the remaining SAMDAs are approximately one order of magnitude or more greater than for these two, as shown in FSER Table 19.6. Moreover, the risk reduction potential for the more cost beneficial SAMDAs (e.g., B2 and D2) is not significant. Accordingly, the NRC staff concludes that none of the other SAMDAs would be cost beneficial as well.

3.5.5 Further Considerations

The NRC staff has reviewed the assumptions on which this conclusion is based and has considered the effect of uncertainties in estimating CDF, the use of alternative cost-benefit criteria, and the inclusion of external events within the scope of the analysis.

On the basis of uncertainty analyses performed by ABB-CE for the Level 1 PRA (see Section 19.1.3.1.3 of the FSER), the 95th percentile CDF is approximately 5×10^{-6} per reactor year. This is roughly a factor of 3 higher than the mean value on which the cost-benefit analysis is based, but still very low

compared to operating plants and also in absolute terms. If the benefits of the various design alternatives were requantified on the basis of this upper bound value and the conservative assumption that each SAMDA eliminates all residual risk was used, only the design alternatives discussed above (C4 and E9) would be cost-beneficial. However, using ABB-CE's calculations of risk reduction potential, which are judged to be more appropriate, no SAMDA was cost-beneficial.

Similarly, if the cost-benefit criteria was increased by a factor of 10, to \$1 million/person-Sv-averted (\$10,000/person-rem-averted), only the two design alternatives previously discussed (C4 and E9) would become cost effective. Again, using the ABB-CE's estimates of risk-reduction potential, as discussed above, none of the design alternatives become cost-beneficial.

A quantitative assessment of the risk from externally initiated events was not performed for the System 80+ design. Based on experience with probabilistic assessments performed for operating plants, the estimate of the residual risk for the System 80+ design could be one or two orders of magnitude higher than considered if external events are included. (Historically, seismic events dominate external risk.) However, even at two orders of magnitude higher, design alternatives that cost more than \$1.7 million would not be cost effective, even if all risk was eliminated. Using ABB-CE's cost estimates, the NRC staff examined the 13 design alternatives that cost less than \$2 million, and found that they all have a relatively low risk reduction potential, would eliminate only 10 percent of the residual risk from internal events, and are not expected to be effective in eliminating the added risk from external events (e.g., seismic events). Given the robustness of the seismic design, i.e., a high-confidence-low-probability-of-failure (HCLPF) value of about 0.7 g, the remaining SAMDAs would be unlikely to eliminate a significant portion of the external risk from seismic events. As a result, none of these design alternatives are expected to be cost effective when their actual effectiveness in reducing risk is taken into account.

Since the draft EA was issued in April 1995, the NRC has issued "Regulatory Analysis Guidelines of the U.S. Nuclear Regulatory Commission" (NUREG/BR-0058, Revision 2, November 1995). This policy document adopts a \$2000 per person-rem conversion factor, subject to present worth considerations and is limited in scope to health effects. Limiting the conversion factor solely to health effects requires that the regulatory analysis include an additional dollar allowance for averted offsite property damage. By adopting the new \$2000 per person-rem conversion factor and a \$3000 per person-rem supplemental allowance for offsite property (see NUREG/CR-6349, "Cost benefit Considerations in Regulatory Analysis"), and assuming a base case 7% real discount rate as prescribed in NUREG/BR-0058, Revision 2, the present value of the health and safety benefits attributable to an individual SAMDA would increase by a factor of about 1.2. A comparable estimate for the health and safety benefits of the same SAMDA based on a 3% real discount rate, which is recommended for sensitivity analysis purposes, would increase its value by a factor of 2.3. Given that the costs to implement the most cost effective SAMDAs are at least a factor of 10 greater than the value that would make them cost effective, an increase in benefits by factor of 2.3 leaves the total costs well in excess of the total benefits.

In summary, the NRC staff concludes that given the significant margins in the results of the cost-benefit analysis, the findings would be unchanged even considering the factors discussed above.

3.6 Conclusions

As discussed in this report, ABB-CE has made extensive use of the results of PRA to arrive at a final System 80+ design. As a result, the estimated CDF and risk calculated for the System 80+ is very low, both relative to operating plants and in absolute terms. The low CDF and risk for the System 80+ is a reflection of ABB-CE's efforts to systematically minimize the effect of initiators and/or sequences that have been important contributors to CDF as calculated in previous pressurized water reactor PRAs. This has been done largely through the incorporation of a number of hardware improvements in the System 80+ design that both reduce CDF and mitigate the consequences of a core-damage event.

Because the System 80+ design already contains numerous plant features oriented toward reducing CDF and risk, the benefit and risk reduction potential of additional plant improvements is significantly reduced. This is true for both internally and externally initiated events. For example, the System 80+ seismic design basis (0.3 g safe-shutdown earthquake) has been shown to result in significant ability to withstand earthquakes well beyond the design basis, as characterized by a HCLPF value of about 0.7 g. Moreover, with the features already incorporated in the System 80+ design, the ability to estimate CDF and risk approached the limitation of probabilistic techniques. Specifically, when CDFs of 1 in 100,000 or 1,000,000 years are estimated in a PRA, it is the area of the PRA where modeling is least complete, or supporting data is sparse or even non-existent, that could actually be the more important contributors to risk. Areas not modeled or incompletely modeled include human reliability, sabotage, rare initiating events, construction or design errors, and systems interactions. Although improvements in the modeling of these areas may introduce additional contributors to CDF and risk, the NRC staff does not expect that the additional contribution would be significant in absolute terms.

In 10 CFR 50.34(f)(1)(i), the NRC staff requires an applicant to perform a plant or site-specific PRA, the aim of which is to seek such improvements in the reliability of core and containment heat removal systems as are significant and practical and do not impact excessively on the plant. The NRC staff concludes that the System 80+ PRA and ABB-CE's use of the insights from the PRA to improve the design of the System 80+ meet this requirement. The NRC staff concurs with ABB-CE's conclusion that none of the potential design alternatives evaluated are justified based on cost-benefit considerations. It is further concluded that it is unlikely that any other design changes would be justified on the basis of person-rem exposure considerations, because the estimated CDFs would remain very low on an absolute scale.

4.0 THE ENVIRONMENTAL IMPACT OF THE PROPOSED ACTION

The issuance of an amendment to 10 CFR Part 52 certifying the System 80+ design would not constitute a significant environmental impact. The amendment

would only codify the results of the NRC's review and approval of the System 80+ design as defined in the FSER, dated August 1994 (NUREG-1462). Further, because the action is a rule, there are no resources involved that would have alternative uses.

In Section 3 of this EA, the NRC staff reviewed alternatives to design certification rulemaking and alternative design features related to the prevention and mitigation of severe accidents. Consideration of alternatives under NEPA were necessary for two reasons: (1) to show that the design certification rule is the appropriate course of action, and (2) to ensure that there are no cost-beneficial design changes relating to the prevention and mitigation of severe accidents that were excluded from the design, as codified in the design certification rule. The NRC concludes that the alternatives to design certification did not provide for resolution of issues as did the proposed design certification rulemaking.

This design certification rulemaking is in keeping with the Commission's intent in the Standardization and Severe Accident Policy Statements, and 10 CFR Part 52, to make future plants safer than the current generation plants, to achieve early resolution of licensing issues, and to enhance the safety benefits of standardization. Through its own independent analysis, the NRC also concludes that ABB-CE adequately considered an appropriate set of SAMDAs, and none were found to be cost-beneficial. Although no design changes resulted from the SAMDAs review, ABB-CE did make changes to the System 80+ design based on the results of the PRA. These changes were related to severe accident prevention and mitigation, but were not considered in the SAMDA evaluation because they were already part of the design. See FSER Section 19.1.6, "PRA as a Design Tool."

The certification rule by itself would not authorize the siting, construction, or operation of a System 80+ design nuclear power plant. The issuance of a CP, ESP, COL, or OL for the System 80+ design will require a prospective applicant to address the environmental impacts of construction and operation at a specific site. At that time, the NRC will evaluate the environmental impacts and issue an environmental impact statement (EIS) in accordance with NEPA. The SAMDAs analysis for the System 80+, however, has been completed as part of this EA and will not need to be evaluated again as part of an EIS related to siting, construction, or operation.

5.0 AGENCIES AND PERSONS CONSULTED AND SOURCES USED

The NRC concludes that design certification rulemaking does not result in a significant environmental impact because the action does not authorize the construction and operation of a facility at a particular site. Therefore, the NRC staff did not issue this EA for comment by Federal, State, and local agencies. However, the NRC's finding of no significant environmental impact, was published in the Federal Register on April 7, 1995, with the proposed System 80+ design certification rule and there were no comments received related to this EA.

The sources for this draft EA include the "Technical Support Document For Amendments to 10 CFR Part 51 Considering Severe Accidents Under NEPA for

Plants of System 80+ Design," Revision 2, dated January 5, 1995; ABB-CE's "Combustion Engineering Standard Safety Analysis Report-Design Certification," through Amendment W; and the NRC staff's "Final Safety Evaluation Report Related to the Certification of the System 80+ Design" (NUREG-1462, Volumes 1 and 2), August 1994.

6.0 FINDING OF NO SIGNIFICANT IMPACT

The Director, Office of Nuclear Reactor Regulation (NRR), has determined under the National Environmental Policy Act of 1969, as amended, and the NRC's regulations in 10 CFR Part 51, Subpart A, that this rule is not a major Federal action significantly affecting the quality of the human environment, and therefore, an environmental impact statement is not required.

The basis for the determination, as documented in this EA, is that the amendment to 10 CFR Part 52 would not authorize the siting, construction, or operation of a facility using the System 80+ design; it would only codify the System 80+ design in a rule. The NRC will evaluate the environmental impacts and issue an EIS as appropriate in accordance with NEPA as part of the application(s) for the siting, construction, or operation of a facility.

In addition, as part of this final EA, the NRC reviewed, pursuant to NEPA, ABB-CE's evaluation of various design alternatives to prevent and mitigate severe accidents that was submitted in ABB-CE's TSD. The Director of NRR finds that ABB-CE's evaluation provides a sufficient basis to conclude that there is reasonable assurance that an amendment to 10 CFR Part 52 certifying the System 80+ design will not exclude a severe accident design alternative for a facility referencing the certified design that would have been cost beneficial had it been considered as part of the original design certification application. The evaluation of these issues under NEPA is considered resolved for the System 80+ design.

Table 1 Summary of ABB-CE's Assessment of Risk Reduction for Candidate Design Improvements

POTENTIAL SYSTEM 80+ DESIGN ALTERNATIVES	ABB-CE's BASIS FOR ESTIMATING RISK REDUCTION	PERSON-SV (PERSON-REM) AVERTED PER YEAR
Increase Primary and Secondary Boundary Integrity 100% SG Inspection (A2) Secondary Side Guard Pipes (A6)	Assume all SGTRs are eliminated 50% reduction in risk from ISLOCAs and steam line breaks	0.00249 (0.249) 0.0000076 (0.00076)
Increase Decay Heat Removal Reliability Alternative DC Batteries and EFWS (B1) 12 Hour Batteries (B2) Alternative Pressurizer Auxiliary Spray (B3) Alternative High Pressure Safety Injection (B4) Alternative RCS Depressurization (B5) Diesel SI Pumps (B6) Extended RWST Source (BB)	Assume capability to remove decay heat using batteries and the turbine-driven feedwater pump for whatever time period is required Decrease probability of failure to restore offsite power by 62% During SGTR, assume spray always depressurizes primary to allow SCS to operate and SCS always removes decay heat Eliminate all sequences with SIS failures Eliminate all sequences where SDS of bleed fails Increase reliability of SIS by factor of 60 and assume SBO is eliminated Assume unlimited RWST water supply	0.0000187 (0.00187) 0.000016 (0.0016) 0.00207 (0.207) 0.00083 (0.083) 0.000142 (0.0142) 0.000834 (0.0834) 0.00182 (0.182)
Improve Electrical Power Reliability Third Diesel Generator (C1) Tornado Protection for Combustion Turbine (C2) Fuel Cells (C3) Hookup for Portable Generator (C4)	Reduce the risk of release classes for SBO by 24% Assume combustion turbine is completely protected and has failure rate of 0.025/d Assume power for EFW is available for unlimited time during SBO Assume power for EFW is available for unlimited time during SBO	0.0000045 (0.00045) 0.000016 (0.0016) 0.0000187 (0.00187) 0.0000187 (0.00187)
ATWS and External Events Alternative ATWS Pressure Relief Valves (D1) ATWS Injection System (D2) Diverse PPS (D3)	Eliminate all ATWS core damage sequences Eliminate all ATWS core damage sequences Eliminate all ATWS core damage sequences	0.0000097 (0.00097) 0.0000097 (0.00097) 0.0000097 (0.00097)
Reduce Radioactive Releases Alternative Containment Spray (E1) Filtered Vent (Containment) (E2) Alternative Concrete Composition (E3) Reactor Vessel Exterior Cooling (E4) Alternative Hydrogen Igniters (E5) Passive Autocatalytic Recombiners (PARS) (E6) MSSV and ADV Scrubbing (E7) Alternative Containment Monitoring System (E8) Cavity Cooling (E9) Water Cooled Rubble Bed (E12) Refractory Lined Crucible (E13)	Prevent all high pressure containment failures caused by slow steam pressurization and eliminate sequences where scrubbing does not occur Prevent all slow high pressure containment failures Assume ideal concrete composition that prevents basemat melt-through Prevent vessel melt-through and subsequent basemat attack or steam explosion Prevent release classes associated with containment failures from hydrogen burns or explosions Prevent release classes associated with containment failures from hydrogen burns or explosions Scrub discharges to remove most fission products during SGTR Eliminate release classes where containment bypass is predicted (except for SGTR) Assume existing shutdown cooling system equipment always works - eliminate vessel failure, steam explosions and concrete interactions Eliminate release classes where basemat melt-through is modeled Eliminate release classes where basemat melt-through is modeled	0.0000733 (0.00733) 0.0000053 (0.00053) 0.0000487 (0.00487) 0.000307 (0.0307) 0.0000093 (0.00093) 0.0000093 (0.00093) 0.00246 (0.246) 0.0000166 (0.00166) 0.000307 (0.0307) 0.0000487 (0.00487) 0.0000487 (0.00487)

Table 2
Potential Design Improvements and Associated Costs (ABB-CE)

Design Alternative	Estimated Cost (\$M)	Person-Sv (Person-Rem) Averted Per Year	Cost(\$M)/ Person-Sv (Person-Rem) Averted Per Year
A2 100% SG inspection	1.0*	0.00249 (0.249)	400 (4.0)
A6 Secondary side pipe guards	1.1	0.0000076 (0.00076)	2,400 (24)
B1 Alternative DC Batteries and EFWS	2.0	0.0000187 (0.00187)	1,800 (18)
B2 12 Hour Batteries	0.3	0.000016 (0.0016)	430 (4.3)
B3 Alternative pressurizer aux. spray	5.0	0.00207 (0.207)	40 (0.40)
B4 Alternative HPSI	2.2	0.00083 (0.083)	43 (0.43)
B5 Alternative RCS Depressurization	0.5	0.000142 (0.0142)	56 (0.56)
B6 Diesel SI Pumps	2.0	0.000834 (0.0834)	39 (0.39)
B8 Extended RWST Source	1.0	0.00182 (0.182)	9.1 (0.091)
C1 Third Diesel Generator	25.0	0.0000045 (0.00045)	93,000 (930)
C2 Tornado Protection for Combustion Turbine	3.0	0.000016 (0.0016)	3,100 (31)
C3 Fuel Cells	2.0	0.0000187 (0.00187)	1,800 (18)
C4 Hookup for Portable Generator	0.01	0.0000187 (0.00187)	8.3 (0.083)
D1 Alternative ATWS Pressure Relief Valves	1.0	0.0000097 (0.00097)	1,700 (17)
D2 ATWS Injection System	0.3	0.0000097 (0.00097)	510 (5.1)
D3 Diverse PPS	3.0	0.0000097 (0.00097)	5,200 (52)
E1 Alternative Containment Spray	1.5	0.0000733 (0.00733)	340 (3.4)
E2 Filtered Vent (Containment)	10.0	0.0000053 (0.00053)	31,000 (310)
E3 Alternative Concrete Composition	5.0	0.0000487 (0.00487)	1,700 (17)
E4 Reactor Vessel Exterior Cooling	2.5	0.000307 (0.0307)	140 (1.4)
E5 Alternative Hydrogen Igniters	1.0	0.0000093 (0.00093)	1,800 (18)
E6 Passive Autocatalytic Recombiners (PARS)	0.76	0.0000093 (0.00093)	1,400 (14)
E7 MSSV and ADV Scrubbing	9.5	0.00246 (0.246)	64 (0.64)
E8 Alternative Containment Monitoring System	1.0	0.0000166 (0.00166)	1,000 (10)
E9 Cavity Cooling	0.05	0.000307 (0.0307)	2.7 (0.027)
E12 Water Cooled Rubble Bed	18.8	0.0000487 (0.00487)	6,400 (64)
E13 Refractory Lined Crucible	108.0	0.0000487 (0.00487)	37,000 (370)

* 100% SG costs are an annual cost and are used directly to calculate \$/person-Sv averted

**NRC CERTIFIES ABB-CE'S
SYSTEM 80+ REACTOR DESIGN**

The Nuclear Regulatory Commission (NRC) is amending its regulations to certify the System 80+ nuclear reactor design developed by Asea Brown Boveri-Combustion Engineering (ABB-CE). The certification will be valid for 15 years.

No application for a license using the System 80+ standard design has been filed with the NRC, and issuance of this regulation does not authorize construction of any specific new nuclear power plant. However, a utility that wishes to build and operate a new nuclear power plant may choose to use the design and reference it in an application for a license. Safety issues within the scope of the certified design are not subject to litigation, although site-specific environmental impacts associated with building and operating the plant at a particular location would be litigable.

Future applicants for a license could make plant-specific changes to portions of the standard System 80+ design by following the procedures set out in the rule. The applicant or licensee would be required to maintain records of all such changes until the license is terminated.

The NRC published a proposed rule on this subject in the Federal Register on April 7 for public comment and held public meetings to explain the proposal on May 11 and December 4, 1995. Responses to the comments received are discussed in a Federal Register notice on the final rule published on _____.

The agency also offered an opportunity to request a hearing on the proposed certification of the System 80+ design. No requests were received.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

The Honorable Dan Schaefer, Chairman
Subcommittee on Energy and Power
Committee on Commerce
United States House of Representatives
Washington, DC 20515

Dear Mr. Chairman:

The NRC has sent to the Office of the Federal Register for publication the enclosed final amendment to the Commission's regulations for commercial nuclear power plants. Specifically, this rule adds a new Appendix to 10 CFR Part 52. This rule will certify the System 80+ design, which was submitted to the NRC for its review by Asea Brown Boveri-Combustion Engineering, Inc. This amendment is necessary to fulfill the objectives of Part 52, which are to provide licensing stability, early resolution of licensing issues, and to foster standardization while allowing sufficient flexibility to incorporate advancements in technology and equipment. Those wishing to obtain a license to build or operate the System 80+ design will be able to do so by referencing the design certification in Appendix B to 10 CFR Part 52.

Sincerely,

Dennis K. Rathbun, Director
Office of Congressional Affairs

Enclosure:
Federal Register Notice

cc: Representative Frank Pallone



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

The Honorable Lauch Faircloth, Chairman
Subcommittee on Clean Air, Wetlands, Private
Property and Nuclear Safety
Committee on Environment and Public Works
United States Senate
Washington, DC 20510

Dear Mr. Chairman:

The NRC has sent to the Office of the Federal Register for publication the enclosed final amendment to the Commission's regulations for commercial nuclear power plants. Specifically, this rule adds a new Appendix to 10 CFR Part 52. This rule will certify the System 80+ design, which was submitted to the NRC for its review by Asea Brown Boveri-Combustion Engineering, Inc. This amendment is necessary to fulfill the objectives of Part 52, which are to provide licensing stability, early resolution of licensing issues, and to foster standardization while allowing sufficient flexibility to incorporate advancements in technology and equipment. Those wishing to obtain a license to build or operate the System 80+ design will be able to do so by referencing the design certification in Appendix B to 10 CFR Part 52.

Sincerely,

Dennis K. Rathbun, Director
Office of Congressional Affairs

Enclosure:
Federal Register Notice

cc: Senator Bob Graham

HISTORY OF APPLICABLE REGULATIONS

In its March 21, 1996 staff requirements memorandum (SRM), the Commission requested the NRC staff to prepare a supplemental paper containing a description and analysis of the historical documentation, evolution, and past Commission statements or decisions regarding the concept of applicable regulations, related to the 10 CFR Part 52 design certification rulemakings. The Commission also instructed the staff to include a discussion of the Commission's intent regarding applicable regulations when 10 CFR Part 52 was promulgated. The following discussion responds to the Commission's SRM.

COMMISSION POLICY STATEMENTS

The evolution and development of applicable regulations begins with the Commission's policy statements issued in the 1980s. In the introduction to its "Policy Statement on Severe Reactor Accidents Regarding Future Designs and Existing Plants" (50 FR 32138) dated August 8, 1985, the Commission stated that "The policies presented in this statement will lead to amendment of NRC regulations ... as part of NRC's ongoing Severe Accident Program." The Commission went on to propose criteria and procedural requirements for severe accident concerns in its *Policy for New Plant Applications* and stated:

Although in the licensing of existing plants, the Commission has determined that these plants pose no undue risk to public health and safety, this should not be viewed as implying a Commission policy that safety improvements in new plant designs should not be actively sought. The Commission fully expects that vendors engaged in designing new standard (or custom) plants will achieve a higher standard of severe accident safety performance than their prior designs. ... (50 FR 32141)

After the Severe Accident Policy Statement was issued, the staff, industry, and Advisory Committee on Reactor Safeguards (ACRS) continued discussions on how to implement the Commission guidance. In its January 15, 1987 letter, the ACRS stated that it "has on several previous occasions recommended that future LWRs should be designed to be safer than current LWRs." The Committee further advised that "Future plants should be able to survive a wider spectrum of off-normal challenges and mistreatments. ... Accident management and mitigation systems should be designed, not for a narrow set of design-basis accidents, but to reasonably accommodate a broad range, variety, and time sequence of threats." In its policy statement on "Nuclear Power Plant Standardization" (52 FR 34884) dated September 15, 1987, the Commission adopted the Severe Accident Policy Statement for future design certification reviews.

IMPLEMENTATION OF SEVERE ACCIDENT POLICY

SECY-88-147, "Integration Plan for Closure of Severe Accident Issues," dated May 25, 1988, presented the staff's plan for integration and closure of severe accident issues. In element #11 (pp. 69-71) of this plan, the staff proposed ... "performance regulations for future reactors ... for addressing severe accidents. This activity is considered to be consistent with the

intent of the Severe Accident Policy Statement and is intended to support the design certification rulemaking (10 CFR 52)." The staff initially proposed to modify 10 CFR 50.34(f) to make it applicable to future plant designs and to include performance requirements. Subsequently, the staff held a public meeting on June 9, 1988 to discuss its plans to establish regulatory requirements for future plants related to postulated severe accidents.

In the statements of consideration (SOC) for the proposed 10 CFR Part 52 (53 FR 32060, 32067), the Commission stated:

12. The staff is considering whether there is a need for further rulemaking or guidance for future reactors, both light-water reactors and other types, to assure that future license applications adequately address the Commission's Safety Goal Policy Statement and the licensing criteria set forth in the Commission's Severe Accident Policy Statement, particularly the criteria that call for demonstration of compliance with the applicable parts of 10 CFR 50.34(f) and completion of a probabilistic risk assessment together with a systematic consideration of any severe accident vulnerabilities the PRA might expose.

Then, in the final rule SOC (54 FR 15372, 15376), the Commission stated:

The Commission recognizes that new designs may incorporate new features not addressed by the current standards in Parts 20, 50, 73 or 100 and that, accordingly, new standards may be required to address any such new design features. Therefore, the NRC staff shall, as soon as practicable, advise the Commission of the need for criteria for judging the safety of designs offered for certification that are different from or supplementary to current standards in 10 CFR Parts 20, 50, 73, and 100. The Commission shall consider the NRC staff's views and determine whether additional rulemaking is needed or appropriate to resolve generic questions that are applicable to multiple designs. The objective of such rulemaking would be to incorporate any new standards in Part 50 or 100, as appropriate, rather than to develop such standards in the context of the Commission's review and approval of individual applications for design certifications. On the other hand, new design features that are unique to a particular design would be addressed in the context of a rulemaking proceeding for that particular design.

In SECY-88-248, "Implementation of Severe Accident Policy," dated September 6, 1988, the staff again proposed "rulemaking to amend 10 CFR 50.34 to require that technical information on severe accidents be included in future applications. In addition to these procedural requirements, we are recommending that general performance requirements be promulgated addressing severe accident prevention and mitigation." The staff stated that it intended to clarify severe accident requirements for future LWRs (including the evolutionary LWRs) before initiation of design certification rulemaking. The staff informed the Commission that it proposed to implement the Commission's severe accident policy for future LWRs by establishing requirements for the consideration of severe accidents applicable to those LWR designs which do not differ significantly from current generation LWR designs (i.e., evolutionary LWRs). The purpose of the proposed rules and regulatory guides was to ensure

an adequate and consistent assessment of severe accidents on future plants. In a memorandum to the Commission on "Implementation of Severe Accident Policy for Evolutionary LWR Designs," dated December 1, 1988, the staff clarified its plan in SECY-88-248 for severe accident rulemaking.

After much internal discussion, the staff concluded that it was more appropriate to implement the Severe Accident Policy for evolutionary LWRs by design-specific rulemaking because the staff believed that there was insufficient time to complete generic rulemaking in a time frame to support the evolutionary LWR review schedules, and because the generic rulemaking would be applicable to only a small class of plant designs. In SECY-89-178, "Policy Statement Integration," dated June 9, 1989, the staff stated its intent to codify the severe accident design features of the evolutionary LWRs through design-specific rulemaking. The staff stated:

[The] approach to implementing the Severe Accident Policy for evolutionary LWRs, on a plant specific basis, replaces the staff's previous proposal in SECY-88-248 to initiate generic rulemaking. This plant-specific approach to severe accidents we are now following on the future plants is viewed as being consistent with that on the existing plants (i.e., a plant-specific IPE, SECY-88-205). And it is an approach that will not prematurely foreclose on innovative developments and designs. Also, it is expected that *those severe accident design features provided by the future designs will be generally codified by the certification rulemaking applicable to each. In this manner, the certification rulemaking will bring generic closure of the severe accident issues for a class of plants subsequently using the certified design and will ensure the intents of the Safety Goal Policy have been achieved by regulations (emphasis added).*

In SECY-89-311, "Resolution Process for Severe Accident Issues on Evolutionary Light Water Reactors," dated October 10, 1989, the staff requested the Commission to endorse its implementation approach or to provide additional guidance. The staff stated:

The first area where the staff provided interpretation of the Commission's guidance concerns the statement in the Severe Accident Policy Statement that "the Commission fully expects that vendors engaged in designing new standard (or custom) plants will achieve a higher standard of severe accident safety performance than their prior designs." The staff has interpreted this statement to mean that new generations of reactor designs should be demonstrably safer than the current generation from a severe accident perspective which will include overall enhancement of the defense-in-depth principle. This objective might result in designs that incorporate features or systems different from those required by current regulations and standards. This interpretation means that the evolutionary ALWR plant designs (e.g., ABWR) should be safer than the current generation of operating reactors ...

The staff further reiterated in SECY-89-311 its revised position regarding design-specific rulemaking:

... SECY-88-248 proposed that generic rulemaking be initiated to address severe accident issues for future LWRs. Since that time, the staff has concluded that generic rulemaking is no longer the preferred approach.... In summary, the staff has concluded that the design-specific rulemaking that results from the design certification process of individual applications is a more effective method of resolving severe accident issues than attempting to develop one generic severe accident rule or several individual rule changes for evolutionary LWRs. Although there is a large body of information available to support design-specific rulemaking for evolutionary LWRs, the staff has concluded that the usefulness of generic rulemakings for this class of plants may be limited because of the diversity and limited number (3) of the evolutionary LWR designs. In addition, such codification would likely not be applicable to other advanced designs owing to their fundamental differences.

In its SRM dated December 15, 1989, the Commission responded to the staff's queries in SECY-89-311 by stating that:

The Commission, with all Commissioners agreeing, reaffirms its expectation stated in the Policy Statement on Severe Reactor Accidents Regarding Future Designs and Existing Plants, "... that vendors engaged in designing new standard (or custom) plants will achieve a higher standard of severe accident safety performance than their prior designs." In order to accomplish this goal, in promulgating 10 CFR Part 52, the Commission incorporated the criteria and procedural requirements from the Severe Accident Policy Statement. Generally, the Commission has indicated that it believes a new design for a nuclear power plant can be shown to be acceptable for severe accident concerns if it addresses the TMI requirements, unresolved safety issues, the medium and high priority generic safety issues, and the severe accident vulnerabilities exposed by a completed probabilistic risk assessment. In staff's application of these criteria during reviews, it is expected that significant policy questions may arise. The staff should elevate to the Commission ... all issues dealing with policy considerations ... Instances where staff proposes to require measures that depart from current regulatory requirements -- including, but not limited to, design enhancements to address severe accident vulnerabilities ...

The Commission also stated, in its SRM on SECY-89-311, " The Commission will provide additional guidance regarding generic rulemaking following receipt of staff's paper on Proposed Departure from Current Regulations." Further, in its SRM on SECY-89-102, "Implementation of the Safety Goals," dated June 15, 1990, the Commission stated:

5) It is important to note that the Commission has made it clear in the

advanced plant and severe accident policy statements that it expects that advanced designs will reflect the benefits of significant research and development work and experience gained in operating the many power and development reactors, and that vendors will achieve a higher standard of severe accident safety performance than their prior designs ... However, the NRC will not use industry's design objectives as the basis to establish new requirements.

9) ... Therefore, the staff in applying the criteria provided in 10 CFR Part 52 may conclude that additional requirements are needed based on experience with prior designs in order to provide substantial assurance that future designs will meet the level of safety provided in the Safety Goal Policy Statement. The staff should elevate such safety issues to the Commission for consideration and should not be constrained from proposing new requirements where benefits cannot be quantified in terms of risk.

IDENTIFICATION AND DEVELOPMENT OF APPLICABLE REGULATIONS

In SECY-89-013, "Design Requirements Related to the Evolutionary Advanced Light-Water Reactors (ALWRs)," dated January 19, 1989, the staff first identified its intent to pursue certain areas of the design review in a manner that may go beyond the present acceptance criteria defined in the Standard Review Plan. In its SRM dated February 10, 1989, the Commission directed the staff to ensure that the Commission was involved early in the development of new requirements for advanced reactors. The direction to keep the Commission informed of policy matters and obtain guidance and approval from the Commission on proposed resolutions of such matters is provided in several subsequent SRMs. The staff elevated these new requirements to the Commission in SECY-90-016, "Evolutionary Light-Water Reactor (LWR) Certification Issues and Their Relationship to Current Regulatory Requirements," dated January 12, 1990. The purpose of this paper was to present the staff's recommendations for proposed departures from current regulations for the evolutionary designs:

The staff recommendations identified in this paper have been developed as a result of (1) the staff's reviews of current generation reactor designs and evolutionary ALWRs, (2) consideration of operating experience, including the TMI-2 accident, (3) results of the PRAs of current-generation reactor designs and the evolutionary LWRs, (4) early efforts conducted in support of severe accident rulemaking, and (5) research conducted to address previously identified safety issues. ... The staff believes its conclusions and recommendations regarding these matters are in keeping with the Commission's policy expectation that future designs for nuclear plants will achieve a higher standard of severe accident safety performance.

In its SRM on SECY-90-016 dated June 26, 1990, the Commission approved some and disapproved some of the staff's recommendations and "... agreed that in those cases where the staff proposed requirements depart from current regulations, consideration should be given to incorporating these requirements into the regulations." The issues in SECY-90-016 and SECY-93-087, "Policy,

Technical, and Licensing Issues Pertaining to Evolutionary and Advanced Light-Water Reactor Designs," that were approved by the Commission became review criteria for the future designs. See the "Table of Applicable Regulations" at the end of this paper. Therefore, in SECY-91-262, "Resolution of Selected Technical and Severe Accident Issues for Evolutionary Light-Water Reactor (LWR) Designs," dated August 16, 1991, the staff stated its intent:

... current course of action for the two evolutionary plant designs is for the final resolutions of selected technical and severe accident issues, including issues that have been the subject of Commission guidance (e.g., the SRM on SECY-90-016), to be codified in rulemaking as part of the specific design certifications for the GE ABWR and the ABB-CE System 80+.

This paper also described the advantages and disadvantages of generic versus design-specific rulemaking. Although there were limited generic rulemaking activities underway, such as revising the source term, the staff requested the Commission to "approve the staff's plans for proceeding with *design-specific rulemakings through individual design certifications* to resolve selected technical and severe accident issues for the ABWR and ABB-CE System 80+." In its SRM on SECY-91-262 dated January 28, 1992, the Commission stated:

The Commission (with all Commissioners agreeing) has approved the staff's recommendation to proceed with design-specific rulemakings through individual design certifications to resolve selected technical and severe accident issues for the ABWR and ABB-CE System 80+ designs. ...

With regard to the issue of obtaining early informal public comment on these issues, the staff should provide a more detailed analysis of exactly what kind of informal public comment is envisioned and elaborate on the following questions ...

The General Counsel responded to these questions in a memorandum to the Commission dated February 28, 1992 and went on to say:

Common to all approaches, the Commission would set forth proposed *special review criteria* that it intends to use in *judging the design certification* for a specified design, with the intention of requesting public comments on the applicability and appropriateness of those review criteria (emphasis added).

The staff proceeded with design-specific rulemaking for the evolutionary LWRs, and also continued with its generic rulemaking activities, with the intent of incorporating, to the extent possible, the Commission-approved positions from SECY-90-016, the ACRS-proposed severe accident containment design criteria and the proposed staff positions for the passive LWRs. In SECY-92-287, "Form and Content for a Design Certification Rule," dated August 18, 1992, the staff provided a conceptual proposed design certification rule along with a discussion of pertinent issues. In Enclosure 3 to the paper regarding documentation of selected technical and severe accident issues, the

staff defined what it termed "applicable regulations," stating

In the SRM pertaining to SECY-91-262 ... the Commission approved the staff's recommendation to proceed with design-specific rulemakings through individual design certifications to resolve selected technical and severe accident issues for the GE ABWR and ABB-CE System 80+ designs. These matters include staff positions that deviate from or are not embodied in current regulations, but were approved by the Commission and will be clearly identified and evaluated in the staff's FSER and supplements, thereto. ... The completed standard design certification rule will then designate these agency positions, which are identified in the FSER and supplements thereto, as "applicable regulations" for the specific design for the purposes of 10 CFR 52.48 and 52.63.

In a memorandum dated September 9, 1992, Commissioner Curtiss asked the staff and the Office of the General Counsel (OGC) to respond to questions related to the September 8, 1992 Commission briefing on SECY-92-287. The staff responded to these questions in Enclosure 2 to SECY-92-287A, "Form and Content for a Design Certification Rule," dated March 26, 1993. The staff provided the following in response to question 1:

The purpose of Section A.9(d) [of Enclosure 1 to SECY-92-287] of the proposed design certification rule is to identify the staff positions that deviate from or are not embodied in current regulations, but were approved by the Commission, such as SECY-90-016 ... These staff positions will then become "applicable regulations" via the certification rulemaking that will be added to the list of regulations in Sections 52.48 and 52.54 that were used to approve the design to be certified. Rather than reference these proposed regulations, as was done in Enclosure 1 to SECY-92-287, the staff now plans to list these proposed regulations in the design certification rule. These proposed regulations would be stated broadly, similar to the general design criteria, and would become part of the Commission's baseline of regulations that were "applicable and in effect at the time the certification was issued." Without this baseline of applicable regulations, the staff could not perform reviews in accordance with Sections 52.59 and 52.63.

After further consideration of Section A.9, OGC recognized that it should be modified to also reference Section 52.59, to make it clear that for the purposes of renewal of a design certification under Section 52.59, the staff positions are part of the applicable regulations in effect at the time that the design certification was first issued.

In its response to a question on whether the staff's technical positions at the referenced FSER pages would be given the force and effect of regulations, the staff stated:

Yes, but the technical positions that are deemed "applicable

regulations" in Section A.9 of the certification rule would have the force and effect of regulations only for those applications or licenses that reference that certified design. In addition, the staff's technical positions would be considered "applicable regulations" for purposes of the design certification rule in which they are included, and for applying the backfitting requirements of 52.63. However, the staff positions would not be "regulations" in the sense of "generally applicable" requirements that all design certification applicants must comply with, e.g., Section 50.48. Each design certification for which the Commission wishes to make the staff positions applicable must specify the staff positions as "applicable regulations."

The staff further stated that:

... The "applicable regulations" should not be in Tier 1 of the design certification rule. The staff does not consider the technical positions themselves to be either "Tier 1" or "Tier 2," since from a legal standpoint, they are requirements that a design must meet, rather than the actual design information. The staff will incorporate into Tier 1 the key features of the design resulting from these regulations. A deviation from a staff technical position (applicable regulation) could affect Tier 1 or Tier 2 information; and any changes to Tier 1 or Tier 2 must involve either exemption, rulemaking, or a determination under the "50.59-like" process. Therefore, an exemption or a rulemaking amendment may be required in order to deviate from the staff technical position.

To solicit public comments on criteria to address severe accidents, the staff issued an advance notice of proposed rulemaking (ANPR) on the subject of severe accident plant performance criteria for future LWRs in the Federal Register (Volume 57, No. 188) on September 28, 1992. In SECY-93-226, "Public Comments on 57 FR 44513 - Proposed Rule on ALWR Severe Accident Performance," dated August 18, 1993, the staff discussed comments on the ANPR. The staff recommended that it continue to develop a draft generic rule [on severe accident design criteria], but to defer a decision to issue the rule until after the FSERs are issued for the GE ABWR and ABB-CE System 80+ designs. The staff indicated that this rulemaking would codify the already existing Commission guidance on severe accident issues that has resulted from reviews of the GE ABWR and the ABB-CE System 80+ reactor designs. Again, the staff pointed out that:

It is expected that severe accident licensing issues will primarily be resolved for the ABWR and System 80+ designs through the individual design certification rulemakings for these two evolutionary designs. However, the staff is considering a procedure wherein if generic rules are put in place sufficiently early to facilitate (through reference) the design certification process for reactor designs licensed after the evolutionary designs, such generic rules or parts of the rules, could possibly be utilized."

In its SRM on SECY-93-226 dated September 14, 1993, the Commission (with all

Commissioners agreeing) "... approved the staff recommendation to delay a decision on the need for generic rulemaking to address severe accidents at least until after the FSERs are issued for the ABWR and the System 80+."

In its May 31, 1994 memorandum to the Commission, "Implementation of Design Certification and Light Water Reactor Design Issues," the staff requested Commission approval of its positions and safety findings addressed in each FSER on the ABWR and System 80+ designs. The staff stated that

... approval of the FSER will indicate Commission acceptance of the staff's implementation of specific issues (such as those discussed in SECY-93-087 ...), as well as other policy issues relating to the general implementation of 10 CFR Part 52.

This memorandum identified the key issues and areas of interest that the Commission was being requested to approve as part of the FSER and FDA reviews. The memorandum went on to say:

... Commission approval of the FSERs will necessarily include consideration of the applicable regulations and exemptions. Final Commission action on applicable regulations will take place in connection with promulgation of the design certification rules.

In its SRMs dated June 30 and July 26, 1994, the Commission approved the publication of the ABWR and System 80+ FSERs, respectively.

In SECY-95-023, "Proposed Design Certification Rules for the Advanced Boiling Water Reactor (ABWR) and System 80+ Standard Designs," dated February 1, 1995, the staff forward proposed rules for the two evolutionary plants. In its SRM dated March 17, 1995, the Commission approved the proposed rules, subject to soliciting comments on whether each specific applicable regulation is justified, and requested the staff to:

- 1) give special attention to the resolution of comments received, particularly regarding inclusion of "applicable regulations" in the rule, and re-evaluate, as necessary, the need for their inclusion; and
- 2) if the staff recommends keeping "applicable regulations" as part of the rule, the statement of each applicable regulation should be reviewed to ensure that it is justified and:
 - a) it is in conformance with past approved Commission guidance;
 - b) that it correctly reflects the intended technical requirements; and
 - c) that requirements have not been inadvertently made more stringent through word changes since Commission approval.

The staff made appropriate modifications to the proposed design certification rules and issued the notice of proposed rulemaking (60 FR 17901) on April 7, 1995. As a result of comments received from the Nuclear Energy Institute (NEI), the staff issued SECY-96-028, "Two Issues for Design Certification

Rules," dated February 6, 1996. One of these issues was applicable regulations, in which the staff concluded that:

... there appears to be agreement [between the staff and industry] that: (1) these new requirements go beyond existing regulations and improve safety; (2) the design descriptions that meet the proposed applicable regulations are binding on the applicants and licensees that reference these design certification rules in the same manner that other design descriptions are binding; (3) in evaluating the possible need for a compliance backfit, as permitted by Part 52, and in evaluating an application to renew or request to change a design certification, these new requirements will have no legal effect unless they are designated as applicable regulations; and (4) the need for these new applicable regulations must be resolved in the final design certification rule.

The staff summarized in SECY-96-028 that it "continues to believe that new applicable regulations are necessary and desirable for the final design certification rules." Subsequently, in response to the Commission's SRM dated March 21, 1996, the staff met with representatives of ABB-CE, GE, and NEI on March 25, 1996 and proposed various means to reduce or otherwise resolve the need for new applicable regulations. The industry, represented by NEI, neither provided a proposal for resolution of applicable regulations (other than to eliminate them altogether) nor indicated any support for the staff's proposals. As a result, the NRC staff has provided revised resolutions of applicable regulations in the final rules (Attachments 1 and 5) that supersede the proposals in SECY-96-028.

SUMMARY

The staff has been working on the development of new "applicable regulations" for future nuclear power plants since 1988, as identified in SECY-88-147. The purpose was to achieve a higher level of safety for future nuclear power plant designs. This effort has included exemptions from as well as additions to existing regulations. The staff proceeded steadily on this course of action and kept the Commission informed of its progress in numerous SECY papers and memoranda, as summarized above. The Commission and industry have been cognizant of the staff's intent to codify applicable regulations since 1989. The pivotal decision in this process was the decision in early 1989 to abandon generic rulemaking and proceed in parallel with design-specific rulemaking for the applicable regulations and design approval for each evolutionary design by rulemaking (design certification). This decision was discussed in several SECY papers and memoranda, in particular SECY-91-262 and its SRM. The consequence of this approach was deferral of the Commission's final decision on applicable regulations until its decision on the final design certification rules.

Incorporation of the new (additional) applicable regulations into the final design certification rules was a fundamental assumption of the staff during its design reviews, as can be seen in the FSERs for the ABWR and System 80+ designs. The staff continues to believe that new applicable regulations are necessary and desirable to achieve the Commission's intent for a higher

level of safety for future designs, to achieve stability and predictability for certified designs, and to identify the requirements for these designs that are applicable and in effect at the time the certification is issued for the purposes of 10 CFR 52.48, 52.54, 52.59, and 52.63.

DERIVATION OF NEW (ADDITIONAL) APPLICABLE REGULATIONS

ADDITIONAL APPLICABLE REGULATION SUBJECT	SECY-90-016 REFERENCE	SECY-93-087 REFERENCE
5(c)(1) INTERSYSTEM LOCA	II.E	I.F
5(c)(2) INSERVICE TESTING OF PUMPS AND VALVES	IV.B	I.N
5(c)(3) DIGITAL INSTRUMENTATION AND CONTROL SYSTEMS	N/A	II.Q
5(c)(4) ALTERNATE OFFSITE POWER SOURCE TO NON-SAFETY EQUIPMENT	N/A	II.B
5(c)(5) OFFSITE POWER SOURCE TO SAFETY DIVISIONS	N/A	II.B
5(c)(6) POST-FIRE SAFE SHUTDOWN	II.D	I.E
5(c)(7) ANALYSIS OF EXTERNAL EVENTS	N/A	II.N
5(c)(8) ALTERNATE AC POWER SOURCE	II.C	I.D
5(c)(9) CORE DEBRIS COOLING	III.B	I.H
5(c)(10) HIGH PRESSURE CORE MELT EJECTION	III.C	I.I
5(c)(11) EQUIPMENT SURVIVABILITY	III.F	I.L
5(c)(12) CONTAINMENT PERFORMANCE	III.D	I.J
5(c)(13) SHUTDOWN RISK	II.B	I.C
5(c)(14) STEAM GENERATOR TUBE RUPTURES	N/A	II.R

DERIVATION OF ADDITIONAL REQUIREMENTS AND RESTRICTIONS

REQUIREMENT/RESTRICTION	SECY-90-016	SECY-93-087
4(a)(vii) INSERVICE TESTING AND INSPECTION OF PUMPS AND VALVES	IV.B	I.N
4(a)(viii) SHUTDOWN RISK	II.B	I.C
4(a)(ix) RELIABILITY ASSURANCE PROGRAM	N/A	II.M