

5.5 Programs and Manuals

5.5.13 Safety Functions Determination Program (SFDP) (continued)

- c. A required system redundant to support system(s) for the supported systems (a) and (b) above is also inoperable.

The SFDP identifies where a loss of safety function exists. If a loss of safety function is determined to exist by this program, the appropriate Conditions and Required Actions of the LCO in which the loss of safety function exists are required to be entered.

5.5.14 Containment Leak Rate Testing Program

Programs shall be established to implement the leak rate testing of the containment as required by 10 CFR 50.54(o) and 10 CFR 50, Appendix J, Option B, as modified by approved exemptions. The Type A test program shall meet the requirements of 10 CFR 50, Appendix J, Option B and shall be in accordance with the guidelines of Regulatory Guide 1.163, "Performance-Based Containment Leakage-Test Program, dated September 1995."

The Type B and Type C test program shall meet the requirements of 10 CFR 50, Appendix J, Option A, as modified by the exemption from certain requirements of 10 CFR 50 Appendix J which was granted in an NRC letter to Consumers Power Company dated December 6, 1989.

The peak calculated containment internal pressure for the design basis loss of coolant accident, P_a , is 53 psig.

The maximum allowable containment leak rate, L_a , at P_a , shall be 0.1% of containment air weight per day.

Local leak rate tests, other than Personnel Airlock doors between the seals tests, shall be performed at ≥ 55 psig.

Local leak rate tests for checking airlock doors seals within 72 hours of each door opening shall be performed as follows:

- a. A between the seals test shall be performed on the Personnel Airlock at ≥ 10 psig.
- b. A full pressure test shall be performed on the Emergency Escape Airlock at ≥ 55 psig. A seal contact check shall be performed on the Emergency Escape Airlock following each full pressure test. Emergency Escape Airlock door opening, solely for the purpose of strongback removal and performance of the seal contact check, does not necessitate additional pressure testing.