

3ECY-02



TXU Electric Comanche Peak Steam Electric Station P.O. Box 1002 Glen Rose, TX 76043 Tel: 254 897 8920 Fax: 254 897 6652 Iterry1@txu.com C. Lance Terry Senior Vice President & Principal Nuclear Officer

lor vice President & Principal Nuclear Offic

'00 AFR 28 P4:11

O AD

Log # TXX-00084 File # 10185 Ref. # 10CFR50 Appendix G

DOCKET NUMBER PETITION RULE PRM 50-69 (65FR 6044)

April 24, 2000

Annette Vietti-Cook Secretary of the Commission U. S. Nuclear Regulatory Commission Washington, DC 20555 Attention: Rulemakings and Adjudications Staff

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES) DOCKET NOS. 50-445 AND 50-446 COMMENTS ON PETION FOR RULEMAKING REGARDING 10CFR50 APPENDIX G, FRACTURE TOUGHNESS REQUIREMENTS

- REF: 1) 65 Federal Register, Pages 6044-6046, dated February 8, 2000, Request for comments on proposed rulemaking
 - 2) Nuclear Energy Institute Letter from David J. Modeen to the NRC dated April 24, 2000

Gentlemen:

On February 8, 2000, the NRC issued a notice (Reference 1) requesting public comments on a petition for rulemaking regarding 10CFR50 Appendix G, Fracture Toughness Requirements. The proposed rulemaking would eliminate requirements for the metal temperature of the closure head flange and vessel flange regions.

The Nuclear Energy Institute (NEI) is providing comments by Reference 2. TXU Electric concurs with NEI's comments and recommends that the NRC revise Table 1 of 10 CFR 50, Appendix G, as described in the petition.

TEMPLATE = SECY-067



TXX-00084 Page 2 of 2

. . .

If you have any questions please contact Carl Corbin at (254) 897-0121 (email: ccorbin1@txu.com).

This communication contains no new licensing basis commitments regarding CPSES Units 1 and 2.

Sincerely,

C. S. Terry

C. L. Terry

alter By:

Roger D. Walker Regulatory Affairs Manager

CBC/cbc

c - E. W. Merschoff, Region IV
J. I. Tapia, Region IV
D. H. Jaffe, NRR
Resident Inspectors, CPSES
David J. Modeen, NEI