

Mr. A. Alan Blind  
 Vice President, Nuclear Power  
 Consolidated Edison Company  
 of New York, Inc.  
 Broadway and Bleakley Avenue  
 Buchanan, NY 10511

April 20, 2000

File Center  
 Template =  
 NER-058

SUBJECT: INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 RE: ISSUANCE OF AMENDMENT TO RELOCATE ITEMS ASSOCIATED WITH TOXIC GAS MONITORING TO THE UPDATED FINAL SAFETY ANALYSIS REPORT (UFSAR) (TAC NO. MA6908)

Dear Mr. Blind:

The Commission has issued the enclosed Amendment No. 208 to Facility Operating License No. DPR-26 for the Indian Point Nuclear Generating Unit No. 2. The amendment consists of changes to the Technical Specifications (TSs) in response to your application transmitted by letter dated September 23, 1999.

The amendment revises TSs 3.3.H.3 and 4.5.E.7 and their associated Bases by relocating the requirements contained in these sections to the UFSAR. These changes are in accordance with the guidance of Generic Letter 95-10.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular biweekly *Federal Register* notice.

Sincerely,

/RA/

Jefferey F. Harold, Project Manager, Section 1  
 Project Directorate I  
 Division of Licensing Project Management  
 Office of Nuclear Reactor Regulation

Docket No. 50-247

Enclosures: 1. Amendment No. 208 to DPR-26  
 2. Safety Evaluation

cc w/encls: See next page

**DISTRIBUTION:**

File Center  
 PUBLIC  
 PDI-1 Reading  
 M.Gamberoni (A)  
 G. Hill (2), T-5 C3  
 J. Rogge, Region I  
 RidsNrrPMGWunder

RidsNrrLASLittle  
 RidsNrrPMJHarold  
 RidsNrrDLPMpdi (E. Adensam)  
 RidsNrrDripRtsb (W.Beckner)  
 RidsOgcRp  
 RidsAcrcAcnwMailCenter

DOCUMENT NAME: G:\PDI-1\IP2\AMD6908.WPD

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PDI-1/PM	E	PDI-1/LA	OGC	ICMB TSB	PDI-1/SC(A)
NAME	JHarold:10		SLittle	W. Newill	W. B. B.	M. Gamberoni
DATE	3/28/00		3/28/00	4/13/00	4/6/00	4/20/00

Official Record Copy *to Luens! condit* DF01



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

April 20, 2000

Mr. A. Alan Blind  
Vice President, Nuclear Power  
Consolidated Edison Company  
of New York, Inc.  
Broadway and Bleakley Avenue  
Buchanan, NY 10511

SUBJECT: INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 RE: ISSUANCE OF  
AMENDMENT TO RELOCATE ITEMS ASSOCIATED WITH TOXIC GAS  
MONITORING TO THE UPDATED FINAL SAFETY ANALYSIS REPORT  
(UFSAR) (TAC NO. MA6908)

Dear Mr. Blind:

The Commission has issued the enclosed Amendment No. 208 to Facility Operating License No. DPR-26 for the Indian Point Nuclear Generating Unit No. 2. The amendment consists of changes to the Technical Specifications (TSs) in response to your application transmitted by letter dated September 23, 1999.

The amendment revises TSs 3.3.H.3 and 4.5.E.7 and their associated Bases by relocating the requirements contained in these sections to the UFSAR. These changes are in accordance with the guidance of Generic Letter 95-10.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular biweekly *Federal Register* notice.

Sincerely,

A handwritten signature in cursive script that reads "Jeffrey F. Harold".

Jefferey F. Harold, Project Manager, Section 1  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-247

Enclosures: 1. Amendment No. 208to DPR-26  
2. Safety Evaluation

cc w/encls: See next page

Indian Point Nuclear Generating Station  
Unit 2

Mayor, Village of Buchanan  
236 Tate Avenue  
Buchanan, NY 10511

Mr. F. William Valentino, President  
New York State Energy, Research,  
and Development Authority  
Corporate Plaza West  
286 Washington Ave. Extension  
Albany, NY 12203-6399

Mr. John McCann  
Manager of Nuclear Safety and  
Licensing  
Consolidated Edison Company  
of New York, Inc.  
Broadway and Bleakley Avenue  
Buchanan, NY 10511

Senior Resident Inspector  
U. S. Nuclear Regulatory Commission  
P.O. Box 38  
Buchanan, NY 10511

Mr. Brent L. Brandenburg  
Assistant General Counsel  
Consolidated Edison Company  
of New York, Inc.  
4 Irving Place - 1822  
New York, NY 10003

Dave Lochbaum  
Nuclear Safety Engineer  
Union Concerned Scientists  
1616 P Street, NW., Suite 310  
Washington, DC 20036

Edward Smeloff  
Pace University School of Law  
The Energy Project  
78 North Broadway  
White Plains, NY 10603

Charles Donaldson, Esquire  
Assistant Attorney General  
New York Department of Law  
120 Broadway  
New York, NY 10271

Ms. Charlene D. Faison, Director  
Nuclear Licensing  
Power Authority of the State  
of New York  
123 Main Street  
White Plains, NY 10601

Mr. Thomas Rose  
Secretary - NFSC  
Consolidated Edison Company  
Of New York, Inc.  
708 First Avenue  
New York, NY 10017

Regional Administrator, Region I  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. Paul Eddy  
New York State Department of  
Public Service  
3 Empire State Plaza, 10th Floor  
Albany, NY 12223

Jim Riccio  
Public Citizen's Critical Mass Energy Project  
215 Pennsylvania Ave., SE  
Washington, DC 20003

Michael Moriotte  
Nuclear Information & Resources Service  
1424 16<sup>th</sup> Street, NW, Suite 404  
Washington, DC 20036



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.

DOCKET NO. 50-247

INDIAN POINT NUCLEAR GENERATING UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 208  
License No. DPR-26


1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Consolidated Edison Company of New York, Inc. (the licensee) dated September 23, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-26 is hereby amended to read as follows:


(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 208, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days. In addition, the licensee shall include the relocated information, as described in the licensee's application dated September 23, 1999, and evaluated in the staff's safety evaluation dated April 20, 2000, in the Updated Final Safety Analysis Report, to be submitted to the NRC pursuant to 10 CFR 50.71(e).

FOR THE NUCLEAR REGULATORY COMMISSION



 Marsha Gamberoni, Acting Chief, Section 1  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: April 20, 2000

ATTACHMENT TO LICENSE AMENDMENT NO. 208

FACILITY OPERATING LICENSE NO. DPR-26

DOCKET NO. 50-247

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

Remove Pages

3.3-10

3.3-15

3.3-16

4.5-5

Insert Pages

3.3-10

3.3-15

3.3-16

4.5-5

#### H. CONTROL ROOM AIR FILTRATION SYSTEM

1. The control room air filtration system shall be operable at all times when containment integrity is required.
2. From the date that the control room air filtration system becomes and remains inoperable for any reason, operations requiring containment integrity are permissible only during the succeeding 3.5 days. At the end of this 3.5 days period, if the conditions for the control room air filtration system cannot be met, the reactor shall be placed in the hot shutdown condition utilizing normal operating procedures. If the conditions are not satisfied within an additional 48 hours, the reactor shall be placed in the cold shutdown condition utilizing normal operating procedures.

#### I. CABLE TUNNEL VENTILATION FANS

1. The reactor shall not be made critical unless the two cable tunnel ventilation fans are operable.
2. During power operation, the requirement of 3.3.I.1 may be modified to allow one cable tunnel ventilation fan to be inoperable for seven days, provided the other fan is operable.

The exhaust line penetrates the containment and then is divided into two parallel lines. Each parallel line contains a pressure sensor and all the valves necessary for controlling the venting operation. The two lines then rejoin and the exhaust passes through a flow sensor and a temperature sensor before passing through roughing, HEPA and charcoal filters. The exhaust is then directed to the plant vent.

The post-accident containment venting system is a passive system in the sense that a differential pressure between the containment and the outside atmosphere provides the driving force for the venting process to take place. The system is designed such that a minimum internal containment pressure of 2.14 psig is required for the system to operate properly.

The flow rate and the duration of venting required to maintain the hydrogen concentration at or below 3 percent of the containment volume are determined from the containment hydrogen concentration measurements and the hydrogen generation rate. The containment pressure necessary to obtain the required vent flow is then determined. Using one of the air compressors, hydrogen-free air is pumped into the containment until the required containment pressure is reached. The air supply is then stopped and the supply/exhaust line is isolated by valves outside the containment. The addition of air to pressurize the containment dilutes the hydrogen; therefore, the containment will remain isolated until analysis of samples indicates that the concentration is again approaching 3 percent by volume. Venting will then be started. This process of containment pressurization followed by venting is repeated as may be necessary to maintain the hydrogen concentration at or below 3 volume percent.

The post-accident venting system is used only in the absence of hydrogen recombiners and only when absolutely necessary. From the standpoint of minimizing offsite radiation doses, the optimum starting time for the venting system, if needed, is the latest possible time after the accident. Consistent with this philosophy, the selected venting initiation point of 3 percent hydrogen maximizes the time period before venting is required while at the same time allows a sufficient margin of safety below the lower flammability limit of hydrogen.

The control room air filtration system is designed to filter the control room atmosphere for intake air and/or for recirculation during control room isolation conditions. The control room system is designed to automatically start upon control room isolation. Control room isolation is initiated either by a safety injection signal or by detection of high radioactivity in the control room. If the control room air filtration system is found to be inoperable, there is no immediate threat to the control room and reactor operation may continue for a limited period of time while repairs are being made. If the system cannot be repaired within 3.5 days, the reactor is placed in the hot shutdown condition.



The cable tunnel is equipped with two temperature-controlled ventilation fans. Each fan has a capacity of 21,000 cfm and is connected to a 480v bus. One fan will start automatically when the temperature in the tunnel reaches 100°F. Under the worst conditions, i.e., loss of outside power and all the Engineered Safety Features in operation, one ventilation fan is capable of maintaining the tunnel temperature below 104°F. Under the same worst conditions, if no ventilation fans were operating, the natural air circulation through the tunnel would be sufficient to limit the gross tunnel temperature to below the tolerable value of 140°F. However, in order to provide for ample tunnel ventilation capacity, the two ventilation fans are required to be operable when the reactor is made critical. If one ventilation fan is found inoperable, the other fan will ensure that cable tunnel ventilation is available.

Valves 856A, C, D and E are maintained in the open position during plant operation to assure a flow path for high-head safety injection during the injection phase of a loss-of-coolant accident. Valves 856B and F are maintained in the closed position during plant operation to prevent hot-leg injection during the injection phase of a loss-of-coolant accident. As an additional assurance of preventing hot-leg injection, the valve motor operators are de-energized to prevent spurious opening of these valves. Power will be restored to these valves at an appropriate time in accordance with plant operating procedures after a loss-of-coolant accident in order to establish hot-leg recirculation.

Valves 842 and 843 in the mini-flow return line from the discharge of the safety injection pumps to the refueling water storage tank are de-energized in the open position to prevent an extremely unlikely spurious closure which would cause the safety injection pumps to overheat if the reactor coolant system pressure is above the shutoff head of the pumps.

The specified quantities of water for the RWST include unavailable water (4687 gals) in the tank bottom, inaccuracies (24,800 gals) in the alarm setpoints, the minimum quantity required during the injection (246,000 gals)<sup>(12)</sup> for accident mitigation and the minimum quantity required during the recirculation phase (60,000 gals) for accident mitigation. The minimum RWST inventory (i.e., 345,000 gals) provides approximately 9,500 gallons margin.

4. At least once every Refueling Interval(#) by:
  - a. verifying that the pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 6 inches water gauge while operating the system at ambient conditions and at a flow rate of 1840 cfm  $\pm 10\%$ .
  - b. verifying that, on a Safety Injection Test Signal or a high radiation signal in the control room, the system automatically switches into a recirculation mode of operation with flow through the HEPA filters and charcoal adsorber banks. <sup>1</sup>
  - c. verifying that the system maintains the control room at a neutral or positive pressure relative to the outside atmosphere during system operation.
5. After each complete or partial replacement of an HEPA filter bank, by verifying that the HEPA filter banks remove greater than or equal to 99% of the DOP when they are tested in-place in accordance with ANSI N510-1975 while operating the system at ambient conditions and at a flow rate of 1840 cfm  $\pm 10\%$ .
6. After each complete or partial replacement of a charcoal adsorber bank, by verifying that the charcoal adsorbers remove greater than or equal to 99.95% of a halogenated hydrocarbon refrigerant test gas when they are tested in-place in accordance with ANSI N510-1975 while operating the system at ambient conditions and at a flow rate of 1840 cfm  $\pm 10\%$ .

**F. FUEL STORAGE BUILDING AIR FILTRATION SYSTEM**

The fuel storage building air filtration system specified in Specification 3.8 shall be demonstrated operable:

1. At least once per 31 days by initiating, from the control room, flow through the HEPA filters and charcoal adsorbers and verifying that the system operates for at least 15 minutes.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 208 TO FACILITY OPERATING LICENSE NO. DPR-26

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.

INDIAN POINT NUCLEAR GENERATING UNIT NO. 2

DOCKET NO. 50-247

1.0 INTRODUCTION

By letter dated September 23, 1999, Consolidated Edison Company of New York, Inc. (the licensee), submitted a request to modify the Technical Specifications (TSs) for Indian Point Nuclear Generating Unit No. 2 (IP2). The proposed amendment would relocate the requirements of TSs 3.3.H.3 and 4.5.E.7 to the Updated Final Safety Analysis Report (UFSAR) and modify the associated Bases.

2.0 EVALUATION

The NRC staff has developed four criteria for determining when a TS is required; these criteria were incorporated into 10 CFR 50.36(c)(2)(ii). Generic Letter (GL) 95-10 provided guidance on relocating items from the TSs to licensee-controlled documents. The toxic gas monitoring requirements were evaluated with respect to criteria for including items in the TSs.

- The first criterion is for instrumentation used to detect significant reactor coolant pressure boundary degradation. The toxic gas detection system is used to detect the presence of poisonous gases, specifically chlorine and anhydrous ammonia, in the control room and to alert operators so that they can take proper action. The toxic gas monitors do not meet the first criterion.
- The second criterion is for process variables, design features or operating restrictions that are an initial condition of a design-basis accident (DBA) or transient that assumes the failure of or presents a challenge to the integrity of a fission product barrier. The toxic gas monitors are not credited with mitigating any such DBA. A toxic gas monitor TS is not required by the second criterion.
- The third criterion is for structures, systems and components that are part of the primary success path and which functions or actuates to mitigate a design basis event that assumes the failure of or presents a challenge to the integrity of a fission product barrier. The toxic gas monitors are not credited with mitigating any such DBA and have no effect on challenges to fission product barriers. A toxic gas monitor TS is not required by the third criterion.

- The last criterion is for structures, systems and components that operating experience or probabilistic risk analysis has shown to be significant to public health and safety. As stated above, the toxic gas monitors are intended to alert operators to the presence of chlorine and anhydrous ammonia in the control room and to allow them to take action to maintain control room habitability. A toxic gas monitor TS is not required by this criterion.

The toxic gas monitors serve an important safety function and the requirements for these monitors should be in a controlled document. If the toxic gas monitor requirements are relocated to the UFSAR, changes to these requirements will be controlled by 10 CFR 50.59. This regulation allows licensees to make changes to their facilities without license amendments only if those changes meet specific standards. The staff has concluded that the toxic gas monitors do not meet the criteria set down in 10 CFR 50.36 for inclusion in the TSs; however, the requirements should be controlled by 10 CFR 50.59. The staff concludes, therefore, that it is appropriate to relocate the requirements for toxic gas monitors to the UFSAR. The improved standard TSs reflect the staff position that chlorine gas monitors do not meet the 10 CFR 50.36 criteria for inclusion in TSs. The staff has concluded that these provisions are not related to dominant contributors to plant risk.

### 3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the New York State official was notified of the proposed issuance of the amendment. The State official had no comments.

### 4.0 ENVIRONMENTAL CONSIDERATION

This amendment changes recordkeeping, reporting, or administrative procedures or requirements. Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(10). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

### 5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: G. Wunder

Date: April 20, 2000