

May 8, 2000

Mr. Thomas F. Plunkett  
President - Nuclear Division  
Florida Power and Light Company  
P.O. Box 14000  
Juno Beach, Florida 33408-0420

SUBJECT: TURKEY POINT PLANT, UNITS 3 AND 4 - COMPLETION OF LICENSING ACTION FOR GENERIC LETTER 99-02, "LABORATORY TESTING OF NUCLEAR-GRADE ACTIVATED CHARCOAL" (TAC NOS. MA5856 AND MA5857)

Dear Mr. Plunkett

On June 3, 1999, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 99-02, "Laboratory Testing of Nuclear-grade Activated Charcoal," to all holders of operating licenses for nuclear power reactors, except those who have permanently ceased operations and have certified that fuel has been permanently removed from the reactor vessel.

The purpose of the GL was to:

- (1) Alert addressees that the NRC has determined that testing nuclear-grade activated charcoal to standards other than American Society for Testing and Materials (ASTM) D3803-1989, "Standard Test Method for Nuclear-Grade Activated Carbon," does not provide assurance for complying with the current licensing basis as it relates to the dose limits of General Design Criterion (GDC) 19 of Appendix A to Part 50 of Title 10 of the *Code of Federal Regulations* (10 CFR) and Subpart A of 10 CFR Part 100.
- (2) Request that all addressees determine whether their Technical Specifications (TS) reference ASTM D3803-1989 for charcoal filter laboratory testing. Addressees whose TS do not reference ASTM D3803-1989 should either amend their TS to reference ASTM D3803-1989 or propose an alternative test protocol and provide the information discussed in the requested actions.
- (3) Alert addressees to the staff's intent to exercise enforcement discretion under certain conditions.
- (4) Request that all addressees send the NRC written responses on the implementation of the actions requested in this GL.

In GL 99-02, the NRC staff established the following four groups of plants:

- (1) plants in compliance with their TS that test in accordance with ASTM D3803-1989

T. Plunkett

- 2 -

- (2) plants in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989
- (3) plants not in compliance with their TS that test in accordance with ASTM D3803-1989
- (4) plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989

In response to GL 99-02, you provided a letter dated November 23, 1999, for Turkey Point Units 3 and 4. Associated with your response was a request for a license amendment to change your TS to provide for testing as described in the GL. The NRC staff has reviewed your response and has concluded that you have provided requested information and a TS change request in accordance with the GL. In addition, you have committed to test in accordance with ASTM D3803-1989 until your TS amendment is issued. Therefore, we consider GL 99-02 to be closed for your Turkey Point facility. The TS change was approved on March 21, 2000, as a separate, plant-specific action under TAC Nos. MA7213 and MA7214. We thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact me at (301) 415-1496.

Sincerely,

*/RA/*

Kahtan N. Jabbour, Senior Project Manager, Section 2  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-250 and 50-251

cc: See next page

- (2) plants in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989
- (3) plants not in compliance with their TS that test in accordance with ASTM D3803-1989
- (4) plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989

In response to GL 99-02, you provided a letter dated November 23, 1999, for Turkey Point Units 3 and 4. Associated with your response was a request for a license amendment to change your TS to provide for testing as described in the GL. The NRC staff has reviewed your response and has concluded that you have provided requested information and a TS change request in accordance with the GL. In addition, you have committed to test in accordance with ASTM D3803-1989 until your TS amendment is issued. Therefore, we consider GL 99-02 to be closed for your Turkey Point facility. The TS change was approved on March 21, 2000, as a separate, plant-specific action under TAC Nos. MA7213 and MA7214. We thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact me at (301) 415-1496.

Sincerely,

**/RA/**

Kahtan N. Jabbour, Senior Project Manager, Section 2  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-250 and 50-251

cc: See next page

**DISTRIBUTION:**

PUBLIC  
PDII Reading  
RCorreia  
EWeiss  
BClayton  
KJabbour  
BMozafari  
JSegala  
JHannon  
OGC  
ACRS  
LWert, RII

**Accession Number ML003712589 \*SEE PREVIOUS CONCURRENCE**

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

|        |           |  |           |  |            |  |         |  |           |  |
|--------|-----------|--|-----------|--|------------|--|---------|--|-----------|--|
| OFFICE | PDII-2\PM |  | PDII-2\LA |  | PD3-1\PM * |  | SPLB\SC |  | PDII-2\SC |  |
| NAME   | KJabbour  |  | BClayton  |  | BMozafari  |  | EWeiss  |  | RCorreia  |  |
| DATE   | 05/3/00   |  | 05/3/00   |  | 02/17/00   |  | 05/3/00 |  | 05/3/00   |  |

OFFICIAL RECORD COPY

Mr. T. F. Plunkett  
Florida Power and Light Company

**TURKEY POINT PLANT**

cc:

M. S. Ross, Attorney  
Florida Power & Light Company  
P.O. Box 14000  
Juno Beach, FL 33408-0420

Attorney General  
Department of Legal Affairs  
The Capitol  
Tallahassee, Florida 32304

Mr. Robert J. Hovey, Site  
Vice President  
Turkey Point Nuclear Plant  
Florida Power and Light Company  
9760 SW. 344th Street  
Florida City, FL 33035

Plant Manager  
Turkey Point Nuclear Plant  
Florida Power and Light Company  
9760 SW. 344th Street  
Florida City, FL 33035

County Manager  
Miami-Dade County  
111 NW 1 Street, 29th Floor  
Miami, Florida 33128

Mr. Steve Franzone  
Licensing Manager  
Turkey Point Nuclear Plant  
9760 SW. 344th Street  
Florida City, FL 33035

Senior Resident Inspector  
Turkey Point Nuclear Plant  
U.S. Nuclear Regulatory Commission  
9762 SW. 344<sup>th</sup> Street  
Florida City, Florida 33035

Mr. John Gianfrancesco  
Manager, Administrative Support  
and Special Projects  
P.O. Box 14000  
Juno Beach, FL 33408-0420

Mr. William A. Passetti, Chief  
Department of Health  
Bureau of Radiation Control  
2020 Capital Circle, SE, Bin #C21  
Tallahassee, Florida 32399-1741

Mr. J.A. Stall  
Vice President - Nuclear Engineering  
Florida Power & Light Company  
P.O. Box 14000  
Juno Beach, FL 33408-0420

Mr. Joe Myers, Director  
Division of Emergency Preparedness  
Department of Community Affairs  
2740 Centerview Drive  
Tallahassee, Florida 32399-2100