

May 15, 2000

Mr. Michael B. Sellman
Senior Vice President and
Chief Nuclear Officer
Wisconsin Electric Power Company
231 West Michigan Street
Milwaukee, WI 53201

SUBJECT: POINT BEACH NUCLEAR POWER PLANT, UNITS 1 AND 2 - REQUEST FOR
ADDITIONAL INFORMATION RE: SECTION 2.0 OF IMPROVED TECHNICAL
SPECIFICATIONS CONVERSION (TAC NOS. MA7186 AND MA7187)

Dear Mr. Sellman:

By letter dated November 15, 1999, the Wisconsin Electric Power Company submitted a license amendment request to convert the current Technical Specifications to improved Technical Specifications for Point Beach, Units 1 and 2.

The enclosed request was discussed with Mr. Jack Gadzala and other members of your staff during a conference call on April 10, 2000. A mutually agreeable target date of 60 days from the date of this letter for your response was established. If circumstances result in the need to revise the target date, please contact me at (301) 415-1355 at the earliest opportunity.

Sincerely,

/RA/

Beth A. Wetzel, Senior Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-266 and 50-301

Enclosure: Request for Additional Information

cc w/encl: See next page

May 15, 2000

Mr. Michael B. Sellman
Senior Vice President and
Chief Nuclear Officer
Wisconsin Electric Power Company
231 West Michigan Street
Milwaukee, WI 53201

SUBJECT: POINT BEACH NUCLEAR POWER PLANT, UNITS 1 AND 2 - REQUEST FOR
ADDITIONAL INFORMATION RE: SECTION 2.0 OF IMPROVED TECHNICAL
SPECIFICATIONS CONVERSION (TAC NOS. MA7186 AND MA7187)

Dear Mr. Sellman:

By letter dated November 15, 1999, the Wisconsin Electric Power Company submitted a license amendment request to convert the current Technical Specifications to improved Technical Specifications for Point Beach, Units 1 and 2.

The enclosed request was discussed with Mr. Jack Gadzala and other members of your staff during a conference call on April 10, 2000. A mutually agreeable target date of 60 days from the date of this letter for your response was established. If circumstances result in the need to revise the target date, please contact me at (301) 415-1355 at the earliest opportunity.

Sincerely,

/RA/

Beth A. Wetzel, Senior Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-266 and 50-301

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION

PDIII-1 Reading	OGC	RLanksbury, RIII
SBlack	ACRS	
CCraig	CHarbuck	
BWetzel	TTjader	
RBouling	TLiu	

OFFICE	PDIII-1/PM	PDIII-1/LA	PDIII-1/SC
NAME	BWetzel	RBouling	TJKim for CCraig
DATE	5/10/00	5/10/00	5/10/00

ACCESSION NO. ML003714026

OFFICIAL RECORD COPY

Point Beach Nuclear Plant, Units 1 and 2

cc:

Mr. John H. O'Neill, Jr.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, NW
Washington, DC 20037-1128

Ms. Sarah Jenkins
Electric Division
Public Service Commission of Wisconsin
P.O. Box 7854
Madison, WI 53707-7854

Mr. Richard R. Grigg
President and Chief Operating Officer
Wisconsin Electric Power Company
231 West Michigan Street
Milwaukee, WI 53201

Mr. Mark E. Reddemann
Site Vice President
Point Beach Nuclear Plant
Wisconsin Electric Power Company
6610 Nuclear Road
Two Rivers, WI 54241

Mr. Ken Duveneck
Town Chairman
Town of Two Creeks
13017 State Highway 42
Mishicot, WI 54228

Chairman
Public Service Commission
of Wisconsin
P.O. Box 7854
Madison, WI 53707-7854

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Resident Inspector's Office
U.S. Nuclear Regulatory Commission
6612 Nuclear Road
Two Rivers, WI 54241

November 1999

REQUEST FOR ADDITIONAL INFORMATION
POINT BEACH NUCLEAR POWER PLANT
IMPROVED STANDARD TECHNICAL SPECIFICATIONS

Point Beach Nuclear Plant, Units 1 and 2
Improved Technical Specification (ITS) Review Comments
ITS Section 2.0, Safety Limits

2.0-1 ITS B2.0 REFERENCES
 STS B2.0 REFERENCES
 JFD 4

References to specific sections of the Final Safety Analysis Report (FSAR) for safety analyses initial conditions are not appropriate because the sections are scattered throughout the FSAR. Also, reactor protection system setpoints are not contained in the FSAR, they are located in the Technical Specifications, and therefore FSAR references have been deleted.

Comment: To the extent possible, include appropriate references or a brief discussion where the information is contained.

Licensee Response:

ENCLOSURE