

Scenario Review Comments

The level of detail of operator expected actions is low in some cases. (Specifics will be addressed during the on-site preview.)

The scenarios appear to require a very low level of diagnostic application.

Request that an electrical malfunction (such as loss of a vital bus or major switch gear) be added to scenario 1 after the steam generator instrument failure.

Request that a plant parameter/data information source (such as the plant computer, SPDS, etc.) be disabled after the loss of control channel A pressurizer level failure.

The scenarios generally do not challenge the SRO to prioritize the response to plant conditions. This can be improved by a more challenging timing sequence which does not make unreasonable demands on the panel operators. (To be addressed during on-site preview.)

TS coverage is minimal but adequate.