

TYPE: OPEN REFERENCE

KA VALUE RO: 2.5 SRO: 3.1 KA REFERENCE: 2.3.4

**REFERENCES: 1903.033 Rev 017-01-0, Protective Action Guidelines For
Rescue/Repair & Damage Control Team, Form 1903.033A**

SRO EXAM -- SUBJECT A.3

QUESTION 2:

Determine whose authorization is required to exceed dose limits of 10CFR20 for the given conditions?

- Large Break LOCA has occurred.
- RAS has actuated.
- Containment Spray Pump 2P35A is Out of Service
- Containment Spray Pump 2P35B has a 5.0 gpm isolable suction gage leak.
- Estimated dose is 6.1 Rem to isolate the leak.

ANSWER:

SS or TSC Director

COMMENTS:

EXAMINEE'S COPY

TYPE: OPEN REFERENCE

SRO EXAM -- SUBJECT A.3

QUESTION 2:

Determine whose authorization is required to exceed dose limits of 10CFR20 for the given conditions?

- Large Break LOCA has occurred.
- RAS has actuated.
- Containment Spray Pump 2P35A is Out of Service
- Containment Spray Pump 2P35B has a 5.0 gpm isolable suction gage leak.
- Estimated dose is 6.1 Rem to isolate the leak.