

May 26, 2000

Mr. Michael B. Sellman
Senior Vice President and
Chief Nuclear Officer
Wisconsin Electric Power Company
231 West Michigan Street
Milwaukee, WI 53201

SUBJECT: POINT BEACH NUCLEAR POWER PLANT, UNITS 1 AND 2 - COMPLETION
OF LICENSING ACTION FOR GENERIC LETTER 99-02, "LABORATORY
TESTING OF NUCLEAR-GRADE ACTIVATED CHARCOAL"
(TAC NOS. MA5831 and MA5832)

Dear Mr. Sellman:

On June 3, 1999, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 99-02, "Laboratory Testing of Nuclear-grade Activated Charcoal," to all holders of operating licenses for nuclear power reactors, except those who have permanently ceased operations and have certified that fuel has been permanently removed from the reactor vessel.

The purpose of the GL was to:

- (1) Alert addressees that the NRC has determined that testing nuclear-grade activated charcoal to standards other than American Society for Testing and Materials (ASTM) D3803-1989, "Standard Test Method for Nuclear-Grade Activated Carbon," does not provide assurance for complying with the current licensing basis as it relates to the dose limits of General Design Criterion (GDC) 19 of Appendix A to Part 50 of Title 10 of the *Code of Federal Regulations* (10 CFR Part 50) and Subpart A of 10 CFR Part 100.
- (2) Request that all addressees determine whether their Technical Specifications (TS) reference ASTM D3803-1989 for charcoal filter laboratory testing. Addressees whose TS do not reference ASTM D3803-1989 should either amend their TS to reference ASTM D3803-1989 or propose an alternative test protocol and provide the information discussed in the requested actions.
- (3) Alert addressees to the staff's intent to exercise enforcement discretion under certain conditions.
- (4) Request that all addressees send the NRC written responses to this GL relating to implementation of the requested actions.

In GL 99-02, the NRC staff established the following four groups of plants:

- (1) plants in compliance with their TS that test in accordance with ASTM D3803-1989

M. Sellman

- 2 -

- (2) plants in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989
- (3) plants not in compliance with their TS that test in accordance with ASTM D3803-1989
- (4) plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989

In response to GL 99-02, you provided a letter dated July 29, 1999, for Point Beach Nuclear Plant, Units 1 and 2. This submittal indicated that yours are Group 1 plants. The staff has reviewed your response and has concluded that all requested information has been provided; therefore, we consider GL 99-02 to be closed for your facilities. We thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact Beth Wetzel at (301) 415-1355.

Sincerely,

/RA/

Beth A. Wetzel, Senior Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-266 and 50-301

cc w/encl: See next page

M. Sellman

- 2 -

- (2) plants in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989
- (3) plants not in compliance with their TS that test in accordance with ASTM D3803-1989
- (4) plants not in compliance with their TS that test in accordance with a test protocol other than ASTM D3803-1989

In response to GL 99-02, you provided a letter dated July 29, 1999, for Point Beach Nuclear Plant, Units 1 and 2. This submittal indicated that yours are Group 1 plants. The staff has reviewed your response and has concluded that all requested information has been provided; therefore, we consider GL 99-02 to be closed for your facilities. We thank you for your prompt and complete response.

If you have any questions regarding this matter, please contact Beth Wetzel at (301) 415-1355.

Sincerely,

/RA/

Beth A. Wetzel, Senior Project Manager, Section 1
 Project Directorate III
 Division of Licensing Project Management
 Office of Nuclear Reactor Regulation

Docket Nos. 50-266 and 50-301

cc w/encl : See next page

DISTRIBUTION

File Center
 PUBLIC
 PDIII-1 Reading
 OGC
 ACRS
 GGrant, RIII
 JSegala

TO RECEIVE A COPY, INDICATE "C" IN THE BOX.

PDIII-1\PM	C	PDIII-1/LA	C	PDIII-1/LPM	C	SPLB/SC	C	PDIII-1/SC	C
BWetzel		RBouling		BMozafari		JHannon		CCraig	
3/1/00		3/1/00		3/1/00		5/23/00		5/24/00	

ACCESSION NO. ML003718048

OFFICIAL RECORD COPY

Point Beach Nuclear Plant, Units 1 and 2

cc:

Mr. John H. O'Neill, Jr.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, NW
Washington, DC 20037-1128

Ms. Sarah Jenkins
Electric Division
Public Service Commission of Wisconsin
P.O. Box 7854
Madison, WI 53707-7854

Mr. Richard R. Grigg
President and Chief Operating Officer
Wisconsin Electric Power Company
231 West Michigan Street
Milwaukee, WI 53201

Mr. Mark E. Reddemann
Site Vice President
Point Beach Nuclear Plant
Wisconsin Electric Power Company
6610 Nuclear Road
Two Rivers, WI 54241

Mr. Ken Duveneck
Town Chairman
Town of Two Creeks
13017 State Highway 42
Mishicot, WI 54228

Chairman
Public Service Commission
of Wisconsin
P.O. Box 7854
Madison, WI 53707-7854

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Resident Inspector's Office
U.S. Nuclear Regulatory Commission
6612 Nuclear Road
Two Rivers, WI 54241

November 1999