

May 25, 2000

ORGANIZATION: Nuclear Energy Institute

SUBJECT: SUMMARY OF MAY 10, 2000, PHONE CALL BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION (NRC) STAFF, CONTRACTOR AND NUCLEAR ENERGY INSTITUTE (NEI) REPRESENTATIVES TO DISCUSS INDUSTRY COMMENTS SUBMITTED BY NEI ON APRIL 24, 2000, ON THE DRAFT "GENERIC AGING LESSONS LEARNED" (GALL) REPORT - ELECTRICAL EQUIPMENT

On May 10, 2000, the NRC staff had a conference call with its contractor and representatives of NEI in Rockville, Maryland. The purpose of the phone call was to clarify certain NEI comments submitted on April 24, 2000, on the draft GALL report regarding electrical equipment. The NEI participants were Doug Walters and Paul Colaianni. The staff participants were Paul Shemanski, Jit Vora, P. T. Kuo, Sam Lee, Peter Kang and S. K. Mitra. Robert Lofaro (Contractor) of Brookhaven National Laboratory (BNL) also participated.

The staff and its contractor asked the industry to clarify the following NEI comments on the draft GALL report:

1. The terms "instrumentation" and "instrumentation and control cable" were used indiscriminately.
2. The term "equipment" or "component" were used interchangeably.
3. The term "aging assessment" appeared to be inappropriate in the title of Chapter X.
4. On page X A-1, the terms "aging provision", "detrimental" in paragraph 2, and "for license renewal" in paragraph 3 appeared to be inappropriate.
5. The title for reference NUREG/CR-6384 was missing.
6. In Chapters XI A-1, XI A-2, XI A-3, Item 2, "Preventive Actions" and Item 5 "Monitoring and Trending" indicated that no actions were taken.
7.
 - a. The term "Non-EQ" appeared to be missing from the title of Chapter XI.
 - b. The scope of existing aging management program in Chapter XI A-1, A-2, A-3 did not include inaccessible cables and connections.

8. The reference, "EPRI TR-109619, Guideline on the Management of Adverse Localized Equipment Environment, June 1999" was deleted.

NEI indicated that the industry will clarify these issues after further review.

/RA/

Sikhindra K. Mitra, Project Manager
License Renewal and Standardization Branch
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Project No. 690

cc: See next page

May 25, 2000

- 8. The reference, "EPRI TR-109619, Guideline or the Management of Adverse Localized Equipment Environment, June 1999" was deleted.

NEI indicated that the industry will clarify these issues after further review.

/RA/

Sikhindra K. Mitra, Project Manager
 License Renewal and Standardization Branch
 Division of Regulatory Improvement Programs
 Office of Nuclear Reactor Regulation

Project No. 690

cc: See next page

DISTRIBUTION:
 See attached page

Accession Number - ML003718225

*See previous concurrence

Document Name: G:\RLSB\MITRA\MAY 10 GALLPHONECALL.WPD

OFFICE	LA:DRIP	PM:RLSB:DRIP	SC:RLSB:DRIP	BC:RLSB:DRIP
NAME	EGHylton*	SKMitra	PTKuo*	CIGrimes*
DATE	05/22/00	05/25/00	05/24/00	05/24/00

OFFICIAL RECORD COPY

NUCLEAR ENERGY INSTITUTE

Project No. 690

cc:

Mr. Dennis Harrison
U.S. Department of Energy
NE-42
Washington, D.C. 20585

Mr. Robert Gill
Duke Energy Corporation
Mail Stop EC-12R
P.O. Box 1006
Charlotte, NC 28201-1006

Mr. Richard P. Sedano, Commissioner
State Liaison Officer
Department of Public Service
112 State Street
Drawer 20
Montpelier, Vermont 05620-2601

Mr. Charles R. Pierce
Southern Nuclear Operating Co.
40 Inverness Center Parkway
BIN B064
Birmingham, AL 35242

Mr. Douglas J. Walters
Nuclear Energy Institute
1776 I Street, N.W., Suite 400
Washington, DC 20006-3708
DJW@NEI.ORG

Chattooga River Watershed Coalition
P. O. Box 2006
Clayton, GA 30525

National Whistleblower Center
3238 P Street, N.W.
Washington, DC 20007-2756

Mr. David Lochbaum
Union of Concerned Scientists
1616 P. St., NW
Suite 310
Washington, DC 20036-1495

Mr. Garry Young
Entergy Operations, Inc.
Arkansas Nuclear One
1448 SR 333 GSB-2E
Russellville, Arkansas 72802