

Tennessee Valley Authority, Post Office Box 2000, Decatur, Alabama 35609

May 17, 2000

10 CFR 50, Appendix E

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D.C. 20555

Gentlemen:

In the Matter of Tennessee Valley Authority Docket No. 50-296

BROWNS FERRY NUCLEAR PLANT (BFN) - UNIT 3 -REVISION/CORRECTION TO THE EMERGENCY RESPONSE DATA SYSTEM (ERDS) DATA POINT LIBRARY

In accordance with 10 CFR 50, Appendix E, Section VI.3.a " "Emergency Response Data System," TVA is providing notification of a revision to the BFN Unit 3 ERDS Data Point Library. This revision was implemented on April 28, 2000, and requires NRC notification within 30 days.

The enclosure to this letter provides revisions to the Unit 3 Data Point Library which involves changing of the Reactor Low-Low Water Level Scram Setpoint from 11.2 inches to 2 inches. Also included is an editorial correction to the Unique System Description field which updates information for sensors that input to the narrow range signal from three 0-60 inch signals to four -10 to +70 inch signals.

There are no commitments contained in this letter. If you have any questions please contact me at (256) 729-2636.

ncerely Manager of Site Licensing and Industry Affairs See page 2



U.S. Nuclear Regulatory Commission Page 2 May 17, 2000 Enclosure cc (Enclosure): Mr. William O. Long, Senior Project Manager U.S. Nuclear Regulatory Commission One White Flint, North 11555 Rockville Pike Rockville, Maryland 20852 Mr. Paul E. Fredrickson, Branch Chief U.S. Nuclear Regulatory Commission Region II Atlanta Federal Center 61 Forsyth Street S.W. Suite 23T85 Atlanta, Georgia 30303 NRC Resident Inspector Browns Ferry Nuclear Plant

10833 Shaw Road Athens, Alabama 35611

-___~

ENCLOSURE

1

TENNESSEE VALLEY AUTHORITY BROWNS FERRY NUCLEAR PLANT UNIT 3

REVISION/CORRECTION TO THE EMERGENCY RESPONSE DATA SYSTEM DATA POINT LIBRARY

SEE ATTACHED:

ERDS Point Number: 4

~7

.

REAC VES LEV

SPDS0007

Reactor Vessel Water Level

Date:	04/28/2000
Reactor Unit:	BF3
Data Feeder:	1
NRC ERDS Parameter:	REAC VES LEV
Point ID:	SPDS0007
Plant Spec Point Desc:	RX WATER LEVEL - COMPOSED
GenericCond Desc:	Reactor Vessel Water Level
Analog/Digitale	A
Analog/Digital.	A
Engr Units/Dig States.	INCHES N/A
Lingi Ullius Minimum Instr Dongo	N/A
Movimum Instr Range:	-208
Zora Doint Deference:	400 MSSVDT
Zelo Folit Reference.	
Reference Point Notes.	J28 above vessel zero
PROC or SENS	Р
Number of Sensors:	10
How Processed:	Weighted Average w/Fault Detect (PSVA)
Sensor Locations:	N/A
Alarm/Trip Set Points:	LOLO=2., LO=27., HI=39., HIHI=51. inch
NID Power Cutoff Level:	N/A
NID Power Cut-On	N/A
Instrument Failure Mode:	N/A
Temperature Compensation :	Y
Level Reference Leg:	N/A
Unique System Desc :	Combines one 0 - +400 (floodup), four -10 - +70 (Normal),
	four -155 - +60 (Emerg) and two -268 - +32 (post accident)
	into one wide range indication; therefore, for off normal
	conditions this point could be difficult to interpret.
	Instruments are calibrated for normal operating conditions,
	except for the floodup instrument which is calibrated for
	atmospheric conditions, and the post accident instruments
	which are calibrated assuming 212 degrees Faranheit water

in all lines. Top of fuel is at -162".