RAS 1753

DEN HYED CORRESPONDENCE

UNITED STATES OF AMERICA NUCLEAR REGULATORY COMMISSION

DOCKETED HENDEL

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of:	:	Docket No.	. 50-423	3-LA-3	MAY ZC	1 21 01	
Northeast Nuclear Energy Company	:			Ortini Fil			
(Millstone Nuclear Power Station, Unit No. 3)	:	ASLBP No.	00-771-	AÖU: AD -la	· .		

CONNECTICUT COALITION AGAINST MILLSTONE AND LONG ISLAND COALITION AGAINST MILLSTONE'S FIRST SUPPLEMENT TO EXHIBIT A (ANNEXED TO INTERVENORS' MARCH 20, 2000 REPLY TO NORTHEAST NUCLEAR ENERGY COMPANY'S FIRST SET OF INTERROGATORIES)

The Connecticut Coalition Against Millstone ("CCAM") and Long Island Coalition Against Millstone ("CAM")(collectively, "Intervenors") herewith supplement the exhibits identified in Exhibit A to Intervenors' March 20, 2000 Reply to Northeast Nuclear Energy Company's First Set of Interrogatories and Request for Production, as follows:

- (1) Yankee Atomic Electric Company to the Nuclear Regulatory Commission, Licensee Event Report (LER) 2000-02, "Fuel Movement Exceeds Travel Height Restriction," April 13, 2000.
- (2) Southern Nuclear Operating Company, Inc. to Nuclear Regulatory Commission, "Joseph M. Farley Nuclear Plant/Unit 1 Licensee Event Report 2000-04-00/Three Spent Fuel Assemblies in Spent Fuel Pool Locations Not Allowed by Technical Specification 3.7.15," April 20, 2000.
- (3) Duke Energy Corporation to Nuclear Regulatory Commission, "McGuire Nuclear Station Unit 1 and 2/Licensee Event Report 369/00/03, Revision 0," March 30, 2000.

CONNECTICUT COALITION AGAINST MILLSTONE LONG ISLAND COALITION AGAINST MILLSTONE

SEC4-02

Dated at Redding, Connecticut this 22nd day of May 2000

By:

Nancy Burton, Esq. 147 Cross Highway Redding Ridge CT 06876 Tel. 203-938-3952

lemplate = SECY-035

+12023320895 UCS DC

130 PC3 - MAY 19 'CC 16:57

YANKEE ATOMIC ELECTRIC COMPANY

Telephone (508) 721-7736 Facsimile (508) 721-7743



Sulte 200, 19 Midstete Drive, Auburn, Massachusetts 01501

April 13, 2000 BYR 2000-035

U.S. Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555

Reference: License No. DPR-3 (Docket No. 50-29)

Subject: Licensee Event Report (LER) 2000-02

This letter forwards Licensee Event Report 2000-02, titled "Fuel Movement Exceeds Travel Height Restriction".

We trust this information is satisfactory; however, if you have any questions, please contact us.

Very truly yours,

YANKEE ATOMIC ELECTRIC COMPANY

Merrill J. Atkins Regulatory Affairs Manager

c: Mr. Phillip Ray, Project Manager Decommissioning Section Project Directorate IV and Decommissioning Division of Licensing Project Management Office of Nuclear Reactor Regulation

÷

Mr. R. Bellamy, Chief Decommissioning and Laboratory Branch USNRC, Region I

IE22

ML003704231

NRC FORM (4-95)	A 366			<u>, </u>	,	Ų.	\$. N	UCLEAR F	EGULATOF	Y COM	NISSION	ESTIM	ATE	APPR	OVED BY O	MB NO. 31 04/30/98 TO COMPL	50-0104	ANDATORY		
		LICE	ENS	EE I	EVE	NT	RE	PORT	(LER)			LEARN BACK ESTIM 6 F33). 0001, / CP MA	TO TO ATE NAG	INDUSTRY. INDUSTRY. TO THE INFOR NUCLEAR RE TO THE PAPE EMENT AND S	DRATED INTO PORWARD MATION AND GULATORY CI RWORK REDL DUDGET, WASH	THE UCEN COMMENT RECORDS I DIMMISSION ICTION PRO INGTON, D	SING PROCES S REGARDING MANAGEMENT WASHINGTON WECT (3150-01 C 20503.	S AND FED 3 BURDEN BRANCH (T 1, DC 20555 (4), OFFICE (4), OFFICE		
FACILITY NAL	WE (1)			<u></u>									Ð	OCKET NUM	BER (2)		PAGE (3)			
			Yar	ikee l	Nucl	ear F	'ow	er Statio	ń					50-02	29		lof	4		
TITLE (4)	=uel M	oveme	nt E	xcee	ds Ti	ravel	He	ight Res	triction											
EVEN		(5)			LERI	NUMB	ËR	(6)	REPO	RT DAT	'E (7)			OTHER	FACILITI	ES INVO	LVED (8)			
MONTH	DAY	YEAR	YE/	AR	SEQU	JENTI. MBER	AL	REVISIO	MONTH	DAY	YEAR	FACIL	ו ירון	NAME		COCK	ET NUMBER			
03	15	2000	20	00		02			04	15	2000	FACIL	117	NAME		DOCK	DOCKETNUMBER			
OPERA	TING	NΔ	тн	S REP	ORT	18 SU	BMI	TTED PUR	SUANT TO	THE RE	QUIREME	ENTS (Ô۴	10 CFA §:	(Check or	ne or mor	9) (11)			
MODE	. (9)			20.220	01(b)				20.2203(1)(2)(v)				50.73(a)(2	2)(1)	(i) 50.73(a)(
POW	ER	000		20.220	03(a)(1)			20.2203(a)(3)(i)			X	50.73(a)(2	2)(H)	50.73(a)(2)(x)				
LEVEL	(10)			20.22	03(a)((2)(i)			20.2203(8	a)(3)(il)				50.73(a)(2	2)(11)		73.71			
200				20.22	03(a)((2)(ii)			20.2203(6	a)(4)				50.73(a)(2	2}(Iv)	!	OTHER			
				20,22	03(a)((2)(fii)			50.36(c)(1)				50.73(a)(2	2)(v)	Spec in NP	bity in Abstract below 9 RC Form 366A			
1. 6. 94		物、小		20.22	03(a)((2)(IV)			50.36(c)(2)				50.73(a)(2	2}(vii)					
		<u> </u>						LICENSE	E CONTAC	r for t	HIS LER	(12)	TTE I	EDSONE MI		Area Code	1			
NAME	.1	A Kai	, p,	Incin	alli	censi	ina	Enginee	•				166	(4	13)424	-5261	4			
		MPLE	TEC	DNE	LINE	FO	RE	ACH CC	MPONEN	T FAI	URE	DESC	RI	BED IN	THIS RE	PORT	(13)			
CAUSE	SYST	EM CON	APON	ENT	ANUF	ACTUR	ER	REPORTAL TO NPRE	BLE HANK	CAUS	BE SY	STEM	CC	OMPONENT	MANUFA	CTURER	REPOR TO NE	TABLE PRDS		
		SUPPI	LEMI	ENTAL	L REF	ORT	EXP	ECTED (14	•>		_	EXPE	CT	ED	MONTI	H	DÁY	YEAP		
YES (If yes	, comple	IS EXPEC	TED	SUBN	MISSI	QN D	ATE).	NC)		DAT	E (15)						
ABSTRA (16)	CT (Limit	τo	140)0 s	pace	ŝ,	i.e.,	approxi	matel	y 15	sing	1]e	-space	ed type	writt	en line	ទ)		

Yankee Nuclear Power Station was permanently shutdown in February 1992 and is currently being decommissioned. In the early 1980s, spent fuel storage capacity was increased by adding an upper tier of fuel storage racks. During preparation to conduct spent fuel inspections in the Spent Fuel Pool, it was discovered that past practice used in moving spent fuel from the lower tier racks to the upper tier racks was contrary to the design basis as described in the FSAR. The FSAR states that "the racks are designed to maintain proper spacing and structural integrity after being impacted by a fuel assembly dropped onto any location from a height of six inches above the top of the racks." The plant procedures for moving fuel assemblies had established a precaution to restrict travel height for moving fuel over lower tier racks. The maximum fuel assembly travel height over "ungrated" SFP racks is six (6) inches above the plane of the top of the rack. Past practice, however, permitted spent fuel movement over the lower tier racks. This resulted in lifting fuel approximately 13 inches above the racks, which is outside the design basis. As such, this LER is submitted in accordance with 10CFR50.73(a)(2)(ii)(B) as a condition outside the design basis of the plant. No fuel handling evolutions were in progress at the time of discovery of this issue.

NRC FORM 365 (4-95)

NRC FORM 366A		υ.	8. NI	JCLEA	RREGULATORY	COMMISSION						
(4-95) LICENSEE EVENT REPORT (LER) TEXT CONTINUATION												
FACILITY NAME (1)	DOCKET NUMBER (2)		LE	NUM	BER (6)	PAGE (3)						
Varkee Nuclear Power Station		YEAR	SEC NL	JUEN I	NUMBER							
TANKEE NUCLEAT FOWEL DEACTON	05000029	2000		Q2		2 of 4						
YEVT (If more space is required, use additional copies of NRC Form 3	66A) (17)	h			<u> </u>							

BACKGROUND INFORMATION

Yankee Nuclear Power Station was permanently shutdown in February 1992 and is currently being decommissioned. During the review and planning for the upcoming fuel inspection campaign, questions arose as to the technical and licensing basis for travel height restrictions for handling fuel assemblies within the Spent Fuel Pool. In particular, there was uncertainty as to the assumptions used in the analysis of the fuel assembly drop accidents when transferring fuel between lower and upper tier racks. No fuel handling evolutions were in progress at the time of discovery of this issue.

EVENT DESCRIPTION

During preparation to conduct spent fuel inspections in the Spent Fuel Pool, it was discovered that past practice used in moving spent fuel to the upper tier racks was contrary to the design basis as described in the FSAR. The FSAR (Section 246.1) states that "the racks are designed to maintain proper spacing and structural integrity after being impacted by a fuel assembly dropped onto any location from a height of six inches above the top of the racks." Moving an assembly from lower tier to the upper tier racks required the installation of gratings over lower tier racks that preclude deformation of the racks in the event of an assembly drop. Installed gratings extend approximately twelve (12) inches above the top of the lower racks. The plant procedures (OP- 4226 & 7107) for moving both dummy and spent fuel assemblies had established a precaution to restrict travel height for moving fuel over lower tier racks. The maximum fuel assembly travel height over "ungrated" SFP racks is six (6) inches above the plane of the top of the rack. Past practice, however, permitted spent fuel movement over the lower tier racks to heights greater than 6 inches to clear the installed grating for storage in the upper tier racks. This resulted in lifting fuel approximately 13 inches above the racks, which is outside the design basis.

The design basis for fuel movement restrictions was first established during modifications to increase fuel storage capacity of the lower racks. These modifications replaced the existing spent fuel storage racks with anodized aluminum fixed-poison (Boral) curtain racks having a reduced center-to-center spacing. Design basis information was provided in Technical Specification Proposed Change # 131, submitted in September 25, 1975. From this submittal, the following was stated:

"An additional design basis which will be met is the requirement that the spent fuel racks as installed be able to maintain proper spacing and structural integrity after being impacted by a spent fuel assembly dropped onto any location from a height of 6 inches above the top of the racks."

The NRC's SER associated with this change (License Amendment #33, dated December 29, 1976) did not restate this commitment explicitly. The SER does, however, state that "dropping a fuel assembly from above the top of the racks will not result in deformation of the racks and the fuel will be sufficiently above that stored in the racks so that the reactivity increase due to an assembly lying across the racks will be negligible."

NRC FORM 366A (4-95)

	LICENSEI	T CONTINUATION							
ACILITY NAME (1)		DOCKET NUMBER (2)	_	LE	RNUM	BER	(6)	PAGE (3)
	lear Power Station		YEAH	SE	IMBER	TAL	NUMBER		
iankee Nacie		05000029	2000		02			3 of	4
EXT (If more space is required	d, use additional copies of NRC Form 3	66A) (17)				*****			

Additional modifications and improvements were subsequently made to the spent her poor to rather determined fuel storage capacity by adding an upper tier of racks. These modifications replaced and installed additional lower tier fuel racks, installed a new stainless steel pool liner, installed structural support modifications, and installed new upper tier racks (including grating installed between the lower and upper tier racks). This information was described in Technical Specification changes associated with Proposed Change # 158 (including supplements) submitted between 1978 and 1982. License Amendment # 75, which culminated these changes, established an additional height restriction when moving spent fuel over a "grated" lower tier spent fuel rack. The grating was a provision of the change in recognition that putting fuel on the upper tier would involve lifting fuel assemblies higher than presently allowed.¹

"The grating will be supported on the lower beams of the second tier support structure. The grating and support structure are designed to resist the impact of a fuel assembly dropped from 11 feet above the existing spent fuel racks. The analysis permits plastic deformation but limits distortion to prevent contact with the racks. This grating will be placed in the pool prior to placing any racks on the second tier."

The practice of moving spent fuel assemblies in accordance with OP-7107 required an implied movement of the assembly higher than 6 inches to move it up and over the lower tier grating. While a precaution in the procedure clearly stated the 6-inch height restriction, the procedure was silent on the steps and pathway necessary to move the assembly up the additional 7 inches and over the grating and preserve the 6-inch travel height restriction. Since it was literally impossible to move the assembly over a partially grated fuel rack without lifting the assembly higher than the 6-inch limitation, the practice was to move the assembly higher in a path directly over vacant fuel storage cells in order to move it up and over the grating. It is believed, however, the practice never moved the fuel assembly above the 6-inch restriction when directly over a location with stored fuel.

A Condition Report (CR) (CR 00-44) has been initiated. This condition is reportable as an LER in accordance with 10CFR50.73(a)(2)(ii)(B) - a condition that was outside the design basis of the plant.

The NRC regional site inspector was notified of this occurrence on 3/22/00.

CAUSE OF EVENT

The cause of this event is the failure to adequately incorporate design basis information into plant procedures to specify the steps and pathway necessary to move the assembly up the additional 7 inches and over the grating and preserve the 6-inch travel height restriction.

NRC FORM 368A (4-95)

YAEC letter to USNRC, "Proposed Change #158, Rev. 1 to Supplement No. 3, dated August 18, 1980.

NRC FORM 366A		U.S. NUCLEAR REGULATORY	COMMISSION
	EVENT REPORT (LER)	
TEXT	CONTINUATION		
FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)	PAGE (3)
Vankas Muclean Rover Station		YEAR SEQUENTIAL REVISION	1
Jankee Macheat Fowet Station	05000029	2000 02	4 of 4
			L
TEXT (In more space is required, use zociounal copies of tarko Poim seav	4) (17)		
SAFETY ASSESSMENT			
No fuel handling evolutions were in progress at the	time of discovery of	this issue.	
CORRECTIVE ACTION			
In preparation for the spent fuel inspection compain	n the following com	ective action plan was devel	oned and
implemented (including engineering evaluations and	procedure changes	to OP-4226 and OP-7107):	oped and
• Before moving any fuel to the upper tier racks, to create a safe load path to the upper tier storage	install the grating ov re racks.	er the entire east bay lower	tier racks
• Perform all spent fuel and component moves in a removed from the lower tier racks to be moved fuel (north end of pool) and then lifted to a here.	compliance with the to a location where ight sufficient to mo	6-inch travel height; requiring there are no racks with store ove the spent fuel over grating	ig all fuel red spent ng to the
 upper tier, Establish a safe zone within the lower tier racks inspections (including installation of inspection and upper tier racks. 	s by emptying the c equipment) and mo	enter bay racks of fuel to pervement of assemblies betwe	ermit fuel en lower
ADDITIONAL INFORMATION			
None.			
PREVIOUS SIMILAR EVENTS			
None.			

NRC FORM 366A (4-95)

Dave Morey Vice President Farley Project Southern Nuclear Operating Company, Inc. Post Office Box 1295 Birmingham, Alabama 35201

Tel 205.992.5131



April 20, 2000

Docket No.: 50-348

NEL-00-0112

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555-0001

> Joseph M. Farley Nuclear Plant Unit 1 Licensee Event Report 2000-004-00 Three Spent Fuel Assemblies in Spent Fuel Pool Locations Not Allowed By Technical Specification 3.7.15

Ladies and Gentlemen:

Joseph M. Farley Nuclear Plant Unit 1 Licensee Event Report (LER) No. 2000-004-00 is being submitted in accordance with 50.73(a)(2)(i). There are two NRC commitments in the LER. They are as follows:

- 1) The applicable procedure will be changed to provide sufficient detail to ensure correct configuration determinations and define independent review requirements prior to moving fuel.
- 2) Responsible personnel will be trained on lessons learned from this event, review requirements, and revisions to the procedure prior to moving fuel.

These will be completed prior to the next fuel assembly movement.

If you have any questions, please advise.

Respectfully submitted,

4 morey

Dave Morey

EWC/maf ler200004-00.doc Attachment

[E221]

Page 2 U. S. Nuclear Regulatory Commission

cc: <u>Southern Nuclear Operating Company</u> Mr. L. M. Stinson, General Manager - Farley

> U. S. Nuclear Regulatory Commission, Washington, D. C. Mr. L. M. Padovan, Licensing Project Manager - Farley

<u>U. S. Nuclear Regulatory Commission, Region II</u> Mr. L. A. Reyes, Regional Administrator Mr. T. P. Johnson, Senior Resident Inspector – Farley

.

NRC FORM 3 (6-1996)	C FORM 346 U.S.NUCLEAR REGULATORY COMMISSION 896)											APPROVED DMB NO. 3150-0104 EXPIRES: Def0/2001 Estimated burden per response to comply with this mandatory information requests 50 hie. Reported escense isamed are incorporated into the licensing process and fed back to industry. Powerd comments															
LICENS (See reverse f dig/ts/characte	EE EVE for required (ans for each)	ENT number block)	REPO	RT (LER)										regari F33), 0001, Mana; collect NRC respon	ung t U.S. end geme- tion d may noto,	Nucl to the int and iness not o the in	in est lets Fi lets Fi Pap not Buk not di pondu not di	apie apie apie apie apie apie apie apie	to t intony ork Ri Was y a cu r spoi colle	pry Commission, Washington, DC 20555- t Reduction Project (3150-0104), Office of Vashington, DC 20503. If an information a currently valid OMB control number, the sponsor, and a person is not required to offection.						
FACILITY NA	UME (1)			e designer and distant											2000	KETI	NUMI	BER (2)						PAG	5 (9)	
Joseph	M. Far	ley l	Nuclea	ar Pl	ant -	Unit	: 1						ل ار سامانی			0	5	0 (0	0	34		8	1	OF		4
Three S	Spent F	uei	Assem	ıblie	s in S	spent	t Fue	el Po	ool L	<u>.oca</u>	itions	Not	Allo)W(ed by	Tec	chr	<u>ica</u>	1 S	Spec	cific	cat	ion	3.	7.15		
August -	DATE (A)	-		ER NI	MBER /A			 \$	EPOR	TÖÄŤ	1(7)					OT:	HER	FACIL	ITLE	SINV	OLVI	D [8	Ŋ				
MONTH DAY	YEAR		YEAR	5	LABER	REVI	SXON I	NONTI	DAY		YEAR		CILITY	NAM	1É					-	000	KET	NUMI O	D D	Δ		
		T										EA.	CIUTY	NAM	1E				••••			<u> </u>	0		······		
0 3 2 3	1200	0 2	.000	0 0	04	0	0	04	20	20	000					1000017.45					0	5	0	0	0	<u></u>	
OPPRATING			THIS REP	PORTH	SUBMI	TTED PL	URBUA	NT TO	THE RE	SQUIR	EMENTS	OF 10 C	FR \$:	(Che	CK DIT OF	mon	e) (1	1)	-	······							
MODE (9)	6		20.22	01(b)			- T	20.2203(a)(2)(v)					<u>IX</u>	50	.73(2)(2)(1)							50.73(a)(2)(viii)					
POWER		╺╼╼╡	20.22	03(a)(1))			20.2203(e)(3)()					50	73(2)(2)(1	<u>}</u>						50.73(a)(2)(x)						
LEVEL (10)	0 0	01	20.22	03(a)(2	10			2	0.2033(2)(3)(ii))			60).73(p)(2)(ii	¹³ (e)(2)(ii)					73.71						
y			20.22	03(a)(2)(1)			2	0.2033((9)(4)				50).79(a)(2)(h	79(a)(2)(lv)					OTHER						
		- S	20.22	03(8)(7	X(II)			5	i0.38(a)((7)				50).75(a)(2)(v) 					Specily in Abstract bet				PACIOOK	W	
	ed and		20.22	93(s)(2	10%			5	:0.36(c)((2)				50).73(a)(2)(v	11)					с 	r in l	VRG /	-070	300A		
		وبالاستر ا				ن السند ار الله		Ľ	CENSE	E CON	ITACT FO	IR THIS	LER (1	2)							1105	D 0-	ciud e	4/4 *	code)		
NAME		*		141		· • • • •		10.0		N 5	Joar I	Dlant					ŀ	3 3	- HQI } 4		- 8	ς) 9	<u></u>	5	1 5	6
			<u>, M. S</u>	uns	on, U	renei	al N	1211	TROL	TARC	-1041		0550	VIRE	O IN THIS	REP	ORT	1131									
CAUSE	SYSTEM	8	MPONENT	M	COMPI ANUFACI	ILETE O	RE	EPOR TO EF	ABLE NX		Varia C		CAU	SE	SYSTE	M	¢	MPO	NEN	π	MAN	JFAC	TURI	57	REPO	RTAB	LE
							+																				
		<u> </u>		-+-			+																				
					d PLACE		IOPT -	YRAC	12 h /14	1		· · ····			and a second	العسم	EXF	ECT	Ð	T	MON	אז	DA	Ŷ	١	ÆAR	
YES OF	yes, complet	te EXPI	ected su	BMISS	ION DAT	E)		<u></u>	<u> </u>	x	NO				,		SUB DA	M(55) .TE (1)	10N 5)	ſ							_
ABSTRACT	(Limit to 140	X) space	es, i.e., apş	ambione	itely 15 ali	ngle-spi	ice type	written	i lines) (1	16)	الشخصيديي	<u>1</u>			a de la completa de l		يتتلقيها										
Or Te co	n Marcl schnical nfigura	n 23, i Spe tions	, 2000 ; cificat 1 contro	at 08 ion (ary t	30, it TS) 3 0 TS]	was 1.7.15 Figur	deter i, in f res 4.	rmin that .3-1	ied th three throu	iat L spe igh 4	Jnit 1 int fue. 4.3-5.	had t 1 asso This	been Smbl	op ies dit	erated were l ion firs	in a loac st o	a co led cou	ndi in t irrea	tio the d d	n co Spe urir	ontr ent l ng tl	ary Fuc he o	to el P core	001 2	in		

offload for the current refueling cycle on March 13, 2000 at 1449. Manual verification of the acceptability of proposed offload configuration on March 11, 2000 failed to identify that three assemblies had insufficient burnup for their planned storage locations. On March 23, 2000, while that three assemblies had insufficient burnup for their planned storage locations. On March 23, 2000, while that three assemblies had insufficient burnup for their planned storage locations. On March 23, 2000, while the fuel location data into a Special Nuclear Materials tracking

that three assemblies had insufficient outhing for their planted storage total of the Materials tracking Reactor Engineering personnel were loading the fuel location data into a Special Nuclear Materials tracking software package being developed for use, three fuel assemblies that did not meet the Technical Specification storage configuration requirements were identified. On March 23, 2000 at 0933, relocation of the three affected assemblies into acceptable locations was completed.

This event was caused by personnel error in that personnel responsible for developing, performing, and verifying the SFP configuration failed to assure that three fuel assemblies met the Technical Specification configuration requirements. Contributing causes were lack of detail in the procedure, experience level of personnel performing this evolution, and insufficient independent review in the verification process. The procedure will be changed to provide sufficient detail to ensure correct configuration determinations. Responsible personnel will be trained on revisions to this procedure and the independent review requirements prior to moving fuel.

NRC Form 366 (8-1998)

	0.3.NUCLEAR REGULATOR	YCOMMISSION	
	LICENSEE EVENT RE	PORT (LER)	
	TEXT CONTINU.	ATION	
FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER	(8) PAGE
Joseph M. Farley Nuclear Plan	nt - Unit 1		
EXT (il mote spece is required, use additional copies o	of NRC Form 355A)(17)	48120001100	41 10 01 210
Westinghouse - Pressuriz	ed Water Reactor		
Energy Industry Identifica	tion Codes are identified in the te	xt as [XX].	
Description of Event			
On March 23, 2000 at 083	30, it was determined that Unit 1 h	ad been operated in a cond	ition contrary to
Technical Specification (T	(S) 3.7.15, in that three spent fuel	assemblies were loaded in	configurations
contrary to 15 Figures 4.3 current refueling cycle on	March 13, 2000 at 1449.	first occurred during the co	re ornoad for the
On March 10 and 11, 2000		reviewed the proposed con	formation for the
Spent Fuel Pool (SFP) for	the Sixteenth Refueling Outage c	ore offload against the TS.	rigination for the
The following combination	n of circumstances created an erro	or likely situation for perfor	mance of this
evolution: As the SFP and	proaches capacity with time, the c	omplexity of the task of de	termining acceptable
	reperformance of this evolution v	vas initially started using co	onservative fuel
storage configurations has additional complexity. Th		plied to the determination of	of acceptable
storage configurations has additional complexity. Th burnups. This resulted in	excessive conservatisms being ap	- 1 C 1 I . COL.	
storage configurations has additional complexity. Th burnups. This resulted in configurations, and the eva available for completion o	excessive conservatisms being ap olution was restarted using actual of the activity. As a result, person	end of cycle burnups. This nel performing the verificat	ion and review chose
storage configurations has additional complexity. Th burnups. This resulted in configurations, and the eve available for completion o to perform the activity tog	excessive conservatisms being ap olution was restarted using actual of the activity. As a result, person ether instead of sequentially, resu	end of cycle burnups. This nel performing the verificat lting in a reduction in quali	s reduced the time tion and review chose ty of the review.
storage configurations has additional complexity. Th burnups. This resulted in configurations, and the eve available for completion o to perform the activity tog Manual verification of the	excessive conservatisms being ap olution was restarted using actual of the activity. As a result, person ether instead of sequentially, resu acceptability of proposed offload	end of cycle burnups. This nel performing the verificat liting in a reduction in quali l configuration failed to ide	s reduced the time tion and review chose ty of the review. ntify that the proposed
storage configurations has additional complexity. Th burnups. This resulted in configurations, and the eve available for completion o to perform the activity tog Manual verification of the configuration would not m	excessive conservatisms being ap olution was restarted using actual of the activity. As a result, person other instead of sequentially, result acceptability of proposed offload neet the acceptable configurations	end of cycle burnups. This nel performing the verificat lting in a reduction in quali configuration failed to ide: defined in TS Figures 4.3-	s reduced the time tion and review chose ty of the review. ntify that the proposed 1 through 4.3-5, for
storage configurations has additional complexity. The burnups. This resulted in configurations, and the even available for completion of to perform the activity tog Manual verification of the configuration would not me three spent fuel assemblies	excessive conservatisms being ap olution was restarted using actual of the activity. As a result, person ether instead of sequentially, result acceptability of proposed offload neet the acceptable configurations s. The review of this verification i humans of up to 3300 Measuret	end of cycle burnups. This nel performing the verificat liting in a reduction in quali configuration failed to iden defined in TS Figures 4.3- process also failed to ident tedays per Metric Ton Uran	s reduced the time tion and review chose ty of the review. ntify that the proposed 1 through 4.3-5, for ify this condition. The ium (MWD/MTTD
storage configurations has additional complexity. Th burnups. This resulted in configurations, and the eve available for completion o to perform the activity tog Manual verification of the configuration would not m three spent fuel assemblies assemblies in question had less than the minimum req	excessive conservatisms being ap olution was restarted using actual of the activity. As a result, person other instead of sequentially, result acceptability of proposed offload neet the acceptable configurations s. The review of this verification I burnups of up to 3300 Megawat juired for the proposed storage loo	end of cycle burnups. This nel performing the verificat lting in a reduction in quali configuration failed to ide: defined in TS Figures 4.3- process also failed to ident t-days per Metric Ton Uran cations. The core offload w	s reduced the time tion and review chose ty of the review. ntify that the proposed 1 through 4.3-5, for ify this condition. The ium (MWD/MTU) vas performed from
storage configurations has additional complexity. The burnups. This resulted in a configurations, and the even available for completion of to perform the activity tog Manual verification of the configuration would not me three spent fuel assemblies assemblies in question had less than the minimum req March 11 through 14, 200	excessive conservatisms being ap olution was restarted using actual of the activity. As a result, person other instead of sequentially, result acceptability of proposed offload neet the acceptable configurations s. The review of this verification d burnups of up to 3300 Megawat juired for the proposed storage loc 10.	end of cycle burnups. This nel performing the verificat liting in a reduction in quali configuration failed to ide: defined in TS Figures 4.3- process also failed to ident t-days per Metric Ton Uran cations. The core offload w	s reduced the time tion and review chose ty of the review. ntify that the proposed 1 through 4.3-5, for ify this condition. The ium (MWD/MTU) as performed from
storage configurations has additional complexity. The burnups. This resulted in a configurations, and the even available for completion of to perform the activity tog Manual verification of the configuration would not me three spent fuel assemblies assemblies in question had less than the minimum req March 11 through 14, 200 On March 23, 2000, while	excessive conservatisms being ap olution was restarted using actual of the activity. As a result, person ether instead of sequentially, result acceptability of proposed offload neet the acceptable configurations s. The review of this verification d burnups of up to 3300 Megawat juired for the proposed storage loc 10.	end of cycle burnups. This nel performing the verificat liting in a reduction in quali l configuration failed to ide: defined in TS Figures 4.3- process also failed to ident t-days per Metric Ton Uran cations. The core offload w	s reduced the time tion and review chose ty of the review. ntify that the proposed 1 through 4.3-5, for ify this condition. The ium (MWD/MTU) /as performed from
storage configurations has additional complexity. The burnups. This resulted in a configurations, and the even available for completion of to perform the activity tog Manual verification of the configuration would not me three spent fuel assemblies assemblies in question had less than the minimum req March 11 through 14, 200 On March 23, 2000, while Nuclear Materials tracking meet the accentable loading	excessive conservatisms being ap olution was restarted using actual of the activity. As a result, person ether instead of sequentially, result acceptability of proposed offload neet the acceptable configurations s. The review of this verification i burnups of up to 3300 Megawat juired for the proposed storage loc 10.	end of cycle burnups. This nel performing the verificat liting in a reduction in quali l configuration failed to ide: defined in TS Figures 4.3- process also failed to ident t-days per Metric Ton Uran cations. The core offload we were loading the fuel locationed for use, these three fuel larch 23, 2000 at 0933, relo	s reduced the time tion and review chose ty of the review. ntify that the proposed 1 through 4.3-5, for ify this condition. The ium (MWD/MTU) was performed from on data into a Special assemblies that did not cation of these three
storage configurations has additional complexity. Th burnups. This resulted in configurations, and the eve available for completion o to perform the activity tog Manual verification of the configuration would not m three spent fuel assemblies assemblies in question had less than the minimum req March 11 through 14, 200 On March 23, 2000, while Nuclear Materials tracking meet the acceptable loadin affected assemblies into ad	excessive conservatisms being ap olution was restarted using actual of the activity. As a result, person other instead of sequentially, result acceptability of proposed offload neet the acceptable configurations s. The review of this verification d burnups of up to 3300 Megawat juired for the proposed storage loc 0. Reactor Engineering personnel v g software package being develop ig patterns were identified. On M cceptable locations was completed	end of cycle burnups. This nel performing the verificat liting in a reduction in quali l configuration failed to ide: defined in TS Figures 4.3- process also failed to ident t-days per Metric Ton Uran cations. The core offload we were loading the fuel locationed ed for use, these three fuel larch 23, 2000 at 0933, relo d.	s reduced the time tion and review chose ty of the review. ntify that the proposed 1 through 4.3-5, for ify this condition. The ium (MWD/MTU) vas performed from on data into a Special assemblies that did not cation of these three

•

130 P12 MAY 19 '00 17:03

NRC	FORM	366A
(8-19	6 61	

U.S.NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1)	DOCKET NUMBER (2)		PAGE (3)		
Joseph M. Farley Nuclear Plant - Unit 1		YEAR	SEQUENTIAL REVISION NUMBER NUMBER		
*	<u>05000348</u>	2000		3 OF 4	

TEXT (If more space is required, use additional copies of NRC Form 366A)(17)

Cause of Event

This event was caused by personnel error in that personnel responsible for developing, performing, and verifying the SFP configuration failed to assure that three fuel assemblies met the Technical Specification configuration requirements. Contributing causes were lack of detail in the procedure, experience level of personnel to perform this evolution, and insufficient independent review in the verification process.

Safety Assessment

Analysis shows that a boron concentration of 700 ppm would have kept Keff below the limit of 0.95. Since the Technical Specifications require a minimum boron concentration in the SFP of 2000 ppm, and actual boron concentration was 2435 ppm, the Keff of the SFP remained less than 0.95 throughout this event. In addition, this analysis conservatively took no credit for the Boraflex neutron adsorber located in the SFP racks

Therefore the health and safety of the public were unaffected by this event.

This event does not represent a Safety System Functional Failure.

Corrective Action

On 3/23/2000 the three assemblies were relocated to acceptable configurations.

The Unit 2 SFP was checked for fuel in incorrect storage configurations. None was identified.

The applicable procedure will be changed to provide sufficient detail to ensure correct configuration determinations and define independent review requirements prior to moving fuel.

Responsible personnel will be trained on lessons learned from this event, review requirements, and revisions to the procedure prior to moving fuel.

.....

......

NRC FORM 366A (8-1098)	U.S.NUCLERK REGULATORY COMMISSION
	LICENSEE EVENT REPORT (LER)
	TEXT CONTINUATION
PAGILITY NAME ((1) LER NUMBER (8) PAGE (2)
	YËAR SEQUENTIAL E REVISION NUMBER NUMBER
Joseph M.	Farley Nuclear Plant - Unit 1 $050003482000 - 004 - 004 0F$
EXT (If more spec	ce is required, use additional copies of NRC Form \$66A((17)
<u>Add</u>	litional Information
As a	an enhancement, a computerized SFP configuration verification system will be placed in service prior to
Sept	tember 30, 2000. The configuration verification procedure will be revised to reflect the computenzed
Eng	incering personnel and supervision will be trained on the software additions and related procedure
char	nges by October 30, 2000.
Av	oluntary 4-hour nonemergency notification was made to the NRC at 1215 on March 23, 2000.
The	following LER has been submitted in the past 2 years on a combination of personnel error and
inad	lequate procedure:
LEF	R 1998-003-00 Unit 1. Waste Gas Decay Tank Hydrogen and Oxygen Exceeded Concentration Limits
12 H2 ***	

,

+12023320895 UCS DC



H. B. Barron Vice Presidens Duke Energy Corporation McGuire Nuclear Station 12700 Hagers Ferry Road Huntersville, NC 28078-9340 (704) 875-4800 OFFICE (704) 875-4809 FAX.

DATE: March 30, 2000

U.S. Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555

Subject: McGuire Nuclear Station, Unit 1 and 2 Docket No. 50-369 Licensee Event Report 369/00-03, Revision 0 Problem Investigation Process No.: PIP M-00-0844

Gentlemen:

Attached is a Licensee Event Report describing a pre-existing design condition associated with criticality calculations. The condition affects calculations used to generate Limiting Conditions for Operation (LCO) for fuel storage requirements in the spent fuel pool. This event is being reported pursuant to 10 CFR 50.73 (a) (2) (ii) (B) "Operation Outside Design Basis of the Plant". This was previously reported under the parallel criteria of 10 CFR 50.72 in Event Number 36748 on March 2, 2000.

The design basis criteria at issue in this report is the required Keff associated with a spent fuel pool filled with water at zero boric acid concentration. The actual boron acid concentration of the spent fuel pools is maintained in excess of 2500 ppm and monitored on a routine basis as required by technical specifications. These factors mitigate this event to the extent that the condition did not adversely impact plant safety. These actual conditions allow for adequate time to detect and mitigate any dilution of the fuel pool before violating the Keff design basis acceptance criteria.

A Regulatory Commitment is listed as a planned corrective action.

Very truly yours,

H. B. Barron, Jr. McGuire Nuclear Station, Vice President Duke Energy Corporation

IE22

ML003701640

Attachment

,

cc: L. A. Reyes U.S. Nuclear Regulatory Commission Region II

> Atlanta Federal Center 61 Forsyth St., SW, Suite 23T85 Atlanta, GA 30323

F. Rinaldi U.S. Nuclear Regulatory Commission Office of Nuclear Reactor Regulation Washington, D.C. 20555

.

INPO Records Center 700 Galleria Parkway Atlanta, GA 30339 (Sent Electronically)

S. Shaeffer NRC Resident Inspector McGuire Nuclear Station Electronic Distribution:

Kay L. Crane (MG01RC) Ronnie B. White (MG01VP) Braxton L. Peele (MG01VP) Barbara L. Walsh (EC11C) Jimmy I. Glenn (MG02ME) Richard T. Bond (ON03SR) Gary D. Gilbert (CN01RC) Guynn H. Savage (EC06G) Gregg B. Swindlehurst (EC11-0842) Charles M. Misenheimer (EC08I) Ronald F. Cole (EC05N) Lee Keller (EC05N) P.M. Abraham (EC08I) Vickie McGinnis (MG05SE) Randy Moose (MG01VP) Mary J. Brown (PB02L) Alan L. Hincher (MG01B1) Patrica H. Cox (NSRB Support) (EC05N) Robert E. Riegel (MG03MT) Charles J. Thomas (EC050) Luellen B. Jones (EC050) Mike Rains (MG01SR) Josh Birmingham (MG01VP) Lisa Vaughn (PB05E) H Duncan Brewer (EC081) Larry E Nicholson (ON03RC)

INPO

Paper Distribution:

Master File (3.3.7) ELL (EC050) Regulatory Compliance LER File and the second

NRC FOR	M 368	1	LICEN	SEI	E EVENT	RE	U.S. NU	CLEAR REQU	LATORY CC	₩₩IS\$40 1		ESTIMATED BU MANDATORY I REPORTED LE UCENSING PF COMMENTS R AND RECORD REGULATORY THE PAPERWO MANAGEMENT	APPROVED BY DRAF IRDEN PER RESPONSI NFORMATION COLLEC SSONS LEARNED ARE OCESS AND FED BACH EGARDING BURDEN ES MANAGEMENT BRAN OMMISSION, WASHIN JAK REDUCTION PROJ AND BURDET, WASHIN	OME NO. 3 IEE 043094 E TO COMP TION REQU INCORPOR I TO INDUS STIMATE TC CH (T-3 F33 IGTON, DC ECT (3150-4 NGTON, DC	150-0104 LY WITH TH EST: 50.0 H ATED INTO RY. FORM THE INFOS), U.S. NUCI 20555-0001 (104), OFFIC 20503.	IS RS. THE TARO MATION LEAR , AND TO DE OF	
FACILI	TY NAM	E (1)	Station	1 In	i+ 4							00	CKET NUMBER (2)		PAGE (3)		
		Java C						at a state of				0	5000 369		1 of 5		
TITLE (4) (N	ion C	onserva	atisri	n in Spent Fi	i iật	-ool Gr	nicality C	aiculati	on							
EVE	T DAT	E (5)			LER NUMBEI	R (6)		REF	ORTDA	TE (7)		ОТ	TER FACILITIES	NVOLVE	D (8)		
BONTH	NUMBER NAMBER								TEAN		FACILITINATE DUCAST NUMBER(S)						
03	02	00	00	-	03	-	0	03	30	00	M Ur	cGuire Nuc hit 2	lear Station,	05000 370			
OPE	RATING		THIS	REPO	1 RT IS SUBMITTE	DPU	RSUANT	TO THE RE	XUIREME	NTS OF 1	0 CFT	R (Check one c	r more of the followin	7) (11)			
640	DE (9)			20.402	2 (b)			20.40	15(c)		Ļ	50.73(a)(2)(fv) 2)(c)	73.	71(b) 71(c)		
POWER 20.405(a)(1)(i) 30.38(c)(1) 30.73(a)(2)(v) 73.71(LEVEL (10) 20.405(a)(1)(ii) 50.36(c)(2) 50.73(a)(2)(vii) OTHE										HER (Spe	dify in						
20,405(a)(1)(iii) 50.73(a)(2)(i) 50.73(a)(2)(viii)(A) Abstract below and 20,405(a)(1)(iv) XX 50.73(a)(2)(ii) 50.73(a)(2)(viii)(B) In Text, NRC Form											v knd Form						
				20.405	(a)(1)(∨)			50.73	(a)(2)(III)	TUIS 50		50.73(8)(2)(×)	36	5A)		
NAME							LIVEI	SEL CONT			((2)		TELEP	HONE NU	MBER	·····	
<u>м. т. (</u>	Cash					LINE	FORFAC			UREDES	CRIB	ED IN THIS RE	(704)	875-4	117	<u>,,,,,,</u>	
CAUSE	SYST	ЕМ	COMPONEN	чт I	KANUFACTURER	F	EPORTAB TO NPROS	LE	CAUSE	ŞYŞT	Ем	COMPONENT	MANUFACTURER	AEPO TO N	RTABLE PRDS		
					·····	ļ				4							
												<u> </u>					
	SUP	PLEM	ENTAL RE	PORT	EXPECTED (14)								EXPECTED	MONTH	DAY	YEAR	
													SUBMISSION			1	
ABSTR	ES (ryes CT (Lim Sta	it to 14	ioo spaces, s: Bo	<i>i.a. 44</i> th	<u>SOBMISSION DA</u> proximately lites Unit 1 a	n sing anc	Vo-space Uni	typewritten ili	nes)(16) ere i	n Mo	de	1 (Pow	er Operat	ion)	at 10	1 DO	
Even crit Spec post pool pool Even addi assu	<pre>percent power at the time of discovery.</pre> Event Description: Modeling methods used to perform spent fuel pool criticality analysis have been determined to be non-conservative. Specifically, certain assumptions may result in Keff in excess of 0.95 for postulated off-normal conditions with 0 ppm boron concentration in the fuel pool. The design basis of the plant requires that fuel stored in the fuel pool remain ≤ 0.95 Keff when fully flooded with unborated water. Event Cause: This event is the result of an original design condition. Corrective Action: Technical Specifications will be revised to include additional conservatism to account for uncertainties associated with modeling assumptions.																

A

NRC FORM 366*NPRDS no longer exists, equipment failures will be reported through EPIX

•

NEC FORM 366A	U.S. NUCLE	AR REGULATORY COMMISSION(6-	APPROVED BY ONB NO. 3150-0104 EXPIRES 64/30/94									
	LICENSEE EVENT REPORT TEXT CONTINUATION	ESTIMATE INFORMA LEARNED BACK TO ESTIMATE (T-0 F33), 20555-000 OFFICE O	ED BURDEN PER RE TION COLLECTION I ARE INCORPORATI INDUSTRY, FORWA E TO THE INFORMAT U.S. NUCLEAR REG U.S. NUCLEAR REG HANAGEMENT AN	SPONSE TO COMPLY REQUEST: 50.0 HRS. ED INTO THE LICENSI RD COMMENTS REG. TION AND RECORDS I ULATORY COMMISSI ERWORK REDUCTION ID BUDGET, WASHING	WITH THIS MANDATORY REPORTED LESSONS NG PROCESS AND FED ARDING BURDEN MANAGEMENT BRANCH DN, WASKINGTON, DC 9 FROJECT (0150-0104), 3TON, DC 20503.							
FACILITY NAME (1)	DOCKET NUMBER (2)		LER NUME	ER (6)	PAGE (3)						
	,		YËAR	SEQUENTIA NUMBER	L REVISION	1						
McGuire Nucl	ear Station,	05000 369	2000	03	0	2 OF 5						

BACKGROUND:

Each unit has an independent fuel storage pool that contains fuel storage racks [EIIS: RK] in a 2 region design. Region 1 uses a high density flux trap design for storage of nuclear fuel. Region 2 uses a high density "egg-crate" design for storage of nuclear fuel. The spent fuel pool storage racks provide for safe storage of nuclear fuel assemblies. This includes maintaining a coolable geometry, preventing criticality, and protecting the fuel assemblies from excess mechanical or thermal loading. The rack design provides for fuel storage in a array such that the Neutron Multiplication Factor (Keff) will remain equal to or less than 0.95 assuming unborated water filled the pool. Keff values less than 1.0 indicates a sub-critical condition.

The water in the spent fuel pool contains boric acid dissolved in solution to act as a neutron absorber. The large neutron absorption characteristics of boron in combination with the rack design results in an actual Keff far below 0.95. Technical Specification (TS) 3.7.14, Spent Fuel Pool Boron Concentration, requires that the spent fuel pool boron concentration be within the limits specified in the Core Operating Limits Report (COLR). Current COLR limits require boron concentration > 2675 ppm. TS Surveillance 3.7.14.1, Spent Fuel Pool Boron Concentration Surveillance, requires fuel pool boron verification every 7 days.

TS 3.7.15, Spent Fuel Assembly Storage, also specify acceptable storage configurations for fuel assemblies in the fuel pool. These limits are indexed against the initial enrichment and burnup of individual fuel assemblies. Based on these parameters fuel assemblies are grouped into one of three classes, Filler Assemblies, Unrestricted Storage, and Restricted Storage. This same TS specifies patterns for locating the fuel assemblies based on class. The classification of fuel assemblies and the associated patterns have been determined using nuclear physics These models consist of sophisticated neutronic computer codes. models. The computer codes simulate the geometry, materials, and physical behavior of the nuclear fuel and surrounding materials in the fuel pool. These models have included an assumption that fuel assembly axial burnup distribution is uniform and that axial neutron leakage will be zero. These assumptions along with geometric models have approximated fuel pools as two dimensional systems. The underlying assumption has been that the conservative assumption of zero axial neutron leakage would result in conservative values of Keff. These models have not taken any credit for soluble boron in the spent fuel pools or for other poisons in the form of fuel assembly inserts. The models have taken credit for the boraflex panels (EIIS: PL) in the region 1 racks.

NAC FORM 366A 88)	U.S. NUCLEAR REGULATORY COMMISSION(5-		·	APPROVED BY OMB HC. 3150-0104 EXPIRES 64/30/66				
LI	LICENSEE EVENT REPORT (LER) TEXT CONTINUATION			ESTIMATED BURDEN PER RESPONSE TO COMPLY WITH THIS MANDATORY INFORMATION COLLECTION REQUEST: SOU HRS. REPORTED LESSONS LEARNED ARE INCORPORATED INTO THE LICENSING PROCESS AND FED BACK TO INDUSTRY. FORWARD COMMENTS REGARDING BURDEN ESTIMATE TO THE INFORMATION AND RECORDS MANAGEMENT BRANCH (T-5 F33), U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, DC 20555-0001, AND TO THE PAPERWORK REDUCTION PROJECT (3150-0104), OFRICE OF MANAGEMENT AND BUDGET, WASHINGTON, DC 20503.				
FACILITY NAME (1)		DOCKET NUMBER (2			LER NUMBE	R (6)		PAGE (3)
			YEAR		SEQUENTIAL NUMBER		REVISION NUMBER	
McGuire Nuclear	Station,	05000 369	2000		03		0	3 OF 5

EVALUATION:

Description of Event

On March 2, 2000, Nuclear Fuel Group engineers in Duke Energy's Corporate Office notified station personnel of a potential nonconservatism in the criticality calculations for the fuel pool storage configurations. Both Unit 1 and Unit 2 were in Mode 1 (Power Operation) at 100 percent power at the time of this notification. Fuel movement was not underway in either units fuel pools at the time of the discovery.

The Nuclear Fuels Group had been performing fuel pool criticality calculations using new models that used 3-dimensional geometry and non uniform fuel assembly axial burnup distributions. These calculations were being performed in support of a proposed TS amendment associated with Boraflex degradation in the spent fuel pools. Results from these analyses caused the Nuclear Fuels Group to suspect previous assumptions regarding the conservatism of 2-dimensional calculations. In the past, it was thought that the range of burnups and enrichments where 2dimensional calculations were conservative easily bounded fuel assemblies in spent fuel pools. The 3-dimensional calculations estimated that 2-dimensional calculations might become non-conservative at lower burnups and enrichments.

The range at which these non-conservatisms could exist includes burnups and enrichments used to generate the TS limits discussed in the text above. Given the actual fuel assembly burnups and the existing limits, the potential existed that Keff would exceed 0.95 under the postulated unborated condition.

Conclusion

This event did not result in any uncontrolled releases of radioactive material, personnel injuries, or radiation overexposures. This event is not Equipment Performance Information Exchange (EPIX) reportable.

This event is the result of an original design condition.

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION		ESTIMATED B INFORMATION LEARNED ARE BACK TO INDU ESTIMATE TO	URDEN PER RESP N COLLECTION REK E INCORPORATED JSTRY, FORWARD	Onse to comply with Duest: 50.0 Mrs. Rep INTO THE LICENSING P COMMENTS REGARDI	h this mandatory Orted Lessons Rocess and fed Ng Burden		
LICENSEE EVENT REPORT (LER) TEXT CONTINUATION			ESTIMATED BURDEN PER RESPONSE TO COMPLY WITH THIS MANDATORY INFORMATION COLLECTION REQUEST: 80.0 HRS. REPORTED LESSONS LEARNED ARE INCORPORATED INTO THE LICENSING PROCESS AND FED BACK TO INDUSTRY. FORWARD COMMENTS REGARDING BURDEN ESTIMATE TO THE INFORMATION AND RECORDS MANAGEMENT BRANCH (T-0 F33), U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, DC 2055-0001, AND YO THE PAPERWORK REDUCTION PROJECT (3150-0104), OFFICE OF MANAGEMENT AND BUDGET, WASHINGTON, DC 2063.				
FACILITY NAME (1) DO	CKET NUMBER (2)		LER NUMBER	(6)	PAGE (3)		
	-	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	•		
McGuire Nuclear Station, 05	000 369	2000	03	- 0	4 OF 5		

Verified that the fuel pools were operable with credit for soluble boron concentration maintained at concentrations as required by TS.

Subsequent

An Operating Experience Release was issued for industry awareness of this issue.

<u>Planned</u>

- 1. Technical Specification limits will be revised to include additional conservatism to account for uncertainties in the 2-dimensional calculations when compared to the 3-dimensional calculations.
- Upon NRC approval of the TS revision, the Updated Final Safety Analysis Report will be revised to specify storage requirements using Boron credit methodology.

SAFETY ANALYSIS:

Based on this analysis, this event is not considered to be significant. At no time were the safety or health of the public or plant personnel affected as a result of the event.

The design of the spent fuel storage racks assumes the use of unborated water, which maintains each region in a subcritical condition during normal operation with the spent fuel pool fully loaded. The double contingency principle discussed in ANSI N-16.1-1975 allows credit for soluble boron under other abnormal or accident conditions, since only a single accident need be considered at one time. For example, the most severe accident scenario is associated with the movement of fuel from Region 1 to Region 2, and accidental misloading of a fuel assembly in Region 1 or Region 2. This could potentially increase the reactivity of the spent fuel pool. To mitigate these postulated criticality related accidents, boron is dissolved in the pool water. Safe operation of the two region poison fuel storage rack with no movement of assemblies may therefore be achieved by controlling the location of each assembly in accordance with the accompanying LCO.

. .

NRC FORM 366A U.S. NUCLEAR REGULATORY COMMISSION(6- APPROVED BY ONE NO. 3160-0104					04		
LICENSEE EVENT REPORT (LER) TEXT CONTINUATION			EXPIRES ORGANY ESTIMATED BURDEN PER RESPONSE TO COMPLY WITH THIS MANDATORY INFORMATION COLLECTION REQUEST: 50.0 HRS. REPORTED LESSONS (LEARNED ARE INCORPORATED INTO THE LICENSING PROCESS AND FED BACK TO INDUSTRY, FORWARD COMMENTS REGARDING BURDEN ESTIMATE TO THE INFORMATION AND RECORDS MANAGEMENT BRANCH (T-6 F33), U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, DC 20255-0001, AND TO THE PAPERWORK REDUCTION PROJECT (3150-0104), OFFICE OF MANAGEMENT AND BUDDET, WASHINGTON, DC 20303.				
FACILITY NAME (1) DOCKET NUMBER (2)			LER NUMBER (6) PAGE (6)				
McGuire Nuclear Station,	05000 369	YEAR 2000	SEQUENTIAL NUMBER 03	REVISION NUMBER	5 OF 5		
Criticality analysis of the Mo that approximately 460 ppm of Region 2 are required to off-s uncertainty. This uncertainty conservative when the 2-dimens the 3-dimensional calculation. McGuire has documented that for minimum soluble boron level in greater than 937 ppm. This di boron concentration of 2475 pp event. The results also show many hours to significantly re under the most limiting condit for operator actions to termin alarms [EIIS: LA] and operator dilution of the fuel pool to g period of time. Therefore, under conservative	Guire spent boron for R set the axia y was identi sional calcu A boron d or any credil the spent lution even that spent that the di educe pool be tions and pro- tate the even trounds it yo undetected	fuel p egion 1 1 burnup fied as lation v ilution p fuel poor t is bas itiating tution p oron com ovides s nt. Bea is not of d for a	ools de and 59 p profi being was com evalue ution e ols wou sed on g point process ncentra suffici cause c credibl signif	emonstrate 50 ppm for 11e non- apared to ation for event the 11d be a minimum for the s requires ation even tent time of level le for a ficant	-		
Therefore, under conservative assumptions, the fuel pool would be diluted to a boron concentration approximately 400 ppm greater than that needed to maintain the fuel pool below 0.95 Keff. A condition of 0.95 Keff is approximately 5000 pcm subcritical. This is a substantial subcritical margin worth approximately 600 ppm boron concentration assuming a differential boron worth of 8.33 pcm per PPM. As such there is no credible scenario which could have resulted in an inadvertent criticality in the fuel pool under normal or off normal conditions. There are no safety consequences of this event beyond the potential for an inadvertent criticality.							
In addition, there have not been any improper loadings of fuel assemblies in the fuel pool in recent operating history that would							

assemblies in the fuel pool in recent operating history that would require consideration of a simultaneous misloading and boron dilution event. This condition had no adverse impact on public health and safety.

UNITED STATES OF AMERICA NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of:	: Docket No. 50-423-LA-3
Northeast Nuclear Energy Company	•
	:
(Millstone Nuclear Power Station, Unit No. 3)	: ASLBP No. 00-771-01-LA

CERTIFICATION

This is to certify that a copy of the foregoing "Connecticut Coalition Against Millstone and Long Island Coalition Against Millstone's First Supplement to Exhibit A (Annexed to Intervenors' March 20, 2000 Reply to Northeast Nuclear Energy Company's First Request for Interrogatories) and attachments thereto, was mailed by U.S. Mail, postage pre-paid, First Class, to the following on May 22, 2000:

David A. Repka, Esq. Winston & Strawn 1400 L Street Washington DC 20005

Office of the Secretary U.S. Nuclear Regulatory Commission Dr. Richard F. Cole Washington DC 20555 (Attn: Rulemakings and Adjudications Staff) (original + two copies)

Adjudicatory File Atomic Safety and Licensing Board Panel Washington DC 20555

Office of Commission Appellate Adjudication U.S. Nuclear Regulatory Commission Washington DC 20555

Charles Bechhoefer Chairman Atomic Safety and Licensing Board U.S. Nuclear Regulatory Commission Washington DC 20555-0001

Administrative Judge Atomic Safety and Licensing Board U.S. Nuclear Regulatory Commission Washington DC 20555-0001

Dr. Charles N. Kelber Administrative Judge Atomic Safety and Licensing Board U.S. Nuclear Regulatory Commission U.S. Nuclear Regulatory Commission Washington DC 20555-0001

> Ann P. Hodgdon Office of General Counsel U.S. Nuclear Regulatory Commission Washington DC 20555

CONNECITICUT COALITION AGAINST MILLSTONE LONG ISLAND COALITION AGAINST MILLSTONE

Toula

Nancy Burton, Esq. 147 Cross Highway Redding Ridge CT 06876 Tel. 203-938-3952

By:

UNITED STATES OF AMERICA NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of:	: Docket No. 50-423-LA-3
	:
Northeast Nuclear Energy Company	:
	:
(Millstone Nuclear Power Station,	:
Unit No. 3)	: ASLBP No. 00-771-01-LA

CERTIFICATION

This is to certify that a copy of the foregoing "Connecticut Coalition Against Millstone and Long Island Coalition Against Millstone's First Supplement to Exhibit A (Annexed to Intervenors' March 20, 2000 Reply to Northeast Nuclear Energy Company's First Request for Interrogatories) and attachments thereto, was mailed by U.S. Mail, postage pre-paid, First Class, to the following on May 22, 2000:

David A. Repka, Esq. Winston & Strawn 1400 L Street Washington DC 20005

Office of the Secretary U.S. Nuclear Regulatory Commission Dr. Richard F. Cole Washington DC 20555 (Attn: Rulemakings and Adjudications Staff) (original + two copies)

Adjudicatory File Atomic Safety and Licensing Board Panel U.S. Nuclear Regulatory Commission Washington DC 20555

Office of Commission Appellate Adjudication U.S. Nuclear Regulatory Commission Washington DC 20555

Charles Bechhoefer Chairman Atomic Safety and Licensing Board U.S. Nuclear Regulatory Commission Washington DC 20555-0001

Administrative Judge Atomic Safety and Licensing Board U.S. Nuclear Regulatory Commission Washington DC 20555-0001

Dr. Charles N. Kelber Administrative Judge Atomic Safety and Licensing Board U.S. Nuclear Regulatory Commission Washington DC 20555-0001

Ann P. Hodgdon Office of General Counsel U.S. Nuclear Regulatory Commission Washington DC 20555

CONNECITICUT COALITION AGAINST MILLSTONE LONG ISLAND COALITION AGAINST MILLSTONE

Track

Nancy Burton, Esq. 147 Cross Highway Redding Ridge CT 06876 Tel. 203-938-3952

By: