

May 26, 2000

MEMORANDUM TO: Biweekly Notice Coordinator

FROM: Robert J. Fretz, Project Manager, Section 2 */RA/*
Project Directorate I
Division of Licensing Project Management

SUBJECT: REQUEST FOR PUBLICATION IN BI-WEEKLY FR NOTICE -
NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE (TAC NO. MA8840)

Public Service Electric & Gas Company, Docket No. 50-272, Salem Nuclear

Generating Station, Unit No. 1, Salem County, New Jersey

Date of application for amendment: May 3, 2000, as supplemented on May 19, 2000

Brief description of amendment: The license amendment modifies the existing requirement under Technical Specification Section 3.1.3.2.1, Action a.1, to determine the position of Rod 1SB2 from once every 8 hours to within 8 hours following any movement of the rod until repair of the rod indication system is completed. This change is applicable for the remainder of the Unit 1 Cycle 14, or until an outage of sufficient duration occurs whereby the licensee can repair the position indication system.

Date of issuance: May 26, 2000

Effective date: As of the date of issuance, and shall be implemented within 30 days.

Amendment No.: 230

Facility Operating License No. DPR-70: This amendment revised the Technical Specifications.

Public comments requested as to proposed no significant hazards consideration (NSHC):

Yes (65 FR 30137) May 10, 2000. The notice provided an opportunity to submit comments

on the Commission's proposed NSHC determination. No comments have been received.

That notice also provided for an opportunity to request a hearing by May 24, 2000, but indicated that if the Commission makes a final NSHC determination, any such hearing would take place after issuance of the amendment.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated May 26, 2000.

on the Commission's proposed NSHC determination. No comments have been received.

That notice also provided for an opportunity to request a hearing by May 24, 2000, but indicated that if the Commission makes a final NSHC determination, any such hearing would take place after issuance of the amendment.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated May 26, 2000.

DISTRIBUTION

OGC

PD I-2 Reading

JClifford

RFretz

TClark

DOCUMENT NAME: C:\BwiMA8840.wpd

OFFICE	PDI-2/PM	PDI-2/LA	OGC	PDI-2/SC
NAME	RFretz	TClark	CMarco	BBuckley for JClifford
DATE	5/24/00	5/24/00	5/26/00	5/26/00

OFFICIAL RECORD COPY