

May 17, 2000

MEMORANDUM TO: James W. Clifford, Chief, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

FROM: Victor Nerses, Senior Project Manager, Section 2 */RAI/*
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

SUBJECT: MILLSTONE, UNIT NO. 3, DRAFT REQUEST FOR ADDITIONAL
INFORMATION, GL 99-02 TECHNICAL SPECIFICATIONS
AMENDMENT REQUEST (TAC NO. MA7231)

The enclosed draft request for additional information (RAI) was transmitted by facsimile on May 17, 2000, to Mr. D. Dodson of Northeast Nuclear Energy Company (licensee). Review of the RAI would allow the licensee to determine and agree upon a schedule to respond to the RAI. This memorandum and the enclosure do not convey a formal request for information or represent an NRC staff position.

Docket No. 50-423

Enclosure: Draft RAI

May 17, 2000

MEMORANDUM TO: James W. Clifford, Chief, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

FROM: Victor Nerses, Senior Project Manager, Section 2 */RA/*
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

SUBJECT: MILLSTONE, UNIT NO. 3, DRAFT REQUEST FOR ADDITIONAL
INFORMATION, GL 99-02 TECHNICAL SPECIFICATIONS
AMENDMENT REQUEST (TAC NO. MA7231)

The enclosed draft request for additional information (RAI) was transmitted by facsimile on May 17, 2000, to Mr. D. Dodson of Northeast Nuclear Energy Company (licensee). Review of the RAI would allow the licensee to determine and agree upon a schedule to respond to the RAI. This memorandum and the attachment do not convey a formal request for information or represent an NRC staff position.

Docket No. 50-423

Enclosure: Draft RAI

DISTRIBUTION

File Center

PUBLIC

Project Manager

OFFICE	PDI, S2/PM
NAME	V.N.
DATE	5/17/00

OFFICIAL RECORD COPY

DOCUMENT NAME:G:\PDI-2\MILLSTONE3\GL99-02TSAMENDRAI.WPD

DRAFT

**REQUEST FOR ADDITIONAL INFORMATION
MILLSTONE NUCLEAR POWER STATION UNIT No.3
TAC NO. MA7231**

- 1.) GL 99-02, under requested actions requested each licensee to provide the total residence time per bed depth for their revised charcoal testing protocol. The licensee submittal did not provide the residence times in the revised TS for the SCLRS, CREVS, ABFS, or the FBES. Please refer to or provide docketed information indicating the residence times.
- 2.) For all 4 systems, due to the significant changes between the current and proposed test penetrations (*0.175% to 2.5%*) with no indication of current safety factors, please verify that there is no change in the credited efficiencies for the accident analyses.